

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
271 Belvidere	1103	2/13/2023	9:28:00 AM	493	0.5	71.6	19.1	0	
271 Belvidere	1105	2/13/2023	9:31:00 AM	498	0.5	71.2	19.4	0	
271 Belvidere	1107	2/13/2023	9:35:00 AM	719	0.5	70.9	22.5	14	
271 Belvidere	1109	2/13/2023	9:38:00 AM	735	0.5	71.2	21.5	18	
271 Belvidere	1111	2/13/2023	9:40:00 AM	495	0.4	71.6	19.6	0	Plants
271 Belvidere	1113	2/13/2023	9:43:00 AM	514	0.4	72.7	19.1	0	
271 Belvidere	1305	2/13/2023	9:14:00 AM	691	0.5	69.4	21.7	1	Stained ceiling tiles
271 Belvidere	1310	2/13/2023	9:13:00 AM	462	0.4	68.9	20.1	0	
271 Belvidere	1401	2/13/2023	9:01:00 AM	445	0.5	69.4	20.4	0	
271 Belvidere	1402	2/13/2023	8:55:00 AM	464	0.6	70.2	20.7	0	
271 Belvidere	2103	2/13/2023	9:45:00 AM	504	0.4	72	18.9	0	
271 Belvidere	2105	2/13/2023	9:49:00 AM	511	0.4	72	18.9	1	
271 Belvidere	2107	2/13/2023	9:52:00 AM	514	0.4	71.8	19.1	0	
271 Belvidere	2109	2/13/2023	9:53:00 AM	518	0.4	71.8	19.1	2	
271 Belvidere	2111	2/13/2023	9:57:00 AM	517	0.4	72	19	2	
271 Belvidere	2113	2/13/2023	9:58:00 AM	509	0.4	72.3	18.8	0	
271 Belvidere	2115	2/13/2023	9:59:00 AM	503	0.4	72.9	18.6	1	
271 Belvidere	1001 OFFICE	2/13/2023	9:34:00 AM	686	0.4	70.9	21.8	2	
271 Belvidere	1002 OFFICE	2/13/2023	9:32:00 AM	674	0.4	71.1	21.5	0	Plants
271 Belvidere	1003 CONFERENCE	2/13/2023	9:37:00 AM	644	0.4	71.1	21.1	0	
271 Belvidere	1106 OFFICE	2/13/2023	9:41:00 AM	716	0.5	72	21	1	
271 Belvidere	1202 GYMNASIUM	2/13/2023	9:25:00 AM	714	0.5	72	21.3	14	
271 Belvidere	1205 STAFF LOUNGE	2/13/2023	9:24:00 AM	487	0.5	71.8	19.5	0	
271 Belvidere	1206 WORKROOM	2/13/2023	9:23:00 AM	481	0.5	72	19.2	0	
271 Belvidere	1301 KITCHEN	2/13/2023	9:21:00 AM	485	0.4	72.1	22.3	1	
271 Belvidere	1302 MULTI PURPOSE	2/13/2023	9:18:00 AM	477	0.4	70.3	20.3	0	
271 Belvidere	1306 CUBICLES	2/13/2023	9:07:00 AM	497	0.5	69.3	20.8	5	
271 Belvidere	1306A OFFICE	2/13/2023	9:10:00 AM	525	0.5	68.9	21.1	1	
271 Belvidere	1307 WORKROOM	2/13/2023	9:11:00 AM	509	0.4	68.9	20.9	0	
271 Belvidere	1311 LIBRARY	2/13/2023	9:05:00 AM	474	0.4	69.4	20.4	1	
271 Belvidere	1314 CONFERENCE	2/13/2023	9:04:00 AM	470	0.5	69.3	20.8	1	
271 Belvidere	1315 CONFERENCE	2/13/2023	9:02:00 AM	456	0.5	69.1	20.4	0	
271 Belvidere	2106 MAIN OFFICE	2/13/2023	9:51:00 AM	548	0.4	72	19.7	2	
271 Belvidere	2108 OFFICE	2/13/2023	9:54:00 AM	576	0.4	71.6	20.2	2	Coffee odor
271 Belvidere	2110 OFFICE	2/13/2023	9:56:00 AM	538	0.4	71.6	19.4	0	
271 Belvidere	2112 OFFICE	2/13/2023	10:00:00 AM	984	0.5	73	22.2	0	Fragrance odor
271 Belvidere	OUTDOORS	2/13/2023		445	0.8	45	62		
Adams Spanish Immersion	1001	2/17/2023	12:04:00 PM	533	0.1	72.5	9	0	
Adams Spanish Immersion	1002	2/17/2023	12:01:00 PM	470		72.9	9.1	0	Aquariums (fish)
Adams Spanish Immersion	1004	2/17/2023	12:06:00 PM	496		72.7	8.7	0	
Adams Spanish Immersion	1006	2/17/2023	12:02:00 PM	470	0.1	72.6	8.2	0	
Adams Spanish Immersion	1007	2/17/2023	12:08:00 PM	495	0.2	72.8	8.4	0	
Adams Spanish Immersion	1008	2/17/2023	12:10:00 PM	485		72.7	8.4	1	Plastic/laminator odor
Adams Spanish Immersion	1009	2/17/2023	12:13:00 PM	493		72.4	7.6	1	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1010	2/17/2023	12:14:00 PM	583		72.1	8.9	1	
Adams Spanish Immersion	1011	2/17/2023	11:56:00 AM	512		71.4	10.4	2	
Adams Spanish Immersion	1103	2/17/2023	12:16:00 PM	573	0.1	71.5	9.9	18	
Adams Spanish Immersion	1201	2/17/2023	11:39:00 AM	866		72.1	17.4	21	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Adams Spanish Immersion	1202	2/17/2023	11:40:00 AM	1108	0.1	72.5	16.5	23	
Adams Spanish Immersion	1203	2/17/2023	11:44:00 AM	989	0.2	71.7	16.5	23	
Adams Spanish Immersion	1301	2/17/2023	11:47:00 AM	758	0.1	71	14.9	21	Bubbling/peeling paint
Adams Spanish Immersion	1302	2/17/2023	11:50:00 AM	718		71.7	14.2	26	
Adams Spanish Immersion	1303	2/17/2023	11:53:00 AM	513	0.1	71.5	11.4	0	
Adams Spanish Immersion	1306	2/17/2023	11:34:00 AM	650	0.1	68.9	15.8	1	
Adams Spanish Immersion	1400	2/17/2023	12:27:00 PM	544	0.1	70.3	9.3	0	
Adams Spanish Immersion	1401	2/17/2023	12:51:00 PM	796	0.1	71.5	14.9	16	
Adams Spanish Immersion	1402	2/17/2023	12:49:00 PM	604		71.6	12.1	23	
Adams Spanish Immersion	1403	2/17/2023	12:47:00 PM	819	0.1	71.6	15.4	24	
Adams Spanish Immersion	1404	2/17/2023	12:45:00 PM	534		70.7	10.9	16	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1405	2/17/2023	12:43:00 PM	585		70.6	12.1	18	
Adams Spanish Immersion	1406	2/17/2023	12:39:00 PM	641	0.1	69.6	12.9	21	
Adams Spanish Immersion	1505	2/17/2023	12:22:00 PM	478		71.1	10.6	0	
Adams Spanish Immersion	1509	2/17/2023	12:29:00 PM	609		70.3	12.1	0	
Adams Spanish Immersion	2201	2/17/2023	1:55:00 PM	1167	0.1	71.9	18.4	22	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2202	2/17/2023	2:12:00 PM	1145		71.8	19.9	26	Sour odor, Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2203	2/17/2023	1:57:00 PM	968		72.8	17.6	21	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2302	2/17/2023	1:52:00 PM	717		71.9	13.7	6	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2303	2/17/2023	1:50:00 PM	494	0.2	72.5	11	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2304	2/17/2023	1:45:00 PM	756		72.4	13.6	24	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2306	2/17/2023	1:43:00 PM	662		72.4	12.5	26	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2307	2/17/2023	1:41:00 PM	496		71.8	11.2	0	
Adams Spanish Immersion	2308	2/17/2023	1:49:00 PM	544		73.4	11.8	2	
Adams Spanish Immersion	2310	2/17/2023	1:54:00 PM	495	0.1	71.4	12.2	0	
Adams Spanish Immersion	2403	2/17/2023	1:32:00 PM	521		69.9	11.6	2	
Adams Spanish Immersion	2404	2/17/2023	1:31:00 PM	470		70.8	10.4	0	
Adams Spanish Immersion	2501	2/17/2023	1:40:00 PM	634		71.8	10.2	3	
Adams Spanish Immersion	2502	2/17/2023	1:35:00 PM	628		71.1	12.2	22	Plants: Kept Away From Return And Supply Vents, Taxidermy
Adams Spanish Immersion	2504	2/17/2023	1:33:00 PM	512		69.7	9.9	1	
Adams Spanish Immersion	2505	2/17/2023	1:28:00 PM	444	0.1	71.7	10.8	0	
Adams Spanish Immersion	2601	2/17/2023	1:25:00 PM	457	0.1	71.9	11.3	1	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2602	2/17/2023	1:23:00 PM	574	0.1	72.1	13.5	26	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2603	2/17/2023	1:20:00 PM	815		72.5	13.4	29	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2604	2/17/2023	1:14:00 PM	428	0.1	71.2	10.4	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2605	2/17/2023	1:11:00 PM	827		72.7	15.6	21	
Adams Spanish Immersion	2801	2/17/2023	1:17:00 PM	448	0.1	71.2	10.2	0	
Adams Spanish Immersion	2802	2/17/2023	1:03:00 PM	552	0.1	70.1	12.3	1	
Adams Spanish Immersion	2803	2/17/2023	1:03:00 PM	431		69	11.1	0	Stained ceiling tiles
Adams Spanish Immersion	3201	2/17/2023	3:22:00 PM	495	0.2	70.5	14.1	0	
Adams Spanish Immersion	3202	2/17/2023	2:42:00 PM	471	0.1	71.1	13.2	0	
Adams Spanish Immersion	3203	2/17/2023	2:44:00 PM	475	0.1	71.2	13.2	0	Stained ceiling tiles
Adams Spanish Immersion	3301	2/17/2023	2:53:00 PM	621		70.8	13.9	0	
Adams Spanish Immersion	3302	2/17/2023	2:46:00 PM	545		71.1	13	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3303	2/17/2023	2:35:00 PM	609		71.5	13.5	1	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3304	2/17/2023	2:48:00 PM	536	0.2	70.7	12.6	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3305	2/17/2023	2:28:00 PM	689	0.1	70.7	14.1	24	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3306	2/17/2023	2:50:00 PM	912		70.9	15	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Adams Spanish Immersion	3307	2/17/2023	3:17:00 PM	472		69.4	12.7	0	
Adams Spanish Immersion	3308	2/17/2023	2:25:00 PM	644		70.9	14.2	24	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3309	2/17/2023	2:31:00 PM	831	0.2	70.9	15.6	20	Live animals: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1011A	2/17/2023	11:57:00 AM	503	0.1	71.6	9.6	0	
Adams Spanish Immersion	1103C	2/17/2023	12:20:00 PM	595	0.1	71.2	10.2	0	
Adams Spanish Immersion	1103D	2/17/2023	12:19:00 PM	573		71.2	10.1	0	
Adams Spanish Immersion	1520A	2/17/2023	12:57:00 PM	590		69.9	12.6	1	
Adams Spanish Immersion	2803A	2/17/2023	1:10:00 PM	450	0.1	69.3	10.4	0	
Adams Spanish Immersion	CAFETERIA	2/17/2023	12:35:00 PM	697		69	12.8	60	Stained ceiling tiles
Adams Spanish Immersion	GYMNASIUM	2/17/2023	12:31:00 PM	648	0.1	66.2	12.1	19	
Adams Spanish Immersion	KITCHEN	2/17/2023	3:08:00 PM	747		71.9	16.8	0	
Adams Spanish Immersion	KITCHEN OFFICE	2/17/2023	3:09:00 PM	554		74.1	12.1	0	
Adams Spanish Immersion	MAIN OFFICE	2/17/2023	11:59:00 AM	531	0.1	72.2	9.6	2	
Adams Spanish Immersion	OUTDOORS	2/17/2023		411	2.9	19	50		
Adams Spanish Immersion	STAGE NEXT TO CAFETERIA	2/17/2023	12:42:00 PM	551		68.5	10.4	15	
Administration Building	105	12/5/2022	9:46:00 AM	547	0.1	70.3	18.3	2	
Administration Building	106	12/5/2022	9:45:00 AM	544	0.1	70.3	18.4	1	
Administration Building	108	12/5/2022	9:41:00 AM	564	0.1	70.2	18.3	0	Rust on Air Supply
Administration Building	109	12/5/2022	9:37:00 AM	623	0.3	72.9	19.4	1	
Administration Building	110	12/5/2022	9:35:00 AM	855	0.1	73.8	19.1	3	
Administration Building	111	12/5/2022	9:17:00 AM	690	0.1	64.4	23.2	3	
Administration Building	112	12/5/2022	9:33:00 AM	543	0	71.8	17.5	1	
Administration Building	113	12/5/2022	9:38:00 AM	535	0.1	72	17.8	0	
Administration Building	114	12/5/2022	9:31:00 AM	738	0.1	71.8	20.3	1	Fragrance odor, Plants: Kept Away From Return And Supply Vents
Administration Building	115	12/5/2022	9:53:00 AM	513	0.1	68	18.7	0	Stained ceiling tiles
Administration Building	116	12/5/2022	9:55:00 AM	499	0.1	69.8	17.9	0	
Administration Building	117	12/5/2022	10:00:00 AM	461	0.1	71.2	17.2	0	
Administration Building	118	12/5/2022	9:46:00 AM	722	0.1	71.6	18.2	1	
Administration Building	118	12/5/2022	10:01:00 AM	469	0.1	71.6	17	0	
Administration Building	141	12/5/2022	10:26:00 AM	562	0.1	71.8	17.5	1	Stained ceiling tiles
Administration Building	207	12/5/2022	10:45:00 AM	512	0.1	71.6	17	0	
Administration Building	211	12/5/2022	10:51:00 AM	512	0.1	73.9	15.7	0	
Administration Building	212	12/5/2022	10:48:00 AM	554	0.1	73.2	17	4	Plants: Kept Away From Return And Supply Vents
Administration Building	213	12/5/2022	10:52:00 AM	600	0.1	73.9	18.6	0	
Administration Building	214	12/5/2022	11:22:00 AM	645	0.1	72.9	18.5	2	
Administration Building	215	12/5/2022	10:49:00 AM	586	0.1	73.4	17.1	4	
Administration Building	218	12/5/2022	11:20:00 AM	533	0.1	71.8	17	1	
Administration Building	221	12/5/2022	11:19:00 AM	502	0.1	71.2	16.8	0	
Administration Building	222	12/5/2022	10:53:00 AM	544	0.1	73.4	16.4	0	Stained ceiling tiles
Administration Building	223	12/5/2022	10:55:00 AM	551	0.1	73.4	16.2	3	Plants: Kept Away From Return And Supply Vents
Administration Building	224	12/5/2022	11:01:00 AM	523	0.1	71.6	16.7	0	
Administration Building	230	12/5/2022	10:56:00 AM	560	0.1	73.6	16.5	1	Moisture damage on Radiator
Administration Building	231	12/5/2022	11:00:00 AM	510	0.1	72.7	16.2	0	
Administration Building	232	12/5/2022	11:12:00 AM	500	0.1	71.4	16.9	0	
Administration Building	233	12/5/2022	11:11:00 AM	584	0.1	71.4	17.6	0	
Administration Building	234	12/5/2022	11:10:00 AM	514	0.1	70.9	17.4	0	
Administration Building	235	12/5/2022	11:13:00 AM	500	0.1	71.4	16.8	0	Plants: Kept Away From Return And Supply Vents
Administration Building	237	12/5/2022	11:15:00 AM	504	0.1	71.6	16.9	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	239	12/5/2022	11:17:00 AM	500	0.1	71.6	16.7	0	
Administration Building	308	12/5/2022	12:44:00 PM	520	0.1	70	17.4	0	
Administration Building	309	12/5/2022	12:42:00 PM	509	0.2	71.1	16.8	0	
Administration Building	310	12/5/2022	12:45:00 PM	535	0.1	70.2	19.1	1	
Administration Building	311	12/5/2022	12:40:00 PM	534	0.2	71.6	17.3	1	
Administration Building	313	12/5/2022	12:41:00 PM	608	0.1	72	17.5	3	Plants: Kept Away From Return And Supply Vents
Administration Building	314	12/5/2022	12:39:00 PM	604	0.1	70.7	18.8	2	
Administration Building	315	12/5/2022	12:36:00 PM	528	0.2	71.1	17.2	1	
Administration Building	322	12/5/2022	12:34:00 PM	569	0.1	72.5	17.4	1	Plants: Kept Away From Return And Supply Vents
Administration Building	323	12/5/2022	12:35:00 PM	601	0.1	72.9	18.3	1	
Administration Building	324	12/5/2022	12:32:00 PM	604	0.2	71.4	18.9	1	
Administration Building	325	12/5/2022	12:29:00 PM	606	0.1	70.5	20.7	0	Plants: Kept Away From Return And Supply Vents
Administration Building	326	12/5/2022	12:28:00 PM	503	0.1	70.3	17.1	0	
Administration Building	328	12/5/2022	12:06:00 PM	564	0.1	72.3	17.3	3	
Administration Building	330	12/5/2022	12:10:00 PM	602	0.1	72.5	17.1	5	
Administration Building	331	12/5/2022	12:19:00 PM	630	0.1	71.1	19.4	1	
Administration Building	332	12/5/2022	12:21:00 PM	594	0.1	71.6	17.7	4	
Administration Building	337	12/5/2022	12:26:00 PM	497	0.1	71.1	16.8	0	
Administration Building	338	12/5/2022	12:17:00 PM	537	0.1	70	17.1	1	
Administration Building	339	12/5/2022	12:16:00 PM	515	0.2	70.2	17.3	0	
Administration Building	340	12/5/2022	12:24:00 PM	535	0.1	71.8	17	0	Stained ceiling tiles
Administration Building	341	12/5/2022	12:47:00 PM	551	0.1	71.1	19.3	1	
Administration Building	342	12/5/2022	12:46:00 PM	545	0.1	70.9	17.4	1	
Administration Building	343	12/5/2022	12:11:00 PM	502	0.1	72.7	16.6	0	
Administration Building	344	12/5/2022	12:13:00 PM	564	0.1	71.8	19.9	1	Plants: Kept Away From Return And Supply Vents
Administration Building	345	12/5/2022	12:12:00 PM	539	0.1	72	16.9	0	
Administration Building	346	12/5/2022	12:27:00 PM	573	0.1	70.7	17.9	1	
Administration Building	347	12/5/2022	12:06:00 PM	524	0.1	72.3	16.9	1	
Administration Building	348	12/5/2022	12:04:00 PM	490	0.1	72	16.6	0	Plants: Kept Away From Return And Supply Vents
Administration Building	349	12/5/2022	12:02:00 PM	508	0.1	71.8	17.7	0	
Administration Building	350	12/5/2022	12:01:00 PM	522	0.1	69.8	18.2	0	
Administration Building	409	12/5/2022	2:19:00 PM	563	0.1	77.4	14	0	
Administration Building	410	12/5/2022	2:16:00 PM	566	0.1	73.6	18.2	0	
Administration Building	414	12/5/2022	1:52:00 PM	560	0.3	71.2	17.4	1	
Administration Building	415	12/5/2022	2:11:00 PM	545	0.3	74.8	15.7	0	Plants: Kept Away From Return And Supply Vents
Administration Building	417	12/5/2022	2:09:00 PM	547	0.1	75	15.6	1	
Administration Building	418	12/5/2022	2:08:00 PM	502	0.2	73.2	15.6	0	
Administration Building	419	12/5/2022	2:06:00 PM	500	0.2	72.9	15.7	0	Stuffy odor
Administration Building	420	12/5/2022	1:57:00 PM	498	0.2	72.3	16.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	423	12/5/2022	1:56:00 PM	497	0.1	72.3	16.8	0	Plants: Kept Away From Return And Supply Vents
Administration Building	424	12/5/2022	2:05:00 PM	549	0.1	73	16.9	1	
Administration Building	425	12/5/2022	1:54:00 PM	553	0.2	71.1	17.1	1	
Administration Building	426	12/5/2022	1:50:00 PM	499	0.3	71.4	16.6	0	
Administration Building	433	12/5/2022	1:50:00 PM	508	0.3	72.3	16.3	0	
Administration Building	435	12/5/2022	1:47:00 PM	548	0.2	72	21	1	Plants: Kept Away From Return And Supply Vents
Administration Building	436	12/5/2022	1:46:00 PM	507	0.3	71.2	17.1	0	Plants: Kept Away From Return And Supply Vents
Administration Building	437	12/5/2022	1:44:00 PM	505	0.3	71.2	17	0	Plants: Kept Away From Return And Supply Vents
Administration Building	438	12/5/2022	1:42:00 PM	615	0.3	71.2	19.1	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	440	12/5/2022	1:40:00 PM	533	0.4	70.7	17.5	0	
Administration Building	441	12/5/2022	1:38:00 PM	665	0.3	70	19.1	0	Plants: Kept Away From Return And Supply Vents
Administration Building	442	12/5/2022	1:36:00 PM	616	0.1	67.6	21	0	
Administration Building	443	12/5/2022	2:01:00 PM	791	0.2	73	19.5	6	
Administration Building	446	12/5/2022	2:03:00 PM	564	0.3	72.9	16.4	1	
Administration Building	511	12/5/2022	2:29:00 PM	500	0.1	71.4	15.9	0	
Administration Building	513	12/5/2022	2:56:00 PM	554	0.2	74.5	15	2	Plants: Kept Away From Return And Supply Vents
Administration Building	514	12/5/2022	2:48:00 PM	531	0.1	74.3	15.1	1	Plants: Kept Away From Return And Supply Vents
Administration Building	515	12/5/2022	2:55:00 PM	531	0.1	74.8	16.2	1	
Administration Building	516	12/5/2022	2:43:00 PM	551	0.1	73.9	15.5	1	
Administration Building	517	12/5/2022	2:42:00 PM	524	0.1	73.6	17.2	1	
Administration Building	524	12/5/2022	2:41:00 PM	519	0.2	74.1	14.9	1	
Administration Building	525	12/5/2022	2:39:00 PM	512	0.1	74.7	14.9	0	
Administration Building	526	12/5/2022	2:36:00 PM	525	0.1	73.9	15.1	0	
Administration Building	527	12/5/2022	2:35:00 PM	510	0.1	73.8	15.2	0	
Administration Building	528	12/5/2022	2:34:00 PM	542	0.1	73.4	15.6	1	Plants: Kept Away From Return And Supply Vents
Administration Building	529	12/5/2022	2:33:00 PM	520	0.1	73.2	15.7	0	
Administration Building	530	12/5/2022	2:53:00 PM	595	0.1	73.6	16.5	2	Plants: Kept Away From Return And Supply Vents
Administration Building	531	12/5/2022	2:38:00 PM	537	0.1	74.5	16.5	2	
Administration Building	533	12/5/2022	2:47:00 PM	544	0.1	74.5	15.8	1	
Administration Building	534	12/5/2022	2:46:00 PM	545	0.1	74.5	15.2	2	Plants: Kept Away From Return And Supply Vents
Administration Building	535	12/5/2022	2:51:00 PM	524	0.2	73.6	15.2	0	
Administration Building	1003	12/5/2022	10:32:00 AM	541	0.1	72.1	17	0	
Administration Building	1004	12/5/2022	10:31:00 AM	643	0.1	72	18.3	1	
Administration Building	1005	12/5/2022	10:29:00 AM	516	0.1	72	16.9	0	
Administration Building	1008	12/5/2022	10:22:00 AM	542	0.1	72.1	17	0	
Administration Building	1009	12/5/2022	10:18:00 AM	618	0.1	72.7	18.1	1	
Administration Building	1009A	12/5/2022	10:19:00 AM	588	0.1	72.9	18.6	1	
Administration Building	1009B	12/5/2022	10:21:00 AM	645	0.1	72.3	18.1	0	
Administration Building	118A	12/5/2022	9:49:00 AM	611	0.1	71.6	18.9	1	
Administration Building	207A	12/5/2022	11:26:00 AM	506	0.1	69.5	16.2	0	
Administration Building	207B	12/5/2022	11:28:00 AM	553	0.1	72.5	18.5	0	
Administration Building	208A	12/5/2022	11:35:00 AM	560	0.1	72.5	17.1	2	Plants: Kept Away From Return And Supply Vents
Administration Building	210A	12/5/2022	10:50:00 AM	580	0.1	73.6	17.4	1	Plants: Kept Away From Return And Supply Vents
Administration Building	329A	12/5/2022	12:23:00 PM	615	0.1	72	17.8	1	
Administration Building	329B	12/5/2022	12:01:00 PM	585	0.1	70.9	19.2	1	Plants: Kept Away From Return And Supply Vents
Administration Building	524A	12/5/2022	2:40:00 PM	512	0.2	74.8	14.7	0	
Administration Building	A SUCHON CUBICLE	12/5/2022	2:13:00 PM	569	0.3	74.1	16.1	1	Plants: Kept Away From Return And Supply Vents
Administration Building	B108	12/5/2022	10:04:00 AM	900	0.1	73.9	20	11	
Administration Building	B109	12/5/2022	10:06:00 AM	533	0.3	72.3	16.9	0	
Administration Building	B110	12/5/2022	10:41:00 AM	525	0.1	71.4	17.1	1	
Administration Building	B111	12/5/2022	10:09:00 AM	531	0.1	72	17.5	0	
Administration Building	B112	12/5/2022	10:39:00 AM	619	0.1	71.2	18	1	
Administration Building	B113	12/5/2022	10:38:00 AM	672	0.1	71.6	18.2	1	Fragrance odor
Administration Building	B114	12/5/2022	10:14:00 AM	542	0.1	71.6	17.3	1	
Administration Building	B115	12/5/2022	10:11:00 AM	1126	0.1	72.5	23.2	16	
Administration Building	B121	12/5/2022	10:15:00 AM	586	0.1	72.1	18.8	1	
Administration Building	B122	12/5/2022	10:16:00 AM	535	0.1	73.8	16.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	B203	12/5/2022	11:23:00 AM	538	0.1	72.5	16.5	4	Stained ceiling tiles
Administration Building	B206	12/5/2022	11:25:00 AM	546	0.1	73.9	16.5	5	Plants: Kept Away From Return And Supply Vents
Administration Building	B206 NORTH	12/5/2022	11:33:00 AM	652	0.1	73.2	16.5	1	
Administration Building	B211	12/5/2022	11:40:00 AM	608	0.1	73.4	17.6	2	
Administration Building	B212	12/5/2022	11:38:00 AM	693	0.1	73	20.8	1	
Administration Building	B213	12/5/2022	11:43:00 AM	564	0.1	73.6	18.1	1	
Administration Building	B214	12/5/2022	11:37:00 AM	668	0.2	72.1	19.7	1	
Administration Building	B214 CONFERENCE ROOM	12/5/2022	11:41:00 AM	523	0.1	73.2	16.3	0	
Administration Building	CAFETERIA	12/5/2022	2:26:00 PM	509	0.1	71.4	16	0	
Administration Building	J REESE CUBICLES	12/5/2022	1:48:00 PM	540	0.3	72.7	16.7	1	Plants: Kept Away From Return And Supply Vents
Administration Building	K WEYANDT OFFICE	12/5/2022	11:16:00 AM	502	0.1	72	16.9	0	
Administration Building	K ZAN CUBICLE	12/5/2022	11:09:00 AM	495	0.1	70.9	17	0	
Administration Building	L006	12/5/2022	9:28:00 AM	539	0.2	72.7	17.9	1	
Administration Building	M MARSICAL CUBICLE	12/5/2022	2:00:00 PM	606	0.2	72.7	17.4	2	
Administration Building	M SAUNDERS CUBICLES	12/5/2022	2:15:00 PM	556	0.2	73.4	16.4	4	Plants: Kept Away From Return And Supply Vents
Administration Building	OUTDOORS	12/5/2022		386	0.4	27	75		
Administration Building	RECEPTION	12/5/2022	2:31:00 PM	521	0.1	72.7	15.8	0	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1001	2/16/2023	1:57:00 PM	652	0.1	70.7	9.1	0	
AGAPE High School	1003	2/16/2023	2:56:00 PM	560	0.1	69.3	8.7	0	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1005	2/16/2023	2:54:00 PM	587	0.1	70.6	7.4	1	
AGAPE High School	1012	2/16/2023	1:58:00 PM	603	0.1	72.1	8.1	0	
AGAPE High School	1013	2/16/2023	2:02:00 PM	589	0.1	72.4	8.2	1	
AGAPE High School	1014	2/16/2023	2:04:00 PM	593	0.1	71.6	7.7	0	
AGAPE High School	1018	2/16/2023	2:06:00 PM	571	0.2	70.8	0.3	1	Taxidermy
AGAPE High School	1019	2/16/2023	2:08:00 PM	553	0.1	70.6	7.9	1	
AGAPE High School	1023	2/16/2023	3:10:00 PM	541	0.1	70	7.8	0	Stained ceiling tiles
AGAPE High School	1024	2/16/2023	3:08:00 PM	543	0.1	71.4	7.4	0	
AGAPE High School	1025	2/16/2023	2:10:00 PM	568	0.1	71.2	8.2	5	
AGAPE High School	1026	2/16/2023	2:12:00 PM	617	0.1	71.6	10.2	5	
AGAPE High School	1027	2/16/2023	2:14:00 PM	644	0.1	71.1	7.7	0	
AGAPE High School	1028	2/16/2023	2:17:00 PM	709	0.1	71.6	9.4	7	
AGAPE High School	1029	2/16/2023	2:26:00 PM	607	0.1	71	8.5	0	
AGAPE High School	1030	2/16/2023	2:19:00 PM	787	0.1	71	9.2	6	
AGAPE High School	1031	2/16/2023	2:20:00 PM	753	0.1	71.2	9.5	5	
AGAPE High School	1032	2/16/2023	2:22:00 PM	742	0.1	71.8	9.5	6	
AGAPE High School	1033	2/16/2023	2:24:00 PM	803	0.1	71.6	9.1	8	
AGAPE High School	1035	2/16/2023	2:27:00 PM	837	0.1	70.4	9.8	3	
AGAPE High School	1038	2/16/2023	2:29:00 PM	574	0.1	70.3	7.9	0	
AGAPE High School	1040	2/16/2023	2:31:00 PM	616	0.1	70.1	9	1	Fragrance odor, Plants: Kept Away From Return And Supply Vents
AGAPE High School	1041	2/16/2023	2:33:00 PM	636	0.1	70.9	8.8	4	Taxidermy
AGAPE High School	1042	2/16/2023	2:34:00 PM	776	0.1	71.2	10.1	3	
AGAPE High School	1043	2/16/2023	2:36:00 PM	586	0.1	70.3	7.4	0	
AGAPE High School	1045	2/16/2023	2:38:00 PM	586	0.1	70.2	8	6	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1046	2/16/2023	2:41:00 PM	535	0.1	70.9	8.1	0	
AGAPE High School	1006 PRINCIPAL	2/16/2023	2:51:00 PM	573	0.1	71.2	7.6	1	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1007 BREAK ROOM	2/16/2023	3:01:00 PM	537	0.1	71.8	8.3	1	
AGAPE High School	1009 RECEPTION	2/16/2023	2:59:00 PM	56	0.1	69.4	8.96	1	
AGAPE High School	1020 HEALTH START	2/16/2023	3:04:00 PM	571	0.1	72.6	8	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
AGAPE High School	1021 EXAM	2/16/2023	3:07:00 PM	556	0.1	72	7.5	0	
AGAPE High School	1048 CAFETERIA	2/16/2023	2:46:00 PM	497	0.1	70.9	10.2	0	
AGAPE High School	1053 KITCHEN	2/16/2023	2:48:00 PM	487	0.1	70.7	11.1	0	
AGAPE High School	1206 COT ROOM	2/16/2023	2:45:00 PM	539	0.1	70.8	7.7	0	Taxidermy
AGAPE High School	MAIN OFFICE 1000	2/16/2023	3:16:00 PM	564	0.1	71.8	7.9	1	
AGAPE High School	OUTDOORS	2/16/2023		688	4.3	18	5.4		
American Indian Magnet	1201	1/25/2023	10:31:00 AM	852	2.5	70.7	23.9	11	
American Indian Magnet	1203	1/25/2023	10:30:00 AM	731	2.5	70.7	23.7	18	
American Indian Magnet	1203	1/25/2023	11:05:00 AM	1224	1.2	72.5	27.6	1	
American Indian Magnet	1205	1/25/2023	10:29:00 AM	734	2.5	70.3	24.2	13	
American Indian Magnet	1207	1/25/2023	10:56:00 AM	1443	1.3	70.5	30.1	1	
American Indian Magnet	1208	1/25/2023	10:55:00 AM	1134	1.3	69.8	28.2	21	Stained ceiling tiles
American Indian Magnet	1209	1/25/2023	10:54:00 AM	951	1.3	69.6	26.4	9	Plants
American Indian Magnet	1301	1/25/2023	10:49:00 AM	1143	1.5	70	28.3	25	
American Indian Magnet	1302	1/25/2023	10:46:00 AM	1254	1.7	69.6	28.9	18	
American Indian Magnet	1303	1/25/2023	10:44:00 AM	1634	1.9	70.5	31.5	23	
American Indian Magnet	1304	1/25/2023	10:42:00 AM	1150	2.1	70.9	26.8	11	
American Indian Magnet	2201	1/25/2023	11:25:00 AM	938	0.7	70.5	25.9	17	
American Indian Magnet	2203	1/25/2023	11:30:00 AM	970	0.7	71.1	26.1	20	
American Indian Magnet	2204	1/25/2023	11:45:00 AM	1247	0.7	69.4	29.7	3	Stained ceiling tiles, Taxidermy
American Indian Magnet	2301	1/25/2023	12:10:00 PM	1224	0.6	69.6	28.5	0	
American Indian Magnet	2302	1/25/2023	12:22:00 PM	1077	0.6	69.8	28.1	25	Stained ceiling tiles
American Indian Magnet	2304	1/25/2023	11:58:00 AM	1372	0.6	70.2	29.9	24	
American Indian Magnet	3201	1/25/2023	12:24:00 PM	731	0.6	70.5	25	17	Live animals
American Indian Magnet	3203	1/25/2023	12:27:00 PM	588	0.6	71.1	23.4	11	
American Indian Magnet	4305	1/25/2023	12:37:00 PM	1281	0.6	71.2	29.6	14	
American Indian Magnet	4307	1/25/2023	12:38:00 PM	1612	0.7	71.1	34	25	
American Indian Magnet	4309	1/25/2023	12:41:00 PM	1188	0.7	70.3	28.8	20	
American Indian Magnet	4403	1/25/2023	12:43:00 PM	1525	0.6	70.7	32.6	25	Plants
American Indian Magnet	4405	1/25/2023	12:44:00 PM	1342	0.7	70.9	30.2	8	Plants
American Indian Magnet	4407	1/25/2023	12:46:00 PM	1370	0.7	70	30.7	5	
American Indian Magnet	4409	1/25/2023	12:47:00 PM	1327	0.7	69.3	30.9	9	
American Indian Magnet	4413	1/25/2023	12:50:00 PM	1285	0.7	69.6	30.5	1	Plants
American Indian Magnet	1101 COMMUNITY ROOM	1/25/2023	10:37:00 AM	607	2.1	69.3	22.8	0	
American Indian Magnet	1103 LONGHOUSE MEDIA	1/25/2023	10:33:00 AM	537	2.4	69.6	22.9	7	
American Indian Magnet	1202 OFFICE	1/25/2023	11:24:00 AM	891	0.8	70.3	27.9	6	
American Indian Magnet	1202 WORKROOM	1/25/2023	11:02:00 AM	1166	1	71.8	28.1	2	Stuffy odor
American Indian Magnet	1204 OFFICE	1/25/2023	11:00:00 AM	968	1	69.8	26	0	
American Indian Magnet	1205 OFFICE	1/25/2023	10:59:00 AM	944	1.2	68.9	27	0	
American Indian Magnet	1206 MAINTENANCE OFFICE	1/25/2023	10:24:00 AM	941	2.7	70.5	26.5	1	
American Indian Magnet	1206 OFFICE	1/25/2023	10:58:00 AM	1138	1.3	69.4	28	0	
American Indian Magnet	1210 OFFICE	1/25/2023	10:52:00 AM	893	1.5	69.8	25.1	0	
American Indian Magnet	1215 OFFICE	1/25/2023	11:06:00 AM	983	1.2	71.1	25.2	1	
American Indian Magnet	2203 NURSE OFFICE	1/25/2023	11:40:00 AM	1055	0.6	68.5	27.6	3	
American Indian Magnet	2203 OFFICE	1/25/2023	11:41:00 AM	1040	0.7	69.3	27.7	2	
American Indian Magnet	2205 NEW SIDE	1/25/2023	12:04:00 PM	822	0.5	72	24	2	
American Indian Magnet	2206A OFFICE	1/25/2023	11:47:00 AM	1092	0.6	70.9	28.6	1	Plants
American Indian Magnet	2207 NEW SIDE	1/25/2023	12:07:00 PM	653	0.7	71.6	22.9	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
American Indian Magnet	2207 OFFICE	1/25/2023	11:51:00 AM	1070	0.7	70.7	26.8	1	
American Indian Magnet	2209 OFFICE	1/25/2023	11:34:00 AM	697	0.7	71.1	23.2	0	
American Indian Magnet	2210 OFFICE	1/25/2023	11:31:00 AM	776	0.7	71.1	24.2	0	
American Indian Magnet	2303 OFFICE	1/25/2023	11:54:00 AM	1033	0.7	69.8	26.6	0	Stained ceiling tiles
American Indian Magnet	2305 OFFICE	1/25/2023	11:59:00 AM	1088	0.7	69.4	28.4	2	
American Indian Magnet	2306 LEFT CLASSROOM	1/25/2023	12:00:00 PM	1171	0.6	69.6	28.9	16	
American Indian Magnet	2306 RIGHT OFFICE	1/25/2023	12:03:00 PM	1033	0.7	69.3	27.6	0	Plants
American Indian Magnet	3208 OFFICE	1/25/2023	12:30:00 PM	711	0.7	71.6	23.5	1	
American Indian Magnet	4204 OFFICE	1/25/2023	12:32:00 PM	881	0.7	71.4	24.8	0	
American Indian Magnet	4301A	1/25/2023	12:34:00 PM	1231	0.7	71.1	28.5	5	Plants
American Indian Magnet	4301C OFFICE	1/25/2023	12:35:00 PM	1142	0.7	70.5	27.4	0	
American Indian Magnet	4303 SMALL MEDIA CENTER	1/25/2023	12:36:00 PM	1033	0.6	70.2	27	0	
American Indian Magnet	4411A OFFICE	1/25/2023	12:50:00 PM	1200	0.6	70	30.6	2	
American Indian Magnet	4411B OFFICE	1/25/2023	12:48:00 PM	858	0.5	69.4	26.7	1	Plants
American Indian Magnet	4414 OFFICE	1/25/2023	12:53:00 PM	1060	0.6	69.1	27.9	0	
American Indian Magnet	ASSISTANT PRINCIPAL OFFICE	1/25/2023	11:43:00 AM	1014	0.7	69.4	27.2	0	
American Indian Magnet	CAFETERIA	1/25/2023	10:38:00 AM	522	1.9	71.2	22	0	
American Indian Magnet	CLASSROOM BY T3 ART	1/25/2023	11:15:00 AM	1234	0.8	70.5	27.7	0	
American Indian Magnet	KITCHEN	1/25/2023	10:40:00 AM	508	1.9	72.1	22.6	3	
American Indian Magnet	KITCHEN OFFICE	1/25/2023	10:41:00 AM	622	1.9	73.2	22	1	
American Indian Magnet	OUTDOORS	1/25/2023		402	0.4	28	50.6		
American Indian Magnet	PRINCIPAL OFFICE	1/25/2023	11:44:00 AM	1014	0.7	69.4	27.1	0	
American Indian Magnet	SPEECH, OT AND VISION OFFICE	1/25/2023	11:36:00 AM	933	0.7	68.5	26.3	1	
American Indian Magnet	T3 ART	1/25/2023	11:09:00 AM	1423	0.4	69.8	36.5	25	
American Indian Magnet	TECH OFFICE IN LONGHOUSE M	1/25/2023	10:35:00 AM	555	2.2	69.4	22.6	1	
American Indian Magnet	WORKROOM BY 1215	1/25/2023	11:07:00 AM	904	1	69.8	25.7	0	
Area Learning Center	1001	12/13/2022	1:21:00 PM	480	0.2	69.6	24.7	1	
Area Learning Center	1002	12/13/2022	1:22:00 PM	543	0.2	70.7	24.3	1	Stained ceiling tiles, Plants
Area Learning Center	1003	12/13/2022	1:23:00 PM	447	0.2	71.8	22.9	0	
Area Learning Center	1004	12/13/2022	1:25:00 PM	457	0.2	71.4	23	0	
Area Learning Center	1101	12/13/2022	1:19:00 PM	450	0.2	68.7	24.6	0	Stained ceiling tiles
Area Learning Center	1106	12/13/2022	1:16:00 PM	466	0.2	68.7	24.8	0	Stained ceiling tiles
Area Learning Center	1201	12/13/2022	1:28:00 PM	460	0.2	70.3	23.6	0	
Area Learning Center	1202	12/13/2022	1:26:00 PM	444		70.3	23.5	0	
Area Learning Center	1203	12/13/2022	1:30:00 PM	445	0.2	69.8	23.9	0	Stained ceiling tiles
Area Learning Center	1204	12/13/2022	1:31:00 PM	444	0.2	69.4	24.1	0	Stained ceiling tiles
Area Learning Center	1205	12/13/2022	1:37:00 PM	440	0.2	69.4	24.5	0	Stained ceiling tiles
Area Learning Center	1206	12/13/2022	1:34:00 PM	446	0.2	69.1	24.1	0	Stained ceiling tiles
Area Learning Center	2103	12/13/2022	2:10:00 PM	474	0.2	70.2	24	0	
Area Learning Center	2106	12/13/2022	2:12:00 PM	485	0.2	69.8	24.3	0	
Area Learning Center	2201	12/13/2022	2:09:00 PM	519	0.2	70.2	24.6	3	Plants
Area Learning Center	2202	12/13/2022	2:05:00 PM	463	0.2	68.7	24.9	0	Plants: Kept Away From Return And Supply Vents
Area Learning Center	2203	12/13/2022	2:03:00 PM	452	0.2	70	24	0	Stained ceiling tiles
Area Learning Center	2204	12/13/2022	2:01:00 PM	472	0.2	70.2	23.8	0	Stained ceiling tiles
Area Learning Center	2301	12/13/2022	2:00:00 PM	488	0.2	71.1	23.4	0	
Area Learning Center	2302	12/13/2022	1:48:00 PM	487	0.2	71.2	23.1	0	Stuffy odor, Stained ceiling tiles
Area Learning Center	2310	12/13/2022	1:42:00 PM	665	0.2	70.9	24.4	2	Stained ceiling tiles, Plants
Area Learning Center	2315	12/13/2022	1:43:00 PM	498	0.2	71.2	23.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Area Learning Center	2320	12/13/2022	1:38:00 PM	530	0.2	70.7	23.7	0	
Area Learning Center	2401	12/13/2022	1:50:00 PM	551	0.2	71.2	23.8	0	
Area Learning Center	2402	12/13/2022	1:51:00 PM	572	0.2	71.1	24.1	0	
Area Learning Center	2405	12/13/2022	1:54:00 PM	607	0.2	71.4	24.8	0	
Area Learning Center	2406	12/13/2022	1:55:00 PM	615	0.2	71.8	22.8	0	
Area Learning Center	2409	12/13/2022	1:57:00 PM	592	0.2	72	23.8	3	Plants
Area Learning Center	2211, 2210	12/13/2022	2:08:00 PM	484	0.2	69.1	25.1	0	
Area Learning Center	2414-2212	12/13/2022	2:04:00 PM	504	0.2	68.9	25.1	1	
Area Learning Center	OUTDOORS	12/13/2022		451	0.5	35	49.5		
Battle Creek Elementary	1001	11/17/2022	10:59:00 AM	570	0.2	71.6	22.5	1	Fragrance odor
Battle Creek Elementary	1002	11/17/2022	11:07:00 AM	605	0.2	72.5	21.9	0	
Battle Creek Elementary	1003	11/17/2022	11:05:00 AM	532	0.3	72.1	22.7	1	
Battle Creek Elementary	1004	11/17/2022	11:01:00 AM	607	0.3	72	22.5	0	Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1005	11/17/2022	11:02:00 AM	760	0.3	72	23	0	Fragrance odor
Battle Creek Elementary	1006	11/17/2022	11:04:00 AM	753	0.3	72.7	23.4	5	
Battle Creek Elementary	1102	11/17/2022	10:14:00 AM	742	0.8	72	21.9	1	
Battle Creek Elementary	1103	11/17/2022	10:19:00 AM	843	0.9	71.6	23.2	2	
Battle Creek Elementary	1104	11/17/2022	11:09:00 AM	760	0.3	71.6	24.2	21	
Battle Creek Elementary	1105	11/17/2022	11:11:00 AM	942	0.3	70.5	26	22	Aquariums (fish), Plants, Taxidermy
Battle Creek Elementary	1106	11/17/2022	11:14:00 AM	879	0.2	69.6	26	24	
Battle Creek Elementary	1107	11/17/2022	10:56:00 AM	666	0.2	69.1	26.1	0	
Battle Creek Elementary	1110	11/17/2022	10:52:00 AM	680	0.3	69.1	25.7	15	
Battle Creek Elementary	1112	11/17/2022	10:57:00 AM	731	0.2	69.4	25.1	25	
Battle Creek Elementary	1202	11/17/2022	12:28:00 PM	601	0.2	71.8	21.8	2	
Battle Creek Elementary	1203	11/17/2022	10:23:00 AM	895	0.9	71.6	22.5	60	
Battle Creek Elementary	1206	11/17/2022	10:27:00 AM	1449	0.8	72.9	28.8	20	Stained ceiling tiles
Battle Creek Elementary	1208	11/17/2022	10:31:00 AM	1048	0.8	71.8	26.4	19	
Battle Creek Elementary	1210	11/17/2022	10:39:00 AM	1213	0.6	70.3	29.4	24	Food odor, Stained ceiling tiles, Plants
Battle Creek Elementary	1211	11/17/2022	10:33:00 AM	1460	0.7	71.6	28.8	24	Fragrance odor, Stained ceiling tiles, Plants
Battle Creek Elementary	1212	11/17/2022	10:41:00 AM	1251	0.5	72	28.1	24	
Battle Creek Elementary	1213	11/17/2022	10:36:00 AM	1247	0.6	72	28.8	23	Live animals: Kept Away From Return And Supply Vents
Battle Creek Elementary	1215	11/17/2022	10:43:00 AM	702	0.5	71.1	24.6	2	Garbage odor, Stained ceiling tiles
Battle Creek Elementary	1216	11/17/2022	10:45:00 AM	967	0.5	70.9	27.6	2	Stained ceiling tiles, Plants
Battle Creek Elementary	1217	11/17/2022	10:47:00 AM	930	0.5	69.8	28.5	1	
Battle Creek Elementary	1218	11/17/2022	10:49:00 AM	920	0.4	69.4	28.2	2	Stained ceiling tiles
Battle Creek Elementary	1219	11/17/2022	10:51:00 AM	1090	0.4	69.4	28.8	3	
Battle Creek Elementary	1301	11/17/2022	11:48:00 AM	509	0.2	69.3	22.4	0	
Battle Creek Elementary	1302	11/17/2022	11:53:00 AM	627	0.2	69.3	25.4	1	
Battle Creek Elementary	1303	11/17/2022	11:56:00 AM	616	0.2	70.5	24.1	6	
Battle Creek Elementary	1304	11/17/2022	11:45:00 AM	535	0.2	70	23.2	0	
Battle Creek Elementary	1305	11/17/2022	11:43:00 AM	566	0.2	70.9	21.8	0	Plants
Battle Creek Elementary	1306	11/17/2022	11:42:00 AM	527	0.2	70.3	23.1	0	Plants
Battle Creek Elementary	1309	11/17/2022	12:02:00 PM	610		71.6	22	0	
Battle Creek Elementary	1310	11/17/2022	11:39:00 AM	760	0.2	72	23.1	9	
Battle Creek Elementary	1311	11/17/2022	11:58:00 AM	614	0.2	70.9	21.7	3	
Battle Creek Elementary	1312	11/17/2022	11:37:00 AM	905	0.2	71.2	23.5	6	Fragrance odor
Battle Creek Elementary	1313	11/17/2022	12:00:00 PM	668	0.2	71.6	22.4	1	Plants
Battle Creek Elementary	1314	11/17/2022	11:35:00 AM	609	0.2	70.5	24.3	9	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Elementary	1315	11/17/2022	12:05:00 PM	684	0.2	71.1	21.6	9	Fragrance odor
Battle Creek Elementary	1316	11/17/2022	11:31:00 AM	609	0.2	71.6	21.4	7	
Battle Creek Elementary	1317	11/17/2022	12:06:00 PM	769	0.2	71.8	22.7	22	
Battle Creek Elementary	1321	11/17/2022	12:07:00 PM	710	0.2	71.8	22.2	15	
Battle Creek Elementary	1322	11/17/2022	12:21:00 PM	548	0.2	72.5	19.9	0	
Battle Creek Elementary	1323	11/17/2022	12:09:00 PM	750	0.2	72	22.5	13	
Battle Creek Elementary	1324	11/17/2022	12:20:00 PM	637	0.2	70.5	22.8	18	
Battle Creek Elementary	1325	11/17/2022	12:12:00 PM	696	0.2	70.2	23.6	15	
Battle Creek Elementary	1326	11/17/2022	12:17:00 PM	700	0.2	71.8	23.8	16	
Battle Creek Elementary	1329	11/17/2022	12:13:00 PM	914	0.2	70.2	23.3	17	
Battle Creek Elementary	1330	11/17/2022	11:29:00 AM	749	0.2	70.5	24.7	15	
Battle Creek Elementary	1331	11/17/2022	11:16:00 AM	712	0.2	69.6	25.3	20	Plants, Taxidermy
Battle Creek Elementary	1332	11/17/2022	11:26:00 AM	600	0.2	70	22.9	5	
Battle Creek Elementary	1334	11/17/2022	12:16:00 PM	852	0.2	71.4	24.1	22	
Battle Creek Elementary	1335	11/17/2022	11:25:00 AM	1025	0.2	70.9	26.6	18	
Battle Creek Elementary	1336	11/17/2022	11:23:00 AM	951	0.2	71.6	26.3	20	
Battle Creek Elementary	1337	11/17/2022	11:21:00 AM	1152	0.2	71.2	26.8	18	
Battle Creek Elementary	OUTDOORS	11/17/2022		485	1.5	26	45.3		
Battle Creek Middle School	103	2/16/2023	10:33:00 AM	752	0.1	70.3	11.8	1	
Battle Creek Middle School	106	2/16/2023	10:43:00 AM	781	0.1	69.8	12.8	1	
Battle Creek Middle School	198	2/16/2023	11:24:00 AM	772	0.1	71.8	10.9	1	
Battle Creek Middle School	1005	2/16/2023	11:42:00 AM	766	0.1	70.3	11	0	
Battle Creek Middle School	1008	2/16/2023	11:38:00 AM	794	0.1	70.6	11.2	2	Plants
Battle Creek Middle School	1010	2/16/2023	11:34:00 AM	798	0.1	70.3	11.2	0	
Battle Creek Middle School	1011	2/16/2023	11:32:00 AM	801	0.1	70.1	11.8	1	
Battle Creek Middle School	1013	2/16/2023	11:14:00 AM	758	0.1	69	11.3	0	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1014	2/16/2023	11:12:00 AM	50	0.1	8.7	11.9	0	
Battle Creek Middle School	1015	2/16/2023	11:17:00 AM	764	0.1	71.2	11.7	0	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1017	2/16/2023	11:20:00 AM	154	0.1	70.9	15.6	2	
Battle Creek Middle School	1018	2/16/2023	11:22:00 AM	830	0.1	71.8	12.1	2	
Battle Creek Middle School	1103	2/16/2023	10:58:00 AM	849	0.1	71.1	12.4	1	
Battle Creek Middle School	1104	2/16/2023	10:37:00 AM	810	0.1	69.5	12.5	28	
Battle Creek Middle School	1105	2/16/2023	10:44:00 AM	678	0.1	67.2	12.6	0	
Battle Creek Middle School	1106	2/16/2023	10:23:00 AM	726	0.1	69.8	11.5	2	
Battle Creek Middle School	1107	2/16/2023	10:25:00 AM	718	0.1	70	12	1	
Battle Creek Middle School	1108	2/16/2023	10:31:00 AM	736	0.1	70.2	11.8	2	
Battle Creek Middle School	1109	2/16/2023	10:29:00 AM	688	0.1	69.7	12.5	0	
Battle Creek Middle School	1112	2/16/2023	10:35:00 AM	737	0.1	70	12.3	0	
Battle Creek Middle School	1113	2/16/2023	10:21:00 AM	1142	0.1	70	15.5	14	Stained ceiling tiles
Battle Creek Middle School	1114	2/16/2023	10:18:00 AM	1153	0.1	69.8	17.3	23	Stained ceiling tiles
Battle Creek Middle School	1201	2/16/2023	10:56:00 AM	915	0.1	71.4	13.5	25	Taxidermy
Battle Creek Middle School	1202	2/16/2023	10:53:00 AM	997	0.1	71.2	13.1	24	
Battle Creek Middle School	1203	2/16/2023	10:49:00 AM	658	0.1	70.5	10.2	0	Fragrance odor, Taxidermy
Battle Creek Middle School	1204	2/16/2023	10:14:00 AM	1029	0.1	69.6	13	19	
Battle Creek Middle School	1205	2/16/2023	10:11:00 AM	584	0.1	70.5	9.4	0	
Battle Creek Middle School	1206	2/16/2023	10:08:00 AM	813	0.1	71.9	11.8	24	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1208	2/16/2023	10:05:00 AM	727	0.1	71.1	11.7	27	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1501	2/16/2023	9:15:00 AM	787	0.3	75.8	9.5	17	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Middle School	1504	2/16/2023	9:23:00 AM	708	0.1	71.9	10.3	0	
Battle Creek Middle School	1505	2/16/2023	9:21:00 AM	683	0.1	72.1	9.5	1	
Battle Creek Middle School	1506	2/16/2023	9:18:00 AM	782	0.1	73.4	10.7	1	
Battle Creek Middle School	1507	2/16/2023	9:10:00 AM	706	0.1	70.2	11.1	0	
Battle Creek Middle School	1508	2/16/2023	9:12:00 AM	755	0.1	80.6	9.6	0	Stained ceiling tiles
Battle Creek Middle School	1509	2/16/2023	8:59:00 AM	642	0.1	67.6	12.2	1	
Battle Creek Middle School	1510	2/16/2023	9:07:00 AM	671	0.1	69.8	10.8	1	
Battle Creek Middle School	1601	2/16/2023	11:01:00 AM	897	0.1	70	12.1	12	Plants
Battle Creek Middle School	1602	2/16/2023	11:04:00 AM	808	0.1	68.8	11.4	1	
Battle Creek Middle School	1603	2/16/2023	11:06:00 AM	907	0.1	68	12.9	21	
Battle Creek Middle School	1604	2/16/2023	11:08:00 AM	1089	0.1	68.4	15.2	22	
Battle Creek Middle School	1605	2/16/2023	11:10:00 AM	1111	0.1	68.3	14.7	14	
Battle Creek Middle School	1606	2/16/2023	9:29:00 AM	731	0.1	72	10	9	
Battle Creek Middle School	1607	2/16/2023	9:26:00 AM	835	0.1	71.9	12.6	21	
Battle Creek Middle School	1608	2/16/2023	9:33:00 AM	783	0.1	72.3	12.2	14	Taxidermy
Battle Creek Middle School	1609	2/16/2023	9:35:00 AM	649	0.1	72.4	10.1	0	
Battle Creek Middle School	1610	2/16/2023	9:38:00 AM	864	0.1	73.1	12.6	24	
Battle Creek Middle School	1916	2/16/2023	11:18:00 AM	1175	0.1	70.8	15.4	2	
Battle Creek Middle School	2201	2/16/2023	12:13:00 PM	819	0.1	69.1	12.3	8	Fragrance odor, Stained ceiling tiles
Battle Creek Middle School	2204	2/16/2023	12:24:00 PM	722	0.1	69.4	11.1	6	
Battle Creek Middle School	2205	2/16/2023	12:25:00 PM	691	0.1	69.5	10.8	1	
Battle Creek Middle School	2206	2/16/2023	12:26:00 PM	662	0.1	69.1	10.2	0	Stained ceiling tiles
Battle Creek Middle School	2208	2/16/2023	12:37:00 PM	832	0.1	69.1	12.5	14	
Battle Creek Middle School	2304	2/16/2023	9:43:00 AM	592	0.1	71.7	8.8	18	
Battle Creek Middle School	2502	2/16/2023	12:54:00 PM	619	0.1	70.2	7.9	4	Stained ceiling tiles
Battle Creek Middle School	2503	2/16/2023	12:52:00 PM	779	0.1	70.6	9.2	26	
Battle Creek Middle School	2504	2/16/2023	12:47:00 PM	703	0.1	69.7	8.3	19	
Battle Creek Middle School	2601	2/16/2023	12:40:00 PM	907	0.1	71.4	12.8	21	
Battle Creek Middle School	2602	2/16/2023	12:44:00 PM	864	0.1	72.4	11.6	1	Bubbling/peeling paint
Battle Creek Middle School	2603	2/16/2023	12:49:00 PM	858	0.1	70.5	12.4	8	
Battle Creek Middle School	2604	2/16/2023	12:56:00 PM	775	0.1	70.6	11.3	1	
Battle Creek Middle School	2605	2/16/2023	12:58:00 PM	741	0.1	70.6	10.7	1	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	2606	2/16/2023	1:01:00 PM	797	0.1	70.5	11.4	1	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	2607	2/16/2023	11:56:00 AM	849	0.1	69.4	12.4	2	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	2608	2/16/2023	11:58:00 AM	1122	0.1	70.1	14.8	17	
Battle Creek Middle School	2609	2/16/2023	12:04:00 PM	966	0.1	69.5	13.7	14	
Battle Creek Middle School	2610	2/16/2023	12:11:00 PM	1023	0.1	69.3	14.5	21	
Battle Creek Middle School	2611	2/16/2023	12:06:00 PM	877	0.1	69	13.4	2	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	2612	2/16/2023	12:08:00 PM	1028	0.1	69.7	16.2	2	
Battle Creek Middle School	2614	2/16/2023	12:00:00 PM	904	0.1	70.1	13.1	2	
Battle Creek Middle School	2615	2/16/2023	12:02:00 PM	910	0.1	70.1	13.3	0	
Battle Creek Middle School	2617	2/16/2023	11:45:00 AM	915	0.1	69.9	13.1	1	
Battle Creek Middle School	2618	2/16/2023	11:55:00 AM	979	0.1	70	14.1	1	
Battle Creek Middle School	2619	2/16/2023	11:53:00 AM	944	0.1	69.8	13.4	0	
Battle Creek Middle School	1001 MAIN OFFICE	2/16/2023	11:44:00 AM	846	0.1	70.3	11.9	5	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1003 NURSES OFFICE	2/16/2023	11:27:00 AM	886	0.1	70.9	12.5	1	
Battle Creek Middle School	1007 PRINCIPALS	2/16/2023	11:40:00 AM	885	0.1	70	12.4	2	Plants: Kept Away From Return And Supply Vents
Battle Creek Middle School	1104A	2/16/2023	10:40:00 AM	835	0.1	69.8	13.4	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Middle School	1104C	2/16/2023	10:46:00 AM	701	0.1	70.7	11.7	0	
Battle Creek Middle School	1304/1305	2/16/2023	9:58:00 AM	688	0.1	70.8	70.2	1	
Battle Creek Middle School	1307 BOYS LOCKER ROOM OFFI	2/16/2023	9:55:00 AM	513	0.1	70.1	9.1	1	
Battle Creek Middle School	1312 GIRLS LOCKER ROOM OFFI	2/16/2023	9:49:00 AM	505	0.1	70.2	9.2	0	Stained ceiling tiles
Battle Creek Middle School	2104 CAFETERIA	2/16/2023	12:28:00 PM	960	0.1	67.9	16.6	1	
Battle Creek Middle School	2105 KITCHEN	2/16/2023	12:35:00 PM	884	0.1	68.1	14.3	4	
Battle Creek Middle School	2202/2203 TEAVHERS LOUNGE	2/16/2023	12:18:00 PM	865	0.1	68.9	13.2	1	
Battle Creek Middle School	282 NURSE	2/16/2023	11:25:00 AM	844	0.1	71	11.8	1	
Battle Creek Middle School	AUDITORIUM	2/16/2023	9:41:00 AM	554	0.1	71.8	9.5	8	
Battle Creek Middle School	COT ROOM 1020	2/16/2023	11:28:00 AM	744	0.1	69.6	11	0	
Battle Creek Middle School	COT ROOM 1021	2/16/2023	11:31:00 AM	848	0.1	69.5	13	1	
Battle Creek Middle School	CUSTODIAL OFFICE	2/16/2023	8:33:00 AM	783	0.1	62.8	12.4	1	
Battle Creek Middle School	KITCHEN	2/16/2023	12:32:00 PM	704	0.1	67.6	12.9	4	
Battle Creek Middle School	KITCHEN OFFICE	2/16/2023	12:34:00 PM	796	0.1	67.9	14.8	1	
Battle Creek Middle School	OUTDOORS	2/16/2023		462	0.4	13.2	6.6		
Battle Creek Middle School	ROOM 1109	2/16/2023	11:36:00 AM	773	0.1	70.3	11.4	0	
Bridge View School	1111	11/29/2022	10:17:00 AM	908	0.4	70.9	29.1	0	
Bridge View School	1112	11/29/2022	10:23:00 AM	1007	0.4	70	24.6	0	
Bridge View School	1113	11/29/2022	10:21:00 AM	1077	0.3	70.3	26.1	0	
Bridge View School	1303	11/29/2022	10:48:00 AM	1068	0.3	71.4	24.1	5	
Bridge View School	1306	11/29/2022	11:01:00 AM	1825	0.3	70.3	24.2	1	
Bridge View School	1311	11/29/2022	10:59:00 AM	1499	0.2	69.8	23.8	5	
Bridge View School	1315	11/29/2022	10:57:00 AM	714	0.3	69.3	23.9	3	Plants
Bridge View School	1316	11/29/2022	10:55:00 AM	421	0.3	70	23	0	
Bridge View School	1318	11/29/2022	10:51:00 AM	657	0.3	70.9	23.1	2	Plants
Bridge View School	1320	11/29/2022	10:43:00 AM	983	0.3	69.8	24.1	7	Plants
Bridge View School	1321	11/29/2022	10:40:00 AM	753	0.3	70.7	23.5	4	
Bridge View School	1401	11/29/2022	11:32:00 AM	454	0.3	68.9	25.3	3	
Bridge View School	1402	11/29/2022	11:35:00 AM	630	0.2	68.7	25.3	0	
Bridge View School	1403	11/29/2022	11:39:00 AM	409	0.3	68.4	24.9	2	
Bridge View School	1404	11/29/2022	11:41:00 AM	717	0.2	68.9	25.1	4	
Bridge View School	1405	11/29/2022	11:45:00 AM	475	0.2	70.3	23.8	2	
Bridge View School	1406	11/29/2022	11:43:00 AM	518	0.2	69.3	23.9	0	
Bridge View School	1407	11/29/2022	11:38:00 AM	643	0.2	69.4	24.2	0	
Bridge View School	1408	11/29/2022	11:37:00 AM	473	0.2	69.3	24.4	2	Fragrance odor
Bridge View School	1602	11/29/2022	11:09:00 AM	847	0.3	69.4	25.8	10	
Bridge View School	1603	11/29/2022	11:11:00 AM	1777	0.2	69.1	26.6	12	
Bridge View School	1604	11/29/2022	11:25:00 AM	656	0.2	68	25.3	0	
Bridge View School	1605	11/29/2022	11:20:00 AM	959	0.2	66.9	25.8	0	
Bridge View School	1606	11/29/2022	11:18:00 AM	919	0.2	67.3	25.8	0	
Bridge View School	1607	11/29/2022	11:15:00 AM	1232	0.2	68	25.9	7	
Bridge View School	1608	11/29/2022	11:14:00 AM	1343	0.3	68.7	24.7	2	
Bridge View School	1609	11/29/2022	11:08:00 AM	949	0.2	69.6	24.8	9	
Bridge View School	1610	11/29/2022	11:04:00 AM	1912	0.3	69.6	24.8	8	
Bridge View School	1001 OFFICE	11/29/2022	11:48:00 AM	385	0.2	70.9	23.9	1	
Bridge View School	1003 PRINCIPLE	11/29/2022	11:58:00 AM	397	0.3	73	22.9	0	
Bridge View School	1004 OFFICE	11/29/2022	11:55:00 AM	570	0.3	72.5	23.4	0	
Bridge View School	1005 OFFICE	11/29/2022	11:54:00 AM	970	0.3	71.6	23	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Bridge View School	1007 COPY ROOM	11/29/2022	11:51:00 AM	777	0.2	72	24.8	0	
Bridge View School	1008 CONFERENCE	11/29/2022	12:01:00 PM	834	0.3	72.7	23.1	0	
Bridge View School	1009 HEALTH OFFICE	11/29/2022	12:04:00 PM	522	0.3	73	23.4	1	
Bridge View School	1009A NURSE STORAGE	11/29/2022	12:06:00 PM	541	0.3	73.8	24.1	1	
Bridge View School	1105 EXERCISE ROOM	11/29/2022	10:10:00 AM	345	0.2	68.9	26.9	0	Bubbling/peeling paint
Bridge View School	1106 OFFICE	11/29/2022	10:15:00 AM	610	0.2	70.2	26	3	
Bridge View School	1201 AND 1202 GYMNASIUM	11/29/2022	10:27:00 AM	736	0.3	70	24.4	0	
Bridge View School	1301 STAFF	11/29/2022	10:29:00 AM	617	0.3	71.2	24.1	2	
Bridge View School	1301A STAFF KITCHEN	11/29/2022	10:39:00 AM	930	0.2	71.4	24	0	
Bridge View School	1302 LIBRARY	11/29/2022	10:45:00 AM	522	0.2	71.2	23.4	0	Stuffy odor
Bridge View School	1317 LOUNGE	11/29/2022	10:54:00 AM	822	0.3	71.2	25.1	8	
Bridge View School	1500 CAFETERIA	11/29/2022	11:29:00 AM	1014	0.2	69.3	24.6	3	
Bridge View School	1501 KITCHEN	11/29/2022	11:31:00 AM	644	0.2	70	27.3	2	
Bridge View School	OUTDOORS	11/29/2022		250	0.5	28.5	29		
Bruce F. Vento Elementary School	1102	1/17/2023	11:22:00 AM	478	0.2	71.8	26.5	14	
Bruce F. Vento Elementary School	1103	1/17/2023	10:28:00 AM	529	0.2	72.3	26.7	2	
Bruce F. Vento Elementary School	1104	1/17/2023	11:16:00 AM	568	0.2	71.8	28	17	
Bruce F. Vento Elementary School	1104	1/17/2023	10:29:00 AM	562	0.2	72.3	27.1	17	
Bruce F. Vento Elementary School	1106	1/17/2023	11:26:00 AM	483	0.2	71.4	27.5	16	
Bruce F. Vento Elementary School	1107	1/17/2023	11:02:00 AM	526	0.2	71.1	27.9	2	
Bruce F. Vento Elementary School	1108	1/17/2023	10:31:00 AM	580	0.2	72	27.3	15	
Bruce F. Vento Elementary School	1110	1/17/2023	10:32:00 AM	577	0.2	71.4	28.2	16	
Bruce F. Vento Elementary School	1111	1/17/2023	10:35:00 AM	599	0.2	71.6	27.6	7	
Bruce F. Vento Elementary School	1112	1/17/2023	10:36:00 AM	633	0.2	71.6	28.3	13	
Bruce F. Vento Elementary School	1113	1/17/2023	10:37:00 AM	593	0.2	71.8	27.8	16	
Bruce F. Vento Elementary School	1114	1/17/2023	10:38:00 AM	562	0.2	71.6	27.3	8	
Bruce F. Vento Elementary School	1115	1/17/2023	10:39:00 AM	619	0.2	71.4	28.1	15	
Bruce F. Vento Elementary School	1204	1/17/2023	9:49:00 AM	552	0.2	71.1	28.3	23	
Bruce F. Vento Elementary School	1206	1/17/2023	9:45:00 AM	502	0.2	71.4	27.1	25	
Bruce F. Vento Elementary School	1207	1/17/2023	9:41:00 AM	490	0.2	71.6	26.8	0	
Bruce F. Vento Elementary School	1210	1/17/2023	9:40:00 AM	626	0.2	71.6	28.2	20	
Bruce F. Vento Elementary School	1211	1/17/2023	9:39:00 AM	605	0.2	71.2	28.4	3	
Bruce F. Vento Elementary School	1212	1/17/2023	10:43:00 AM	534	0.2	70.9	27.7	17	
Bruce F. Vento Elementary School	1213	1/17/2023	9:38:00 AM	667	0.2	70.7	29.1	19	
Bruce F. Vento Elementary School	1214	1/17/2023	9:37:00 AM	618	0.2	70.3	28.8	0	
Bruce F. Vento Elementary School	1215	1/17/2023	9:35:00 AM	608	0.2	69.8	29	6	
Bruce F. Vento Elementary School	1304	1/17/2023	9:15:00 AM	456	0.2	70.9	26.8	5	
Bruce F. Vento Elementary School	1309	1/17/2023	9:23:00 AM	633	0.2	69.3	29	0	
Bruce F. Vento Elementary School	1402	1/17/2023	9:12:00 AM	741	0.2	73.8	30	4	
Bruce F. Vento Elementary School	1403	1/17/2023	9:11:00 AM	1138	0.3	74.5	30.1	25	
Bruce F. Vento Elementary School	1404	1/17/2023	9:10:00 AM	866	0.4	75	27.7	24	
Bruce F. Vento Elementary School	1406	1/17/2023	9:09:00 AM	790	0.3	76.8	26	14	
Bruce F. Vento Elementary School	1417	1/17/2023	9:00:00 AM	797	0.2	72.1	29.1	22	Fragrance odor
Bruce F. Vento Elementary School	1418	1/17/2023	8:58:00 AM	823	0.2	71.8	29.3	16	Stuffy odor
Bruce F. Vento Elementary School	1419	1/17/2023	8:57:00 AM	851	0.2	71.2	29.5	21	Stuffy odor
Bruce F. Vento Elementary School	1420	1/17/2023	8:56:00 AM	945	0.2	70.7	31.4	24	
Bruce F. Vento Elementary School	1502	1/17/2023	10:25:00 AM	857	0.2	73.9	28.6	16	
Bruce F. Vento Elementary School	1503	1/17/2023	10:23:00 AM	856	0.2	72.5	29	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Bruce F. Vento Elementary School	1504	1/17/2023	11:30:00 AM	659	0.2	72.1	28.8	17	
Bruce F. Vento Elementary School	1505	1/17/2023	10:21:00 AM	819	0.2	71.4	29.1	14	
Bruce F. Vento Elementary School	1506	1/17/2023	11:58:00 AM	903	0.2	72.1	29	18	
Bruce F. Vento Elementary School	1507	1/17/2023	10:18:00 AM	793	0.2	71.6	29.4	15	
Bruce F. Vento Elementary School	1510	1/17/2023	10:16:00 AM	1109	0.2	71.6	31.1	17	
Bruce F. Vento Elementary School	1512	1/17/2023	10:13:00 AM	929	0.2	71.1	30.6	2	
Bruce F. Vento Elementary School	1514	1/17/2023	10:08:00 AM	898	0.2	71.1	31.6	19	
Bruce F. Vento Elementary School	1515	1/17/2023	10:05:00 AM	957	0.2	71.2	30	18	
Bruce F. Vento Elementary School	1516	1/17/2023	10:17:00 AM	851	0.2	71.4	29.7	14	
Bruce F. Vento Elementary School	1517	1/17/2023	10:03:00 AM	1044	0.2	70.9	31.2	18	
Bruce F. Vento Elementary School	1606	1/17/2023	9:57:00 AM	514	0.2	71.2	26.7	1	
Bruce F. Vento Elementary School	1607	1/17/2023	9:56:00 AM	489	0.2	70.9	27	0	
Bruce F. Vento Elementary School	1000 RECEPTION WAITING	1/17/2023	10:47:00 AM	543	0.2	70.9	27.6	0	
Bruce F. Vento Elementary School	1001 MAIN OFFICE	1/17/2023	10:53:00 AM	522	0.2	72.5	27.1	3	
Bruce F. Vento Elementary School	1002 NURSE OFFICE	1/17/2023	10:48:00 AM	522	0.2	71.4	28	2	
Bruce F. Vento Elementary School	1003 COT ROOM	1/17/2023	10:49:00 AM	528	0.2	72.1	27.4	0	
Bruce F. Vento Elementary School	1005 CONFERENCE	1/17/2023	10:55:00 AM	635	0.2	72.1	28.3	0	
Bruce F. Vento Elementary School	1006 OFFICE	1/17/2023	10:56:00 AM	565	0.2	71.6	27.7	0	
Bruce F. Vento Elementary School	1007 OFFICE	1/17/2023	10:58:00 AM	513	0.2	71.8	27.1	0	
Bruce F. Vento Elementary School	1008 WORKROOM	1/17/2023	10:57:00 AM	565	0.2	71.6	28.1	1	
Bruce F. Vento Elementary School	1009 OFFICE	1/17/2023	10:59:00 AM	541	0.2	72.3	27.7	0	Fragrance odor
Bruce F. Vento Elementary School	1010 PRINCIPAL	1/17/2023	11:00:00 AM	617	0.2	72.3	27.8	1	
Bruce F. Vento Elementary School	1203 OFFICE	1/17/2023	9:48:00 AM	501	0.2	71.1	27.4	0	
Bruce F. Vento Elementary School	1208 OFFICE	1/17/2023	9:47:00 AM	498	0.2	71.2	27.2	0	
Bruce F. Vento Elementary School	1300B	1/17/2023	9:20:00 AM	440	0.2	70.5	26.8	0	
Bruce F. Vento Elementary School	1301 OFFICE	1/17/2023	9:29:00 AM	497	0.2	69.3	28.2	2	
Bruce F. Vento Elementary School	1302 OFFICE	1/17/2023	9:27:00 AM	457	0.2	69.4	27.9	0	Plants
Bruce F. Vento Elementary School	1306 WORKROOM	1/17/2023	9:31:00 AM	497	0.2	69.3	29	1	
Bruce F. Vento Elementary School	1309A	1/17/2023	9:25:00 AM	587	0.2	68.7	29.4	0	
Bruce F. Vento Elementary School	1310 OFFICE	1/17/2023	9:32:00 AM	571	0.2	68.5	29.2	0	
Bruce F. Vento Elementary School	1311 CAFETERIA	1/17/2023	8:54:00 AM	611	0.2	70.3	28.6	2	
Bruce F. Vento Elementary School	1312 KITCHEN	1/17/2023	8:40:00 AM	669	0.2	70.7	29.4	3	
Bruce F. Vento Elementary School	1317 CUSTODIAN OFFICE	1/17/2023	8:28:00 AM	606	0.2	70.2	29.8	1	
Bruce F. Vento Elementary School	1321 OFFICE	1/17/2023	8:52:00 AM	672	0.2	70.7	29.1	1	
Bruce F. Vento Elementary School	1407 OFFICE	1/17/2023	9:06:00 AM	578	0.2	76.1	24.5	0	
Bruce F. Vento Elementary School	1408 LOINGE	1/17/2023	9:14:00 AM	570	0.2	74.7	25.5	0	
Bruce F. Vento Elementary School	1409 OFFICE	1/17/2023	9:04:00 AM	596	0.2	73.8	26.4	0	
Bruce F. Vento Elementary School	1411 OFFICE	1/17/2023	9:01:00 AM	699	0.5	71.8	27.5	1	
Bruce F. Vento Elementary School	1415 OFFICE	1/17/2023	9:02:00 AM	684	0.2	71.6	27.4	0	
Bruce F. Vento Elementary School	1511 OFFICE	1/17/2023	10:14:00 AM	879	0.2	71.4	28.6	2	
Bruce F. Vento Elementary School	1513 OFFICE	1/17/2023	10:11:00 AM	880	0.2	71.2	29.6	0	
Bruce F. Vento Elementary School	1601 GYMNASIUM	1/17/2023	10:01:00 AM	439	0.2	70.9	27.2	11	
Bruce F. Vento Elementary School	1604 CONFERENCE	1/17/2023	9:58:00 AM	564	0.2	71.6	27.5	5	Stained ceiling tiles
Bruce F. Vento Elementary School	1605 OFFICE	1/17/2023	9:59:00 AM	553	0.2	72	27.3	0	
Bruce F. Vento Elementary School	1608 OFFICE	1/17/2023	9:54:00 AM	526	0.2	71.8	26.8	0	
Bruce F. Vento Elementary School	1610 MEDIA CENTER	1/17/2023	9:50:00 AM	532	0.2	71.2	27.3	25	
Bruce F. Vento Elementary School	OUTDOORS	1/17/2023		410	0.2	34	33		
Central Senior High School	101	12/16/2022	11:16:00 AM	451	0.1	69.6	22.9	32	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	202	12/16/2022	11:20:00 AM	415	0.1	70	22.1	27	Bubbling/peeling paint
Central Senior High School	203	12/16/2022	11:23:00 AM	388	0.1	70.3	21.7	0	
Central Senior High School	218	12/16/2022	1:52:00 PM	882	0.1	73.8	21.7	38	
Central Senior High School	401	12/16/2022	11:27:00 AM	397	0.1	71.2	23.1	1	
Central Senior High School	401	12/16/2022	2:18:00 PM	584		71.8	19.4	8	
Central Senior High School	404	12/16/2022	11:30:00 AM	396	0.1	70.9	22.7	0	Bubbling/peeling paint
Central Senior High School	404	12/16/2022	2:13:00 PM	547		72.1	18.8	0	
Central Senior High School	1101	12/16/2022	9:13:00 AM	389	0.1	70.9	21.9	3	
Central Senior High School	1102	12/16/2022	9:15:00 AM	354	0.1	71.2	21.7	0	
Central Senior High School	1103	12/16/2022	9:16:00 AM	406	0.1	71.2	21.6	5	Stained ceiling tiles
Central Senior High School	1104	12/16/2022	9:19:00 AM	416	0.1	71.8	21.4	5	
Central Senior High School	1106	12/16/2022	9:21:00 AM	411	0.1	71.8	22.3	5	
Central Senior High School	1108	12/16/2022	9:23:00 AM	464	0.1	71.8	26.2	5	Fragrance odor
Central Senior High School	1109	12/16/2022	11:10:00 AM	352	0.1	72	24.5	1	
Central Senior High School	1111	12/16/2022	9:25:00 AM	325	0.1	72.5	25.8	0	
Central Senior High School	1112	12/16/2022	9:27:00 AM	329	0.1	72.9	24.2	0	
Central Senior High School	1114	12/16/2022	9:27:00 AM	365	0.2	70.9	25.3	7	
Central Senior High School	1117	12/16/2022	9:35:00 AM	405	0.3	69.6	24.8	8	
Central Senior High School	1119	12/16/2022	9:55:00 AM	385	0.1	72.3	25	13	
Central Senior High School	1121	12/16/2022	9:54:00 AM	329	0.2	71.9	24.4	1	
Central Senior High School	1201	12/16/2022	9:11:00 AM	388	0.1	70.5	22.1	2	
Central Senior High School	1202	12/16/2022	9:09:00 AM	450	0.2	71.4	22.2	14	Plants: Kept Away From Return And Supply Vents
Central Senior High School	1203	12/16/2022	9:06:00 AM	395	0.1	70	23.1	19	
Central Senior High School	1208	12/16/2022	10:21:00 AM	382	0.1	72	21.1	0	
Central Senior High School	1209	12/16/2022	10:19:00 AM	405	0.1	71.4	22.3	1	Stained ceiling tiles
Central Senior High School	1210	12/16/2022	10:20:00 AM	465	0.1	71.8	22.4	1	Stained ceiling tiles
Central Senior High School	1214	12/16/2022	9:49:00 AM	466	0.1	72.1	26.4	15	
Central Senior High School	1217	12/16/2022	11:12:00 AM	369	0.2	71.8	20.7	1	
Central Senior High School	1218	12/16/2022	11:14:00 AM	460	0.3	69.4	23.1	7	
Central Senior High School	1303	12/16/2022	8:27:00 AM	504	0.2	70.5	23.2	18	Stained ceiling tiles, Plants
Central Senior High School	1304	12/16/2022	8:31:00 AM	491	0.2	69.8	24.2	23	
Central Senior High School	1304	12/16/2022	8:29:00 AM	309	0.2	72.7	21.9	1	
Central Senior High School	1305	12/16/2022	8:32:00 AM	335	0.3	72	22.6	14	Stained ceiling tiles, Plants
Central Senior High School	1309	12/16/2022	8:36:00 AM	380	0.2	71.2	24.6	6	
Central Senior High School	1310	12/16/2022	11:40:00 AM	341	0.2	73	19.4	0	
Central Senior High School	1311	12/16/2022	8:50:00 AM	283	0.1	73	20	0	Bubbling/peeling paint
Central Senior High School	1312	12/16/2022	8:47:00 AM	484	0.1	72.3	24.5	2	
Central Senior High School	1313	12/16/2022	8:56:00 AM	284	0.2	73.4	20.9	0	
Central Senior High School	1314	12/16/2022	8:58:00 AM	362	0.2	71.2	22.4	13	Bubbling/peeling paint
Central Senior High School	1316	12/16/2022	8:34:00 AM	436	0.3	71.1	24.8	19	Stained ceiling tiles
Central Senior High School	1317	12/16/2022	9:02:00 AM	467	0.1	70.9	23.3	15	
Central Senior High School	1318	12/16/2022	8:24:00 AM	330	0.3	71.1	23.2	7	
Central Senior High School	1405	12/16/2022	8:18:00 AM	315	1.3	72.3	23	2	
Central Senior High School	1406	12/16/2022	8:17:00 AM	295	1.2	72.3	23	2	Stained ceiling tiles
Central Senior High School	1407	12/16/2022	10:18:00 AM	430	0.1	71.2	21	2	
Central Senior High School	1409	12/16/2022	10:13:00 AM	395	0.1	71.8	21	0	
Central Senior High School	1410	12/16/2022	10:14:00 AM	383	0.1	71.2	21.3	2	Stained ceiling tiles
Central Senior High School	1414	12/16/2022	10:10:00 AM	449	0.1	72.5	21.4	23	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	1415	12/16/2022	10:44:00 AM	346	0.1	71.2	20.5	0	Stained ceiling tiles
Central Senior High School	1415	12/16/2022	2:03:00 PM	447		70	18	1	Stained ceiling tiles
Central Senior High School	1501	12/16/2022	10:47:00 AM	348	0.1	70.5	21.1	35	
Central Senior High School	1503	12/16/2022	10:49:00 AM	414	0.1	70.5	22.4	1	
Central Senior High School	1505	12/16/2022	9:44:00 AM	332	0.2	68.5	23.4	1	
Central Senior High School	1506	12/16/2022	9:38:00 AM	339	0.1	70.6	23.4	0	
Central Senior High School	2001	12/16/2022	1:02:00 PM	650	0.1	73.8	19.3	5	
Central Senior High School	2002	12/16/2022	1:00:00 PM	690	0.1	73.4	19.4	1	Fragrance odor
Central Senior High School	2003	12/16/2022	1:07:00 PM	619	0.1	73.4	19.5	0	
Central Senior High School	2005	12/16/2022	1:12:00 PM	682	0.1	73.2	19.7	2	
Central Senior High School	2006	12/16/2022	1:13:00 PM	691	0.1	73	20.4	1	
Central Senior High School	2007	12/16/2022	1:14:00 PM	694	0.1	73	20.3	2	
Central Senior High School	2008	12/16/2022	1:21:00 PM	602	0.1	72.9	19.3	0	Plants
Central Senior High School	2009	12/16/2022	1:24:00 PM	625		72.5	20.3	0	
Central Senior High School	2012	12/16/2022	1:19:00 PM	723	0.1	72.9	20.1	1	
Central Senior High School	2013	12/16/2022	1:06:00 PM	610	0.1	74.1	18.5	0	
Central Senior High School	2014	12/16/2022	1:05:00 PM	725	0.1	73.9	19.7	2	
Central Senior High School	2015	12/16/2022	1:51:00 PM	658	0.1	74.7	18.5	0	
Central Senior High School	2016	12/16/2022	1:49:00 PM	667	0.1	74.5	19.8	0	
Central Senior High School	2017	12/16/2022	1:41:00 PM	751	0.1	73.9	19.6	1	
Central Senior High School	2018	12/16/2022	1:45:00 PM	634	0.1	73.9	18.4	0	
Central Senior High School	2019	12/16/2022	1:39:00 PM	723	0.1	73.6	19.5	1	
Central Senior High School	2020	12/16/2022	1:37:00 PM	725	0.1	74.7	19	1	
Central Senior High School	2021	12/16/2022	1:35:00 PM	714		73	20.3	1	
Central Senior High School	2022	12/16/2022	1:32:00 PM	673		72.3	20.6	1	Plants
Central Senior High School	2023	12/16/2022	1:31:00 PM	634		72.5	19.6	0	
Central Senior High School	2026	12/16/2022	1:39:00 PM	662	0.1	74.1	19	1	
Central Senior High School	2027	12/16/2022	1:46:00 PM	652	0.1	73.8	19.2	0	
Central Senior High School	2104	12/16/2022	12:36:00 PM	596		72.1	19.4	1	
Central Senior High School	2105	12/16/2022	12:38:00 PM	704		72.9	20.2	1	
Central Senior High School	2106	12/16/2022	12:46:00 PM	586	0.2	75.7	16.7	1	
Central Senior High School	2107	12/16/2022	12:39:00 PM	579	0.1	74.1	18.1	1	
Central Senior High School	2109	12/16/2022	12:43:00 PM	564	0.1	75.2	17.6	0	
Central Senior High School	2111	12/16/2022	12:47:00 PM	569	0.2	75.9	17	0	
Central Senior High School	2112	12/16/2022	12:49:00 PM	563	0.2	76.1	16.4	0	
Central Senior High School	2113	12/16/2022	12:51:00 PM	577	0.2	75.7	16.7	0	
Central Senior High School	2114	12/16/2022	12:54:00 PM	566	0.2	74.8	16.9	0	
Central Senior High School	2115	12/16/2022	12:56:00 PM	556	0.1	73.8	18.2	0	
Central Senior High School	2116	12/16/2022	12:57:00 PM	570	0.1	73.6	17.8	0	
Central Senior High School	2200	12/16/2022	12:25:00 PM	801		69.6	23.11	120	
Central Senior High School	2201	12/16/2022	10:05:00 AM	308	0.2	73.2	19.5	5	
Central Senior High School	2201	12/16/2022	12:32:00 PM	383		69.6	16.4	1	
Central Senior High School	2204	12/16/2022	12:06:00 PM	860	0.1	72.9	23.4	3	
Central Senior High School	2304	12/16/2022	12:11:00 PM	630	0.1	73	18.5	19	Stained ceiling tiles
Central Senior High School	2305	12/16/2022	12:16:00 PM	471		71.1	18.3	0	
Central Senior High School	2306	12/16/2022	12:21:00 PM	502	0.1	70.2	18.7	1	
Central Senior High School	2307	12/16/2022	12:24:00 PM	699		70.3	21.1	38	
Central Senior High School	2311	12/16/2022	12:14:00 PM	610		71.4	19.2	24	Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	2312	12/16/2022	12:13:00 PM	657	0.1	72	20.4	28	
Central Senior High School	2403	12/16/2022	12:03:00 PM	635		72.3	19.4	20	
Central Senior High School	2404	12/16/2022	12:00:00 PM	558		73	17.1	3	Plants
Central Senior High School	2405	12/16/2022	11:58:00 AM	639		72.7	18.1	13	
Central Senior High School	2406	12/16/2022	11:57:00 AM	729		72.1	19.4	33	Stained ceiling tiles
Central Senior High School	2407	12/16/2022	11:55:00 AM	468		72.9	15.7	1	
Central Senior High School	2408	12/16/2022	11:46:00 AM	633		74.3	16.9	23	
Central Senior High School	2410	12/16/2022	12:01:00 PM	499		72.9	17.1	1	
Central Senior High School	2501	12/16/2022	1:54:00 PM	689	0.2	72.1	19.2	39	Fragrance odor
Central Senior High School	2503	12/16/2022	1:57:00 PM	600		71.2	20.8	1	
Central Senior High School	2504	12/16/2022	1:58:00 PM	640		72.5	19.2	2	
Central Senior High School	2505	12/16/2022	2:00:00 PM	620		72.1	19.4	4	
Central Senior High School	2507	12/16/2022	2:02:00 PM	458		71.2	18.2	0	
Central Senior High School	3101	12/16/2022	10:59:00 AM	952	0.1	70	22.8	25	
Central Senior High School	3102	12/16/2022	10:55:00 AM	651	0.1	70.9	21	18	
Central Senior High School	3103	12/16/2022	10:54:00 AM	714	0.1	70.5	21.4	15	
Central Senior High School	3104	12/16/2022	10:53:00 AM	715	0.1	10.5	21	14	Plants
Central Senior High School	3105	12/16/2022	10:51:00 AM	540	0.1	70.7	19.5	2	Plants
Central Senior High School	3106	12/16/2022	10:49:00 AM	680	0.1	71.2	21	18	
Central Senior High School	3107	12/16/2022	10:48:00 AM	674		70.9	20.6	2	Fragrance odor
Central Senior High School	3108	12/16/2022	10:45:00 AM	890		70.5	22.8	21	
Central Senior High School	3110	12/16/2022	10:41:00 AM	547	0.1	70.2	19.9	1	Fragrance odor
Central Senior High School	3114	12/16/2022	10:39:00 AM	696		69.8	21.2	1	
Central Senior High School	3115	12/16/2022	10:36:00 AM	569		69.4	20.5	0	
Central Senior High School	3118	12/16/2022	10:38:00 AM	656		69.4	23	6	
Central Senior High School	3121	12/16/2022	10:57:00 AM	702	0.1	70	20.6	1	
Central Senior High School	3205	12/16/2022	11:03:00 AM	538		72.3	17.3	1	Plants
Central Senior High School	3206	12/16/2022	11:05:00 AM	547	0.2	75.7	15.5	0	
Central Senior High School	3401	12/16/2022	11:07:00 AM	809	0.2	75.7	18.2	34	
Central Senior High School	3402	12/16/2022	11:18:00 AM	633	0.2	73.8	19.1	19	
Central Senior High School	3403	12/16/2022	11:21:00 AM	656	0.1	73.2	19.2	26	
Central Senior High School	3404	12/16/2022	11:28:00 AM	641		72.7	20	18	
Central Senior High School	3405	12/16/2022	11:29:00 AM	679		72.7	20.2	19	Plants
Central Senior High School	3406	12/16/2022	11:31:00 AM	600		72.3	17.7	20	
Central Senior High School	3407	12/16/2022	11:32:00 AM	454		70.2	16.7	1	
Central Senior High School	3408	12/16/2022	11:35:00 AM	631		69.3	19.6	14	
Central Senior High School	3409	12/16/2022	11:37:00 AM	466	0.1	68.9	18.4	0	Plants
Central Senior High School	3410	12/16/2022	11:42:00 AM	499	0.1	68.9	18.5	0	
Central Senior High School	3414	12/16/2022	11:43:00 AM	556	0.1	70.2	19.1	0	
Central Senior High School	3415	12/16/2022	11:14:00 AM	527	0.2	74.7	16	0	
Central Senior High School	3419	12/16/2022	11:12:00 AM	586	0.2	74.8	17.3	0	
Central Senior High School	3420	12/16/2022	11:11:00 AM	572	0.3	75	17.6	6	
Central Senior High School	3420	12/16/2022	11:16:00 AM	529	0.2	75	16.5	0	
Central Senior High School	4101	12/16/2022	9:53:00 AM	673	0.4	72	20.4	13	
Central Senior High School	4102	12/16/2022	9:55:00 AM	718	0.3	70.9	22.4	2	Plants
Central Senior High School	4103	12/16/2022	9:57:00 AM	704	0.3	70.9	22.3	15	Plants
Central Senior High School	4104	12/16/2022	9:59:00 AM	739	0.3	70.5	23.6	13	
Central Senior High School	4105	12/16/2022	10:00:00 AM	656	0.3	70.7	22.9	1	Food odor, Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	4106	12/16/2022	10:06:00 AM	831	0.3	71.8	21.2	23	
Central Senior High School	4107	12/16/2022	10:07:00 AM	872	0.3	71.2	23.5	17	
Central Senior High School	4108	12/16/2022	10:08:00 AM	833	0.3	71.6	24.1	25	
Central Senior High School	4109	12/16/2022	10:29:00 AM	553	0.2	71.4	19.2	0	
Central Senior High School	4110	12/16/2022	10:10:00 AM	731	0.3	72.9	22.2	14	
Central Senior High School	4112	12/16/2022	10:13:00 AM	851	0.3	72.1	22.3	8	Fragrance odor
Central Senior High School	4114	12/16/2022	10:04:00 AM	893	0.3	72.1	23.1	19	Food odor
Central Senior High School	4116	12/16/2022	10:02:00 AM	817	0.2	71.2	24.6	0	
Central Senior High School	4117	12/16/2022	9:52:00 AM	707	0.5	72.9	21.2	19	
Central Senior High School	4201	12/16/2022	8:49:00 AM	460	0.3	68.2	21.4	7	
Central Senior High School	4202	12/16/2022	9:03:00 AM	490	0.3	68.5	21.7	1	Stuffy odor
Central Senior High School	4205	12/16/2022	9:04:00 AM	895	0.3	67.8	28.5	23	
Central Senior High School	4206	12/16/2022	9:08:00 AM	444	0.3	68.7	22.6	0	
Central Senior High School	4207	12/16/2022	8:54:00 AM	480	0.2	67.6	22.8	0	Stuffy odor
Central Senior High School	4208	12/16/2022	8:59:00 AM	471	0.3	67.5	22.3	0	
Central Senior High School	4209	12/16/2022	8:53:00 AM	452	0.2	67.5	22.3	0	
Central Senior High School	4210	12/16/2022	9:00:00 AM	499	0.3	68.5	23.1	0	Stuffy odor
Central Senior High School	4213	12/16/2022	9:43:00 AM	539	0.4	72.1	18.8	3	
Central Senior High School	4214	12/16/2022	9:47:00 AM	512	0.4	74.7	17	0	
Central Senior High School	4215	12/16/2022	10:23:00 AM	584	0.3	75.4	16.2	0	
Central Senior High School	4216	12/16/2022	10:21:00 AM	622	0.3	74.5	17.8	1	
Central Senior High School	4217	12/16/2022	10:25:00 AM	603	0.3	75.4	16.8	0	
Central Senior High School	4218	12/16/2022	9:44:00 AM	578	0.4	73.6	18.8	1	
Central Senior High School	4219	12/16/2022	10:19:00 AM	615	0.2	72.9	19.4	1	Plants
Central Senior High School	4222	12/16/2022	9:09:00 AM	492	0.3	71.6	19.7	0	
Central Senior High School	4401	12/16/2022	9:21:00 AM	744	0.4	73	20.5	20	
Central Senior High School	4402	12/16/2022	9:22:00 AM	705	0.5	73	20.1	29	Fragrance odor
Central Senior High School	4403	12/16/2022	9:24:00 AM	686	0.5	72.7	20.5	24	
Central Senior High School	4404	12/16/2022	9:25:00 AM	702	0.5	72.3	21.9	28	
Central Senior High School	4405	12/16/2022	9:26:00 AM	635	0.5	72.1	23.5	26	Stuffy odor
Central Senior High School	4406	12/16/2022	9:32:00 AM	637	0.5	73.4	18.8	22	
Central Senior High School	4407	12/16/2022	9:33:00 AM	487	0.5	72.1	19.4	2	
Central Senior High School	4408	12/16/2022	9:36:00 AM	641	0.4	70.9	20.4	19	
Central Senior High School	4409	12/16/2022	9:37:00 AM	748	0.4	70.7	21.9	13	Fragrance odor
Central Senior High School	4410	12/16/2022	9:38:00 AM	618	0.4	71.1	20.3	33	
Central Senior High School	4412	12/16/2022	9:40:00 AM	492	0.4	71.8	18.3	0	
Central Senior High School	4414	12/16/2022	9:29:00 AM	543	0.5	74.1	19.1	1	
Central Senior High School	4417	12/16/2022	9:28:00 AM	541	0.5	72.3	19.7	1	
Central Senior High School	1102A	12/16/2022	10:27:00 AM	357	0.1	71.1	21	0	
Central Senior High School	1103A	12/16/2022	9:18:00 AM	452	0.1	71.2	23.1	2	
Central Senior High School	1119A	12/16/2022	9:56:00 AM	320	0.1	71.1	24.8	0	Stained ceiling tiles
Central Senior High School	1119B	12/16/2022	9:57:00 AM	335	0.1	71.6	24.8	0	
Central Senior High School	1119C	12/16/2022	9:58:00 AM	391	0.1	72.1	24.8	5	Stained ceiling tiles
Central Senior High School	1119D	12/16/2022	9:50:00 AM	376	0.2	72.3	25.8	3	
Central Senior High School	1505A	12/16/2022	9:47:00 AM	324	0.1	67.1	25	0	
Central Senior High School	2001A	12/16/2022	1:03:00 PM	633	0.1	73.9	19	1	
Central Senior High School	2010A	12/16/2022	1:27:00 PM	641		72.7	20	3	
Central Senior High School	2010B	12/16/2022	1:29:00 PM	650		72.5	20.1	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	2201A	12/16/2022	12:33:00 PM	406		68.7	17.2	18	
Central Senior High School	2204A	12/16/2022	12:08:00 PM	942	0.2	74.1	21.9	1	
Central Senior High School	OUTDOORS	12/16/2022		323	0.3	53.8	31.4		
Central Senior High School	POOL	12/16/2022	11:45:00 AM	355	0.1	77.5	25.3	0	
Central Senior High School	POOL OFFICE	12/16/2022	11:46:00 AM	374	0.1	79	22	0	
Central Service Station	CLASSROOM	1/13/2023	1:51:00 PM	1249	0.2	61.7	40.3	8	
Central Service Station	GARAGE	1/13/2023	1:49:00 PM	630	0.2	59.5	53.1	0	
Central Service Station	OUTDOORS	1/13/2023		280	0.8	22	34.6		
Chelsea Heights Elementary School	205	2/3/2023	9:46:00 AM	682	0.1	70	10.7	0	
Chelsea Heights Elementary School	206	2/3/2023	10:03:00 AM	863	0.4	69.6	10.7	15	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	1001	2/3/2023	10:44:00 AM	691	0.3	68.7	9	1	
Chelsea Heights Elementary School	1002	2/3/2023	10:47:00 AM	717	0.3	68.4	9.1	0	
Chelsea Heights Elementary School	1003	2/3/2023	10:46:00 AM	682	0.3	68.5	8.7	1	
Chelsea Heights Elementary School	1101	2/3/2023	11:01:00 AM	763	0.3	68.7	9.4	0	
Chelsea Heights Elementary School	1102	2/3/2023	11:02:00 AM	1246	0.2	68.4	13.5	25	Plants
Chelsea Heights Elementary School	1103	2/3/2023	11:07:00 AM	1007	0.3	68	10.7	0	
Chelsea Heights Elementary School	1106	2/3/2023	11:10:00 AM	796	0.1	67.5	9.8	0	
Chelsea Heights Elementary School	1108	2/3/2023	11:08:00 AM	980	0.2	67.6	11.2	1	
Chelsea Heights Elementary School	1117	2/3/2023	11:14:00 AM	563	0.2	66.4	6.1	0	Stained ceiling tiles
Chelsea Heights Elementary School	1118	2/3/2023	11:19:00 AM	674	0.1	65.8	7.8	0	
Chelsea Heights Elementary School	1119	2/3/2023	11:15:00 AM	690	0.1	65.5	7.8	0	
Chelsea Heights Elementary School	1201	2/3/2023	10:41:00 AM	876	0.3	68.5	11.2	15	
Chelsea Heights Elementary School	1202	2/3/2023	10:43:00 AM	1016	0.3	69.1	11.9	20	
Chelsea Heights Elementary School	1203	2/3/2023	10:49:00 AM	785	0.2	68.9	11.7	0	
Chelsea Heights Elementary School	1204	2/3/2023	10:47:00 AM	760	0.3	68.7	11.2	1	
Chelsea Heights Elementary School	1207	2/3/2023	10:50:00 AM	661	0.3	67.8	8.3	2	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	1208	2/3/2023	10:54:00 AM	708	0.2	68.4	9.5	0	
Chelsea Heights Elementary School	1209	2/3/2023	11:00:00 AM	798	0.3	69.1	9.1	4	
Chelsea Heights Elementary School	1210	2/3/2023	10:56:00 AM	674	0.2	68.5	9	0	
Chelsea Heights Elementary School	1211	2/3/2023	10:57:00 AM	757	0.2	68.7	10.1	1	
Chelsea Heights Elementary School	1212	2/3/2023	10:56:00 AM	675	0.2	68.5	8.9	0	
Chelsea Heights Elementary School	1214	2/3/2023	10:59:00 AM	684	0.2	68.9	9	0	
Chelsea Heights Elementary School	1301	2/3/2023	11:20:00 AM	786	0.2	67.8	10	1	
Chelsea Heights Elementary School	1302	2/3/2023	11:24:00 AM	761	0.2	68	10.2	1	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	1303	2/3/2023	11:26:00 AM	824	0.3	67.8	10.7	20	
Chelsea Heights Elementary School	1304	2/3/2023	11:28:00 AM	773	0.3	67.1	10.1	20	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	1305	2/3/2023	11:31:00 AM	702	0.2	66.7	9.4	25	
Chelsea Heights Elementary School	1306	2/3/2023	11:32:00 AM	735	0.1	68.4	9.5	20	
Chelsea Heights Elementary School	2100	2/3/2023	10:05:00 AM	865	0.4	69.4	10.3	1	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2101	2/3/2023	10:17:00 AM	793	0.4	68.2	9.4	0	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2102	2/3/2023	10:16:00 AM	1079	0.4	69.3	12.1	20	
Chelsea Heights Elementary School	2103	2/3/2023	10:14:00 AM	1132	0.4	69.1	12.9	25	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2104	2/3/2023	10:11:00 AM	786	0.4	69.3	8.9	0	
Chelsea Heights Elementary School	2106	2/3/2023	10:09:00 AM	839	0.4	70	10.1	0	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2109	2/3/2023	10:23:00 AM	796	0.3	68.9	9.3	0	
Chelsea Heights Elementary School	2110	2/3/2023	10:22:00 AM	1015	0.3	68.7	11.8	25	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2111	2/3/2023	10:20:00 AM	881	0.3	68.9	10.1	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Chelsea Heights Elementary School	2112	2/3/2023	10:24:00 AM	957	0.3	68.9	11.1	10	
Chelsea Heights Elementary School	2117	2/3/2023	10:28:00 AM	798	0.2	73	8	0	Stained ceiling tiles
Chelsea Heights Elementary School	2118	2/3/2023	10:18:00 AM	1149	0.3	69.1	14.2	2	Stained ceiling tiles
Chelsea Heights Elementary School	2201	2/3/2023	10:31:00 AM	606	0.4	70.9	6.8	0	
Chelsea Heights Elementary School	2202	2/3/2023	10:33:00 AM	612	0.3	69.8	8	0	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2203	2/3/2023	10:35:00 AM	807	0.3	69.4	9.8	25	
Chelsea Heights Elementary School	2204	2/3/2023	10:39:00 AM	652	0.3	69.6	7.9	0	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2205	2/3/2023	10:40:00 AM	598	0.3	69.3	7.1	1	
Chelsea Heights Elementary School	2206	2/3/2023	10:37:00 AM	602	0.3	69.9	7.1	0	Plants: Kept Away From Return And Supply Vents
Chelsea Heights Elementary School	2208	2/3/2023	10:30:00 AM	703	0.4	72.3	7.4	30	
Chelsea Heights Elementary School	1102A	2/3/2023	11:05:00 AM	1180	0.2	68.7	12.5	0	
Chelsea Heights Elementary School	1207B	2/3/2023	10:52:00 AM	641	0.3	67.3	8.3	1	
Chelsea Heights Elementary School	1207D	2/3/2023	10:53:00 AM	653	0.2	67.6	8.7	0	
Chelsea Heights Elementary School	1305 COMMONS	2/3/2023	11:30:00 AM	693	0.3	66.4	10.1	2	Stained ceiling tiles
Chelsea Heights Elementary School	CAFETERIA	2/3/2023	11:35:00 AM	873	0.3	67.5	12.6	40	
Chelsea Heights Elementary School	KITCHEN	2/3/2023	11:38:00 AM	808	0.3	67.1	14.3	4	
Chelsea Heights Elementary School	OUTDOORS	2/3/2023		300	0.5	-9	64.5		
Chelsea Heights Elementary School	STAGE	2/3/2023	11:37:00 AM	907	0.3	67.3	12.9	1	
Cherokee Heights Elementary School	1102	2/10/2023	11:42:00 AM	629	0.5	66.2	13.6	1	Stained ceiling tiles
Cherokee Heights Elementary School	1103	2/10/2023	8:26:00 AM	657	0.6	68.4	12.5	25	
Cherokee Heights Elementary School	1104	2/10/2023	8:29:00 AM	935	0.6	67.1	13.7	7	
Cherokee Heights Elementary School	1104	2/10/2023	11:32:00 AM	514	0.5	67.3	10	0	
Cherokee Heights Elementary School	1106	2/10/2023	8:36:00 AM	488	0.6	70	7.8	0	
Cherokee Heights Elementary School	1107	2/10/2023	8:39:00 AM	589	0.6	67.8	11.6	3	
Cherokee Heights Elementary School	1109	2/10/2023	8:43:00 AM	653	0.6	67.6	12.4	1	
Cherokee Heights Elementary School	1113	2/10/2023	9:01:00 AM	609	0.5	67.6	10.5	21	Stained ceiling tiles
Cherokee Heights Elementary School	1201	2/10/2023	8:08:00 AM	58	0.6	68.7	12.9	35	
Cherokee Heights Elementary School	1208	2/10/2023	8:55:00 AM	447	0.6	68.7	8.1	0	Bubbling/peeling paint
Cherokee Heights Elementary School	1213	2/10/2023	8:53:00 AM	510	0.8	78.8	13.1	1	
Cherokee Heights Elementary School	2002	2/10/2023	10:12:00 AM	524	0.6	70	8.8	0	
Cherokee Heights Elementary School	2003	2/10/2023	10:10:00 AM	571	0.6	71.6	7.6	0	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	2004	2/10/2023	10:03:00 AM	537	0.6	71.4	10.1	0	
Cherokee Heights Elementary School	2008	2/10/2023	10:00:00 AM	553	0.5	72.3	10.7	0	
Cherokee Heights Elementary School	2102	2/10/2023	10:17:00 AM	535	0.6	7.5	8.6	0	Stained ceiling tiles
Cherokee Heights Elementary School	2103	2/10/2023	10:25:00 AM	868	0.5	70.9	12.6	18	
Cherokee Heights Elementary School	2104	2/10/2023	10:28:00 AM	881	0.6	72.5	12.1	13	
Cherokee Heights Elementary School	2202	2/10/2023	10:15:00 AM	582	0.5	70	9	3	
Cherokee Heights Elementary School	2203	2/10/2023	9:54:00 AM	486	0.5	68.5	7.6	0	
Cherokee Heights Elementary School	2206	2/10/2023	9:57:00 AM	506	0.5	67.5	8.1	1	Bubbling/peeling paint
Cherokee Heights Elementary School	2207	2/10/2023	9:51:00 AM	579	0.4	68.4	10.6	2	
Cherokee Heights Elementary School	2208	2/10/2023	9:48:00 AM	515	0.4	66.4	8.5	0	
Cherokee Heights Elementary School	2209	2/10/2023	9:46:00 AM	481	0.6	67.3	6.3	0	
Cherokee Heights Elementary School	2210	2/10/2023	9:44:00 AM	458	0.5	69.6	5.6	1	
Cherokee Heights Elementary School	2211	2/10/2023	9:41:00 AM	588	0.5	70.2	11.6	5	
Cherokee Heights Elementary School	2213	2/10/2023	9:37:00 AM	682	0.5	69.3	10.8	1	
Cherokee Heights Elementary School	2214	2/10/2023	9:33:00 AM	655	0.5	67.6	11.3	0	
Cherokee Heights Elementary School	3109	2/10/2023	10:42:00 AM	971	0.6	71.4	12.7	0	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	3110	2/10/2023	10:40:00 AM	1331	0.6	71.6	15.6	17	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Cherokee Heights Elementary School	3111	2/10/2023	10:53:00 AM	727	0.6	71.1	10.6	2	Stained ceiling tiles
Cherokee Heights Elementary School	3114	2/10/2023	10:55:00 AM	820	0.6	69.8	12	0	
Cherokee Heights Elementary School	3201	2/10/2023	10:58:00 AM	511	0.5	69.4	8	5	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	3203	2/10/2023	11:02:00 AM	543	0.5	68.9	9	3	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	3204	2/10/2023	11:05:00 AM	678	0.5	67.8	12.1	0	
Cherokee Heights Elementary School	3205	2/10/2023	11:07:00 AM	659	0.5	68.7	13.7	0	
Cherokee Heights Elementary School	3206	2/10/2023	11:10:00 AM	803	0.5	69.6	12.7	2	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	4201	2/10/2023	11:29:00 AM	481	0.5	68.4	8.3	0	
Cherokee Heights Elementary School	4202	2/10/2023	11:21:00 AM	562	0.6	68.4	11.6	0	
Cherokee Heights Elementary School	4203	2/10/2023	11:24:00 AM	527	0.6	69.1	8.6	0	
Cherokee Heights Elementary School	4204	2/10/2023	11:28:00 AM	558	0.6	68.7	8.9	2	
Cherokee Heights Elementary School	2001 MAIN OFFICE LOBBY	2/10/2023	10:08:00 AM	515	0.6	71.8	7.7	2	Stained ceiling tiles
Cherokee Heights Elementary School	2007 COPY ROOM	2/10/2023	10:05:00 AM	545	0.6	72	10.9	0	Stained ceiling tiles
Cherokee Heights Elementary School	2105/2106	2/10/2023	10:30:00 AM	837	0.6	70.5	12	1	
Cherokee Heights Elementary School	2107/2108	2/10/2023	10:33:00 AM	711	0.5	72.7	9.9	2	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	2109/2110	2/10/2023	10:36:00 AM	477	0.6	73	8.5	1	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	2211A	2/10/2023	9:43:00 AM	622	0.5	70.5	11.5	0	
Cherokee Heights Elementary School	3103/3104	2/10/2023	10:51:00 AM	976	0.6	71.2	11.6	16	
Cherokee Heights Elementary School	3106 /3105	2/10/2023	10:47:00 AM	1242	0.7	71.4	13.8	26	
Cherokee Heights Elementary School	3107/3108	2/10/2023	10:44:00 AM	795	0.6	69.3	12	2	
Cherokee Heights Elementary School	C OPEN OFFICES	2/10/2023	9:23:00 AM	475	0.5	70.3	11.2	9	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	C100 LOBBY	2/10/2023	9:16:00 AM	462	0.5	69.6	11.1	1	Stained ceiling tiles
Cherokee Heights Elementary School	C102	2/10/2023	9:10:00 AM	448	0.5	69.3	11.4	0	Stained ceiling tiles
Cherokee Heights Elementary School	C108	2/10/2023	9:08:00 AM	501	0.5	69.1	11.6	0	
Cherokee Heights Elementary School	C109	2/10/2023	9:05:00 AM	475	0.5	68.5	11.5	2	
Cherokee Heights Elementary School	C201	2/10/2023	9:26:00 AM	465	0.5	70.9	10.5	0	
Cherokee Heights Elementary School	C202A BREAK ROOM	2/10/2023	9:18:00 AM	452	0.5	69.6	11.5	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary School	C202B	2/10/2023	9:21:00 AM	488	0.5	70.2	11.4	0	
Cherokee Heights Elementary School	C204	2/10/2023	9:30:00 AM	518	0.5	70.7	11.5	8	Plants
Cherokee Heights Elementary School	OUTDOORS	2/10/2023		567	0.7	20.1	15.6		
Cherokee Heights Elementary School	POOL	2/10/2023	8:47:00 AM	472	0.7	79	15.5	2	Bubbling/peeling paint, Moisture damage at Exterior Door 15
Como Park Elementary School	1001	11/14/2022	10:20:00 AM	568	0.1	69.3	25.7	2	
Como Park Elementary School	1002	11/14/2022	10:21:00 AM	562	0.1	69.3	25.6	0	Bubbling/peeling paint
Como Park Elementary School	1003	11/14/2022	10:24:00 AM	523	0.1	69.6	25.3	0	Plants
Como Park Elementary School	1004	11/14/2022	8:55:00 AM	581	0.4	70	27	1	Bubbling/peeling paint
Como Park Elementary School	1005	11/14/2022	10:31:00 AM	489	0.2	70	23.9	0	Musty odor
Como Park Elementary School	1006	11/14/2022	8:57:00 AM	500	0.4	69.4	25	1	
Como Park Elementary School	1105	11/14/2022	10:18:00 AM	959	0.2	68.9	27.8	43	
Como Park Elementary School	1107	11/14/2022	9:24:00 AM	634	0.2	68	26.8	17	
Como Park Elementary School	1112	11/14/2022	9:29:00 AM	589	0.2	69.6	25.2	15	
Como Park Elementary School	1114	11/14/2022	9:31:00 AM	631	0.2	68.9	26.1	16	
Como Park Elementary School	1117	11/14/2022	9:34:00 AM	732	0.2	69.4	26.4	13	
Como Park Elementary School	1118	11/14/2022	9:38:00 AM	565	0.2	69.3	24.9	0	Plants: Kept Away From Return And Supply Vents
Como Park Elementary School	1119	11/14/2022	9:43:00 AM	606	0.2	69.3	26.5	2	
Como Park Elementary School	1120	11/14/2022	9:48:00 AM	627	0.2	68.7	26.2	9	
Como Park Elementary School	1121	11/14/2022	9:52:00 AM	535	0.2	68.5	24.9	0	
Como Park Elementary School	1122	11/14/2022	9:54:00 AM	513	0.1	70.9	23.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Elementary School	1123	11/14/2022	10:02:00 AM	575	0.1	70.5	26.2	0	
Como Park Elementary School	1124	11/14/2022	10:05:00 AM	668	0.1	70.5	25.9	0	Moisture damage at Hallway Wall ceiling
Como Park Elementary School	1126	11/14/2022	10:39:00 AM	518	0.1	69.4	25.2	0	Bubbling/peeling paint
Como Park Elementary School	1128	11/14/2022	10:15:00 AM	742	0.2	70.3	26.7	9	
Como Park Elementary School	1130	11/14/2022	10:11:00 AM	557	0.1	70	26.7	0	
Como Park Elementary School	1132	11/14/2022	9:11:00 AM	554	0.3	70.2	26.5	0	
Como Park Elementary School	1132	11/14/2022	10:08:00 AM	621	0.1	70	25.6	1	Musty odor
Como Park Elementary School	1133	11/14/2022	9:02:00 AM	575	0.4	69.8	26.4	1	
Como Park Elementary School	1134	11/14/2022	9:12:00 AM	578	0.3	69.6	25.4	0	Bubbling/peeling paint
Como Park Elementary School	1135	11/14/2022	9:09:00 AM	610	0.3	70.3	25.8	2	
Como Park Elementary School	1136	11/14/2022	9:07:00 AM	605	0.4	69.6	25.9	1	
Como Park Elementary School	1137	11/14/2022	10:36:00 AM	601	0.1	69.4	26.3	0	Stuffy odor
Como Park Elementary School	1138	11/14/2022	10:38:00 AM	566	0.2	69.4	25.9	0	
Como Park Elementary School	1141	11/14/2022	10:47:00 AM	568	0.1	69.3	26.8	0	
Como Park Elementary School	1201	11/14/2022	10:00:00 AM	543	0.2	70.2	24.4	10	
Como Park Elementary School	1202	11/14/2022	10:49:00 AM	528	0.1	68.5	25.2	0	
Como Park Elementary School	1203	11/14/2022	10:59:00 AM	531	0.1	69.8	24.4	1	
Como Park Elementary School	1204	11/14/2022	11:03:00 AM	520	0.2	69.8	24.3	0	
Como Park Elementary School	1206	11/14/2022	11:06:00 AM	626	0.2	72.7	26	1	
Como Park Elementary School	1207	11/14/2022	11:34:00 AM	602	0.2	69.6	27.3	18	
Como Park Elementary School	1210	11/14/2022	11:12:00 AM	573	0.2	66.4	37	0	
Como Park Elementary School	1301	11/14/2022	8:49:00 AM	585	0.4	68	25.5	0	
Como Park Elementary School	1302	11/14/2022	11:29:00 AM	533	0.2	70.3	25.6	2	
Como Park Elementary School	1307	11/14/2022	11:21:00 AM	522	0.2	69.4	24.3	0	
Como Park Elementary School	1308	11/14/2022	11:19:00 AM	518	0.2	70	24	0	
Como Park Elementary School	1309	11/14/2022	11:16:00 AM	578	0.1	69.8	24.5	1	
Como Park Elementary School	1310	11/14/2022	11:09:00 AM	534	0.2	70.5	24.1	0	
Como Park Elementary School	1311	11/14/2022	11:11:00 AM	505	0.2	69.1	24.4	0	
Como Park Elementary School	1314	11/14/2022	10:56:00 AM	540	0.1	69.3	25.2	0	
Como Park Elementary School	1318	11/14/2022	10:33:00 AM	502	0.2	68.9	24.5	0	Dirty or dusty carpet odor
Como Park Elementary School	1319	11/14/2022	10:52:00 AM	576	0.1	69.6	24.6	1	Fragrance odor
Como Park Elementary School	1320	11/14/2022	10:55:00 AM	564	0.1	69.4	25.8	9	Formaldehyde odor
Como Park Elementary School	1321	11/14/2022	10:45:00 AM	625	0.2	69.4	25.1	10	Food odor
Como Park Elementary School	2001	11/14/2022	1:19:00 PM	494	0.1	68.4	25.5	0	Garbage odor, Stained ceiling tiles
Como Park Elementary School	2002	11/14/2022	1:25:00 PM	562	0.1	68.5	26.1	0	Chemical/burnt odor
Como Park Elementary School	2004	11/14/2022	1:22:00 PM	513	0.1	68.3	26.3	0	Paint odor
Como Park Elementary School	2101	11/14/2022	1:33:00 PM	630	0.3	68.2	26.6	20	Crayons odor
Como Park Elementary School	2102	11/14/2022	1:34:00 PM	548	0.2	68	27.1	1	Essential oils odor
Como Park Elementary School	2103	11/14/2022	1:37:00 PM	494	0.1	68.7	27.4	0	Diffuser odor
Como Park Elementary School	2104	11/14/2022	1:40:00 PM	577	0.1	67.3	28	2	Stale odor
Como Park Elementary School	2105	11/14/2022	1:44:00 PM	572	0.1	70.3	25.4	6	Stale odor
Como Park Elementary School	2106	11/14/2022	1:46:00 PM	510	0.3	68.2	26.6	0	Stale odor
Como Park Elementary School	2107	11/14/2022	12:05:00 PM	497	0.2	67.1	26.5	0	Stale odor
Como Park Elementary School	2108	11/14/2022	12:01:00 PM	568	0.2	68.2	26.8	1	Coffee odor
Como Park Elementary School	2201	11/14/2022	11:59:00 AM	618	0.2	68.9	26.2	18	Rubber odor
Como Park Elementary School	2202	11/14/2022	11:58:00 AM	524	0.2	69.6	24.7	0	Rubber/plastic odor
Como Park Elementary School	2203	11/14/2022	11:56:00 AM	517	0.2	69.1	25.2	0	Coffee odor
Como Park Elementary School	2204	11/14/2022	11:41:00 AM	543	0.2	70.3	25.2	0	Plastic odor, laminator in room

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Elementary School	2207	11/14/2022	11:37:00 AM	510	0.2	69.1	25.3	1	Sour, yogurt like odor
Como Park Elementary School	2209	11/14/2022	11:39:00 AM	733	0.1	70.7	26.2	16	Essential oils odor
Como Park Elementary School	2301	11/14/2022	1:31:00 PM	481	0.1	70	24.6	0	Natural gas odor
Como Park Elementary School	2302	11/14/2022	1:27:00 PM	486	0.1	68	26	0	Strong smelling essential oils odor
Como Park Elementary School	2303	11/14/2022	1:16:00 PM	514	0.1	68.7	25.5	0	Essential oils odor
Como Park Elementary School	2304	11/14/2022	1:13:00 PM	526	0.1	68	26.5	0	
Como Park Elementary School	2307	11/14/2022	1:08:00 PM	484	0.1	69.1	26.1	0	
Como Park Elementary School	2308	11/14/2022	12:59:00 PM	591	0.2	68.4	26	10	
Como Park Elementary School	2309	11/14/2022	1:06:00 PM	568	0.1	70.3	24.7	20	
Como Park Elementary School	2310	11/14/2022	1:07:00 PM	504	0.1	72	23.5	16	
Como Park Elementary School	2313	11/14/2022	12:03:00 PM	514	0.1	68.9	25.9	0	
Como Park Elementary School	2321	11/14/2022	1:10:00 PM	890	0.2	68.5	25.8	0	
Como Park Elementary School	2401	11/14/2022	12:14:00 PM	642	0.2	70	28.4	9	
Como Park Elementary School	2402	11/14/2022	12:10:00 PM	565	0.2	68.5	28.8	0	
Como Park Elementary School	2403	11/14/2022	12:09:00 PM	1003	0.2	69.6	31	17	
Como Park Elementary School	2404	11/14/2022	12:12:00 PM	768	0.2	69.6	30.6	18	
Como Park Elementary School	2504	11/14/2022	12:16:00 PM	681	0.2	70.9	26.8	17	
Como Park Elementary School	2505	11/14/2022	12:19:00 PM	631	0.3	70	26.3	0	
Como Park Elementary School	2506	11/14/2022	12:28:00 PM	782	0.3	71.6	27	17	
Como Park Elementary School	2509	11/14/2022	12:26:00 PM	588	0.3	72.1	24.6	0	
Como Park Elementary School	2510	11/14/2022	12:24:00 PM	624	0.3	72.7	24.8	0	Stuffy odor
Como Park Elementary School	2511	11/14/2022	12:21:00 PM	631	0.2	73.2	24.5	1	
Como Park Elementary School	2604	11/14/2022	12:53:00 PM	802	0.2	71.8	27.3	11	
Como Park Elementary School	2605	11/14/2022	12:49:00 PM	601	0.3	73.2	24.3	0	
Como Park Elementary School	2606	11/14/2022	12:43:00 PM	594	0.2	70.5	26.1	1	Moisture damage on ceiling tile hangers, Stained ceiling tiles
Como Park Elementary School	2607	11/14/2022	12:38:00 PM	740	0.2	69.4	28.1	16	
Como Park Elementary School	2608	11/14/2022	12:35:00 PM	636	0.2	69.8	27.1	1	
Como Park Elementary School	2609	11/14/2022	12:41:00 PM	576	0.1	70.3	26	0	
Como Park Elementary School	2610	11/14/2022	12:46:00 PM	590	0.2	72.5	24.8	0	
Como Park Elementary School	2611	11/14/2022	12:48:00 PM	593	0.3	72.3	24.7	0	
Como Park Elementary School	2614	11/14/2022	12:56:00 PM	587	0.2	72.7	24.3	0	
Como Park Elementary School	2704	11/14/2022	12:32:00 PM	556	0.2	70.3	25	0	Dirty or dusty carpet odor
Como Park Elementary School	1118A	11/14/2022	9:45:00 AM	572	0.2	68.7	25.7	0	Musty odor
Como Park Elementary School	1120A	11/14/2022	9:50:00 AM	546	0.1	69.6	25.3	0	Moisture damage at corner above door
Como Park Elementary School	1202A	11/14/2022	10:51:00 AM	585	0.1	68.9	25.4	1	
Como Park Elementary School	1204A	11/14/2022	11:01:00 AM	606	0.1	69.8	25	0	Bubbling/peeling paint
Como Park Elementary School	1308A	11/14/2022	11:25:00 AM	560	0.1	69.6	24.9	1	
Como Park Elementary School	2701 ENTRY	11/14/2022	12:31:00 PM	552	0.2	70.9	24.8	3	
Como Park Elementary School	CAFETERIA	11/14/2022	11:23:00 AM	675	0.2	69.3	28.3	60	
Como Park Elementary School	KITCHEN	11/14/2022	11:26:00 AM	627	0.2	71.1	28.3	2	
Como Park Elementary School	OUTDOORS	11/14/2022		384	0.5	26	87		
Como Park Elementary School	OUTDOORS	11/14/2022	3:52:00 PM	445	0.6	31	88		
Como Park Senior High School	1001	1/19/2023	8:56:00 AM	559	0.4	70.7	25.5	4	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1002	1/19/2023	9:03:00 AM	587	0.4	71.1	24.9	1	
Como Park Senior High School	1003	1/19/2023	9:10:00 AM	515	0.4	71.4	23.7	0	
Como Park Senior High School	1004	1/19/2023	9:08:00 AM	502	0.4	71.4	23.3	0	
Como Park Senior High School	1005	1/19/2023	12:19:00 PM	618	0.4	69.8	26.6	0	Moisture damage at upper edge of window
Como Park Senior High School	1006	1/19/2023	9:05:00 AM	556	0.4	71.2	24.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1007	1/19/2023	12:09:00 PM	509	0.5	71.2	24.6	0	Moisture damage at top window edge
Como Park Senior High School	1009	1/19/2023	9:11:00 AM	634	0.4	71.1	24.6	1	
Como Park Senior High School	1011	1/19/2023	9:12:00 AM	522	0.4	71.2	23.7	0	
Como Park Senior High School	1013	1/19/2023	9:14:00 AM	535	0.4	71.4	23.5	0	Moisture damage at top edge of window
Como Park Senior High School	1014	1/19/2023	9:33:00 AM	587	0.4	70.5	25.3	0	
Como Park Senior High School	1015	1/19/2023	9:16:00 AM	535	0.4	71.6	23.6	0	
Como Park Senior High School	1016	1/19/2023	9:33:00 AM	641	0.4	70.3	25.5	3	
Como Park Senior High School	1017	1/19/2023	9:24:00 AM	620	0.4	72.1	24.3	1	
Como Park Senior High School	1018	1/19/2023	9:30:00 AM	537	0.4	70.9	23.9	1	
Como Park Senior High School	1019	1/19/2023	9:19:00 AM	565	0.4	72.3	24.3	1	
Como Park Senior High School	1021	1/19/2023	9:21:00 AM	498	0.4	72.1	22.8	0	
Como Park Senior High School	1022	1/19/2023	9:26:00 AM	531	0.4	71.2	23.4	0	
Como Park Senior High School	1024	1/19/2023	9:27:00 AM	542	0.4	70.9	24.1	0	
Como Park Senior High School	1025	1/19/2023	9:18:00 AM	567	0.4	71.8	23.8	0	
Como Park Senior High School	1026	1/19/2023	9:28:00 AM	493	0.4	71.1	23.4	0	
Como Park Senior High School	1027	1/19/2023	9:17:00 AM	580	0.4	71.8	24.3	0	Fragrance odor
Como Park Senior High School	1036	1/19/2023	9:29:00 AM	519	0.4	71.1	23.2	0	
Como Park Senior High School	1038	1/19/2023	12:07:00 PM	585	0.5	70.5	25.5	1	
Como Park Senior High School	1104	1/19/2023	10:23:00 AM	446	0.4	67.6	33.4	0	Rusting around ice machine
Como Park Senior High School	1106	1/19/2023	10:22:00 AM	430	0.4	69.4	28.8	0	
Como Park Senior High School	1107	1/19/2023	10:44:00 AM	497	0.4	69.8	25.1	0	
Como Park Senior High School	1109	1/19/2023	10:39:00 AM	506	0.4	69.1	25.7	0	
Como Park Senior High School	1113	1/19/2023	10:36:00 AM	553	0.5	68.9	26.4	3	Live animals: Kept Away From Return And Supply Vents
Como Park Senior High School	1119	1/19/2023	10:29:00 AM	392	0.4	70.2	23.6	0	
Como Park Senior High School	1128	1/19/2023	10:15:00 AM	488	0.4	68.5	26.9	1	Moisture damage inside light
Como Park Senior High School	1203	1/19/2023	11:14:00 AM	881	0.4	71.1	29.4	1	
Como Park Senior High School	1204	1/19/2023	11:37:00 AM	858	0.5	69.6	27.9	0	
Como Park Senior High School	1205	1/19/2023	12:39:00 PM	948	0.5	70.5	29.4	15	
Como Park Senior High School	1206	1/19/2023	11:41:00 AM	1033	0.5	70.2	29.2	5	Fragrance odor, Stained ceiling tiles
Como Park Senior High School	1207	1/19/2023	11:19:00 AM	751	0.4	70.3	26.8	22	
Como Park Senior High School	1208	1/19/2023	11:38:00 AM	592	0.4	70	25.7	0	Stained ceiling tiles
Como Park Senior High School	1209	1/19/2023	12:40:00 PM	718	0.4	70.2	27.6	14	
Como Park Senior High School	1211	1/19/2023	12:41:00 PM	809	0.5	69.6	29.2	17	
Como Park Senior High School	1212	1/19/2023	11:47:00 AM	580	0.5	70.5	25.8	1	Stained ceiling tiles
Como Park Senior High School	1214	1/19/2023	11:48:00 AM	655	0.5	71.1	25.9	17	Stained ceiling tiles, Plants
Como Park Senior High School	1215	1/19/2023	11:10:00 AM	588	0.4	68.4	26.8	0	Bubbling/peeling paint
Como Park Senior High School	1216	1/19/2023	11:54:00 AM	742	0.4	71.6	24.5	13	
Como Park Senior High School	1217	1/19/2023	11:11:00 AM	635	0.4	68.5	27.4	0	Bubbling/peeling paint
Como Park Senior High School	1218	1/19/2023	10:50:00 AM	604	0.4	72.7	22.6	24	Water staining on ceiling and pipe, Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1218	1/19/2023	11:56:00 AM	712	0.4	71.8	25.6	11	Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1219	1/19/2023	11:13:00 AM	600	0.4	68.7	26.9	0	
Como Park Senior High School	1222	1/19/2023	12:02:00 PM	620	0.4	71.4	25.9	6	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents, Plants
Como Park Senior High School	1224	1/19/2023	10:45:00 AM	518	0.4	70.9	25.5	0	Stained ceiling tiles
Como Park Senior High School	1226	1/19/2023	11:00:00 AM	749	0.5	70.3	26.7	24	
Como Park Senior High School	1227	1/19/2023	11:18:00 AM	581	0.4	68.5	26.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1229	1/19/2023	11:20:00 AM	585	0.4	68.5	26.7	0	
Como Park Senior High School	1233	1/19/2023	11:16:00 AM	617	0.4	68.7	27.4	1	
Como Park Senior High School	1235	1/19/2023	11:07:00 AM	593	0.4	68.4	26.8	0	
Como Park Senior High School	1237	1/19/2023	11:06:00 AM	638	0.4	68.4	26.9	12	
Como Park Senior High School	1312	1/19/2023	11:09:00 AM	965	0.3	70	29.3	25	Fragrance odor
Como Park Senior High School	1401	1/19/2023	10:49:00 AM	710	0.3	69.4	27.7	18	
Como Park Senior High School	1405	1/19/2023	1:33:00 PM	776	0.4	70.3	30	0	
Como Park Senior High School	1409	1/19/2023	10:53:00 AM	822	0.4	70	29.8	22	
Como Park Senior High School	1411	1/19/2023	10:56:00 AM	584	0.4	68.9	26.1	2	Stained ceiling tiles
Como Park Senior High School	1415	1/19/2023	11:02:00 AM	594	0.3	69.4	25.9	2	
Como Park Senior High School	1601	1/19/2023	10:07:00 AM	770	0.4	71.6	24.5	5	
Como Park Senior High School	1603	1/19/2023	11:36:00 AM	851	0.4	70.9	27.4	17	
Como Park Senior High School	1605	1/19/2023	9:29:00 AM	742	0.4	71.6	25.2	11	
Como Park Senior High School	1606	1/19/2023	9:24:00 AM	570	0.5	70.9	24.3	1	
Como Park Senior High School	1607	1/19/2023	9:34:00 AM	779	0.4	71.6	26.9	18	Plants
Como Park Senior High School	1609	1/19/2023	9:36:00 AM	986	0.5	71.8	30	7	
Como Park Senior High School	1615	1/19/2023	9:40:00 AM	644	0.4	70.9	24.8	5	Plants
Como Park Senior High School	1616	1/19/2023	10:02:00 AM	865	0.4	71.2	26.7	10	
Como Park Senior High School	1618	1/19/2023	9:59:00 AM	1222	0.4	71.2	31.3	23	
Como Park Senior High School	1701	1/19/2023	9:43:00 AM	1406	0.4	70.2	36.1	28	
Como Park Senior High School	1703	1/19/2023	9:51:00 AM	814	0.4	70.7	28.2	21	
Como Park Senior High School	1706	1/19/2023	9:58:00 AM	720	0.4	71.1	25.8	0	
Como Park Senior High School	1708	1/19/2023	9:49:00 AM	1074	0.3	70.7	29.4	12	
Como Park Senior High School	1709	1/19/2023	9:45:00 AM	1042	0.4	70.2	30.7	19	
Como Park Senior High School	1711	1/19/2023	10:30:00 AM	793	0.4	70.3	26.7	0	Fragrance odor, Dirty or dusty carpet odor
Como Park Senior High School	1712	1/19/2023	11:20:00 AM	982	0.4	70.2	29.9	21	
Como Park Senior High School	1716	1/19/2023	9:55:00 AM	894	0.4	70.5	27.4	20	
Como Park Senior High School	1717	1/19/2023	10:37:00 AM	764	0.4	70.5	25.9	3	Plants
Como Park Senior High School	1718	1/19/2023	10:45:00 AM	1155	0.4	70.7	28.8	18	
Como Park Senior High School	1724	1/19/2023	10:42:00 AM	1052	0.4	70.7	29	25	Plants
Como Park Senior High School	1726	1/19/2023	10:40:00 AM	934	0.3	70.2	28.4	17	
Como Park Senior High School	2302	1/19/2023	1:21:00 PM	735	0.3	70.3	27.5	0	Fragrance odor
Como Park Senior High School	2601	1/19/2023	11:37:00 AM	1205	0.5	70.5	30.7	24	
Como Park Senior High School	2603	1/19/2023	11:42:00 AM	1012	0.5	70.2	28.5	10	
Como Park Senior High School	2605	1/19/2023	1:13:00 PM	886	0.4	71.2	27.5	13	
Como Park Senior High School	2606	1/19/2023	11:43:00 AM	999	0.4	71.2	28.2	18	
Como Park Senior High School	2611	1/19/2023	1:11:00 PM	904	0.4	71.8	27.5	24	
Como Park Senior High School	2613	1/19/2023	11:52:00 AM	992	0.4	71.2	29	20	
Como Park Senior High School	2613	1/19/2023	11:58:00 AM	801	0.4	70.9	27	3	
Como Park Senior High School	2617	1/19/2023	1:08:00 PM	776	0.4	72.1	26	12	Plants
Como Park Senior High School	2618	1/19/2023	11:57:00 AM	855	0.4	71.1	26.4	3	
Como Park Senior High School	2624	1/19/2023	1:09:00 PM	836	0.4	72	26.4	13	
Como Park Senior High School	2626	1/19/2023	11:59:00 AM	978	0.4	70.7	28.2	10	
Como Park Senior High School	2701	1/19/2023	12:01:00 PM	805	0.4	71.4	26.3	14	
Como Park Senior High School	2703	1/19/2023	12:03:00 PM	896	0.5	71.2	27.4	15	
Como Park Senior High School	2708	1/19/2023	12:04:00 PM	859	0.4	71.1	28.8	1	
Como Park Senior High School	2709	1/19/2023	12:12:00 PM	972	0.3	69.8	30.7	20	
Como Park Senior High School	2712	1/19/2023	1:05:00 PM	798	0.3	71.8	26.1	18	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	2713	1/19/2023	12:56:00 PM	862	0.4	71.6	27.2	15	
Como Park Senior High School	2714	1/19/2023	12:13:00 PM	814	0.4	70.9	27.3	15	
Como Park Senior High School	2715	1/19/2023	12:31:00 PM	785	0.4	70.2	27.1	2	
Como Park Senior High School	2726	1/19/2023	12:17:00 PM	667	0.3	70.7	25.5	2	
Como Park Senior High School	2728	1/19/2023	12:19:00 PM	1001	0.4	70.9	28.7	20	
Como Park Senior High School	2732	1/19/2023	12:20:00 PM	1266	0.4	71.4	31.5	21	Fragrance odor
Como Park Senior High School	2734	1/19/2023	12:23:00 PM	713	0.4	71.6	25.7	0	
Como Park Senior High School	2736	1/19/2023	12:26:00 PM	719	0.5	71.2	25.7	1	
Como Park Senior High School	2738	1/19/2023	12:27:00 PM	903	0.5	70.7	28.4	15	
Como Park Senior High School	2742	1/19/2023	12:28:00 PM	932	0.4	70.2	29	17	
Como Park Senior High School	1031 AUDITORIUM	1/19/2023	11:24:00 AM	466	0.4	70	24.5	0	
Como Park Senior High School	1033 STAGE	1/19/2023	11:25:00 AM	475	0.5	70.9	23.7	0	Bubbling/peeling paint, Efflorescence
Como Park Senior High School	1101 GYMNASIUM	1/19/2023	9:38:00 AM	568	0.4	70.9	26.1	33	Bubbling/peeling paint
Como Park Senior High School	1103A	1/19/2023	9:45:00 AM	451	0.4	70.7	24.6	0	Musty odor
Como Park Senior High School	1105A	1/19/2023	9:44:00 AM	444	0.4	71.2	24.2	0	
Como Park Senior High School	1109A	1/19/2023	10:41:00 AM	498	0.4	69.6	25.6	0	
Como Park Senior High School	1112B	1/19/2023	10:13:00 AM	442	0.4	72	25.2	0	Bubbling/peeling paint
Como Park Senior High School	1113A	1/19/2023	10:34:00 AM	524	0.5	70	25.6	1	Fragrance odor
Como Park Senior High School	1114B	1/19/2023	10:08:00 AM	451	0.2	80.2	28.5	0	
Como Park Senior High School	1136 WRESTLING	1/19/2023	9:55:00 AM	417	0.4	69.1	26.5	0	
Como Park Senior High School	1142 WRESTLING ROOM	1/19/2023	9:53:00 AM	409	0.4	70	25.2	0	
Como Park Senior High School	1146 FIELD HOUSE	1/19/2023	9:59:00 AM	527	0.3	69.8	25.5	24	Rubber/plastic odor
Como Park Senior High School	1214A	1/19/2023	11:52:00 AM	553	0.4	71.2	24.7	0	
Como Park Senior High School	1218 OFFICE	1/19/2023	10:57:00 AM	453	0.4	72.7	22.4	1	
Como Park Senior High School	1222A	1/19/2023	12:00:00 PM	625	0.5	71.4	27.5	2	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1222B	1/19/2023	12:04:00 PM	601	0.4	71.1	26.2	0	
Como Park Senior High School	1303 OFFICE	1/19/2023	9:21:00 AM	515	0.4	71.1	24.2	0	
Como Park Senior High School	1304 KITCHEN	1/19/2023	9:15:00 AM	860	0.6	70	27.2	3	
Como Park Senior High School	1304 OFFICE	1/19/2023	10:51:00 AM	661	0.3	70	25.8	3	
Como Park Senior High School	1305 CAFETERIA	1/19/2023	9:20:00 AM	531	0.5	70.3	25.2	3	
Como Park Senior High School	1307B OFFICE	1/19/2023	9:19:00 AM	714	0.4	70.2	25.5	1	
Como Park Senior High School	1311 CUSTODIAN OFFICE	1/19/2023	9:14:00 AM	595	0.5	70	27	1	
Como Park Senior High School	1412 OFFICE	1/19/2023	11:06:00 AM	607	0.4	69.6	25.8	0	
Como Park Senior High School	1413 OFFICE	1/19/2023	11:01:00 AM	626	0.3	69.1	26.7	1	
Como Park Senior High School	1416 CUBICLES	1/19/2023	11:04:00 AM	607	0.4	69.8	26.1	0	
Como Park Senior High School	1501 OFFICE	1/19/2023	10:11:00 AM	686	0.4	70.9	25.9	3	
Como Park Senior High School	1503 OFFICE	1/19/2023	10:12:00 AM	742	0.3	69.8	26.4	1	
Como Park Senior High School	1505 OFFICE	1/19/2023	10:14:00 AM	622	0.3	69.8	25.8	0	
Como Park Senior High School	1506 CONFERENCE	1/19/2023	10:23:00 AM	578	0.4	68.5	25.8	0	
Como Park Senior High School	1507 OFFICE	1/19/2023	10:15:00 AM	787	0.4	70	27.3	1	
Como Park Senior High School	1509 OFFICE	1/19/2023	10:17:00 AM	574	0.3	70	25.3	0	
Como Park Senior High School	1511 OFFICE	1/19/2023	10:18:00 AM	604	0.4	70	25.1	1	Stained ceiling tiles
Como Park Senior High School	1512 OFFICE	1/19/2023	10:21:00 AM	603	0.3	70.2	25.4	1	
Como Park Senior High School	1513 OFFICE	1/19/2023	10:19:00 AM	681	0.4	70	25.9	2	
Como Park Senior High School	1514 OFFICE	1/19/2023	10:22:00 AM	577	0.4	69.6	25.1	0	
Como Park Senior High School	1606A	1/19/2023	9:28:00 AM	598	0.4	70.2	25	0	
Como Park Senior High School	1608 OFFICE	1/19/2023	10:10:00 AM	679	0.4	71.1	25	1	
Como Park Senior High School	1611 OFFICE	1/19/2023	9:37:00 AM	728	0.5	72.1	25	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1612 OFFICE	1/19/2023	10:09:00 AM	658	0.4	71.1	24.7	0	
Como Park Senior High School	1614 OFFICE	1/19/2023	10:03:00 AM	654	0.3	71.1	24.8	0	
Como Park Senior High School	1711A OFFICE	1/19/2023	10:33:00 AM	727	0.4	70.3	25.5	0	
Como Park Senior High School	1713 OFFICE	1/19/2023	10:35:00 AM	749	0.4	71.1	25.3	0	
Como Park Senior High School	1717A	1/19/2023	10:39:00 AM	843	0.4	70	27	0	
Como Park Senior High School	1722 OFFICE	1/19/2023	10:43:00 AM	742	0.4	70.9	25.7	0	
Como Park Senior High School	1803 OFFICE	1/19/2023	10:28:00 AM	779	0.4	71.1	25.8	1	
Como Park Senior High School	1811 CUBICLES	1/19/2023	10:24:00 AM	745	0.2	69.4	26.9	1	
Como Park Senior High School	2303 CUBICLES	1/19/2023	1:15:00 PM	724	0.5	71.2	26.8	0	Food odor
Como Park Senior High School	2306 WORKROOM	1/19/2023	1:25:00 PM	644	0.4	70.7	26.5	0	Plants
Como Park Senior High School	2307 CONFERENCE	1/19/2023	1:18:00 PM	641	0.4	70.9	25.8	0	
Como Park Senior High School	2311 OFFICE	1/19/2023	1:19:00 PM	747	0.4	70.5	27	0	
Como Park Senior High School	2313 LIBRARY	1/19/2023	1:17:00 PM	700	0.4	71.1	26.4	1	
Como Park Senior High School	2609 CUBICLES	1/19/2023	11:46:00 AM	674	0.4	70.3	25.6	0	
Como Park Senior High School	2614 OFFICE	1/19/2023	11:55:00 AM	811	0.4	71.2	26.7	3	
Como Park Senior High School	2616 OFFICE	1/19/2023	11:54:00 AM	716	0.5	71.1	26	1	
Como Park Senior High School	2707 CUBICLES	1/19/2023	12:06:00 PM	698	0.4	70.2	26.2	0	
Como Park Senior High School	2716 OFFICE	1/19/2023	12:15:00 PM	660	0.5	70.2	25.7	0	Fragrance odor
Como Park Senior High School	2744 OFFICE	1/19/2023	12:30:00 PM	680	0.3	70.7	26.1	0	
Como Park Senior High School	OUTDOORS	1/19/2023		400	0.5	32	91		
Creative Arts Secondary School	106	12/12/2022	10:33:00 AM	374	0.3	72.9	22.5	0	Stained ceiling tiles
Creative Arts Secondary School	107	12/12/2022	10:40:00 AM	352	0.3	73.2	22	0	
Creative Arts Secondary School	109	12/12/2022	10:36:00 AM	363	0.3	73	22.3	0	
Creative Arts Secondary School	112	12/12/2022	10:44:00 AM	356	0.3	73.8	21.3	0	Fragrance odor
Creative Arts Secondary School	113	12/12/2022	10:46:00 AM	372	0.3	73.6	21.8	0	Stained ceiling tiles, Taxidermy
Creative Arts Secondary School	114	12/12/2022	10:48:00 AM	356	0.3	72.7	22.4	0	Stained ceiling tiles
Creative Arts Secondary School	116	12/12/2022	10:50:00 AM	343	0.3	72	22.9	0	Moisture damage at back corner, Stained ceiling tiles, Suspect microbial growth: Middle of the room by sagging tile
Creative Arts Secondary School	117	12/12/2022	10:37:00 AM	373	0.3	73.4	21.9	0	Stained ceiling tiles
Creative Arts Secondary School	118	12/12/2022	10:53:00 AM	348	0.3	71.8	23	0	
Creative Arts Secondary School	204	12/12/2022	11:00:00 AM	328	0.2	71.2	21.5	0	
Creative Arts Secondary School	208	12/12/2022	10:57:00 AM	374	0.2	70.9	22.3	1	
Creative Arts Secondary School	1102	12/12/2022	9:49:00 AM	371	0.1	62.4	27.5	3	
Creative Arts Secondary School	1103	12/12/2022	10:04:00 AM	371	0.3	69.8	22.2	0	
Creative Arts Secondary School	1104	12/12/2022	9:59:00 AM	408	0.2	69.4	22.5	1	
Creative Arts Secondary School	1105	12/12/2022	10:22:00 AM	468	0.3	70.7	23	1	
Creative Arts Secondary School	1106	12/12/2022	10:02:00 AM	536	0.3	70.9	22.9	14	Stained ceiling tiles
Creative Arts Secondary School	1202	12/12/2022	10:10:00 AM	385	0.2	70.9	21.9	0	
Creative Arts Secondary School	1202	12/12/2022	10:18:00 AM	321	0.2	69.6	21.2	0	
Creative Arts Secondary School	1203	12/12/2022	10:12:00 AM	318	0.3	68.2	22.1	0	
Creative Arts Secondary School	1208	12/12/2022	10:08:00 AM	601	0.3	68.2	23.7	5	Stained ceiling tiles
Creative Arts Secondary School	1209	12/12/2022	10:20:00 AM	466	0.2	69.4	24.1	6	
Creative Arts Secondary School	2100	12/12/2022	11:37:00 AM	588	0.2	72.1	23	1	
Creative Arts Secondary School	2201	12/12/2022	11:46:00 AM	530	0.2	72.5	22.1	1	
Creative Arts Secondary School	2202	12/12/2022	11:48:00 AM	400	0.2	72.3	21.3	0	
Creative Arts Secondary School	2204	12/12/2022	11:52:00 AM	538	0.2	72.1	22.5	0	Moisture damage at window sills
Creative Arts Secondary School	2207	12/12/2022	11:54:00 AM	773	0.2	72.3	23.9	18	
Creative Arts Secondary School	2305	12/12/2022	12:10:00 PM	556	0.3	70.7	23.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Creative Arts Secondary School	2306	12/12/2022	12:17:00 PM	525	0.3	68.7	25	0	
Creative Arts Secondary School	2310	12/12/2022	12:08:00 PM	544	0.3	72.7	22.2	0	
Creative Arts Secondary School	2311	12/12/2022	12:07:00 PM	653	0.2	73.9	22.6	0	
Creative Arts Secondary School	2312	12/12/2022	12:06:00 PM	562	0.2	72	23.5	0	
Creative Arts Secondary School	2313	12/12/2022	12:14:00 PM	581	0.2	69.8	24.9	1	
Creative Arts Secondary School	2314	12/12/2022	12:13:00 PM	525	0.2	69.6	24.3	0	
Creative Arts Secondary School	2315	12/12/2022	12:05:00 PM	735	0.3	71.1	25.3	12	
Creative Arts Secondary School	2316	12/12/2022	11:57:00 AM	616	0.2	72.5	24.4	1	
Creative Arts Secondary School	2316	12/12/2022	11:58:00 AM	626	0.2	72.5	23	1	
Creative Arts Secondary School	4105	12/12/2022	12:34:00 PM	495	0.3	70.7	23.5	0	
Creative Arts Secondary School	4106	12/12/2022	12:36:00 PM	525	0.2	70.2	23.9	2	
Creative Arts Secondary School	4108	12/12/2022	12:39:00 PM	962	0.3	71.8	33.6	18	
Creative Arts Secondary School	4109	12/12/2022	12:41:00 PM	538	0.3	72.5	22.7	0	Stained ceiling tiles
Creative Arts Secondary School	4111	12/12/2022	12:43:00 PM	648	0.3	72.1	23.9	2	
Creative Arts Secondary School	4112	12/12/2022	12:44:00 PM	537	0.3	71.8	24.6	0	
Creative Arts Secondary School	5102	12/12/2022	1:00:00 PM	728	0.3	70.9	25.4	9	
Creative Arts Secondary School	5103	12/12/2022	1:01:00 PM	591	0.2	69.2	24.5	0	
Creative Arts Secondary School	5104	12/12/2022	1:02:00 PM	573	0.2	69.3	25	0	
Creative Arts Secondary School	5105	12/12/2022	12:58:00 PM	555	0.3	71.4	23.5	0	
Creative Arts Secondary School	5106	12/12/2022	12:56:00 PM	737	0.2	71.8	25	12	
Creative Arts Secondary School	5107	12/12/2022	12:55:00 PM	933	0.3	71.6	26.4	14	
Creative Arts Secondary School	5109	12/12/2022	12:53:00 PM	611	0.2	70.9	24.1	0	
Creative Arts Secondary School	6106	12/12/2022	1:17:00 PM	795	0.3	74.5	24.2	13	
Creative Arts Secondary School	6107	12/12/2022	1:13:00 PM	730	0.4	74.7	24.1	15	
Creative Arts Secondary School	6108	12/12/2022	1:18:00 PM	598	0.3	74.8	21.9	2	
Creative Arts Secondary School	6109	12/12/2022	1:12:00 PM	579	0.3	74.7	21.3	0	
Creative Arts Secondary School	6110	12/12/2022	1:08:00 PM	890	0.3	74.1	24.8	16	
Creative Arts Secondary School	6112	12/12/2022	1:05:00 PM	672	0.1	72.3	24.5	0	
Creative Arts Secondary School	6113	12/12/2022	1:06:00 PM	582	0.2	73	23	1	
Creative Arts Secondary School	6114	12/12/2022	1:10:00 PM	561	0.3	74.7	21.8	0	
Creative Arts Secondary School	7106	12/12/2022	1:34:00 PM	675	0.3	74.1	23.3	0	
Creative Arts Secondary School	7107	12/12/2022	1:32:00 PM	708	0.3	73.8	24.2	17	
Creative Arts Secondary School	7108	12/12/2022	1:31:00 PM	763	0.3	73.8	24.5	1	
Creative Arts Secondary School	7109	12/12/2022	1:28:00 PM	1111	0.3	74.1	27.1	15	
Creative Arts Secondary School	7110	12/12/2022	1:25:00 PM	695	0.3	73.9	24.4	14	Plants: Kept Away From Return And Supply Vents
Creative Arts Secondary School	7112	12/12/2022	1:21:00 PM	616	0.3	73.9	22.8	0	Plants: Kept Away From Return And Supply Vents
Creative Arts Secondary School	7113	12/12/2022	1:23:00 PM	552	0.3	73.8	22	1	
Creative Arts Secondary School	7114	12/12/2022	1:26:00 PM	545	0.3	74.1	22.3	0	
Creative Arts Secondary School	8106	12/12/2022	1:47:00 PM	708	0.2	73.6	23.8	10	Condensation
Creative Arts Secondary School	8107	12/12/2022	1:45:00 PM	831	0.4	71.8	27	20	Condensation
Creative Arts Secondary School	8108	12/12/2022	1:43:00 PM	737	0.3	72.5	24.1	0	
Creative Arts Secondary School	8110	12/12/2022	1:38:00 PM	739	0.3	72.3	25.9	16	
Creative Arts Secondary School	8112	12/12/2022	1:37:00 PM	585	0.3	73	22.7	14	
Creative Arts Secondary School	8113	12/12/2022	1:40:00 PM	718	0.2	73.2	23.1	0	
Creative Arts Secondary School	8114	12/12/2022	1:41:00 PM	849	0.3	74.1	24	1	Plants: Kept Away From Return And Supply Vents
Creative Arts Secondary School	0107A	12/12/2022	10:42:00 AM	342	0.3	73.2	21.8	0	
Creative Arts Secondary School	1102A	12/12/2022	9:57:00 AM	1063	0.2	68.9	27	3	
Creative Arts Secondary School	1102B	12/12/2022	9:55:00 AM	389	0.2	66.6	24.3	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Creative Arts Secondary School	1102C	12/12/2022	9:54:00 AM	375	0.1	65.5	25.5	0	
Creative Arts Secondary School	1105A	12/12/2022	10:24:00 AM	354	0.2	71.2	20.6	1	
Creative Arts Secondary School	1105B	12/12/2022	11:29:00 AM	816	0.2	72.1	25.7	3	
Creative Arts Secondary School	1107A	12/12/2022	10:27:00 AM	521	0.2	70	23.9	0	
Creative Arts Secondary School	1209A	12/12/2022	10:15:00 AM	332	0.2	69.6	21.9	0	
Creative Arts Secondary School	2203B	12/12/2022	11:53:00 AM	618	0.2	72	23.4	1	
Creative Arts Secondary School	2203C	12/12/2022	11:50:00 AM	442	0.2	72.3	21.9	0	Food odor
Creative Arts Secondary School	2316A	12/12/2022	12:23:00 PM	601	0.2	71.2	23.9	1	
Creative Arts Secondary School	2316B	12/12/2022	12:01:00 PM	700	0.3	72.5	23.1	2	Fragrance odor, Plants: Kept Away From Return And Supply Vents
Creative Arts Secondary School	2316D	12/12/2022	11:59:00 AM	596	0.2	72.7	23.5	1	Plants: Kept Away From Return And Supply Vents
Creative Arts Secondary School	3102A	12/12/2022	12:27:00 PM	525	0.2	69.6	26.3	1	
Creative Arts Secondary School	CAFETERIA NEAR KITCHEN	12/12/2022	12:29:00 PM	432	0.2	70	23.8	0	
Creative Arts Secondary School	CAFETERIA SOUTH	12/12/2022	12:31:00 PM	419	0.1	72	22.2	0	
Creative Arts Secondary School	GYM	12/12/2022	12:19:00 PM	836	0.1	69.6	28.8	20	Musty odor
Creative Arts Secondary School	KITCHEN	12/12/2022	12:26:00 PM	525	0.2	70.7	26.3	4	
Creative Arts Secondary School	M1	12/12/2022	11:33:00 AM	520	0.2	72.7	22.1	0	
Creative Arts Secondary School	M10	12/12/2022	11:39:00 AM	497	0.2	71.8	22.4	0	
Creative Arts Secondary School	M2	12/12/2022	11:33:00 AM	542	0.2	72.5	22.3	0	
Creative Arts Secondary School	M3	12/12/2022	11:35:00 AM	510	0.2	72.3	22.3	0	
Creative Arts Secondary School	M7	12/12/2022	11:43:00 AM	619	0.2	71.4	23.8	1	
Creative Arts Secondary School	M8	12/12/2022	11:42:00 AM	520	0.2	71.4	22.9	0	
Creative Arts Secondary School	M9	12/12/2022	11:41:00 AM	610	0.2	71.4	24.1	1	Fragrance odor
Creative Arts Secondary School	OUTDOORS	12/12/2022		303	0.4	32	77		
Crossroads Montessori	1008	3/7/2023	10:57:00 AM	831		71.3	33.8	0	
Crossroads Montessori	1018	3/7/2023	10:42:00 AM	906		69.7	23.9	1	
Crossroads Montessori	1020	3/7/2023	10:44:00 AM	696		68.9	22.3	0	
Crossroads Montessori	1102	3/7/2023	9:38:00 AM	646		71.7	23	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1104	3/7/2023	9:38:00 AM	681		71.6	23	1	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1106	3/7/2023	9:40:00 AM	627		71.4	25.2	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1107	3/7/2023	9:41:00 AM	643		71.4	22.4	0	
Crossroads Montessori	1108	3/7/2023	9:41:00 AM	702		71.5	26.6	0	
Crossroads Montessori	1109	3/7/2023	9:43:00 AM	641		71.7	26.8	0	
Crossroads Montessori	1111	3/7/2023	9:44:00 AM	652		71.6	22.3	1	
Crossroads Montessori	1112	3/7/2023	9:45:00 AM	664		71.3	21.9	0	
Crossroads Montessori	1122	3/7/2023	9:48:00 AM	695		71.9	23.5	1	
Crossroads Montessori	1126	3/7/2023	9:51:00 AM	682		71.3	21.7	0	
Crossroads Montessori	1127	3/7/2023	9:52:00 AM	675		71.1	21.7	0	
Crossroads Montessori	1130	3/7/2023	9:53:00 AM	631		70.9	21.3	0	
Crossroads Montessori	1202	3/7/2023	9:55:00 AM	809		71.7	38.1	3	
Crossroads Montessori	1204	3/7/2023	10:10:00 AM	779		71.1	24	2	
Crossroads Montessori	1206	3/7/2023	9:57:00 AM	796		72.7	21.5	0	
Crossroads Montessori	1208	3/7/2023	10:09:00 AM	773		70.9	22.7	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1210	3/7/2023	9:59:00 AM	786		72.5	22.2	0	
Crossroads Montessori	1212	3/7/2023	10:07:00 AM	779		70.9	24.2	1	
Crossroads Montessori	1214	3/7/2023	10:01:00 AM	794		73.3	23.4	0	
Crossroads Montessori	1216	3/7/2023	10:05:00 AM	770		70.9	22.4	0	
Crossroads Montessori	1218	3/7/2023	10:03:00 AM	776		72.2	21.2	0	
Crossroads Montessori	1302	3/7/2023	10:11:00 AM	807		70.2	23.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Crossroads Montessori	1304	3/7/2023	10:13:00 AM	729		70.5	26	1	
Crossroads Montessori	1306	3/7/2023	10:15:00 AM	1024		71.5	34	24	
Crossroads Montessori	1308	3/7/2023	10:17:00 AM	746		71.5	23.1	3	
Crossroads Montessori	1310	3/7/2023	10:18:00 AM	854		70.8	25.2	16	
Crossroads Montessori	1312	3/7/2023	10:20:00 AM	754		70.4	23.6	6	
Crossroads Montessori	1314	3/7/2023	10:23:00 AM	696		70.8	25.1	0	
Crossroads Montessori	1320	3/7/2023	10:40:00 AM	797		70.1	22.7	1	
Crossroads Montessori	1402	3/7/2023	10:39:00 AM	782		70.2	24.4	1	
Crossroads Montessori	1404	3/7/2023	10:37:00 AM	840		69.7	24.8	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1406	3/7/2023	10:36:00 AM	668		69.8	21.8	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1408	3/7/2023	10:34:00 AM	702		70.1	24	1	
Crossroads Montessori	1410	3/7/2023	10:33:00 AM	858		70.2	24.7	0	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1412	3/7/2023	10:31:00 AM	906		70	25	0	
Crossroads Montessori	1414	3/7/2023	10:30:00 AM	845		69.6	23.7	0	
Crossroads Montessori	1416	3/7/2023	10:24:00 AM	850		69.7	24	8	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1417	3/7/2023	10:26:00 AM	875		69.5	24.5	0	
Crossroads Montessori	1419	3/7/2023	10:27:00 AM	771		68.9	23.6	1	
Crossroads Montessori	1501	3/7/2023	10:45:00 AM	690		68.8	21.4	0	
Crossroads Montessori	1503	3/7/2023	10:47:00 AM	968		69.5	25.5	24	
Crossroads Montessori	1526	3/7/2023	10:53:00 AM	705		69.7	26.6	0	
Crossroads Montessori	1533	3/7/2023	10:54:00 AM	668		69.9	23.3	0	
Crossroads Montessori	1600	3/7/2023	9:11:00 AM	630		66.7	30	0	
Crossroads Montessori	1601	3/7/2023	9:13:00 AM	646		67.5	29.9	0	
Crossroads Montessori	1604	3/7/2023	9:08:00 AM	643		66.4	29	0	
Crossroads Montessori	1606	3/7/2023	9:15:00 AM	644		68.5	33.6	1	
Crossroads Montessori	1608	3/7/2023	9:23:00 AM	641		70.2	28.2	0	
Crossroads Montessori	1612	3/7/2023	9:19:00 AM	631		69.2	23.9	0	
Crossroads Montessori	1614	3/7/2023	9:21:00 AM	627		69.7	24.1	0	
Crossroads Montessori	1618	3/7/2023	9:17:00 AM	650		68.7	29.1	1	
Crossroads Montessori	1620	3/7/2023	9:24:00 AM	633		70.2	23.6	0	
Crossroads Montessori	1624	3/7/2023	9:25:00 AM	685		69.9	23.6	1	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1625	3/7/2023	9:28:00 AM	637		69.8	24.4	0	
Crossroads Montessori	1626	3/7/2023	9:29:00 AM	627		69.1	22.9	0	
Crossroads Montessori	1628	3/7/2023	9:31:00 AM	670		69.7	24.1	1	
Crossroads Montessori	1630	3/7/2023	9:32:00 AM	766		70.7	36.3	15	
Crossroads Montessori	2001	3/7/2023	11:02:00 AM	536		72.2	22.3	1	
Crossroads Montessori	2003	3/7/2023	11:04:00 AM	532		72.9	20.5	0	
Crossroads Montessori	2016	3/7/2023	11:04:00 AM	651		72.5	22.8	0	
Crossroads Montessori	2018	3/7/2023	11:35:00 AM	646		71.2	24.8	0	Musty odor
Crossroads Montessori	2020	3/7/2023	11:07:00 AM	685		71.9	31.3	0	
Crossroads Montessori	2302	3/7/2023	11:10:00 AM	753		71.1	22.4	0	
Crossroads Montessori	2304	3/7/2023	11:11:00 AM	732		71.8	22.2	0	Stained ceiling tiles
Crossroads Montessori	2306	3/7/2023	11:12:00 AM	693		71.1	21.9	2	
Crossroads Montessori	2308	3/7/2023	11:13:00 AM	679		71.2	21.6	1	
Crossroads Montessori	2310	3/7/2023	11:14:00 AM	677		70.5	21.2	0	
Crossroads Montessori	2312	3/7/2023	11:16:00 AM	750		71.2	24	1	
Crossroads Montessori	2314	3/7/2023	11:17:00 AM	789		71.7	25.5	2	
Crossroads Montessori	2320	3/7/2023	11:08:00 AM	655		70.9	20.9	0	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Crossroads Montessori	2322	3/7/2023	11:31:00 AM	688		71.8	23.7	0	
Crossroads Montessori	2402	3/7/2023	11:29:00 AM	696		72.6	22	2	
Crossroads Montessori	2404	3/7/2023	11:28:00 AM	836		72.3	22.7	0	
Crossroads Montessori	2406	3/7/2023	11:27:00 AM	796		72.6	30	5	
Crossroads Montessori	2408	3/7/2023	11:25:00 AM	967		72.1	34.3	15	
Crossroads Montessori	2410	3/7/2023	11:24:00 AM	909		71.4	23.7	1	
Crossroads Montessori	2412	3/7/2023	11:23:00 AM	720		71.3	21.2	0	
Crossroads Montessori	2414	3/7/2023	11:21:00 AM	702		70.9	22.4	1	
Crossroads Montessori	2416	3/7/2023	11:19:00 AM	728		71.8	23.2	1	
Crossroads Montessori	2424	3/7/2023	11:32:00 AM	802		71.6	20.8	1	
Crossroads Montessori	2428	3/7/2023	11:34:00 AM	819		71.7	28.2	3	
Crossroads Montessori	1100 MAIN OFFICE	3/7/2023	9:34:00 AM	655		71.6	24.5	4	
Crossroads Montessori	1120 NORTH	3/7/2023	9:50:00 AM	701		71.6	22	1	
Crossroads Montessori	1120 SOUTH	3/7/2023	9:46:00 AM	699		71.3	34.8	0	
Crossroads Montessori	CAFETERIA	3/7/2023	10:49:00 AM	839		70.3	26.2	35	
Crossroads Montessori	GYMNASIUM	3/7/2023	10:55:00 AM	791		70.4	27.4	22	
Crossroads Montessori	KITCHEN OFFICE	3/7/2023	10:51:00 AM	783		70.7	28.1	0	
Crossroads Montessori	OUTDOORS	3/7/2023		541	1.1	33	81		
Dayton's Bluff Elementary School	1101	11/21/2022	10:08:00 AM	655	0.1	70.2	20.1	0	
Dayton's Bluff Elementary School	1102	11/21/2022	10:13:00 AM	814	0.2	70.9	21.9	1	
Dayton's Bluff Elementary School	1103	11/21/2022	10:11:00 AM	573	0.1	70.3	19.9	0	
Dayton's Bluff Elementary School	1105	11/21/2022	10:15:00 AM	610	0.1	71.2	19.7	1	Stuffy odor
Dayton's Bluff Elementary School	1114	11/21/2022	10:28:00 AM	620	0.1	73.2	21.9	1	Bubbling/peeling paint
Dayton's Bluff Elementary School	1201	11/21/2022	10:06:00 AM	630	0.1	68	21	0	
Dayton's Bluff Elementary School	1202	11/21/2022	9:57:00 AM	674	0.1	69.3	20.4	22	
Dayton's Bluff Elementary School	1203	11/21/2022	9:59:00 AM	764	0.2	69.4	21	2	
Dayton's Bluff Elementary School	1204	11/21/2022	10:02:00 AM	640	0.2	68.5	20.6	0	
Dayton's Bluff Elementary School	1301	11/21/2022	9:33:00 AM	561	0.3	68.9	19.7	0	
Dayton's Bluff Elementary School	1302	11/21/2022	9:37:00 AM	644	0.3	68.2	20.7	15	
Dayton's Bluff Elementary School	1304	11/21/2022	9:44:00 AM	568	0.2	70.2	19.3	1	Bubbling/peeling paint
Dayton's Bluff Elementary School	1305	11/21/2022	9:49:00 AM	835	0.3	70.2	20.8	5	Bubbling/peeling paint
Dayton's Bluff Elementary School	1306	11/21/2022	9:53:00 AM	694	0.2	68.2	22	13	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
Dayton's Bluff Elementary School	1307	11/21/2022	9:40:00 AM	594	0.3	66.7	21.2	1	Bubbling/peeling paint
Dayton's Bluff Elementary School	1307	11/21/2022	9:47:00 AM	843	0.3	71.1	21.5	16	
Dayton's Bluff Elementary School	1401	11/21/2022	9:23:00 AM	593	0.4	69.8	21.6	1	
Dayton's Bluff Elementary School	1402	11/21/2022	9:26:00 AM	621	0.4	67.3	21.6	0	Plants: Kept Away From Return And Supply Vents
Dayton's Bluff Elementary School	1405	11/21/2022	10:34:00 AM	590	0.1	65.8	22.1	0	Moisture damage on wall
Dayton's Bluff Elementary School	1406	11/21/2022	9:30:00 AM	650	0.2	68.5	21.8	3	
Dayton's Bluff Elementary School	1407	11/21/2022	9:20:00 AM	712	0.3	70.2	20.6	13	Bubbling/peeling paint
Dayton's Bluff Elementary School	1408	11/21/2022	9:02:00 AM	805	1	68	23	21	
Dayton's Bluff Elementary School	1409	11/21/2022	9:08:00 AM	615	0.8	70.3	22.5	12	
Dayton's Bluff Elementary School	1414	11/21/2022	9:05:00 AM	610	0.9	69.8	21.4	0	
Dayton's Bluff Elementary School	1510	11/21/2022	9:12:00 AM	472	0.7	68.9	18.6	0	
Dayton's Bluff Elementary School	1512	11/21/2022	9:15:00 AM	542	0.6	69.6	19.4	0	
Dayton's Bluff Elementary School	1513	11/21/2022	10:22:00 AM	525	0.1	69.3	18.5	0	
Dayton's Bluff Elementary School	1514	11/21/2022	10:19:00 AM	529	0.1	69.8	19	0	
Dayton's Bluff Elementary School	1515	11/21/2022	10:24:00 AM	533	0.1	69.4	19.1	0	Musty odor, Efflorescence

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Dayton's Bluff Elementary School	1516	11/21/2022	10:18:00 AM	707	0.2	70.5	21.9	16	
Dayton's Bluff Elementary School	2002	11/21/2022	12:04:00 PM	595	0.2	68.7	18.8	0	
Dayton's Bluff Elementary School	2003	11/21/2022	12:03:00 PM	546	0.2	70.2	17.7	0	
Dayton's Bluff Elementary School	2004	11/21/2022	12:02:00 PM	687	0.3	71.1	18	0	
Dayton's Bluff Elementary School	2005	11/21/2022	12:01:00 PM	539	0.2	71.2	17.9	524	
Dayton's Bluff Elementary School	2006	11/21/2022	11:59:00 AM	565	0.2	70.2	18.5	0	Stained ceiling tiles
Dayton's Bluff Elementary School	2007	11/21/2022	11:58:00 AM	536	0.2	69.6	19.7	1	
Dayton's Bluff Elementary School	2008	11/21/2022	11:56:00 AM	599	0.2	69.3	20	1	
Dayton's Bluff Elementary School	2010	11/21/2022	11:55:00 AM	668	0.1	68.7	20.1	1	Stained ceiling tiles
Dayton's Bluff Elementary School	2011	11/21/2022	11:54:00 AM	532	0.1	68.4	18.6	0	
Dayton's Bluff Elementary School	2012	11/21/2022	11:53:00 AM	485	0.1	67.6	19.4	0	
Dayton's Bluff Elementary School	2014	11/21/2022	11:51:00 AM	558	0.2	68.4	19	0	
Dayton's Bluff Elementary School	2015	11/21/2022	11:50:00 AM	574	0.3	69.4	18.6	0	
Dayton's Bluff Elementary School	2016	11/21/2022	11:47:00 AM	568	0.2	70	18.7	0	
Dayton's Bluff Elementary School	2019	11/21/2022	11:46:00 AM	578	0.2	69.8	19.6	0	
Dayton's Bluff Elementary School	2020	11/21/2022	11:45:00 AM	625	0.2	70.2	21	1	
Dayton's Bluff Elementary School	2021	11/21/2022	11:43:00 AM	644	0.3	70.2	20.7	0	
Dayton's Bluff Elementary School	2022	11/21/2022	11:42:00 AM	723	0.1	68.9	20.5	1	
Dayton's Bluff Elementary School	2103	11/21/2022	11:39:00 AM	584	0.2	66.2	23.8	0	Chemical/burnt odor
Dayton's Bluff Elementary School	2301	11/21/2022	11:00:00 AM	694	0.3	71.4	19.3	2	
Dayton's Bluff Elementary School	2302	11/21/2022	10:59:00 AM	640	0.1	69.6	19.7	5	
Dayton's Bluff Elementary School	2303	11/21/2022	10:48:00 AM	570	0.1	71.2	18.5	0	
Dayton's Bluff Elementary School	2304	11/21/2022	10:45:00 AM	585	0.1	70.7	19.1	2	
Dayton's Bluff Elementary School	2305	11/21/2022	10:43:00 AM	569	0.1	70.9	19	3	
Dayton's Bluff Elementary School	2306	11/21/2022	10:41:00 AM	915	0.2	71.1	19.5	16	
Dayton's Bluff Elementary School	2307	11/21/2022	10:47:00 AM	846	0.1	71.6	21.3	19	
Dayton's Bluff Elementary School	2313	11/21/2022	10:39:00 AM	872	0.1	70	21.4	2	
Dayton's Bluff Elementary School	2401	11/21/2022	11:03:00 AM	812	0.3	68.5	21.1	1	Plants: Kept Away From Return And Supply Vents
Dayton's Bluff Elementary School	2402	11/21/2022	11:04:00 AM	663	0.1	69.8	22.1	4	
Dayton's Bluff Elementary School	2403	11/21/2022	11:08:00 AM	813	0.2	70	20.8	4	
Dayton's Bluff Elementary School	2404	11/21/2022	11:06:00 AM	1399	0.4	69.6	23.9	20	
Dayton's Bluff Elementary School	2405	11/21/2022	11:10:00 AM	590	0.1	70	20	0	
Dayton's Bluff Elementary School	2406	11/21/2022	11:13:00 AM	777	0.2	69.4	21.9	5	
Dayton's Bluff Elementary School	2407	11/21/2022	11:12:00 AM	570	0.1	69.8	19.9	0	
Dayton's Bluff Elementary School	2408	11/21/2022	11:14:00 AM	569	0.1	69.1	20.5	0	
Dayton's Bluff Elementary School	2409	11/21/2022	11:16:00 AM	714	0.2	69.3	22.5	0	
Dayton's Bluff Elementary School	2410	11/21/2022	11:17:00 AM	588	0.1	69.6	20.7	0	
Dayton's Bluff Elementary School	2101B	11/21/2022	11:36:00 AM	572	0.1	69.4	19.5	0	
Dayton's Bluff Elementary School	CAFETERIA	11/21/2022	11:20:00 AM	945	0.2	68.7	25.5	35	
Dayton's Bluff Elementary School	CHEF OFFICE	11/21/2022	11:22:00 AM	875	0.2	69.6	27.1	0	
Dayton's Bluff Elementary School	GYM	11/21/2022	11:34:00 AM	572	0.2	68.7	19.9	0	
Dayton's Bluff Elementary School	KITCHEN	11/21/2022	11:23:00 AM	811	0.3	70.2	28.6	6	
Dayton's Bluff Elementary School	OUTDOORS	11/21/2022		402	0.8	25	74		
Dayton's Bluff Elementary School	OUTDOORS	11/21/2022	12:06:00 PM	394	0.4	31	62		
Early Childhood Hub West	100	12/9/2022	1:15:00 PM	383	0.2	69.8	21.4	1	
Early Childhood Hub West	101	12/9/2022	1:10:00 PM	446	0.2	70	22.8	14	
Early Childhood Hub West	102	12/9/2022	1:12:00 PM	435	0.1	70.5	21.4	14	
Early Childhood Hub West	1001	12/9/2022	1:19:00 PM	373	0.1	70.3	20.9	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Early Childhood Hub West	1003	12/9/2022	1:28:00 PM	384	0.2	72.9	21.3	0	
Early Childhood Hub West	1005	12/9/2022	1:27:00 PM	409	0.2	73	20.1	1	
Early Childhood Hub West	1006	12/9/2022	1:22:00 PM	385	0.1	72	19.9	1	
Early Childhood Hub West	1009	12/9/2022	1:25:00 PM	369	0.1	72.9	9.9	0	
Early Childhood Hub West	1013	12/9/2022	1:20:00 PM	351	0.2	70	20.6	0	
Early Childhood Hub West	1014	12/9/2022	1:21:00 PM	370	0.1	70.7	20.3	0	Stained ceiling tiles
Early Childhood Hub West	1141	12/9/2022	12:11:00 PM	405	0.1	70	21.4	5	
Early Childhood Hub West	1142	12/9/2022	12:16:00 PM	399	0.1	68.7	21.4	14	
Early Childhood Hub West	1143	12/9/2022	12:18:00 PM	402	0.1	69.4	21.8	2	
Early Childhood Hub West	1144	12/9/2022	12:18:00 PM	420	0.1	69.8	21.7	2	
Early Childhood Hub West	1145	12/9/2022	12:19:00 PM	434	0.1	69.4	22.5	19	Stained ceiling tiles
Early Childhood Hub West	1146	12/9/2022	12:22:00 PM	408	0.1	69.3	22.3	2	
Early Childhood Hub West	1153	12/9/2022	12:24:00 PM	489	0.1	69.4	24	17	
Early Childhood Hub West	1154	12/9/2022	12:27:00 PM	382	0.1	69.9	21.5	7	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	1155	12/9/2022	12:29:00 PM	405	0.2	70.7	21.9	15	Bubbling/peeling paint
Early Childhood Hub West	1162	12/9/2022	1:34:00 PM	365	0.1	69.8	22.6	0	
Early Childhood Hub West	1201	12/9/2022	12:08:00 PM	524	0.1	70.5	22.1	16	
Early Childhood Hub West	1202	12/9/2022	11:46:00 AM	392	0.1	69.6	21.6	3	
Early Childhood Hub West	1203	12/9/2022	12:07:00 PM	363	0.1	68.7	21.5	1	
Early Childhood Hub West	1207	12/9/2022	11:56:00 AM	386	0.1	69.1	21.4	1	Stained ceiling tiles
Early Childhood Hub West	2200	12/9/2022	12:40:00 PM	353	0.1	69.4	20.9	0	Moisture damage at skylights in front of room 2253
Early Childhood Hub West	2244	12/9/2022	1:07:00 PM	577	0.1	69.3	23.8	8	
Early Childhood Hub West	2245	12/9/2022	1:00:00 PM	367	0.1	69.4	21.1	1	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	2246	12/9/2022	12:59:00 PM	370	0.1	70	20.8	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	2252	12/9/2022	12:58:00 PM	346	0.1	69.8	20.6	0	
Early Childhood Hub West	2253	12/9/2022	12:47:00 PM	339	0.1	70	20.4	0	Plants
Early Childhood Hub West	2254	12/9/2022	12:46:00 PM	341	0.1	69.9	20.5	0	
Early Childhood Hub West	1145A	12/9/2022	12:21:00 PM	352	0.1	69.3	21.1	0	
Early Childhood Hub West	1162A	12/9/2022	1:38:00 PM	470	0.1	69.6	22.2	3	
Early Childhood Hub West	1202A	12/9/2022	11:47:00 AM	368	0.1	68.9	21.1	0	
Early Childhood Hub West	1202B	12/9/2022	11:48:00 AM	372	0.1	69.1	20.9	0	
Early Childhood Hub West	1203A	12/9/2022	12:03:00 PM	361	0.1	68.2	21.4	0	
Early Childhood Hub West	1208B	12/9/2022	11:56:00 AM	435	0.1	66.2	23.3	0	
Early Childhood Hub West	1209C	12/9/2022	11:44:00 AM	376	0.1	69.3	20.8	0	
Early Childhood Hub West	2245A	12/9/2022	1:06:00 PM	378	0.1	68.7	21.7	2	Plants
Early Childhood Hub West	2245B	12/9/2022	1:04:00 PM	390	0.1	68.9	21.8	0	
Early Childhood Hub West	2245C	12/9/2022	1:03:00 PM	365	0.1	69.3	21.1	0	
Early Childhood Hub West	2253A	12/9/2022	12:50:00 PM	369	0.1	69.6	21.4	2	
Early Childhood Hub West	2253B	12/9/2022	12:52:00 PM	341	0.1	69.6	20.5	0	
Early Childhood Hub West	2253C	12/9/2022	12:53:00 PM	339	0.1	69.3	20.8	0	
Early Childhood Hub West	KITCHEN	12/9/2022	11:43:00 AM	440	0.1	69.1	21.7	1	
Early Childhood Hub West	NORTH 1208 GYMNASIUM	12/9/2022	11:53:00 AM	458	0.2	67.5	22.8	18	
Early Childhood Hub West	OUTDOORS	12/9/2022		291	0.4	54.7	29.8		
Early Childhood Hub West	SOUTH 1208 GYMNASIUM	12/9/2022	11:49:00 AM	405	0.1	70	21	7	
Early Learning Hub East	1001	11/15/2022	3:06:00 PM	476	0.2	69.3	26.4	1	
Early Learning Hub East	1002	11/15/2022	3:03:00 PM	942	0.3	70	27.6	1	Fragrance odor
Early Learning Hub East	1003	11/15/2022	3:05:00 PM	766	0.2	69.3	26.7	0	
Early Learning Hub East	1006	11/15/2022	3:07:00 PM	465	0.2	69.1	26.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Early Learning Hub East	1010	11/15/2022	3:10:00 PM	446	0.2	68.4	26.9	0	
Early Learning Hub East	1012	11/15/2022	3:11:00 PM	470	0.1	68.7	26.8	0	
Early Learning Hub East	1013	11/15/2022	1:48:00 PM	592	0.3	69.3	28.8	2	
Early Learning Hub East	1014	11/15/2022	1:50:00 PM	463	0.3	69.8	26.8	0	Plants
Early Learning Hub East	1101	11/15/2022	3:00:00 PM	1279	0.3	70.2	28.5	9	
Early Learning Hub East	1102	11/15/2022	2:56:00 PM	688	0.2	69.6	27.9	4	
Early Learning Hub East	1103	11/15/2022	2:44:00 PM	618	0.2	68	26.7	1	
Early Learning Hub East	1104	11/15/2022	2:47:00 PM	426	0.1	67.6	28.5	1	
Early Learning Hub East	1107	11/15/2022	2:51:00 PM	519	0.1	69.1	27.8	1	
Early Learning Hub East	1108	11/15/2022	2:40:00 PM	420	0.1	69.3	26.8	0	Stuffy odor, Live animals
Early Learning Hub East	1115	11/15/2022	2:53:00 PM	484	0.2	70.2	26.2	0	Stained ceiling tiles
Early Learning Hub East	1201	11/15/2022	2:34:00 PM	455	0.1	69.8	26.5	0	Plants
Early Learning Hub East	1202	11/15/2022	2:32:00 PM	551	0.1	69.8	27.6	2	
Early Learning Hub East	1203	11/15/2022	2:27:00 PM	539	0.2	69.6	27.7	7	Plants: Kept Away From Return And Supply Vents
Early Learning Hub East	1204	11/15/2022	2:24:00 PM	726	0.2	71.4	29.6	12	Plants
Early Learning Hub East	1205	11/15/2022	2:18:00 PM	512	0.2	68.9	27.6	9	
Early Learning Hub East	1206	11/15/2022	2:22:00 PM	652	0.2	69.3	28.9	11	
Early Learning Hub East	1301	11/15/2022	1:52:00 PM	808	0.2	69.6	28.7	16	Stuffy odor
Early Learning Hub East	1302	11/15/2022	2:15:00 PM	695	0.2	70	27.9	8	
Early Learning Hub East	1303	11/15/2022	1:56:00 PM	472	0.2	69.1	27.2	0	
Early Learning Hub East	1304	11/15/2022	2:13:00 PM	452	0.1	70	26.2	0	
Early Learning Hub East	1305	11/15/2022	1:58:00 PM	477	0.2	69.6	27	0	
Early Learning Hub East	1306	11/15/2022	2:07:00 PM	455	0.1	69.8	26.6	0	Plants
Early Learning Hub East	1307	11/15/2022	2:00:00 PM	452	0.2	69.8	27.1	0	
Early Learning Hub East	1308	11/15/2022	2:06:00 PM	778	0.2	71.4	26.8	4	Fragrance odor, Aquariums (fish), Plants
Early Learning Hub East	1312	11/15/2022	2:04:00 PM	471	0.2	70.9	26.6	0	
Early Learning Hub East	CUSTODIAL OFFICE	11/15/2022	2:38:00 PM	474	0.2	69.4	27	1	
Early Learning Hub East	OUTDOORS	11/15/2022		488	0.4	33	90		
Eastern Heights Elementary School	1202	1/20/2023	9:59:00 AM	556	0.2	70	20.7	8	
Eastern Heights Elementary School	1209	1/20/2023	10:01:00 AM	442	0.3	70.2	19	0	
Eastern Heights Elementary School	1301	1/20/2023	10:04:00 AM	651	0.4	70.5	21.1	19	Plants
Eastern Heights Elementary School	1302	1/20/2023	10:11:00 AM	807	0.3	69.6	23.1	20	
Eastern Heights Elementary School	1303	1/20/2023	10:06:00 AM	724	0.3	70.2	24.4	15	
Eastern Heights Elementary School	1305	1/20/2023	10:07:00 AM	919	0.4	70	23.6	21	
Eastern Heights Elementary School	1307	1/20/2023	10:09:00 AM	714	0.3	69.8	21.3	21	
Eastern Heights Elementary School	1309	1/20/2023	10:12:00 AM	938	0.3	69.8	23.9	18	
Eastern Heights Elementary School	2101	1/20/2023	10:35:00 AM	634	0.04	70.3	22.4	7	
Eastern Heights Elementary School	2102	1/20/2023	10:37:00 AM	600	0.4	70.3	22	7	
Eastern Heights Elementary School	2201	1/20/2023	10:15:00 AM	543	0.4	71.1	19.8	2	
Eastern Heights Elementary School	2202	1/20/2023	10:18:00 AM	993	0.4	70.9	22.7	24	
Eastern Heights Elementary School	2204	1/20/2023	10:20:00 AM	874	0.4	70	22.7	17	
Eastern Heights Elementary School	2206	1/20/2023	10:22:00 AM	982	0.4	69.6	23.8	18	
Eastern Heights Elementary School	2207	1/20/2023	10:23:00 AM	599	0.3	69.3	20.7	5	Plants
Eastern Heights Elementary School	2301	1/20/2023	10:24:00 AM	848	0.3	69.1	23	20	Plants
Eastern Heights Elementary School	2302	1/20/2023	10:55:00 AM	821	0.4	70.9	22.8	23	
Eastern Heights Elementary School	2303	1/20/2023	10:25:00 AM	872	0.3	69.1	23.8	22	
Eastern Heights Elementary School	2304	1/20/2023	10:30:00 AM	823	0.4	71.1	28.1	7	Plants
Eastern Heights Elementary School	2307	1/20/2023	10:56:00 AM	706	0.5	70.3	22.2	10	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Eastern Heights Elementary School	2309	1/20/2023	10:28:00 AM	603	0.3	69.8	22.4	2	
Eastern Heights Elementary School	2311	1/20/2023	10:52:00 AM	926	0.3	70.5	28.1	21	
Eastern Heights Elementary School	2313	1/20/2023	10:33:00 AM	977	0.5	70.5	24.1	9	Plants
Eastern Heights Elementary School	1001 MAIN OFFICE	1/20/2023	9:47:00 AM	544	0.4	71.4	20.4	2	
Eastern Heights Elementary School	1003 PARENT RESOURCE CONF	1/20/2023	9:49:00 AM	564	0.4	71.1	20.9	0	
Eastern Heights Elementary School	1004 NURSE OFFICE	1/20/2023	9:45:00 AM	624	0.4	72	20.3	1	
Eastern Heights Elementary School	1005 NURSE COT	1/20/2023	9:46:00 AM	538	0.5	71.8	19.9	0	
Eastern Heights Elementary School	1006 OFFICE	1/20/2023	9:44:00 AM	659	0.4	72	21.3	1	
Eastern Heights Elementary School	1007 OFFICE	1/20/2023	9:42:00 AM	526	0.4	72.1	20.1	0	Stained ceiling tiles
Eastern Heights Elementary School	1008 OFFICE	1/20/2023	9:40:00 AM	603	0.6	73	20.4	1	Fragrance odor
Eastern Heights Elementary School	1010 WORKROOM	1/20/2023	9:39:00 AM	535	0.6	74.5	19.2	0	
Eastern Heights Elementary School	1011 LOUNGE	1/20/2023	9:28:00 AM	523	0.7	75	18.4	0	
Eastern Heights Elementary School	1101 CAFETERIA	1/20/2023	9:50:00 AM	581	0.3	71.2	21.1	24	
Eastern Heights Elementary School	1108 KITCHEN	1/20/2023	9:51:00 AM	644	0.3	72.5	20.9	1	
Eastern Heights Elementary School	1109 OFFICE	1/20/2023	9:52:00 AM	648	0.3	72.7	21	1	
Eastern Heights Elementary School	1201 GYMNASIUM	1/20/2023	9:53:00 AM	477	0.4	70.5	18.8	17	
Eastern Heights Elementary School	1304 COMPUTER LAB	1/20/2023	10:13:00 AM	476	0.2	71.1	19.7	0	Plants
Eastern Heights Elementary School	1313 MAINTENANCE OFFICE	1/20/2023	9:22:00 AM	685	0.6	73.6	22.8	2	
Eastern Heights Elementary School	1403 MEDIA CENTER	1/20/2023	9:58:00 AM	445	0.3	69.6	19.2	3	Stained ceiling tiles
Eastern Heights Elementary School	1404 OFFICE	1/20/2023	9:56:00 AM	465	0.3	70.2	19.3	0	
Eastern Heights Elementary School	2305 OFFICE	1/20/2023	10:27:00 AM	499	0.3	69.4	20.1	0	
Eastern Heights Elementary School	2306 OFFICE	1/20/2023	10:38:00 AM	455	0.5	70.9	18.8	0	Plants
Eastern Heights Elementary School	3101 GYM	1/20/2023	10:44:00 AM	590	0.3	69.4	22.8	0	
Eastern Heights Elementary School	3103 OFFICE	1/20/2023	10:42:00 AM	561	0.4	70.2	21.4	1	
Eastern Heights Elementary School	3104 OFFICE	1/20/2023	10:49:00 AM	542	0.4	68.9	23.7	0	
Eastern Heights Elementary School	3105 OFFICE	1/20/2023	10:48:00 AM	730	0.3	68.7	23.8	0	
Eastern Heights Elementary School	3107 OFFICE	1/20/2023	10:47:00 AM	617	0.3	69.1	22.8	1	
Eastern Heights Elementary School	4301 OFFICE	1/20/2023	10:50:00 AM	713	0.3	69.3	22.9	0	
Eastern Heights Elementary School	OUTDOORS	1/20/2023		422	0.3	30	62		
Education & Operations Services	1052	12/14/2022	10:27:00 AM	444	0.3	70.2	30.9	1	
Education & Operations Services	1054	12/14/2022	10:20:00 AM	449	0.1	69.4	37.1	1	Stained ceiling tiles
Education & Operations Services	1101	12/14/2022	9:21:00 AM	630	0.3	71.2	29.5	5	
Education & Operations Services	1102	12/14/2022	9:44:00 AM	431	0.3	72.1	27.5	0	
Education & Operations Services	1103	12/14/2022	1:06:00 PM	601	0.3	72	29.9	2	
Education & Operations Services	1104	12/14/2022	1:04:00 PM	945	0.3	71.2	33.7	24	
Education & Operations Services	1105	12/14/2022	10:04:00 AM	440	0.1	70.5	27.9	0	
Education & Operations Services	1116	12/14/2022	10:25:00 AM	474	0.2	72.3	29.7	1	Stained ceiling tiles
Education & Operations Services	1121	12/14/2022	9:45:00 AM	416	0.3	71.4	26.7	0	
Education & Operations Services	1123	12/14/2022	9:36:00 AM	472	0.2	70.9	26.7	0	
Education & Operations Services	1124	12/14/2022	9:33:00 AM	464	0.2	70.7	26.8	0	
Education & Operations Services	1125	12/14/2022	9:32:00 AM	505	0.2	70.7	27	0	
Education & Operations Services	1126	12/14/2022	9:30:00 AM	512	0.2	70.5	27.5	0	Plants: Kept Away From Return And Supply Vents
Education & Operations Services	1127	12/14/2022	9:37:00 AM	454	0.2	71.1	26.6	0	
Education & Operations Services	1128	12/14/2022	9:35:00 AM	437	0.2	71.1	26.5	0	
Education & Operations Services	1129	12/14/2022	9:42:00 AM	808	0.3	72.3	28.3	1	
Education & Operations Services	1130	12/14/2022	9:31:00 AM	433	0.2	70.9	26.3	0	
Education & Operations Services	1131	12/14/2022	9:39:00 AM	771	0.3	71.4	29.7	1	
Education & Operations Services	1132	12/14/2022	9:28:00 AM	582	0.2	70.2	30.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Education & Operations Services	1133	12/14/2022	9:27:00 AM	490	0.2	69.8	27.9	0	
Education & Operations Services	1134	12/14/2022	9:25:00 AM	433	0.2	70.2	27.2	0	
Education & Operations Services	1140	12/14/2022	9:22:00 AM	551	0.3	70.9	28.1	2	
Education & Operations Services	1144	12/14/2022	10:01:00 AM	428	0.1	70.7	27.2	0	
Education & Operations Services	1145	12/14/2022	10:02:00 AM	422	0.1	70.5	27.4	0	
Education & Operations Services	1405	12/14/2022	10:06:00 AM	407	0.2	69.6	27.9	0	Stained ceiling tiles
Education & Operations Services	1409	12/14/2022	10:09:00 AM	408	0.1	68.5	29.3	0	
Education & Operations Services	1502	12/14/2022	12:16:00 PM	878	10.3	71.8	30.7	1	
Education & Operations Services	1503	12/14/2022	12:14:00 PM	467	6.5	70.3	29.9	0	
Education & Operations Services	1612	12/14/2022	11:04:00 AM	486	0.5	71.1	26.4	0	
Education & Operations Services	1616	12/14/2022	12:53:00 PM	547	1.1	70.3	28	1	
Education & Operations Services	1617	12/14/2022	12:56:00 PM	564	1	69.4	28.8	0	
Education & Operations Services	1618	12/14/2022	12:59:00 PM	552	1.2	70.2	28.1	0	
Education & Operations Services	1620	12/14/2022	11:31:00 AM	493	0.6	71.2	26.9	0	
Education & Operations Services	1621	12/14/2022	11:35:00 AM	500	0.6	69.3	28	0	
Education & Operations Services	1622	12/14/2022	11:39:00 AM	587	1.5	69.6	30.4	1	
Education & Operations Services	1624	12/14/2022	11:41:00 AM	606	1.5	69.8	32.4	1	
Education & Operations Services	1638	12/14/2022	11:46:00 AM	587	0.6	72.3	25.3	0	
Education & Operations Services	1639	12/14/2022	10:47:00 AM	643	0.3	72.7	28.1	10	
Education & Operations Services	1641	12/14/2022	10:56:00 AM	612	0.3	69.8	29.2	3	
Education & Operations Services	1642	12/14/2022	12:27:00 PM	645	0.3	71.4	29.4	2	
Education & Operations Services	1644	12/14/2022	10:48:00 AM	635	0.3	72.5	27.9	2	
Education & Operations Services	1645	12/14/2022	10:49:00 AM	563	0.3	72.1	27	0	
Education & Operations Services	1647	12/14/2022	10:51:00 AM	628	0.3	71.4	28.5	1	
Education & Operations Services	1648	12/14/2022	10:53:00 AM	558	0.3	70.7	28.2	0	
Education & Operations Services	1649	12/14/2022	12:50:00 PM	559	0.4	70	29.4	0	
Education & Operations Services	1656	12/14/2022	10:58:00 AM	610	0.2	70.2	29.7	0	
Education & Operations Services	1658	12/14/2022	11:01:00 AM	801	0.3	71.6	30.4	8	
Education & Operations Services	1660	12/14/2022	10:31:00 AM	585	0.2	70.2	29.1	3	
Education & Operations Services	1663	12/14/2022	10:33:00 AM	576	0.2	70.7	28.3	0	
Education & Operations Services	1664	12/14/2022	10:34:00 AM	674	0.3	72.9	28.1	1	
Education & Operations Services	1664	12/14/2022	11:37:00 AM	501	0.6	69.3	28.1	0	
Education & Operations Services	2101	12/14/2022	8:43:00 AM	445	0.1	70.2	29.2	0	
Education & Operations Services	2104	12/14/2022	8:45:00 AM	433	0.3	69.3	27.8	0	
Education & Operations Services	2105	12/14/2022	8:47:00 AM	462	0.3	69.6	27.9	0	
Education & Operations Services	2107	12/14/2022	8:50:00 AM	457	0.3	71.8	26	0	
Education & Operations Services	2108	12/14/2022	9:18:00 AM	521	0.3	72.1	26.6	0	
Education & Operations Services	2109	12/14/2022	9:11:00 AM	592	0.3	70.9	27.5	0	
Education & Operations Services	2110	12/14/2022	9:59:00 AM	1026	0.3	70.7	30.7	2	
Education & Operations Services	2111	12/14/2022	9:10:00 AM	507	0.3	71.1	26.9	0	
Education & Operations Services	2112	12/14/2022	9:09:00 AM	695	0.3	71.4	30.7	1	
Education & Operations Services	2117	12/14/2022	8:48:00 AM	502	0.3	70.5	27.7	1	
Education & Operations Services	2119	12/14/2022	8:49:00 AM	471	0.3	71.2	26.5	0	
Education & Operations Services	2120	12/14/2022	8:52:00 AM	441	0.3	72.1	25.2	0	
Education & Operations Services	2121	12/14/2022	8:53:00 AM	459	0.3	72.1	25.9	0	
Education & Operations Services	2122	12/14/2022	8:54:00 AM	539	0.3	72.1	28	1	
Education & Operations Services	2124	12/14/2022	8:56:00 AM	460	0.3	71.2	26.3	0	
Education & Operations Services	2202	12/14/2022	1:09:00 PM	559	0.3	71.8	27.2	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Education & Operations Services	2203	12/14/2022	1:10:00 PM	558	0.3	72.1	27.1	0	
Education & Operations Services	2204	12/14/2022	1:12:00 PM	547	0.3	72.1	26.6	0	
Education & Operations Services	2205	12/14/2022	9:05:00 AM	449	0.3	71.6	26	0	
Education & Operations Services	2206	12/14/2022	1:13:00 PM	808	0.3	72.5	30.1	1	
Education & Operations Services	1100B BY VENDING	12/14/2022	10:03:00 AM	448	0.1	70.3	27.9	0	
Education & Operations Services	1114A	12/14/2022	10:24:00 AM	559	0.1	72.1	30.6	1	
Education & Operations Services	1116B	12/14/2022	10:22:00 AM	445	0.1	71.8	29.7	0	Stained ceiling tiles
Education & Operations Services	1140 S HALF	12/14/2022	9:24:00 AM	514	0.2	70.5	27.8	4	
Education & Operations Services	1404 NE	12/14/2022	10:13:00 AM	408	0.1	69.6	27.9	0	
Education & Operations Services	1404 WEST	12/14/2022	10:11:00 AM	402	0.1	68.9	28.2	0	
Education & Operations Services	1404A	12/14/2022	10:15:00 AM	404	0.1	69.4	27.8	0	
Education & Operations Services	1506B	12/14/2022	12:07:00 PM	575	1	71.4	31	4	
Education & Operations Services	1508B	12/14/2022	12:10:00 PM	521	0.4	71.6	31.3	2	
Education & Operations Services	1605 EAST	12/14/2022	11:15:00 AM	485	0.5	71.2	26.6	1	
Education & Operations Services	1605 WEST	12/14/2022	11:13:00 AM	504	0.5	71.1	26.8	0	
Education & Operations Services	1605A	12/14/2022	11:12:00 AM	555	0.5	71.2	27.2	2	
Education & Operations Services	1607A	12/14/2022	12:48:00 PM	521	1	70.5	27.5	0	
Education & Operations Services	1609 EAST	12/14/2022	11:25:00 AM	512	0.7	71.4	26.5	1	
Education & Operations Services	1609 WEST	12/14/2022	11:23:00 AM	515	0.6	73	25	2	
Education & Operations Services	1609A	12/14/2022	11:21:00 AM	572	0.6	73.8	37.9	1	
Education & Operations Services	1609B	12/14/2022	11:28:00 AM	576	0.6	72.1	26	0	
Education & Operations Services	1609C	12/14/2022	11:26:00 AM	504	0.6	71.2	26.4	0	
Education & Operations Services	1611A	12/14/2022	11:51:00 AM	936	0.9	71.6	31.7	2	
Education & Operations Services	1612A	12/14/2022	11:10:00 AM	596	0.5	71.4	27.3	1	
Education & Operations Services	1613A	12/14/2022	12:46:00 PM	535	0.9	69.6	29.1	0	
Education & Operations Services	1613B	12/14/2022	11:07:00 AM	514	0.5	71.6	26.7	0	Stained ceiling tiles
Education & Operations Services	1620A	12/14/2022	11:33:00 AM	507	0.6	69.8	29.1	1	
Education & Operations Services	1649A	12/14/2022	10:58:00 AM	575	0.2	70.3	28.6	1	
Education & Operations Services	2100 NE CORNER	12/14/2022	9:16:00 AM	561	0.3	71.8	27.2	3	
Education & Operations Services	2100 NW CORNER	12/14/2022	9:17:00 AM	476	0.3	71.8	26.3	2	
Education & Operations Services	2100 SE CORNER	12/14/2022	9:14:00 AM	562	0.2	71.4	28.4	8	
Education & Operations Services	2100 SW CORNER	12/14/2022	9:13:00 AM	557	0.3	71.1	27.6	3	
Education & Operations Services	2200 NE CORNER	12/14/2022	9:01:00 AM	483	0.3	71.2	26.9	1	
Education & Operations Services	2200 NW CORNER	12/14/2022	9:00:00 AM	492	0.3	71.4	27	6	
Education & Operations Services	2200 SE CORNER	12/14/2022	9:03:00 AM	465	0.3	71.6	26.3	1	
Education & Operations Services	2200 SW CORNER	12/14/2022	9:07:00 AM	491	0.3	71.6	26.4	1	
Education & Operations Services	KITCHEN CENTER	12/14/2022	12:03:00 PM	562	0.5	70.5	31.5	3	
Education & Operations Services	KITCHEN EAST	12/14/2022	12:04:00 PM	606	0.4	70.9	31.2	3	
Education & Operations Services	KITCHEN NORTH	12/14/2022	12:09:00 PM	456	0.4	71.2	36.6	4	
Education & Operations Services	KITCHEN NW CORNER	12/14/2022	11:59:00 AM	452	0.7	69.6	31.4	2	
Education & Operations Services	KITCHEN SW CORNER	12/14/2022	12:02:00 PM	465	0.6	70.3	33.1	2	
Education & Operations Services	OUTDOORS	12/14/2022		394	0.5	35	92		
E-STEM Middle School	1012	2/9/2023	11:00:00 AM	651	0.1	70.5	24.7	0	
E-STEM Middle School	1024	2/9/2023	10:31:00 AM	490	0.4	71.2	22.2	0	Taxidermy
E-STEM Middle School	1038	2/9/2023	10:27:00 AM	64	0.6	71.4	22.9	5	
E-STEM Middle School	1044	2/9/2023	11:39:00 AM	589	0.3	69.8	24.5	0	
E-STEM Middle School	1046	2/9/2023	11:28:00 AM	565	0.3	70	23.7	0	
E-STEM Middle School	1048	2/9/2023	11:29:00 AM	994	0.3	70.5	26.7	6	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
E-STEM Middle School	1050	2/9/2023	11:31:00 AM	585	0.3	69.9	24.1	0	
E-STEM Middle School	1052	2/9/2023	11:32:00 AM	598	0.3	6.4	24.1	0	
E-STEM Middle School	1053	2/9/2023	11:34:00 AM	737	0.3	69.4	25.3	2	
E-STEM Middle School	1054	2/9/2023	11:33:00 AM	583	0.3	69.4	24.3	0	
E-STEM Middle School	1100	2/9/2023	11:16:00 AM	717	0.3	69.8	25.4	0	
E-STEM Middle School	1106	2/9/2023	11:21:00 AM	655	0.3	70.1	24.2	0	
E-STEM Middle School	1108	2/9/2023	11:20:00 AM	1034	0.3	70.2	29.9	28	
E-STEM Middle School	1109	2/9/2023	11:19:00 AM	632	0.3	69.6	23.9	0	
E-STEM Middle School	1200	2/9/2023	11:14:00 AM	727	0.3	69.8	28.3	0	
E-STEM Middle School	1206	2/9/2023	11:10:00 AM	674	0.3	70.3	24.1	2	
E-STEM Middle School	1300	2/9/2023	10:48:00 AM	694	0.3	70	24.4	0	
E-STEM Middle School	1306	2/9/2023	10:49:00 AM	669	0.3	69.8	24.5	0	
E-STEM Middle School	1306	2/9/2023	10:51:00 AM	668	0.3	69.4	24.3	0	
E-STEM Middle School	1400	2/9/2023	10:34:00 AM	696	0.4	70.2	23.9	0	
E-STEM Middle School	1406	2/9/2023	10:41:00 AM	605	0.3	71.8	22.5	0	
E-STEM Middle School	1409	2/9/2023	10:40:00 AM	812	0.4	70.9	25.3	25	Stained ceiling tiles
E-STEM Middle School	1500	2/9/2023	10:21:00 AM	584	0.4	70	23.2	2	
E-STEM Middle School	1506	2/9/2023	10:24:00 AM	739	0.4	70.3	24.8	4	
E-STEM Middle School	1508	2/9/2023	10:25:00 AM	658	0.4	70	23.9	1	
E-STEM Middle School	1509	2/9/2023	10:22:00 AM	581	0.4	69.8	23.2	0	
E-STEM Middle School	1600	2/9/2023	10:17:00 AM	722	0.4	69.8	24.7	3	
E-STEM Middle School	1606	2/9/2023	10:15:00 AM	593	0.4	70	23.1	1	
E-STEM Middle School	1710	2/9/2023	10:07:00 AM	509	0.4	69.6	22.7	0	
E-STEM Middle School	1714	2/9/2023	10:04:00 AM	622	0.4	68.4	26.1	1	
E-STEM Middle School	2006	2/9/2023	12:40:00 PM	643	0.3	70.6	28.5	0	
E-STEM Middle School	2024	2/9/2023	11:45:00 AM	644	0.3	71.1	23.8	0	
E-STEM Middle School	2040	2/9/2023	11:44:00 AM	633	0.3	71.2	25.2	0	
E-STEM Middle School	2044	2/9/2023	11:43:00 AM	630	0.3	71.1	23.7	2	
E-STEM Middle School	2053	2/9/2023	11:39:00 AM	633	0.3	70.3	24.2	13	
E-STEM Middle School	2101	2/9/2023	12:37:00 PM	643	0.3	70.2	25.8	0	
E-STEM Middle School	2106	2/9/2023	12:38:00 PM	765	0.3	70.7	25.3	5	
E-STEM Middle School	2201	2/9/2023	12:22:00 PM	811	0.3	70	25.5	1	
E-STEM Middle School	2206	2/9/2023	12:33:00 PM	825	0.3	70.2	27.2	0	
E-STEM Middle School	2301	2/9/2023	12:21:00 PM	613	0.3	70.6	25.6	0	
E-STEM Middle School	2308	2/9/2023	12:14:00 PM	1044	0.3	70.5	28.5	27	
E-STEM Middle School	2308	2/9/2023	12:16:00 PM	599	0.3	70.2	25.4	0	
E-STEM Middle School	2401	2/9/2023	12:04:00 PM	589	0.3	70.7	23.2	0	
E-STEM Middle School	2406	2/9/2023	12:11:00 PM	592	0.3	70.3	24.6	0	
E-STEM Middle School	2501	2/9/2023	11:57:00 AM	882	0.3	71.4	26	1	
E-STEM Middle School	2506	2/9/2023	12:03:00 PM	605	0.3	70.5	23.7	0	
E-STEM Middle School	2515	2/9/2023	12:00:00 PM	759	0.3	70.3	24.2	2	
E-STEM Middle School	2601	2/9/2023	11:52:00 AM	587	0.3	70.9	22.9	0	
E-STEM Middle School	2606	2/9/2023	11:54:00 AM	550	0.2	70.7	23.3	0	
E-STEM Middle School	2608	2/9/2023	11:55:00 AM	926	0.3	71.2	27.9	31	
E-STEM Middle School	1042 OFFICE	2/9/2023	10:28:00 AM	580	0.4	71.6	23.2	1	
E-STEM Middle School	1043 MAIN OFFICE	2/9/2023	11:26:00 AM	615	0.3	69.8	24.2	2	
E-STEM Middle School	1070 NURSE	2/9/2023	11:37:00 AM	637	0.3	69.8	24.7	4	
E-STEM Middle School	1072 NURSE OFFICE	2/9/2023	11:38:00 AM	593	0.3	69.8	23.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
E-STEM Middle School	1102/1104	2/9/2023	11:17:00 AM	882	0.3	69.8	26.3	26	
E-STEM Middle School	1201/1101	2/9/2023	11:12:00 AM	736	0.3	70.2	24.9	2	
E-STEM Middle School	1210/1208	2/9/2023	11:07:00 AM	769	0.3	70.2	25	1	Plants
E-STEM Middle School	1308/1310	2/9/2023	10:52:00 AM	692	0.3	69.4	24.7	23	
E-STEM Middle School	1310/1308	2/9/2023	11:11:00 AM	768	0.3	70.3	25	0	
E-STEM Middle School	1401/1301	2/9/2023	10:46:00 AM	698	0.4	70.7	23.9	0	
E-STEM Middle School	1404/1402	2/9/2023	10:43:00 AM	685	0.4	71.2	23.5	26	
E-STEM Middle School	1502/1504	2/9/2023	10:20:00 AM	620	0.4	70	24.1	7	
E-STEM Middle School	1601/1501	2/9/2023	10:18:00 AM	677	0.4	69.6	24.9	3	
E-STEM Middle School	1604/1602	2/9/2023	10:16:00 AM	711	0.5	69.8	24.3	29	
E-STEM Middle School	1610/1608	2/9/2023	10:11:00 AM	785	0.5	70	24.8	25	
E-STEM Middle School	1804 OFFICE	2/9/2023	10:10:00 AM	593	0.4	70.9	23	0	
E-STEM Middle School	2102/2104	2/9/2023	12:38:00 PM	861	0.3	70.5	28.8	28	
E-STEM Middle School	2202/2204	2/9/2023	12:31:00 PM	758	0.3	70.2	26.7	33	
E-STEM Middle School	2208A	2/9/2023	12:34:00 PM	715	0.3	70.3	25.5	0	
E-STEM Middle School	2210/2108	2/9/2023	12:35:00 PM	785	0.2	70.9	25.5	29	Stained ceiling tiles
E-STEM Middle School	2304/2302	2/9/2023	12:18:00 PM	753	0.3	70.2	26.3	26	
E-STEM Middle School	2402/2402	2/9/2023	12:09:00 PM	734	0.3	70.3	25	29	
E-STEM Middle School	2408/2410	2/9/2023	12:12:00 PM	614	0.3	70	24.1	0	
E-STEM Middle School	2503/2504	2/9/2023	12:01:00 PM	587	0.3	70.2	23.6	0	
E-STEM Middle School	2510/2508	2/9/2023	11:59:00 AM	625	0.3	71.4	23.3	6	
E-STEM Middle School	2604/2602	2/9/2023	11:54:00 AM	734	0.3	70.7	24.9	23	
E-STEM Middle School	CAFETERIA 1042	2/9/2023	10:32:00 AM	621	0.4	71.1	24.1	165	
E-STEM Middle School	GYMNASIUM 1800	2/9/2023	10:07:00 AM	939	0.3	69.3	28.6	60	
E-STEM Middle School	OUTDOORS	2/9/2023		442	0.5	29	88		
EXPO Magnet	101	11/22/2022	9:33:00 AM	582	0.2	70.3	19.9	0	
EXPO Magnet	102	11/22/2022	9:37:00 AM	570	0.2	70	20.3	0	
EXPO Magnet	103	11/22/2022	9:39:00 AM	856	0.2	70	23	11	Stained ceiling tiles
EXPO Magnet	104	11/22/2022	9:42:00 AM	815	0.3	71.8	23.6	17	
EXPO Magnet	105	11/22/2022	9:47:00 AM	776	0.3	72.9	19.9	14	
EXPO Magnet	106	11/22/2022	9:49:00 AM	1012	0.3	72	20.8	16	
EXPO Magnet	107	11/22/2022	9:52:00 AM	703	0.3	71.4	21.3	25	
EXPO Magnet	108	11/22/2022	9:57:00 AM	757	0.1	71.6	20.8	24	
EXPO Magnet	109	11/22/2022	10:00:00 AM	554	0.1	70.3	18.9	0	Plants
EXPO Magnet	117	11/22/2022	9:24:00 AM	621	0.3	74.5	18.5	1	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	121	11/22/2022	9:27:00 AM	563	0.2	69.8	19.3	0	
EXPO Magnet	201	11/22/2022	10:37:00 AM	918	0.3	71.1	24.4	95	
EXPO Magnet	1003	11/22/2022	10:52:00 AM	608	0.2	68.9	21.7	0	
EXPO Magnet	1004	11/22/2022	10:54:00 AM	633	0.1	68.4	22.2	1	Plants
EXPO Magnet	1005	11/22/2022	10:56:00 AM	666	0.1	68.9	22.5	1	
EXPO Magnet	1006	11/22/2022	10:58:00 AM	594	0.1	69.3	21.2	0	
EXPO Magnet	1007	11/22/2022	11:02:00 AM	1193	0.2	70.2	25.9	4	
EXPO Magnet	1008	11/22/2022	10:50:00 AM	646	0.1	69.8	22.4	0	
EXPO Magnet	1102	11/22/2022	11:08:00 AM	592	0.2	70.2	20.5	0	Crayons odor
EXPO Magnet	1103	11/22/2022	11:22:00 AM	663	0.2	69.6	21.5	6	
EXPO Magnet	1104	11/22/2022	11:28:00 AM	520	0.1	70.7	18.9	0	Stained ceiling tiles
EXPO Magnet	1105	11/22/2022	11:31:00 AM	629	0.2	70.5	20.4	3	
EXPO Magnet	1106	11/22/2022	11:33:00 AM	589	0.2	70.2	19.8	9	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
EXPO Magnet	1107	11/22/2022	11:37:00 AM	621	0.1	70.3	20.7	7	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	1108	11/22/2022	11:38:00 AM	566	0.1	70	20.1	3	
EXPO Magnet	1110	11/22/2022	10:04:00 AM	704	0.1	70.7	20.9	5	
EXPO Magnet	1111	11/22/2022	10:10:00 AM	809	0.2	71.6	21.4	17	
EXPO Magnet	1112	11/22/2022	10:12:00 AM	617	0.2	71.4	19.6	2	
EXPO Magnet	1113	11/22/2022	10:16:00 AM	785	0.2	72.5	20.5	11	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	1114	11/22/2022	10:18:00 AM	761	0.2	72	21.3	17	Stained ceiling tiles
EXPO Magnet	1115	11/22/2022	10:20:00 AM	936	0.2	71.4	21.9	23	Stained ceiling tiles
EXPO Magnet	1116	11/22/2022	10:22:00 AM	681	0.2	70.2	20.2	3	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	1117	11/22/2022	10:25:00 AM	820	0.2	70.2	23.4	24	
EXPO Magnet	1202	11/22/2022	11:34:00 AM	711	0.2	70.3	21.3	4	Stained ceiling tiles
EXPO Magnet	1205	11/22/2022	11:16:00 AM	851	0.2	70.9	23.2	1	Stained ceiling tiles
EXPO Magnet	1206	11/22/2022	10:30:00 AM	800	0.2	71.2	23.1	23	
EXPO Magnet	1309	11/22/2022	11:19:00 AM	828	0.3	70.3	23.7	0	
EXPO Magnet	2102	11/22/2022	12:49:00 PM	720	0.2	70.5	21.6	15	
EXPO Magnet	2103	11/22/2022	12:53:00 PM	802	0.1	70	23.2	20	
EXPO Magnet	2104	11/22/2022	12:55:00 PM	937	0.2	70.3	25.2	26	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2105	11/22/2022	12:58:00 PM	565	0.2	70.2	20.2	16	
EXPO Magnet	2106	11/22/2022	1:03:00 PM	511	0.1	70.2	20.1	1	
EXPO Magnet	2106	11/22/2022	1:05:00 PM	510	0.1	70.2	19.9	1	
EXPO Magnet	2108	11/22/2022	11:54:00 AM	913	0.2	70.2	23.3	25	
EXPO Magnet	2109	11/22/2022	11:55:00 AM	904	0.2	70.2	23.7	22	
EXPO Magnet	2110	11/22/2022	11:57:00 AM	944	0.2	70.5	24.3	25	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2111	11/22/2022	12:09:00 PM	559	0.2	70.2	21.2	0	
EXPO Magnet	2112	11/22/2022	12:03:00 PM	671	0.2	70.7	21.4	5	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2113	11/22/2022	12:05:00 PM	616	0.2	70.5	20.9	0	
EXPO Magnet	2114	11/22/2022	12:00:00 PM	561	0.2	70.7	20.9	1	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2115	11/22/2022	12:17:00 PM	662	0.2	70.3	23.6	23	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2116	11/22/2022	12:19:00 PM	682	0.1	70.5	22.6	16	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2119	11/22/2022	12:30:00 PM	691	0.2	70.2	23	26	
EXPO Magnet	2120	11/22/2022	12:41:00 PM	475	0.2	70.9	19.3	0	
EXPO Magnet	2121	11/22/2022	12:46:00 PM	736	0.1	70.7	22.8	16	Plants: Kept Away From Return And Supply Vents
EXPO Magnet	2206	11/22/2022	12:34:00 PM	692	0.1	71.4	22.2	2	Stained ceiling tiles
EXPO Magnet	2207	11/22/2022	12:36:00 PM	670	0.3	71.6	20.6	1	
EXPO Magnet	2208	11/22/2022	12:42:00 PM	488	0.1	70.5	19.5	0	
EXPO Magnet	0202 KITCHEN	11/22/2022	10:40:00 AM	667	0.2	70.9	20.9	2	
EXPO Magnet	0205 KITCHEN OFFICE	11/22/2022	10:41:00 AM	643	0.2	70.7	20.7	0	
EXPO Magnet	1001 MAIN OFFICE	11/22/2022	10:47:00 AM	623	0.2	69.3	21	1	
EXPO Magnet	1101 NURSE	11/22/2022	11:04:00 AM	728	0.2	70.2	21.6	3	
EXPO Magnet	1101A NURSES OFFICE	11/22/2022	11:06:00 AM	688	0.2	70	22.3	0	Stained ceiling tiles
EXPO Magnet	1201 GYM	11/22/2022	11:11:00 AM	800	0.2	70	23.9	16	
EXPO Magnet	2102B	11/22/2022	12:51:00 PM	750	0.1	70	22.1	6	
EXPO Magnet	2117A	11/22/2022	12:21:00 PM	551	0.2	69.6	21.1	0	
EXPO Magnet	2117B	11/22/2022	12:26:00 PM	513	0.1	69.8	20.4	0	
EXPO Magnet	OUTDOORS	11/22/2022		407	0.3	37	57		
Farnsworth Aerospace Lower	1001	3/2/2023	12:36:00 PM	707		71.9	25.7	3	
Farnsworth Aerospace Lower	1002	3/2/2023	12:39:00 PM	639		71.9	24.7	0	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Farnsworth Aerospace Lower	1003	3/2/2023	12:43:00 PM	649		71.5	24.5	1	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1005	3/2/2023	12:40:00 PM	716		72.1	26.8	3	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1005	3/2/2023	12:42:00 PM	667		71.9	25.6	0	
Farnsworth Aerospace Lower	1101	3/2/2023	12:45:00 PM	615		70.7	25.3	22	Fragrance odor, Bubbling/peeling paint
Farnsworth Aerospace Lower	1102	3/2/2023	12:49:00 PM	646		69.9	26.2	2	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1103	3/2/2023	12:50:00 PM	898		70.4	29.1	24	
Farnsworth Aerospace Lower	1104	3/2/2023	12:52:00 PM	624		70.8	25.7	0	Essential oil odor, Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1105	3/2/2023	12:56:00 PM	894		70.6	28.7	23	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1201	3/2/2023	12:58:00 PM	722		70.1	27.7	0	
Farnsworth Aerospace Lower	1202	3/2/2023	1:01:00 PM	933		71	29.8	1	
Farnsworth Aerospace Lower	1204	3/2/2023	12:35:00 PM	802		71.3	26.3	1	
Farnsworth Aerospace Lower	1205	3/2/2023	12:31:00 PM	635		69.4	26.9	0	
Farnsworth Aerospace Lower	1206	3/2/2023	12:26:00 PM	779		69.9	28.3	7	Stained ceiling tiles
Farnsworth Aerospace Lower	1207	3/2/2023	12:28:00 PM	878		69.7	31.2	19	
Farnsworth Aerospace Lower	1208	3/2/2023	12:32:00 PM	662		70.5	26.1	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1302	3/2/2023	12:23:00 PM	674		67.2	29.9	1	
Farnsworth Aerospace Lower	2101	3/2/2023	1:37:00 PM	872		71.5	28.5	24	Plants
Farnsworth Aerospace Lower	2102	3/2/2023	1:39:00 PM	843		70.6	28.6	20	
Farnsworth Aerospace Lower	2103	3/2/2023	1:44:00 PM	716		71.4	26.2	24	Bubbling/peeling paint, Plants
Farnsworth Aerospace Lower	2104	3/2/2023	2:44:00 PM	734		70.1	27.1	0	
Farnsworth Aerospace Lower	2105	3/2/2023	1:41:00 PM	738		70.8	26.2	0	Bubbling/peeling paint, Plants, Taxidermy
Farnsworth Aerospace Lower	2201	3/2/2023	1:15:00 PM	779		71.6	27.6	2	
Farnsworth Aerospace Lower	2203	3/2/2023	1:16:00 PM	708		72.7	24.9	7	
Farnsworth Aerospace Lower	2204	3/2/2023	1:19:00 PM	888		72.6	29.6	17	Plants
Farnsworth Aerospace Lower	2205	3/2/2023	1:21:00 PM	761		72.4	24.8	2	Stained ceiling tiles
Farnsworth Aerospace Lower	2206	3/2/2023	1:22:00 PM	706		72.3	25.1	5	Plants
Farnsworth Aerospace Lower	2208	3/2/2023	1:26:00 PM	793		72.1	28.3	21	
Farnsworth Aerospace Lower	2209	3/2/2023	1:28:00 PM	649		71.2	24.5	0	Essential oil odor
Farnsworth Aerospace Lower	3101	3/2/2023	2:00:00 PM	663		69.3	26.6	5	Bubbling/peeling paint, Plants
Farnsworth Aerospace Lower	3102	3/2/2023	1:58:00 PM	679		69.3	26	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3103	3/2/2023	1:52:00 PM	832		70.1	28	19	Bubbling/peeling paint
Farnsworth Aerospace Lower	3104	3/2/2023	1:50:00 PM	697		69.9	26	3	Bubbling/peeling paint
Farnsworth Aerospace Lower	3105	3/2/2023	1:54:00 PM	753	0.1	69.7	27.1	23	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3201	3/2/2023	2:05:00 PM	986		71.5	29.4	23	Stained ceiling tiles
Farnsworth Aerospace Lower	3203	3/2/2023	2:14:00 PM	1118		71	29.6	24	
Farnsworth Aerospace Lower	3204	3/2/2023	2:16:00 PM	803		70.6	27.3	15	
Farnsworth Aerospace Lower	3205	3/2/2023	2:18:00 PM	762		70.2	26.6	1	Stained ceiling tiles
Farnsworth Aerospace Lower	3206	3/2/2023	2:24:00 PM	579		70.6	25.7	0	
Farnsworth Aerospace Lower	3207	3/2/2023	2:20:00 PM	741		70.7	26.9	27	
Farnsworth Aerospace Lower	3208	3/2/2023	2:12:00 PM	998		70.4	30.9	15	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3209	3/2/2023	2:10:00 PM	721		78.5	27.4	0	
Farnsworth Aerospace Lower	3210	3/2/2023	2:06:00 PM	792		70	26.5	19	
Farnsworth Aerospace Lower	3211	3/2/2023	2:02:00 PM	786		70.4	28.4	5	
Farnsworth Aerospace Lower	1203A	3/2/2023	1:07:00 PM	863		71.8	31.9	1	
Farnsworth Aerospace Lower	1301A	3/2/2023	1:04:00 PM	1008		71.3	33.9	14	
Farnsworth Aerospace Lower	1301B	3/2/2023	1:01:00 PM	1068		71.2	36.2	40	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Farnsworth Aerospace Lower	3299 STAIRWELL GROUP AREA	3/2/2023	1:47:00 PM	876		70.2	28.4	7	
Farnsworth Aerospace Lower	KITCHEN	3/2/2023	1:09:00 PM	656		70.4	29.8	4	
Farnsworth Aerospace Lower	OUTDOORS	3/2/2023		500	1.2	37	82		
Farnsworth Aerospace Lower	OUTDOORS	3/2/2023		515	0.2	39	52		
Farnsworth Aerospace Lower	RETAKE ROOM 2206	3/2/2023	1:55:00 PM	717		69.8	27.4	24	
Farnsworth Aerospace Lower	RETAKE ROOM 3102	3/2/2023	1:58:00 PM	721		70.8	22.5	21	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	RETEST ROOM 2101	3/2/2023	1:03:00 PM	891		72.2	22.1	27	
Farnsworth Aerospace Lower	RETEST ROOM 3105	3/2/2023	1:47:00 PM	762		70.5	28.9	25	
Farnsworth Aerospace Upper	401	1/20/2023	1:22:00 PM	699	0.5	69.6	19.8	0	Stained ceiling tiles
Farnsworth Aerospace Upper	402	1/20/2023	1:26:00 PM	823	0.4	66.9	23.1	1	
Farnsworth Aerospace Upper	403	1/20/2023	1:25:00 PM	762	0.5	68	21.7	1	
Farnsworth Aerospace Upper	408	1/20/2023	1:18:00 PM	481	0.5	70.9	16.4	2	
Farnsworth Aerospace Upper	1000	1/20/2023	1:58:00 PM	671	0.5	71.8	18.6	1	
Farnsworth Aerospace Upper	1003	1/20/2023	2:02:00 PM	683	0.6	71.4	19.5	0	
Farnsworth Aerospace Upper	1005	1/20/2023	1:59:00 PM	705	0.5	71.6	18.4	0	
Farnsworth Aerospace Upper	1007	1/20/2023	1:53:00 PM	749	0.5	70.7	21.5	2	
Farnsworth Aerospace Upper	1008	1/20/2023	1:51:00 PM	595	0.6	71.2	20.5	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	1009	1/20/2023	1:49:00 PM	581	0.6	72	19.7	0	
Farnsworth Aerospace Upper	1010	1/20/2023	1:05:00 PM	910	0.7	74.8	22	2	
Farnsworth Aerospace Upper	1102	1/20/2023	1:10:00 PM	1327	0.8	75.6	26.8	65	
Farnsworth Aerospace Upper	1103	1/20/2023	1:28:00 PM	735	0.7	73.6	25	0	
Farnsworth Aerospace Upper	1105	1/20/2023	1:35:00 PM	572	0.6	73.8	20.3	0	
Farnsworth Aerospace Upper	1106	1/20/2023	1:39:00 PM	742	0.7	72	25.4	0	
Farnsworth Aerospace Upper	1203	1/20/2023	10:46:00 AM	591	0.5	70.5	19.7	0	
Farnsworth Aerospace Upper	1204	1/20/2023	2:01:00 PM	678	0.5	72.1	18.7	1	
Farnsworth Aerospace Upper	1204	1/20/2023	10:39:00 AM	563	0.3	68.4	20.1	1	
Farnsworth Aerospace Upper	1205	1/20/2023	10:52:00 AM	595	0.5	70.7	19.6	0	
Farnsworth Aerospace Upper	1303	1/20/2023	10:58:00 AM	735	0.5	72.3	19.5	4	
Farnsworth Aerospace Upper	1304	1/20/2023	10:54:00 AM	976	0.5	72.1	20.6	2	
Farnsworth Aerospace Upper	1305	1/20/2023	11:01:00 AM	921	0.5	72.9	20	3	
Farnsworth Aerospace Upper	1306	1/20/2023	11:02:00 AM	606	0.5	72.7	17.7	0	
Farnsworth Aerospace Upper	1307	1/20/2023	11:05:00 AM	579	0.6	72	17.8	1	
Farnsworth Aerospace Upper	1308	1/20/2023	11:09:00 AM	886	0.5	71.2	19.8	8	
Farnsworth Aerospace Upper	1309	1/20/2023	11:07:00 AM	655	0.5	71.2	18.4	4	
Farnsworth Aerospace Upper	1310	1/20/2023	11:14:00 AM	906	0.5	71.1	20.6	11	Musty odor
Farnsworth Aerospace Upper	1311	1/20/2023	11:10:00 AM	584	0.5	71.2	18.1	0	
Farnsworth Aerospace Upper	1312	1/20/2023	11:18:00 AM	1079	0.5	72	21.9	13	
Farnsworth Aerospace Upper	1313	1/20/2023	11:12:00 AM	683	0.57	71.1	19.1	1	
Farnsworth Aerospace Upper	1314	1/20/2023	11:19:00 AM	667	0.6	72.1	18.4	1	Stained ceiling tiles
Farnsworth Aerospace Upper	1315	1/20/2023	11:16:00 AM	919	0.5	71.2	21.6	8	
Farnsworth Aerospace Upper	1403	1/20/2023	11:27:00 AM	1015	0.4	71	19.3	22	
Farnsworth Aerospace Upper	1405	1/20/2023	11:32:00 AM	889	0.5	69.4	20.4	24	
Farnsworth Aerospace Upper	1407	1/20/2023	11:34:00 AM	926	0.5	70.3	20.2	30	Aquariums (fish)
Farnsworth Aerospace Upper	1409	1/20/2023	11:35:00 AM	932	0.5	70	21.1	26	
Farnsworth Aerospace Upper	1420	1/20/2023	11:22:00 AM	548	0.5	70.3	17.3	0	
Farnsworth Aerospace Upper	1422	1/20/2023	11:24:00 AM	540	0.5	70	17.9	0	
Farnsworth Aerospace Upper	2102	1/20/2023	12:11:00 PM	1264	0.5	71.4	25.1	24	
Farnsworth Aerospace Upper	2103	1/20/2023	12:06:00 PM	629	0.5	71.8	22.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Farnsworth Aerospace Upper	2104	1/20/2023	12:08:00 PM	516	0.6	70.3	19.4	0	
Farnsworth Aerospace Upper	2106	1/20/2023	12:10:00 PM	538	0.6	69.4	20.1	0	
Farnsworth Aerospace Upper	2202	1/20/2023	12:14:00 PM	775	0.6	73.2	19.3	3	
Farnsworth Aerospace Upper	2205	1/20/2023	12:23:00 PM	658	0.5	70.2	20.5	0	
Farnsworth Aerospace Upper	2206	1/20/2023	12:19:00 PM	698	0.5	69.8	31	17	
Farnsworth Aerospace Upper	2304	1/20/2023	12:02:00 PM	743	0.5	70.9	20.4	1	Taxidermy
Farnsworth Aerospace Upper	2305	1/20/2023	12:05:00 PM	656	0.5	70.7	19	0	
Farnsworth Aerospace Upper	2306	1/20/2023	11:59:00 AM	882	0.5	71.8	19.4	218	
Farnsworth Aerospace Upper	2307	1/20/2023	12:00:00 PM	655	0.5	71.1	21	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	2308	1/20/2023	11:53:00 AM	1106	0.5	70.5	24	15	
Farnsworth Aerospace Upper	2309	1/20/2023	11:56:00 AM	642	0.5	71.6	18.8	2	
Farnsworth Aerospace Upper	2310	1/20/2023	11:50:00 AM	663	0.5	69.8	20.4	1	
Farnsworth Aerospace Upper	2311	1/20/2023	11:52:00 AM	680	0.5	70.2	19.9	3	
Farnsworth Aerospace Upper	2312	1/20/2023	11:42:00 AM	1015	0.6	71.1	21.2	1	Taxidermy
Farnsworth Aerospace Upper	2313	1/20/2023	11:48:00 AM	1493	0.6	71.2	2.4	0	
Farnsworth Aerospace Upper	3103	1/20/2023	12:54:00 PM	816	0.7	74.3	21.3	0	Bubbling/peeling paint
Farnsworth Aerospace Upper	3104	1/20/2023	12:56:00 PM	595	0.7	73.6	17.3	0	
Farnsworth Aerospace Upper	3202	1/20/2023	12:57:00 PM	803	0.6	73	16.9	21	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	3303	1/20/2023	12:52:00 PM	736	0.5	72.3	19.4	0	
Farnsworth Aerospace Upper	3305	1/20/2023	12:48:00 PM	1014	0.6	71.2	23.2	0	
Farnsworth Aerospace Upper	3305	1/20/2023	1:44:00 PM	1087	0.6	72.9	24.2	26	
Farnsworth Aerospace Upper	3306	1/20/2023	12:50:00 PM	1172	0.6	71.6	23.8	25	
Farnsworth Aerospace Upper	3307	1/20/2023	12:44:00 PM	965	0.5	71.1	23.7	18	
Farnsworth Aerospace Upper	3308	1/20/2023	12:46:00 PM	1335	0.6	71.4	25.1	24	
Farnsworth Aerospace Upper	3309	1/20/2023	12:40:00 PM	1059	0.6	72.1	23.8	20	
Farnsworth Aerospace Upper	3310	1/20/2023	12:42:00 PM	1267	0.6	70.3	26	24	
Farnsworth Aerospace Upper	3312	1/20/2023	12:38:00 PM	718	0.5	70.5	20.3	0	
Farnsworth Aerospace Upper	3399	1/20/2023	12:34:00 PM	740	0.5	70.7	20	0	
Farnsworth Aerospace Upper	1006A	1/20/2023	1:54:00 PM	622	0.5	70.5	20.3	0	
Farnsworth Aerospace Upper	1204A	1/20/2023	10:44:00 AM	566	0.3	68.2	20.8	0	Fragrance odor
Farnsworth Aerospace Upper	1204B	1/20/2023	10:43:00 AM	548	0.4	67.5	20.6	0	
Farnsworth Aerospace Upper	1303B	1/20/2023	11:00:00 AM	778	0.5	72.5	19.8	1	
Farnsworth Aerospace Upper	1402B	1/20/2023	11:38:00 AM	657	0.5	69.4	18.1	0	Stained ceiling tiles
Farnsworth Aerospace Upper	1403A	1/20/2023	11:31:00 AM	770	0.5	69.8	19.2	0	
Farnsworth Aerospace Upper	2202B	1/20/2023	12:18:00 PM	806	0.6	73.4	19.7	6	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	2205A	1/20/2023	12:26:00 PM	853	0.5	71.2	21.3	0	Musty odor
Farnsworth Aerospace Upper	2206A	1/20/2023	12:16:00 PM	887	0.6	72.7	20	3	Stained ceiling tiles
Farnsworth Aerospace Upper	2207/253	1/20/2023	12:21:00 PM	671	0.6	71.1	20.2	1	
Farnsworth Aerospace Upper	3205B	1/20/2023	1:01:00 PM	965	0.5	72.7	26.9	1	Condensation
Farnsworth Aerospace Upper	406B	1/20/2023	1:17:00 PM	646	0.6	71.2	18.3	0	
Farnsworth Aerospace Upper	408C	1/20/2023	1:20:00 PM	473	0.5	71.1	17.2	0	
Farnsworth Aerospace Upper	D406	1/20/2023	1:12:00 PM	661	0.6	72	17.6	4	
Farnsworth Aerospace Upper	KITCHEN	1/20/2023	1:38:00 PM	643	0.7	72.5	24.4	6	
Farnsworth Aerospace Upper	OUTDOORS	1/20/2023		767	0.5	31.5	51.8		
Farnsworth Aerospace Upper		1/20/2023	1:56:00 PM						
Farnsworth Aerospace Upper		1/20/2023	12:28:00 PM						
Focus Beyond	1201	11/29/2022	12:36:00 PM	636	0.3	70.3	25.5	9	
Focus Beyond	1203	11/29/2022	12:38:00 PM	605	0.4	70.5	24.8	9	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Focus Beyond	1204	11/29/2022	12:41:00 PM	474	0.3	69.1	24.7	5	
Focus Beyond	1301	11/29/2022	12:59:00 PM	550	0.3	70.2	26.2	8	
Focus Beyond	1302	11/29/2022	1:00:00 PM	538	0.3	70.2	25.5	4	
Focus Beyond	1303	11/29/2022	1:01:00 PM	474	0.3	69.6	24.1	1	
Focus Beyond	1304	11/29/2022	1:03:00 PM	563	0.3	70.2	26.1	6	
Focus Beyond	1401	11/29/2022	1:07:00 PM	691	0.3	70.7	25	9	
Focus Beyond	1402	11/29/2022	1:09:00 PM	471	0.3	70.3	23.1	1	
Focus Beyond	1403	11/29/2022	1:10:00 PM	525	0.4	70	24.5	1	
Focus Beyond	1404	11/29/2022	1:14:00 PM	525	0.3	68.7	25.2	2	Food odor
Focus Beyond	1502	11/29/2022	1:30:00 PM	694	0.3	70.2	28.7	10	
Focus Beyond	1503	11/29/2022	1:24:00 PM	667	0.2	70.2	26.5	5	
Focus Beyond	1507	11/29/2022	1:26:00 PM	566	0.3	69.4	25.7	1	
Focus Beyond	1508	11/29/2022	1:32:00 PM	482	0.4	70.2	24.7	1	
Focus Beyond	1512	11/29/2022	1:34:00 PM	648	0.3	70.3	28.7	8	
Focus Beyond	1001BMAIN OFFICE	11/29/2022	12:48:00 PM	467	0.3	70.7	25	1	
Focus Beyond	1002 NURSE COT ROOM	11/29/2022	12:55:00 PM	498	0.3	70.9	24.3	0	
Focus Beyond	1003 NURSE OFFICE	11/29/2022	12:53:00 PM	502	0.3	71.6	25	1	
Focus Beyond	1004 CONFERENCE ROOM	11/29/2022	12:51:00 PM	571	0.3	70.7	25.5	0	
Focus Beyond	1005 PRINCIPLE	11/29/2022	12:50:00 PM	544	0.3	71.2	26.6	2	
Focus Beyond	1006 WORK ROOM	11/29/2022	12:45:00 PM	532	0.3	69.4	25.9	0	
Focus Beyond	1008 OFFICE	11/29/2022	12:43:00 PM	567	0.3	69.8	26	0	Stuffy odor
Focus Beyond	1009 OFFICE	11/29/2022	12:47:00 PM	630	0.3	70	27.4	2	
Focus Beyond	1101 DANCE	11/29/2022	12:33:00 PM	474	0.4	69.6	24.3	0	
Focus Beyond	1103 THEATER	11/29/2022	12:32:00 PM	632	0.4	69.3	29.6	3	
Focus Beyond	1104 ART	11/29/2022	12:29:00 PM	575	0.3	68.9	24.9	0	
Focus Beyond	1105 CAFETERIA	11/29/2022	12:21:00 PM	750	0.2	64.4	29.3	4	
Focus Beyond	1106 KITCHEN	11/29/2022	12:22:00 PM	915	1	67.6	29.1	2	
Focus Beyond	1106A KITCHEN OFFICE	11/29/2022	12:24:00 PM	882	1.5	68.4	28.6	0	
Focus Beyond	1200 GATHERING AREA	11/29/2022	12:34:00 PM	466	0.3	69.8	24.4	1	
Focus Beyond	1300 GATHERING AREA	11/29/2022	12:56:00 PM	561	0.3	70	25.1	1	
Focus Beyond	1400 GATHERING AREA	11/29/2022	1:06:00 PM	581	0.4	70	28.1	4	
Focus Beyond	1501 MUSIC	11/29/2022	1:16:00 PM	541	0.2	69.3	25.8	9	
Focus Beyond	1506 MEDIA CENTER	11/29/2022	1:28:00 PM	640	0.3	69.8	27.5	9	Plants
Focus Beyond	1507A	11/29/2022	1:27:00 PM	553	0.3	69.3	25.9	1	
Focus Beyond	1513 STAFF	11/29/2022	1:18:00 PM	492	0.3	70.2	25.9	0	
Focus Beyond	1603 AND 1602 TECH	11/29/2022	1:39:00 PM	486	0.3	69.8	25.6	2	
Focus Beyond	1604 OFFICE	11/29/2022	1:44:00 PM	890	0.3	70.2	25.9	1	
Focus Beyond	1605 OFFICE	11/29/2022	1:38:00 PM	579	0.3	70.3	25.9	1	
Focus Beyond	1606 STAFF LOUNGE	11/29/2022	1:37:00 PM	528	0.3	70.2	25.7	0	
Focus Beyond	OUTDOORS	11/29/2022		484	0.3	26	32.1		
Four Seasons A+ Elementary School	1102	2/14/2023	11:52:00 AM	599	0.5	70	30	2	
Four Seasons A+ Elementary School	1103	2/14/2023	11:48:00 AM	597	0.5	70.2	30.3	1	
Four Seasons A+ Elementary School	1104	2/14/2023	11:50:00 AM	615	0.5	70.3	29.9	1	
Four Seasons A+ Elementary School	1106	2/14/2023	11:46:00 AM	590	0.6	70.7	29.1	3	
Four Seasons A+ Elementary School	1301	2/14/2023	12:06:00 PM	539	0.5	70.2	28.7	0	
Four Seasons A+ Elementary School	1304	2/14/2023	12:12:00 PM	597	0.5	69.6	30	17	
Four Seasons A+ Elementary School	1309	2/14/2023	12:21:00 PM	684	0.5	70	29.1	4	
Four Seasons A+ Elementary School	1310	2/14/2023	12:16:00 PM	659	0.5	70	28	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Four Seasons A+ Elementary School	1311	2/14/2023	12:20:00 PM	646	0.5	70.2	28.6	0	
Four Seasons A+ Elementary School	1501	2/14/2023	11:53:00 AM	517	0.5	69.6	28.6	2	
Four Seasons A+ Elementary School	1502	2/14/2023	12:29:00 PM	574	0.5	69.6	30.4	12	
Four Seasons A+ Elementary School	1600	2/14/2023	12:44:00 PM	740	0.5	70.3	31	13	
Four Seasons A+ Elementary School	1604	2/14/2023	12:40:00 PM	755	0.5	69.6	31	7	
Four Seasons A+ Elementary School	1605	2/14/2023	12:46:00 PM	643	0.5	70.2	30	3	
Four Seasons A+ Elementary School	1606	2/14/2023	12:47:00 PM	566	0.5	69.8	29.7	0	
Four Seasons A+ Elementary School	2004	2/14/2023	1:20:00 PM	793	0.5	69.6	33	23	
Four Seasons A+ Elementary School	2005	2/14/2023	12:52:00 PM	795	0.5	69.8	32.5	20	
Four Seasons A+ Elementary School	2006	2/14/2023	1:22:00 PM	559	0.5	69.8	31.6	1	
Four Seasons A+ Elementary School	2007	2/14/2023	1:18:00 PM	698	0.5	69.4	33.5	23	
Four Seasons A+ Elementary School	2008	2/14/2023	1:24:00 PM	959	0.5	70	32.2	3	
Four Seasons A+ Elementary School	2009	2/14/2023	1:25:00 PM	861	0.5	70.3	33.4	20	
Four Seasons A+ Elementary School	2010	2/14/2023	1:26:00 PM	1119	0.6	70.5	35.6	29	
Four Seasons A+ Elementary School	2011	2/14/2023	1:27:00 PM	845	0.5	70.5	32.3	17	
Four Seasons A+ Elementary School	2303	2/14/2023	1:29:00 PM	934	0.5	69.8	31	0	
Four Seasons A+ Elementary School	2304	2/14/2023	1:31:00 PM	673	0.5	69.3	30.2	0	
Four Seasons A+ Elementary School	2305	2/14/2023	1:32:00 PM	699	0.5	69.3	30.1	1	
Four Seasons A+ Elementary School	2501	2/14/2023	12:59:00 PM	878	0.5	69.3	29.7	0	
Four Seasons A+ Elementary School	2504	2/14/2023	12:56:00 PM	801	0.5	69.8	31.2	15	
Four Seasons A+ Elementary School	2506	2/14/2023	12:58:00 PM	609	0.5	69.6	30.2	0	
Four Seasons A+ Elementary School	1002 MAIN OFFICE	2/14/2023	11:56:00 AM	570	0.5	69.4	29.4	1	
Four Seasons A+ Elementary School	1004 OFFICE	2/14/2023	11:57:00 AM	503	0.4	69.8	29	0	
Four Seasons A+ Elementary School	1006 COT ROOM	2/14/2023	11:58:00 AM	541	0.5	69.6	29.6	1	
Four Seasons A+ Elementary School	1006B NURSE OFFICE	2/14/2023	12:00:00 PM	532	0.4	70	29.5	2	
Four Seasons A+ Elementary School	1007 WORKROOM	2/14/2023	12:01:00 PM	524	0.5	70.3	28.4	0	
Four Seasons A+ Elementary School	1008 CONFERENCE	2/14/2023	12:25:00 PM	552	0.5	69.8	29.4	0	
Four Seasons A+ Elementary School	1009 OFFICE	2/14/2023	12:02:00 PM	559	0.5	70.7	28.3	0	
Four Seasons A+ Elementary School	1010 OFFICE	2/14/2023	12:04:00 PM	581	0.6	70.5	29.1	1	
Four Seasons A+ Elementary School	1101 CAFETRIA	2/14/2023	11:41:00 AM	711	0.5	70.9	31.2	80	
Four Seasons A+ Elementary School	1107A KITCHEN	2/14/2023	11:38:00 AM	1029	0.5	71.1	32.4	0	
Four Seasons A+ Elementary School	1201 GYMNASIUM	2/14/2023	11:43:00 AM	550	0.4	70.9	28.5	26	
Four Seasons A+ Elementary School	1202 OFFICE	2/14/2023	11:45:00 AM	524	0.4	71.1	28.3	0	
Four Seasons A+ Elementary School	1208 KITCHEN OFFICE	2/14/2023	11:36:00 AM	666	0.5	71.4	29.2	0	
Four Seasons A+ Elementary School	1211 CUSTODIAL OFFICE	2/14/2023	11:08:00 AM	753	0.8	70.5	27.5	1	
Four Seasons A+ Elementary School	1305 PRIVACY ROOM	2/14/2023	12:07:00 PM	565	0.4	69.6	29.5	0	
Four Seasons A+ Elementary School	1306 OFFICE	2/14/2023	12:23:00 PM	562	0.5	69.8	29.4	0	
Four Seasons A+ Elementary School	1308 OFFICE	2/14/2023	12:14:00 PM	656	0.5	69.8	28.4	1	
Four Seasons A+ Elementary School	1310 NORTH	2/14/2023	12:19:00 PM	682	0.5	70.3	27.1	1	
Four Seasons A+ Elementary School	1310 SOUTH	2/14/2023	12:17:00 PM	704	0.5	70.2	28.4	0	
Four Seasons A+ Elementary School	1403 OFFICE	2/14/2023	12:27:00 PM	549	0.5	69.8	29.4	0	
Four Seasons A+ Elementary School	1501A OFFICE	2/14/2023	12:28:00 PM	523	0.5	69.6	29.5	0	
Four Seasons A+ Elementary School	1504 OFFICE	2/14/2023	12:31:00 PM	707	0.5	69.6	30.3	1	
Four Seasons A+ Elementary School	1506 AND 1505 MUSIC	2/14/2023	12:32:00 PM	874	0.5	69.4	30.4	22	
Four Seasons A+ Elementary School	1507 SPARE CLASSROOM	2/14/2023	12:34:00 PM	639	0.5	69.4	27.4	0	
Four Seasons A+ Elementary School	1509 OFFICE	2/14/2023	12:36:00 PM	780	0.5	69.4	29.3	0	
Four Seasons A+ Elementary School	1510 OFFICE	2/14/2023	12:39:00 PM	631	0.5	69.8	28.6	0	
Four Seasons A+ Elementary School	2301 OFFICE	2/14/2023	1:33:00 PM	602	0.5	68.5	32.2	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Four Seasons A+ Elementary School	2503 OFFICE	2/14/2023	12:55:00 PM	644	0.5	70.2	30.2	1	
Four Seasons A+ Elementary School	MEDIA CENTER	2/14/2023	12:49:00 PM	635	0.5	69.8	30.7	0	
Four Seasons A+ Elementary School	OUTDOORS	2/14/2023		451	0.8	440	49.8		
Frost Lake Elementary School	1002	2/17/2023	3:28:00 PM	569	0.1	71.8	8.8	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1003	2/17/2023	3:30:00 PM	760	0.1	72.6	10.4	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1004	2/17/2023	3:32:00 PM	637	0.1	71.6	9.1	1	
Frost Lake Elementary School	1102	2/17/2023	12:57:00 PM	541	0.1	71.7	7.5	1	
Frost Lake Elementary School	1114	2/17/2023	1:11:00 PM	509	0.1	71.5	7.1	0	
Frost Lake Elementary School	1115	2/17/2023	1:13:00 PM	569	0.1	71.7	6.6	1	Dirty or dusty carpet odor
Frost Lake Elementary School	1119	2/17/2023	1:15:00 PM	496	0.1	71.6	5.8	3	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1121	2/17/2023	1:17:00 PM	613	0.1	71.4	8.3	6	
Frost Lake Elementary School	1122	2/17/2023	1:20:00 PM	598	0.1	71.8	9.3	2	
Frost Lake Elementary School	1123	2/17/2023	1:18:00 PM	912	0.1	71.6	12.1	19	
Frost Lake Elementary School	1201	2/17/2023	1:23:00 PM	478	0.1	71	7.6	1	
Frost Lake Elementary School	1205	2/17/2023	1:25:00 PM	598	0.1	70.1	8.7	2	
Frost Lake Elementary School	1207	2/17/2023	1:28:00 PM	739	0.1	70.8	10.5	21	
Frost Lake Elementary School	1209	2/17/2023	1:30:00 PM	893	0.1	71.9	11.7	26	
Frost Lake Elementary School	1210	2/17/2023	1:33:00 PM	1128	0.1	74.5	15.9	26	
Frost Lake Elementary School	1211	2/17/2023	1:36:00 PM	562	0.2	73	7.9	4	
Frost Lake Elementary School	1213	2/17/2023	1:37:00 PM	576	0.1	71.3	8.4	5	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1215	2/17/2023	1:40:00 PM	461	0.1	70.6	7.4	0	
Frost Lake Elementary School	1219	2/17/2023	1:42:00 PM	466	0.1	70.8	8	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1221	2/17/2023	1:48:00 PM	821	0.1	71.3	9.8	9	Fragrance odor
Frost Lake Elementary School	1222	2/17/2023	1:52:00 PM	512	0.1	70	8.1	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1223	2/17/2023	1:50:00 PM	582	0.1	70	8.6	1	
Frost Lake Elementary School	1224	2/17/2023	1:58:00 PM	522	0.1	71.4	8.4	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1225	2/17/2023	1:54:00 PM	1044	0.1	71.1	14.5	33	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1227	2/17/2023	2:01:00 PM	823	0.1	71.6	11.4	24	
Frost Lake Elementary School	1301	2/17/2023	3:05:00 PM	796	0.1	71.4	12.4	19	
Frost Lake Elementary School	1303	2/17/2023	3:03:00 PM	912	0.1	70.8	13.8	23	
Frost Lake Elementary School	1307	2/17/2023	3:01:00 PM	541	0.1	69.7	9.6	1	
Frost Lake Elementary School	1308	2/17/2023	2:57:00 PM	536	0.1	68.8	8.1	0	
Frost Lake Elementary School	1309	2/17/2023	3:00:00 PM	518	0.1	68.7	10.1	0	
Frost Lake Elementary School	1310	2/17/2023	2:56:00 PM	868	0.1	71.2	12.3	16	
Frost Lake Elementary School	1311	2/17/2023	2:51:00 PM	581	0.1	71.1	9.6	1	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1313	2/17/2023	2:48:00 PM	539	0.1	71.4	9.1	1	
Frost Lake Elementary School	1315	2/17/2023	2:46:00 PM	847	0.1	72.1	12.1	24	
Frost Lake Elementary School	1320	2/17/2023	3:08:00 PM	589	0.1	71.5	9.5	1	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1321	2/17/2023	2:44:00 PM	774	0.1	72.3	11.1	20	
Frost Lake Elementary School	1323	2/17/2023	2:36:00 PM	778	0.1	73.2	10.2	13	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1324	2/17/2023	2:42:00 PM	531	0.1	73.1	7.7	0	
Frost Lake Elementary School	1352	2/17/2023	2:38:00 PM	553	0.1	72.6	8	0	Stuffy, dirty or dusty carpet odor
Frost Lake Elementary School	1355	2/17/2023	2:41:00 PM	523	0.1	74.4	8.1	1	
Frost Lake Elementary School	1357	2/17/2023	2:39:00 PM	549	0.1	76.5	8.4	1	
Frost Lake Elementary School	1401	2/17/2023	2:08:00 PM	814	0.1	72.1	10.8	16	
Frost Lake Elementary School	1405	2/17/2023	2:10:00 PM	683	0.1	71.8	9.3	0	
Frost Lake Elementary School	1409	2/17/2023	2:12:00 PM	694	0.1	71.9	9.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Frost Lake Elementary School	1411	2/17/2023	2:18:00 PM	714	0.1	72.3	9.9	0	
Frost Lake Elementary School	1415	2/17/2023	2:19:00 PM	935	0.1	72.5	12	27	
Frost Lake Elementary School	1416	2/17/2023	2:14:00 PM	881	0.1	71.4	11.1	17	
Frost Lake Elementary School	1417	2/17/2023	2:22:00 PM	692	0.1	71.9	9.4	0	
Frost Lake Elementary School	1419	2/17/2023	2:23:00 PM	777	0.1	72.1	10.3	2	
Frost Lake Elementary School	1422	2/17/2023	2:25:00 PM	693	0.1	72.6	9.4	1	
Frost Lake Elementary School	1423	2/17/2023	2:28:00 PM	775	0.1	73.1	10.6	1	
Frost Lake Elementary School	1425	2/17/2023	2:30:00 PM	773	0.1	73.3	9.8	0	
Frost Lake Elementary School	1427	2/17/2023	2:32:00 PM	838	0.1	74.6	11.5	2	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1428	2/17/2023	2:34:00 PM	703	0.1	73.2	8.7	0	
Frost Lake Elementary School	1501	2/17/2023	3:09:00 PM	735	0.1	71.6	10.5	14	
Frost Lake Elementary School	1503	2/17/2023	3:12:00 PM	638	0.1	71.7	9.8	18	
Frost Lake Elementary School	1504	2/17/2023	3:26:00 PM	559	0.1	73.1	8.2	1	
Frost Lake Elementary School	1505	2/17/2023	3:14:00 PM	656	0.1	71.9	10	15	
Frost Lake Elementary School	1506	2/17/2023	3:22:00 PM	651	0.1	72.9	9.6	16	
Frost Lake Elementary School	1506	2/17/2023	3:23:00 PM	717	0.1	72.6	10.3	6	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1507	2/17/2023	3:16:00 PM	584	0.1	72	9.1	1	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1509	2/17/2023	3:18:00 PM	743	0.1	73.9	12	15	Stained ceiling tiles
Frost Lake Elementary School	1513	2/17/2023	3:20:00 PM	720	0.1	73.8	9.5	15	
Frost Lake Elementary School	1008 NURSE	2/17/2023	1:03:00 PM	600	0.1	73.2	8.2	3	
Frost Lake Elementary School	1008C	2/17/2023	1:05:00 PM	587	0.2	72.4	8.3	1	
Frost Lake Elementary School	1104 STAFF LOUNGE	2/17/2023	1:00:00 PM	603	0.1	71.6	9.3	3	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1113 MOTOR ROOM	2/17/2023	1:06:00 PM	448	0.1	71.9	5	0	
Frost Lake Elementary School	1220 CONSELOR	2/17/2023	1:45:00 PM	508	0.1	70.7	8.2	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1224A	2/17/2023	2:00:00 PM	508	0.1	71.3	8.2	0	Plants: Kept Away From Return And Supply Vents
Frost Lake Elementary School	1402 WORK ROOM	2/17/2023	2:04:00 PM	764	0.1	72.7	10.9	0	
Frost Lake Elementary School	CAFETERIA	2/17/2023	12:43:00 PM	694	0.1	69.9	12.5	26	
Frost Lake Elementary School	CUSTODIAL OFFICE	2/17/2023	12:42:00 PM	622	0.1	70.8	9.9	1	
Frost Lake Elementary School	GYM OFFICE	2/17/2023	12:52:00 PM	614	0.1	70.8	9.3	0	
Frost Lake Elementary School	GYMNASIUM 101	2/17/2023	12:49:00 PM	714	0.1	69.5	10.4	25	
Frost Lake Elementary School	KITCHEN	2/17/2023	12:46:00 PM	663	0.1	69.7	12.6	6	
Frost Lake Elementary School	KITCHEN OFFICE	2/17/2023	12:48:00 PM	667	0.1	70.2	12	1	
Frost Lake Elementary School	MAIN OFFICE	2/17/2023	3:33:00 PM	586	0.1	71.5	8.8	4	
Frost Lake Elementary School	MEDIA CENTER	2/17/2023	12:54:00 PM	551	0.1	71.6	8.3	2	
Frost Lake Elementary School	OUTDOORS	2/17/2023		500	0.5	15	15.5		
Global Arts Plus Lower	101	2/6/2023	2:46:00 PM	654	0.2	67.3	14.5	0	
Global Arts Plus Lower	1002	2/6/2023	2:52:00 PM	509	0.1	70.9	7.7	0	
Global Arts Plus Lower	1003	2/6/2023	2:56:00 PM	578	0.1	71.2	9.8	0	
Global Arts Plus Lower	1004	2/6/2023	2:57:00 PM	529	0.1	72	8.4	2	
Global Arts Plus Lower	1006	2/6/2023	2:59:00 PM	763	0.2	72.9	11.8	2	
Global Arts Plus Lower	1008	2/6/2023	2:59:00 PM	564	0.1	72.5	9.2	0	
Global Arts Plus Lower	1102	2/6/2023	3:29:00 PM	735	0.2	71.1	12.3	25	
Global Arts Plus Lower	1103	2/6/2023	3:23:00 PM	735	0.3	69.1	12.2	0	
Global Arts Plus Lower	1104	2/6/2023	3:27:00 PM	711	0.3	70	11.4	25	
Global Arts Plus Lower	1105	2/6/2023	3:30:00 PM	805	0.3	70.7	11.4	15	Plants
Global Arts Plus Lower	1107	2/6/2023	3:25:00 PM	682	0.2	70	10.8	6	Fragrance odor
Global Arts Plus Lower	1403	2/6/2023	3:06:00 PM	1407	0.3	69.8	21	20	
Global Arts Plus Lower	1405	2/6/2023	3:09:00 PM	1598	0.2	70.3	22.8	25	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Lower	1411	2/6/2023	3:19:00 PM	884	0.3	70.2	15.1	15	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	1503	2/6/2023	3:17:00 PM	535	0.3	70.2	24.4	0	Musty odor
Global Arts Plus Lower	1505	2/6/2023	3:18:00 PM	495	0.2	70.9	13.8	0	
Global Arts Plus Lower	2104	2/6/2023	2:04:00 PM	650	0.2	70.5	12.5	3	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2106	2/6/2023	2:18:00 PM	529	0.3	72.9	9.2	0	
Global Arts Plus Lower	2108	2/6/2023	2:14:00 PM	471	0.2	80.1	7.5	1	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2109	2/6/2023	2:16:00 PM	889	0.3	74.6	10.9	25	
Global Arts Plus Lower	2202	2/6/2023	2:19:00 PM	518	0.3	73.2	8.7	0	
Global Arts Plus Lower	2204	2/6/2023	2:22:00 PM	872	0.3	71.8	12.4	25	
Global Arts Plus Lower	2206	2/6/2023	2:25:00 PM	610	0.2	72.3	11.7	1	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2208	2/6/2023	2:26:00 PM	736	0.2	72.7	11.3	0	
Global Arts Plus Lower	2401	2/6/2023	2:28:00 PM	1110	0.3	70.7	16.2	1	
Global Arts Plus Lower	2403	2/6/2023	2:31:00 PM	1000	0.3	70.7	16.9	20	
Global Arts Plus Lower	2404	2/6/2023	2:33:00 PM	617	0.2	70.5	12.6	0	
Global Arts Plus Lower	2409	2/6/2023	2:44:00 PM	729	0.3	68.5	14.1	25	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2411	2/6/2023	2:44:00 PM	648	0.2	70.2	13	0	
Global Arts Plus Lower	2412	2/6/2023	2:34:00 PM	715	0.2	70.5	13.2	0	
Global Arts Plus Lower	2413	2/6/2023	2:42:00 PM	764	0.2	70.5	13.5	20	
Global Arts Plus Lower	2414	2/6/2023	2:41:00 PM	698	0.2	70.3	13.9	6	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2415	2/6/2023	2:40:00 PM	799	0.2	70.3	14.6	20	
Global Arts Plus Lower	2416	2/6/2023	2:37:00 PM	603	0.2	71.2	13.3	0	
Global Arts Plus Lower	2417	2/6/2023	2:38:00 PM	751	0.2	70.9	14.2	20	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2418	2/6/2023	2:36:00 PM	494	0.2	70.3	11.8	0	
Global Arts Plus Lower	3102	2/6/2023	1:56:00 PM	562	0.3	70.9	10.2	0	
Global Arts Plus Lower	3106	2/6/2023	1:57:00 PM	714	0.3	71.2	12	20	
Global Arts Plus Lower	3107	2/6/2023	2:01:00 PM	1097	0.4	70.5	14.3	15	
Global Arts Plus Lower	3108	2/6/2023	1:59:00 PM	477	0.3	71.1	9.2	0	
Global Arts Plus Lower	3109	2/6/2023	2:03:00 PM	541	0.3	69.8	9.5	0	
Global Arts Plus Lower	3202	2/6/2023	1:55:00 PM	562	0.3	71.8	10	1	
Global Arts Plus Lower	3204	2/6/2023	1:53:00 PM	515	0.3	70.9	10	0	
Global Arts Plus Lower	3206	2/6/2023	1:51:00 PM	748	0.2	68.5	15.8	10	
Global Arts Plus Lower	3211	2/6/2023	1:48:00 PM	940	0.4	67.5	15.6	1	
Global Arts Plus Lower	3401	2/6/2023	1:47:00 PM	827	0.3	69.4	15.3	20	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	3403	2/6/2023	1:45:00 PM	656	0.3	69.4	13.2	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	3404	2/6/2023	1:44:00 PM	760	0.3	69.7	14.1	0	Stained ceiling tiles
Global Arts Plus Lower	3409	2/6/2023	1:41:00 PM	571	0.3	69.1	12.8	0	
Global Arts Plus Lower	3411	2/6/2023	1:41:00 PM	813	0.3	69.4	15	1	
Global Arts Plus Lower	3412	2/6/2023	1:43:00 PM	768	0.3	69.4	13.9	2	
Global Arts Plus Lower	3413	2/6/2023	1:39:00 PM	963	0.3	69.6	17.5	20	
Global Arts Plus Lower	3414	2/6/2023	1:38:00 PM	804	0.3	69.4	14.7	4	
Global Arts Plus Lower	3415	2/6/2023	1:37:00 PM	959	0.3	69.4	16.8	28	
Global Arts Plus Lower	3416	2/6/2023	1:35:00 PM	635	0.3	69.1	13.1	0	
Global Arts Plus Lower	3417	2/6/2023	1:34:00 PM	1000	0.2	68.4	17.1	25	
Global Arts Plus Lower	3418	2/6/2023	1:24:00 PM	708	0.2	68.4	13.9	1	
Global Arts Plus Lower	1001A	2/6/2023	3:36:00 PM	641	0.1	69.3	9	1	
Global Arts Plus Lower	1007 COMMONS	2/6/2023	3:04:00 PM	623	0.3	72	10.6	0	
Global Arts Plus Lower	1007A	2/6/2023	3:02:00 PM	556	0.3	73	8.7	1	
Global Arts Plus Lower	1007B	2/6/2023	3:03:00 PM	551	0.2	73	8.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Lower	1301 GYM	2/6/2023	3:12:00 PM	629	0.2	69.4	11.5	0	
Global Arts Plus Lower	2104A	2/6/2023	2:13:00 PM	608	0.2	71.4	11.5	1	
Global Arts Plus Lower	2206 COMMONS	2/6/2023	2:23:00 PM	751	0.3	71.4	12.6	10	
Global Arts Plus Lower	3201 COMMONS	2/6/2023	1:50:00 PM	811	0.3	66.6	16.1	2	
Global Arts Plus Lower	CAFETERIA	2/6/2023	3:14:00 PM	522	0.2	69.4	14.8	2	
Global Arts Plus Lower	HEALTH OFFICE	2/6/2023	3:01:00 PM	609	0.2	72.7	9.3	2	
Global Arts Plus Lower	MAIN OFFICE	2/6/2023	2:49:00 PM	528	0.1	68.9	9.7	3	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	OUTDOORS	2/6/2023		375	0.9	9.6	69.9		
Global Arts Plus Lower	STAGE	2/6/2023	3:14:00 PM	618	0.3	68.9	11.6	0	
Global Arts Plus Upper	1002	2/2/2023	11:08:00 AM	508	0.3	67.6	9.8	3	
Global Arts Plus Upper	1004	2/2/2023	11:10:00 AM	542	0.3	67.8	10.8	0	
Global Arts Plus Upper	1005	2/2/2023	11:11:00 AM	488	0.3	68.4	8.8	1	
Global Arts Plus Upper	1006	2/2/2023	11:12:00 AM	516	0.3	68.5	9.6	2	
Global Arts Plus Upper	1007	2/2/2023	11:13:00 AM	458	0.2	69.3	8	0	
Global Arts Plus Upper	1008	2/2/2023	11:14:00 AM	520	0.2	69.6	9.5	1	
Global Arts Plus Upper	1101	2/2/2023	11:09:00 AM	466	0.3	67.8	8.2	0	
Global Arts Plus Upper	1104	2/2/2023	11:15:00 AM	511	0.3	68.7	9.4	2	
Global Arts Plus Upper	1106	2/2/2023	11:31:00 AM	689	0.2	67.6	12.9	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1120	2/2/2023	11:33:00 AM	705	0.1	68.4	12.6	50	
Global Arts Plus Upper	1122	2/2/2023	11:36:00 AM	623	0.2	68.7	11.4	5	
Global Arts Plus Upper	1201	2/2/2023	11:36:00 AM	722	0.2	66.2	12.2	20	
Global Arts Plus Upper	1203	2/2/2023	11:38:00 AM	728	0.1	67.3	12.4	1	
Global Arts Plus Upper	1207	2/2/2023	11:40:00 AM	590	0.1	67.8	10.5	0	
Global Arts Plus Upper	1209	2/2/2023	11:41:00 AM	642	0.1	67.7	10.6	0	
Global Arts Plus Upper	1211	2/2/2023	11:42:00 AM	625	0.1	67.6	10.8	0	
Global Arts Plus Upper	1217	2/2/2023	11:48:00 AM	660	0.1	69.1	11.1	0	
Global Arts Plus Upper	1219	2/2/2023	11:50:00 AM	621	0.1	69.1	10.4	8	Aquariums (fish)
Global Arts Plus Upper	1221	2/2/2023	11:52:00 AM	541	0.1	68.9	9.6	0	Aquariums (fish)
Global Arts Plus Upper	1223	2/2/2023	11:53:00 AM	611	0.1	68.7	11.3	0	
Global Arts Plus Upper	1250	2/2/2023	11:47:00 AM	780	0.1	69.4	10.3	2	
Global Arts Plus Upper	1255	2/2/2023	11:43:00 AM	622	0.1	68.4	11.2	0	
Global Arts Plus Upper	1257	2/2/2023	11:46:00 AM	777	0.1	68.9	11	2	
Global Arts Plus Upper	1320	2/2/2023	11:24:00 AM	683	0.2	68.2	12.3	3	
Global Arts Plus Upper	1330	2/2/2023	11:25:00 AM	734	0.2	67.8	10.4	0	
Global Arts Plus Upper	1332	2/2/2023	11:28:00 AM	493	0.1	68.2	9.6	0	
Global Arts Plus Upper	1334	2/2/2023	11:28:00 AM	497	0.1	68.5	10.2	0	
Global Arts Plus Upper	1401	2/2/2023	10:58:00 AM	512	0.4	68.4	8.6	0	
Global Arts Plus Upper	1402	2/2/2023	10:56:00 AM	558	0.4	68.5	10.1	0	
Global Arts Plus Upper	1405	2/2/2023	10:45:00 AM	638	0.4	68.4	12.7	1	
Global Arts Plus Upper	1406	2/2/2023	10:55:00 AM	505	0.4	68.7	9	1	
Global Arts Plus Upper	1408	2/2/2023	10:53:00 AM	685	0.4	68.5	9.5	2	
Global Arts Plus Upper	1410	2/2/2023	10:52:00 AM	690	0.4	68.5	11	15	
Global Arts Plus Upper	1412	2/2/2023	10:50:00 AM	489	0.4	68.7	9.2	0	
Global Arts Plus Upper	1414	2/2/2023	10:47:00 AM	558	0.4	68.7	9.6	10	
Global Arts Plus Upper	1501	2/2/2023	11:07:00 AM	488	0.3	68.5	9.4	0	
Global Arts Plus Upper	1503	2/2/2023	11:04:00 AM	892	0.3	69.1	13.9	25	Stained ceiling tiles
Global Arts Plus Upper	1504	2/2/2023	11:05:00 AM	480	0.3	69.3	9.4	0	
Global Arts Plus Upper	1507	2/2/2023	11:02:00 AM	962	0.3	67.8	12	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Upper	1510	2/2/2023	11:03:00 AM	518	0.3	68.4	10.2	1	
Global Arts Plus Upper	1511	2/2/2023	11:00:00 AM	479	0.3	67.8	9	0	
Global Arts Plus Upper	2101	2/2/2023	12:15:00 PM	747	0.1	69.3	10.8	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	2102	2/2/2023	12:11:00 PM	669	0.5	70	14.2	1	
Global Arts Plus Upper	2120	2/2/2023	12:14:00 PM	529	0.1	69.4	8.6	0	
Global Arts Plus Upper	2122	2/2/2023	12:10:00 PM	504	0.1	69.4	8.5	0	
Global Arts Plus Upper	2201	2/2/2023	12:05:00 PM	463	0.1	69.4	8.3	0	
Global Arts Plus Upper	2205	2/2/2023	12:03:00 PM	911	0.1	69.8	18.4	25	
Global Arts Plus Upper	2206	2/2/2023	12:00:00 PM	536	0.1	68.7	9.2	2	
Global Arts Plus Upper	2207	2/2/2023	12:02:00 PM	883	0.1	69.3	12.9	30	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	2210	2/2/2023	11:55:00 AM	567	0.1	68.2	9.7	3	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	2215	2/2/2023	12:00:00 PM	803	0.1	68.4	12	25	
Global Arts Plus Upper	2217	2/2/2023	11:58:00 AM	890	0.1	68.4	13.4	30	
Global Arts Plus Upper	2219	2/2/2023	11:57:00 AM	656	0.1	68.4	9.5	0	
Global Arts Plus Upper	2301	2/2/2023	12:17:00 PM	591	0.1	68.9	9.5	5	
Global Arts Plus Upper	2305	2/2/2023	12:19:00 PM	1293	0.1	69.6	17.2	15	
Global Arts Plus Upper	2310	2/2/2023	12:16:00 PM	684	0.5	69.5	14.1	1	
Global Arts Plus Upper	2330	2/2/2023	12:29:00 PM	695	0.6	70.4	12.1	15	Stained ceiling tiles
Global Arts Plus Upper	2402	2/2/2023	12:20:00 PM	509	0.1	68.9	8.5	0	Bubbling/peeling paint
Global Arts Plus Upper	2405	2/2/2023	12:27:00 PM	603	0.1	70.2	10.7	0	
Global Arts Plus Upper	2406	2/2/2023	12:25:00 PM	636	0.2	68.2	9.9	4	
Global Arts Plus Upper	2408	2/2/2023	12:25:00 PM	527	0.1	68.2	8.8	1	
Global Arts Plus Upper	2410	2/2/2023	12:28:00 PM	602	0.1	70.3	9.6	0	
Global Arts Plus Upper	3101	2/2/2023	12:49:00 PM	477	0.1	69.4	8.9	0	
Global Arts Plus Upper	3103	2/2/2023	12:46:00 PM	479	0.1	69.4	9.4	5	
Global Arts Plus Upper	3104	2/2/2023	12:48:00 PM	1016	0.2	69.4	14.4	30	
Global Arts Plus Upper	3301	2/2/2023	12:42:00 PM	542	0.1	69.4	9.6	5	
Global Arts Plus Upper	3302	2/2/2023	12:44:00 PM	614	0.1	69.9	10.6	4	
Global Arts Plus Upper	3303	2/2/2023	12:37:00 PM	496	0.1	69.4	9.7	5	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	3304	2/2/2023	12:39:00 PM	612	0.1	69.8	10.9	0	
Global Arts Plus Upper	3402	2/2/2023	12:40:00 PM	744	0.2	69.4	11.6	15	
Global Arts Plus Upper	3405	2/2/2023	12:33:00 PM	660	0.1	69.6	11.5	0	
Global Arts Plus Upper	3406	2/2/2023	12:36:00 PM	844	0.1	69.8	12.4	25	
Global Arts Plus Upper	3408	2/2/2023	12:34:00 PM	730	0.1	70.2	11	25	
Global Arts Plus Upper	3410	2/2/2023	12:30:00 PM	756	0.1	69.1	11.8	20	
Global Arts Plus Upper	1104A	2/2/2023	11:17:00 AM	519	0.2	68.5	10.2	0	
Global Arts Plus Upper	1104C	2/2/2023	11:18:00 AM	500	0.2	68.7	9.6	0	
Global Arts Plus Upper	1120A	2/2/2023	11:35:00 AM	591	0.1	68.9	11.4	1	
Global Arts Plus Upper	1255B	2/2/2023	11:45:00 AM	534	0.1	68.7	9.8	0	
Global Arts Plus Upper	1310A	2/2/2023	11:22:00 AM	680	0.2	68.4	13.6	0	
Global Arts Plus Upper	1334A	2/2/2023	11:30:00 AM	550	0.1	68.5	11.6	0	
Global Arts Plus Upper	2201B	2/2/2023	12:09:00 PM	496	0.1	69.1	8.5	0	
Global Arts Plus Upper	2201C	2/2/2023	12:08:00 PM	455	0.1	68.9	8.4	0	
Global Arts Plus Upper	2201D	2/2/2023	12:06:00 PM	454	0.1	69.3	8.7	0	
Global Arts Plus Upper	2201E	2/2/2023	12:07:00 PM	484	0.1	69.1	8.8	0	
Global Arts Plus Upper	MEDIA CENTER	2/2/2023	11:19:00 AM	751	0.3	67.6	13.6	3	
Global Arts Plus Upper	OUTDOORS	2/2/2023		366	0.8	9.6	69.9		
Gordon Parks High School	1003	1/12/2023	3:01:00 PM	514	0.2	70.5	16	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Gordon Parks High School	1007	1/12/2023	2:59:00 PM	521	0.1	71.2	16.3	0	
Gordon Parks High School	1009	1/12/2023	2:58:00 PM	526	0.1	71.2	15.9	0	
Gordon Parks High School	1013	1/12/2023	2:55:00 PM	537	0.2	72.4	15.3	6	
Gordon Parks High School	1019	1/12/2023	2:57:00 PM	526	0.1	71.4	15.5	1	
Gordon Parks High School	1100	1/12/2023	3:21:00 PM	627	0.2	73.4	16.3	1	
Gordon Parks High School	1101	1/12/2023	2:21:00 PM	606	0.1	69.3	18.2	7	Plants
Gordon Parks High School	1102	1/12/2023	2:18:00 PM	550	0.1	69.8	17.1	1	
Gordon Parks High School	1103	1/12/2023	2:24:00 PM	597	0.2	69	18.4	0	
Gordon Parks High School	1104	1/12/2023	2:20:00 PM	539	0.1	69.7	17	0	
Gordon Parks High School	1107	1/12/2023	2:16:00 PM	911	0.1	70.6	22.1	2	
Gordon Parks High School	1108	1/12/2023	2:47:00 PM	703	0.1	71.8	20.1	0	
Gordon Parks High School	1109	1/12/2023	2:13:00 PM	602	0.1	70.2	18.4	2	
Gordon Parks High School	1110	1/12/2023	2:52:00 PM	767	0.1	75.9	18.4	2	Plants: Kept Away From Return And Supply Vents
Gordon Parks High School	1115	1/12/2023	2:15:00 PM	614	0.1	70.3	19.1	0	
Gordon Parks High School	1118	1/12/2023	3:23:00 PM	756	0.2	73.6	18.3	3	
Gordon Parks High School	1122	1/12/2023	3:20:00 PM	664	0.1	73.1	17.6	1	
Gordon Parks High School	1126	1/12/2023	3:17:00 PM	584	0.1	72.3	16.8	0	Plants: Kept Away From Return And Supply Vents
Gordon Parks High School	1201	1/12/2023	3:02:00 PM	506	0.1	69.7	15.8	1	
Gordon Parks High School	1203	1/12/2023	3:08:00 PM	506	0.1	69.1	16.3	0	
Gordon Parks High School	1205	1/12/2023	3:06:00 PM	498	0.1	69.1	15.8	1	
Gordon Parks High School	1207	1/12/2023	3:05:00 PM	491	0.2	69.7	15.6	1	
Gordon Parks High School	1208	1/12/2023	1:39:00 PM	542	0.1	70.1	21.4	1	
Gordon Parks High School	1209	1/12/2023	3:03:00 PM	486	0.1	70	15.5	0	
Gordon Parks High School	1210	1/12/2023	1:36:00 PM	645	0.1	69.4	24.3	2	
Gordon Parks High School	1214	1/12/2023	1:40:00 PM	533	0.1	70.3	20.9	1	
Gordon Parks High School	1302	1/12/2023	2:11:00 PM	444	0.2	69.7	13.9	1	
Gordon Parks High School	2001	1/12/2023	2:45:00 PM	613	0.1	70.7	18.1	1	
Gordon Parks High School	2003	1/12/2023	2:42:00 PM	540	0.1	69.1	17.4	1	
Gordon Parks High School	2005	1/12/2023	2:43:00 PM	599	0.1	69.3	18.1	3	
Gordon Parks High School	2011	1/12/2023	2:37:00 PM	563	0.1	69.6	16.8	0	
Gordon Parks High School	2013	1/12/2023	2:41:00 PM	545	0.1	69	16.7	0	
Gordon Parks High School	2101	1/12/2023	2:26:00 PM	700	0.1	68.8	20.1	12	
Gordon Parks High School	2102	1/12/2023	2:28:00 PM	696	0.1	69.1	19.5	6	
Gordon Parks High School	2103	1/12/2023	2:27:00 PM	745	0.1	69	20	6	
Gordon Parks High School	2104	1/12/2023	2:30:00 PM	641	0.1	69.5	18.4	1	
Gordon Parks High School	2105	1/12/2023	2:31:00 PM	790	0.1	69.7	19.8	0	
Gordon Parks High School	2107	1/12/2023	2:34:00 PM	650	0.1	69.3	18.1	4	
Gordon Parks High School	2109	1/12/2023	2:36:00 PM	667	0.1	69.4	18.5	8	
Gordon Parks High School	1306A	1/12/2023	3:10:00 PM	475	0.1	69.2	15	0	
Gordon Parks High School	NURSE WAITING ROOM	1/12/2023	3:15:00 PM	739	0.1	71	20	3	
Gordon Parks High School	OUTDOORS	1/12/2023		391	0.2	24.3	75.4		
Groveland Park Elementary School	1105	2/14/2023	9:54:00 AM	582	0.5	71.8	24.8	19	
Groveland Park Elementary School	1113	2/14/2023	9:52:00 AM	669	0.6	72.3	25.7	26	
Groveland Park Elementary School	1123	2/14/2023	9:48:00 AM	578	0.6	72.1	25.1	5	
Groveland Park Elementary School	1135	2/14/2023	9:45:00 AM	911	0.5	72	26.3	25	
Groveland Park Elementary School	1319	2/14/2023	9:28:00 AM	555	0.5	70	25.1	0	
Groveland Park Elementary School	2102	2/14/2023	10:26:00 AM	853	0.3	71.6	26.8	22	
Groveland Park Elementary School	2103	2/14/2023	10:23:00 AM	516	0.4	73.2	23.1	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Groveland Park Elementary School	2104	2/14/2023	10:28:00 AM	848	0.3	71.4	26.9	23	
Groveland Park Elementary School	2109	2/14/2023	10:22:00 AM	495	0.4	74.5	22.3	1	
Groveland Park Elementary School	2113	2/14/2023	10:20:00 AM	920	0.4	74.8	27.7	21	
Groveland Park Elementary School	2123	2/14/2023	10:18:00 AM	634	0.4	74.3	24.5	23	
Groveland Park Elementary School	2137	2/14/2023	10:05:00 AM	1415	0.5	73.8	31	30	
Groveland Park Elementary School	2138	2/14/2023	9:58:00 AM	885	0.4	72.9	26.7	30	
Groveland Park Elementary School	2139	2/14/2023	10:04:00 AM	777	0.5	73.2	25.6	21	
Groveland Park Elementary School	2142	2/14/2023	10:02:00 AM	930	0.5	73	28	25	
Groveland Park Elementary School	3102	2/14/2023	10:59:00 AM	1022	0.4	70.7	30.3	30	
Groveland Park Elementary School	3103	2/14/2023	10:57:00 AM	743	0.4	71.1	28.7	26	
Groveland Park Elementary School	3104	2/14/2023	10:55:00 AM	1264	0.4	72.5	30	30	
Groveland Park Elementary School	3108	2/14/2023	10:52:00 AM	821	0.4	73.6	26	2	
Groveland Park Elementary School	3109	2/14/2023	10:54:00 AM	558	0.5	73.4	24.6	1	
Groveland Park Elementary School	3113	2/14/2023	10:50:00 AM	638	0.5	73.4	25	6	
Groveland Park Elementary School	3114	2/14/2023	10:49:00 AM	724	0.4	73.4	26.1	2	
Groveland Park Elementary School	3123	2/14/2023	10:40:00 AM	621	0.4	73.4	24.8	4	Plants
Groveland Park Elementary School	3124	2/14/2023	10:43:00 AM	752	0.4	74.5	25.5	11	
Groveland Park Elementary School	3137	2/14/2023	10:38:00 AM	735	0.3	72.1	24.9	6	
Groveland Park Elementary School	3138	2/14/2023	10:33:00 AM	1095	0.4	73	28.8	23	
Groveland Park Elementary School	3139	2/14/2023	10:36:00 AM	660	0.5	72.3	24.8	1	
Groveland Park Elementary School	3142	2/14/2023	10:34:00 AM	803	0.4	73.6	25.4	1	
Groveland Park Elementary School	1101 CAFETERIA	2/14/2023	9:57:00 AM	470	0.5	71.2	24.3	5	
Groveland Park Elementary School	1118 KITCHEN OFFICE	2/14/2023	9:51:00 AM	826	0.6	73	25.6	1	
Groveland Park Elementary School	1120 KITCHEN	2/14/2023	9:50:00 AM	541	0.5	72.7	25.6	3	
Groveland Park Elementary School	1200 LIBRARY	2/14/2023	9:41:00 AM	525	0.5	70.2	24.9	1	
Groveland Park Elementary School	1201 OFFICE	2/14/2023	9:44:00 AM	515	0.5	70.5	25.1	2	
Groveland Park Elementary School	1301 OFFICE	2/14/2023	9:24:00 AM	803	0.6	69.8	26.3	0	
Groveland Park Elementary School	1302 CHILD CARE	2/14/2023	9:27:00 AM	858	0.7	69.1	27.4	4	
Groveland Park Elementary School	1311 OFFICE	2/14/2023	9:22:00 AM	817	0.6	70.2	26.3	1	
Groveland Park Elementary School	1320 GYMNASIUM	2/14/2023	9:19:00 AM	432	0.8	71.1	24.3	0	
Groveland Park Elementary School	1321 STAFF LOUNGE	2/14/2023	9:40:00 AM	499	0.5	70.3	24.9	0	
Groveland Park Elementary School	2000 MAIN OFFICE	2/14/2023	10:12:00 AM	577	0.6	75.9	22.5	3	
Groveland Park Elementary School	2011 OFFICE	2/14/2023	10:14:00 AM	629	0.5	75.6	23.1	1	
Groveland Park Elementary School	2012 OFFICE	2/14/2023	10:13:00 AM	634	0.5	75.7	23.1	0	Stained ceiling tiles
Groveland Park Elementary School	2014 STAFF WORKROOM	2/14/2023	10:15:00 AM	548	0.5	74.8	22.9	0	
Groveland Park Elementary School	2015 OFFICE	2/14/2023	10:16:00 AM	577	0.4	73.8	23.7	1	
Groveland Park Elementary School	2021 NURSE OFFICE	2/14/2023	10:11:00 AM	562	0.6	76.8	21.8	1	
Groveland Park Elementary School	2024 NURSE OFFICE	2/14/2023	10:07:00 AM	567	0.5	75.6	22.6	1	
Groveland Park Elementary School	2130 NURSE WAITING	2/14/2023	10:10:00 AM	570	0.6	77.7	21.4	1	
Groveland Park Elementary School	3120 OFFICE	2/14/2023	10:46:00 AM	599	0.4	72.9	25.5	1	
Groveland Park Elementary School	3121 OFFICE	2/14/2023	10:44:00 AM	509	0.6	74.3	24.3	0	
Groveland Park Elementary School	3136 STAFF LOUNGE	2/14/2023	10:29:00 AM	654	0.4	72.9	25.2	2	
Groveland Park Elementary School	NURSE COT ROOM	2/14/2023	10:09:00 AM	619	0.5	77	24.2	0	
Groveland Park Elementary School	OUTDOORS	2/14/2023		439	0.7	40	45.3		
Hamline Elementary School	1101	1/13/2023	10:53:00 AM	607	0.2	71.4	19.5	20	
Hamline Elementary School	1103	1/13/2023	9:46:00 AM	483	0.2	69.6	19.7	1	
Hamline Elementary School	1105	1/13/2023	9:53:00 AM	473	0.2	70.3	19.2	1	
Hamline Elementary School	1107	1/13/2023	9:55:00 AM	526	0.2	69.8	21.7	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hamline Elementary School	1109	1/13/2023	10:51:00 AM	679	0.2	71.8	19.8	26	
Hamline Elementary School	1201	1/13/2023	11:11:00 AM	818	0.2	69.1	22.4	15	
Hamline Elementary School	1202	1/13/2023	11:07:00 AM	760	0.2	68.9	57.8	8	
Hamline Elementary School	1203	1/13/2023	11:13:00 AM	826	0.2	69.3	22.4	15	
Hamline Elementary School	1204	1/13/2023	11:58:00 AM	876	0.2	70.9	21.4	17	
Hamline Elementary School	1205	1/13/2023	11:14:00 AM	564	0.2	69.3	23	18	
Hamline Elementary School	1206	1/13/2023	11:46:00 AM	774	0.3	73	20.1	19	
Hamline Elementary School	1213	1/13/2023	10:58:00 AM	763	0.2	71.8	20.3	1	
Hamline Elementary School	1214	1/13/2023	11:06:00 AM	847	0.2	68.9	23	18	
Hamline Elementary School	1216	1/13/2023	11:05:00 AM	819	0.2	69.3	22.3	16	
Hamline Elementary School	1217	1/13/2023	11:04:00 AM	80	0.2	69.6	21.9	20	
Hamline Elementary School	1401	1/13/2023	10:01:00 AM	473	0.2	71.2	17.1	5	Plants
Hamline Elementary School	1405	1/13/2023	10:03:00 AM	421	0.2	72	16.5	1	Plants
Hamline Elementary School	1407	1/13/2023	10:12:00 AM	592	0.2	72	18.2	29	
Hamline Elementary School	1410	1/13/2023	10:19:00 AM	562	0.2	73	16.5	0	
Hamline Elementary School	1411	1/13/2023	10:08:00 AM	429	0.2	71.4	16.7	0	
Hamline Elementary School	1412	1/13/2023	10:17:00 AM	435	0.2	72.9	16	0	
Hamline Elementary School	1414	1/13/2023	10:16:00 AM	417	0.2	72.5	15.9	0	
Hamline Elementary School	1420	1/13/2023	10:13:00 AM	419	0.2	72.3	16.2	0	
Hamline Elementary School	1507	1/13/2023	10:28:00 AM	360	0.2	67.8	17.6	0	Plants
Hamline Elementary School	2201	1/13/2023	12:01:00 PM	835	0.2	70.3	21.7	18	
Hamline Elementary School	2202	1/13/2023	11:18:00 AM	871	0.2	69.6	22.8	18	
Hamline Elementary School	2203	1/13/2023	11:25:00 AM	864	0.2	69.8	23.4	24	
Hamline Elementary School	2204	1/13/2023	12:24:00 PM	834	0.2	69.6	23	15	
Hamline Elementary School	2205	1/13/2023	11:26:00 AM	883	0.2	70	22.7	25	
Hamline Elementary School	2206	1/13/2023	12:29:00 PM	881	0.2	69.4	24.1	23	
Hamline Elementary School	2213	1/13/2023	11:37:00 AM	775	0.2	70	21.2	0	
Hamline Elementary School	2217	1/13/2023	11:27:00 AM	973	0.2	70.3	23.3	24	
Hamline Elementary School	2218	1/13/2023	11:33:00 AM	967	0.2	69.4	23.5	20	
Hamline Elementary School	2219	1/13/2023	12:04:00 PM	801	0.2	70	22.3	1	
Hamline Elementary School	2220	1/13/2023	12:02:00 PM	818	0.5	69.1	22.9	5	
Hamline Elementary School	2221	1/13/2023	11:29:00 AM	774	0.2	70.2	21.6	0	
Hamline Elementary School	2222	1/13/2023	11:31:00 AM	791	0.2	69.4	23.5	5	
Hamline Elementary School	1000 MAIN OFFICE	1/13/2023	9:09:00 AM	438	0.3	72.9	17.3	2	
Hamline Elementary School	1001 OFFICE	1/13/2023	9:23:00 AM	441	0.2	72.5	17.4	1	
Hamline Elementary School	1003 CONFERENCE	1/13/2023	9:24:00 AM	425	0.2	72.1	17.4	0	
Hamline Elementary School	1004 COT	1/13/2023	9:29:00 AM	487	0.2	72	19.1	3	
Hamline Elementary School	1005 WORKROOM	1/13/2023	9:25:00 AM	391	0.2	71.8	17.2	1	
Hamline Elementary School	1006 OFFICE	1/13/2023	9:31:00 AM	584	0.2	72.9	19.1	2	
Hamline Elementary School	1008 OFFICE	1/13/2023	9:28:00 AM	456	0.2	71.2	18.9	0	
Hamline Elementary School	1010 PRINCIPAL OFFICE	1/13/2023	9:26:00 AM	435	0.2	71.4	18.7	0	
Hamline Elementary School	1012 LOUNGE	1/13/2023	9:33:00 AM	466	0.2	74.3	17.6	1	
Hamline Elementary School	1120 CAFETERIA	1/13/2023	9:44:00 AM	559	0.2	72.3	20.2	36	
Hamline Elementary School	1123 KITCHEN	1/13/2023	9:41:00 AM	498	0.3	71.8	17.7	1	
Hamline Elementary School	1208 MAINTENANCE OFFICE	1/13/2023	9:07:00 AM	331	0.2	73	18.3	1	
Hamline Elementary School	1211 OFFICE	1/13/2023	10:57:00 AM	809	0.2	71.1	21	0	
Hamline Elementary School	1215 OFFICE	1/13/2023	11:02:00 AM	746	0.2	71.2	20.8	1	Stained ceiling tiles
Hamline Elementary School	1223 OFFICE	1/13/2023	10:55:00 AM	737	0.2	71.6	20.2	0	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hamline Elementary School	1238 KITCHEN OFFICE	1/13/2023	9:43:00 AM	523	0.2	72	19.2	0	
Hamline Elementary School	1307 GYMNASIUM	1/13/2023	10:00:00 AM	434	0.2	70.9	18	0	
Hamline Elementary School	130B OFFICE	1/13/2023	10:41:00 AM	569	0.2	71.2	19.8	0	Stuffy odor
Hamline Elementary School	1411A OFFICE	1/13/2023	10:20:00 AM	451	0.2	72.5	76.1	1	Plants
Hamline Elementary School	1411B	1/13/2023	10:09:00 AM	420	0.2	71.2	16.5	0	
Hamline Elementary School	1411C OFFICE	1/13/2023	10:05:00 AM	421	0.2	71.6	16.1	2	
Hamline Elementary School	1501 REC CONFERENCE	1/13/2023	10:35:00 AM	352	0.2	69.4	16.7	0	
Hamline Elementary School	1503 RECEPTION OFFICE	1/13/2023	10:30:00 AM	392	0.2	67.8	17.7	0	
Hamline Elementary School	1503B OFFICE	1/13/2023	10:34:00 AM	357	0.2	68.5	17.3	0	
Hamline Elementary School	1504OFFICE	1/13/2023	10:38:00 AM	428	0.2	69.8	18	1	
Hamline Elementary School	1506 CONFERENCE	1/13/2023	10:39:00 AM	358	0.2	69.3	16.9	0	
Hamline Elementary School	1515 REC STUDIO	1/13/2023	10:21:00 AM	355	0.2	69.8	16	0	
Hamline Elementary School	2110 LIBRARY	1/13/2023	11:16:00 AM	788	0.2	69.1	22.1	0	
Hamline Elementary School	2211 OFFICE	1/13/2023	11:35:00 AM	790	0.2	69.4	21.8	0	
Hamline Elementary School	OUTDOORS	1/13/2023		355	0.2	19	27		
Harding Senior High School	1001	1/13/2023	12:13:00 PM	680	0.5	73.2	16.7	4	
Harding Senior High School	1003	1/13/2023	12:06:00 PM	584	0.4	72.9	15.3	0	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1005	1/13/2023	12:11:00 PM	710	0.5	73.9	16.3	1	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1006	1/13/2023	12:02:00 PM	576	0.4	70.7	16.3	0	
Harding Senior High School	1007	1/13/2023	12:04:00 PM	612	0.4	71.1	16.4	0	
Harding Senior High School	1010	1/13/2023	11:58:00 AM	662	0.5	70.7	16.2	1	
Harding Senior High School	1011	1/13/2023	12:00:00 PM	630	0.4	71.1	16.1	1	Stained ceiling tiles
Harding Senior High School	1012	1/13/2023	12:01:00 PM	682	0.5	70.9	16.8	1	
Harding Senior High School	1014	1/13/2023	11:52:00 AM	896	0.5	71.4	18.2	8	Condensation, Stained ceiling tiles
Harding Senior High School	1015	1/13/2023	11:55:00 AM	574	0.5	70.5	16.1	0	
Harding Senior High School	1017	1/13/2023	11:53:00 AM	552	0.4	71.6	15.2	0	
Harding Senior High School	1017	1/13/2023	11:59:00 AM	812	0.5	70.9	16.3	1	Stained ceiling tiles
Harding Senior High School	1018	1/13/2023	11:50:00 AM	630	0.5	71.6	16.5	1	
Harding Senior High School	1020	1/13/2023	11:43:00 AM	573	0.4	70.7	15.8	0	Stained ceiling tiles
Harding Senior High School	1021	1/13/2023	11:46:00 AM	637	0.5	71.9	15.7	1	
Harding Senior High School	1022	1/13/2023	11:47:00 AM	585	0.5	71.6	16.2	0	
Harding Senior High School	1103	1/13/2023	12:19:00 PM	841	0.5	69.3	24	0	
Harding Senior High School	1110	1/13/2023	1:09:00 PM	988	0.5	69.1	26.6	22	
Harding Senior High School	1114	1/13/2023	1:24:00 PM	577	0.4	71.2	21.9	1	
Harding Senior High School	1117	1/13/2023	1:26:00 PM	676	0.2	73.1	16.8	1	
Harding Senior High School	1120	1/13/2023	1:17:00 PM	463	0.1	71.3	11.7	1	
Harding Senior High School	1121	1/13/2023	1:12:00 PM	571	0.1	70.1	14.1	1	
Harding Senior High School	1123	1/13/2023	1:14:00 PM	471	0.1	71.3	12.3	1	
Harding Senior High School	1129	1/13/2023	12:32:00 PM	759	0.4	71.1	18.5	0	
Harding Senior High School	1129	1/13/2023	12:39:00 PM	573	0.5	70.2	16.5	1	Stained ceiling tiles
Harding Senior High School	1130	1/13/2023	12:50:00 PM	582	0.4	70.2	16.2	0	
Harding Senior High School	1131	1/13/2023	1:02:00 PM	794	0.4	70.7	18.9	8	Stained ceiling tiles
Harding Senior High School	1133	1/13/2023	12:59:00 PM	693	0.4	68.7	19.6	14	
Harding Senior High School	1134	1/13/2023	12:52:00 PM	567	0.5	69.4	16.7	2	Stained ceiling tiles
Harding Senior High School	1135	1/13/2023	12:57:00 PM	559	0.4	69.1	17.9	0	
Harding Senior High School	1136	1/13/2023	12:56:00 PM	586	0.4	68.7	17.6	0	
Harding Senior High School	1137	1/13/2023	12:54:00 PM	574	0.4	69.1	17	0	
Harding Senior High School	1138	1/13/2023	12:30:00 PM	868	0.4	70.3	190	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1139	1/13/2023	12:29:00 PM	696	0.4	70	17.5	6	
Harding Senior High School	1140	1/13/2023	12:28:00 PM	647	0.4	69.8	17.4	2	
Harding Senior High School	1142	1/13/2023	11:36:00 AM	533	0.5	70.3	15.6	0	
Harding Senior High School	1204	1/13/2023	9:11:00 AM	437	0.4	69.8	15.5	0	
Harding Senior High School	1205	1/13/2023	9:09:00 AM	734	0.5	71.2	17.9	32	
Harding Senior High School	1206	1/13/2023	9:05:00 AM	706	0.5	70.3	16.9	30	
Harding Senior High School	1208	1/13/2023	9:02:00 AM	461	0.4	70.3	15.9	0	Stained ceiling tiles
Harding Senior High School	1209	1/13/2023	9:04:00 AM	442	0.4	70.7	15.7	0	Stained ceiling tiles
Harding Senior High School	1212	1/13/2023	8:52:00 AM	458	0.5	70.6	15.3	0	
Harding Senior High School	1214	1/13/2023	8:44:00 AM	522	0.5	72.7	15.8	0	
Harding Senior High School	1215	1/13/2023	9:21:00 AM	464	0.5	72	14.6	1	Dirty or dusty carpet odor, Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1216	1/13/2023	9:36:00 AM	651	0.5	71.5	15.6	0	Dirty or dusty carpet odor
Harding Senior High School	1240	1/13/2023	9:59:00 AM	594	0.5	72	16	0	
Harding Senior High School	1241	1/13/2023	12:24:00 PM	622	0.4	69.6	17.2	0	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1244	1/13/2023	9:52:00 AM	855	0.5	72.5	18.8	1	
Harding Senior High School	1245	1/13/2023	9:55:00 AM	928	0.5	72.5	17.2	6	
Harding Senior High School	1246	1/13/2023	9:56:00 AM	758	0.5	72.9	16.1	6	
Harding Senior High School	1247	1/13/2023	9:58:00 AM	671	0.5	73.2	17.6	0	
Harding Senior High School	1301	1/13/2023	10:42:00 AM	1149	0.5	70.9	21.6	14	
Harding Senior High School	1302	1/13/2023	10:47:00 AM	976	0.5	70.2	22.8	34	
Harding Senior High School	1303	1/13/2023	10:49:00 AM	937	0.5	70.7	19.6	0	
Harding Senior High School	1305	1/13/2023	10:51:00 AM	752	0.6	70.5	18.5	24	
Harding Senior High School	1306	1/13/2023	10:52:00 AM	780	0.5	70.3	18.6	0	
Harding Senior High School	1307	1/13/2023	10:54:00 AM	862	0.6	70	20.2	17	
Harding Senior High School	1308	1/13/2023	10:57:00 AM	1138	0.5	69.6	22.7	15	
Harding Senior High School	1309	1/13/2023	10:58:00 AM	657	0.6	69.6	18.5	0	
Harding Senior High School	1310	1/13/2023	11:00:00 AM	958	0.4	71.2	19.9	26	
Harding Senior High School	1311	1/13/2023	11:03:00 AM	917	0.5	70.3	20.4	0	
Harding Senior High School	1312	1/13/2023	11:06:00 AM	1294	0.5	71.6	23	25	
Harding Senior High School	1313	1/13/2023	11:04:00 AM	683	0.5	71.2	18	8	
Harding Senior High School	1315	1/13/2023	11:09:00 AM	749	0.6	71.8	18	6	
Harding Senior High School	1316	1/13/2023	11:15:00 AM	1181	0.6	72.3	22.6	9	
Harding Senior High School	1317	1/13/2023	11:11:00 AM	683	0.6	70.9	17.6	6	
Harding Senior High School	1323	1/13/2023	11:13:00 AM	482	0.4	72	14.8	0	
Harding Senior High School	1323	1/13/2023	12:01:00 PM	582	0.1	70.8	13.9	1	
Harding Senior High School	1324	1/13/2023	11:16:00 AM	790	0.5	71.6	18.3	3	
Harding Senior High School	1325	1/13/2023	11:18:00 AM	1046	0.6	71.4	21.7	15	
Harding Senior High School	1326	1/13/2023	11:20:00 AM	655	0.5	68.5	18	1	
Harding Senior High School	1328	1/13/2023	11:23:00 AM	1257	0.6	69.1	24.4	26	
Harding Senior High School	1329	1/13/2023	11:25:00 AM	1056	0.6	70.7	22.2	23	
Harding Senior High School	1333	1/13/2023	11:28:00 AM	942	0.5	70.3	20.8	16	
Harding Senior High School	1334	1/13/2023	11:30:00 AM	786	0.5	69.3	19.8	1	
Harding Senior High School	1341	1/13/2023	12:55:00 PM	862	0.1	74.1	16.2	3	
Harding Senior High School	1342	1/13/2023	12:54:00 PM	826	0.1	73.5	16.7	2	Stained ceiling tiles
Harding Senior High School	1343	1/13/2023	12:52:00 PM	850	0.1	72.7	16.6	1	
Harding Senior High School	1345	1/13/2023	1:00:00 PM	946	0.1	74.1	16.6	20	
Harding Senior High School	1347	1/13/2023	10:28:00 AM	737	0.1	72.8	15.2	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1348	1/13/2023	10:29:00 AM	710	0.1	73.2	14.6	1	Fragrance odor
Harding Senior High School	1349	1/13/2023	10:31:00 AM	739	0.1	73.8	14.6	1	
Harding Senior High School	1350	1/13/2023	10:32:00 AM	700	0.1	74	13.7	0	
Harding Senior High School	1351	1/13/2023	10:33:00 AM	667	0.2	74	13.5	1	
Harding Senior High School	1352	1/13/2023	10:25:00 AM	731	0.2	73.3	14.8	0	
Harding Senior High School	1354	1/13/2023	10:23:00 AM	610	0.1	73.9	13.9	0	
Harding Senior High School	1355	1/13/2023	10:20:00 AM	641	0.1	71.6	14.6	2	
Harding Senior High School	1356	1/13/2023	10:21:00 AM	642	0.1	72.1	14.6	10	
Harding Senior High School	1358	1/13/2023	11:33:00 AM	673	0.4	70.3	17.3	3	
Harding Senior High School	1358	1/13/2023	10:17:00 AM	690		70.6	15.3	30	
Harding Senior High School	1359	1/13/2023	10:13:00 AM	548	0.1	70	14	15	
Harding Senior High School	1361	1/13/2023	10:12:00 AM	546	0.2	69.8	14.4	2	
Harding Senior High School	1363	1/13/2023	10:09:00 AM	536	0.1	69.2	14.2	1	
Harding Senior High School	1364	1/13/2023	10:07:00 AM	532	0.2	70.4	13.3	0	
Harding Senior High School	1366	1/13/2023	9:42:00 AM	513	0.2	69.5	13.4	8	
Harding Senior High School	1370	1/13/2023	10:02:00 AM	537	0.2	71	13.6	0	
Harding Senior High School	1371	1/13/2023	10:04:00 AM	630	0.2	71.5	14.7	2	
Harding Senior High School	1372	1/13/2023	10:01:00 AM	560	0.1	70.8	13.7	0	
Harding Senior High School	1373	1/13/2023	10:00:00 AM	549	0.1	71	13.7	0	
Harding Senior High School	1374	1/13/2023	9:58:00 AM	567	0.2	71.2	13.5	0	
Harding Senior High School	1375	1/13/2023	9:57:00 AM	575	0.2	71.4	13.7	1	
Harding Senior High School	1376	1/13/2023	9:56:00 AM	600	0.1	71.8	13.7	0	
Harding Senior High School	1378	1/13/2023	10:05:00 AM	662	0.1	71.7	14.7	1	
Harding Senior High School	1380	1/13/2023	9:55:00 AM	662	0.1	72	14.4	1	
Harding Senior High School	1381	1/13/2023	9:49:00 AM	658	0.1	70.5	14.8	1	
Harding Senior High School	1382	1/13/2023	9:53:00 AM	532	0.1	70	13.7	1	
Harding Senior High School	1383	1/13/2023	9:50:00 AM	608	0.1	70.4	13.6	0	
Harding Senior High School	1402	1/13/2023	10:38:00 AM	588	0.2	71.2	14.4	9	Stained ceiling tiles
Harding Senior High School	1403	1/13/2023	10:44:00 AM	770	0.2	70.6	17	2	
Harding Senior High School	1404	1/13/2023	10:42:00 AM	690	0.1	70.8	16	15	
Harding Senior High School	1405	1/13/2023	10:46:00 AM	806	0.2	70.4	17.5	30	
Harding Senior High School	1406	1/13/2023	10:49:00 AM	767	0.2	70	17.3	30	
Harding Senior High School	1407	1/13/2023	10:48:00 AM	717	0.1	70.3	16.4	35	Stained ceiling tiles
Harding Senior High School	1409	1/13/2023	10:52:00 AM	642	0.1	69.7	15.8	2	
Harding Senior High School	1410	1/13/2023	10:50:00 AM	891	0.1	70.3	18.9	30	
Harding Senior High School	1411	1/13/2023	10:54:00 AM	820	0.1	69.3	18.3	25	
Harding Senior High School	1412	1/13/2023	10:56:00 AM	688	0.1	69.9	18.3	20	
Harding Senior High School	1413	1/13/2023	10:58:00 AM	819	0.1	70.4	17	20	
Harding Senior High School	1415	1/13/2023	10:59:00 AM	834	0.1	70.9	17	20	
Harding Senior High School	1416	1/13/2023	11:01:00 AM	710	0.1	75.4	14.7	2	
Harding Senior High School	1417	1/13/2023	11:03:00 AM	771	0.2	72.5	15.4	1	
Harding Senior High School	1418	1/13/2023	11:06:00 AM	699	0.1	70.7	15.1	0	Stained ceiling tiles
Harding Senior High School	1419	1/13/2023	11:13:00 AM	815	0.1	70.8	16.4	10	
Harding Senior High School	1420	1/13/2023	11:05:00 AM	987	0.1	71.9	17.7	25	
Harding Senior High School	1421	1/13/2023	11:10:00 AM	738	0.1	70.9	16.2	1	
Harding Senior High School	1422	1/13/2023	12:31:00 PM	892	0.1	71.8	16.9	1	
Harding Senior High School	1423	1/13/2023	12:32:00 PM	992	0.2	71.8	19.2	20	
Harding Senior High School	1424	1/13/2023	12:28:00 PM	897	0.2	71.9	16.8	10	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1425	1/13/2023	12:29:00 PM	1069		72.3	20.3	25	Stuffy odor
Harding Senior High School	1426	1/13/2023	12:25:00 PM	914	0.2	71.5	16.8	15	
Harding Senior High School	1427	1/13/2023	12:27:00 PM	1054	0.1	72.5	19.9	30	
Harding Senior High School	1428	1/13/2023	12:21:00 PM	880	0.2	72.9	16.5	0	
Harding Senior High School	1429	1/13/2023	12:22:00 PM	913	0.1	72.9	16.8	0	
Harding Senior High School	1430	1/13/2023	12:19:00 PM	874	0.2	72.7	17.1	1	
Harding Senior High School	1431	1/13/2023	12:16:00 PM	841	0.1	72.4	16.9	0	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1432	1/13/2023	12:07:00 PM	910	0.2	71.7	17.1	15	
Harding Senior High School	1433	1/13/2023	12:08:00 PM	846	0.1	71.5	16.8	1	
Harding Senior High School	1434	1/13/2023	12:11:00 PM	948	0.1	70.8	17.9	30	
Harding Senior High School	1435	1/13/2023	12:12:00 PM	856	0.2	70.9	17.4	2	
Harding Senior High School	1436	1/13/2023	12:14:00 PM	944	0.1	71.2	17.8	10	
Harding Senior High School	1437	1/13/2023	12:15:00 PM	991	0.1	71.7	18.8	20	
Harding Senior High School	1438	1/13/2023	11:24:00 AM	918	0.1	71.2	17.2	20	
Harding Senior High School	1439	1/13/2023	11:18:00 AM	835	0.1	70.8	17	0	
Harding Senior High School	1440	1/13/2023	11:12:00 AM	713	0.1	71.1	15.3	20	
Harding Senior High School	1441	1/13/2023	11:15:00 AM	799	0.2	70.8	16.7	1	Fragrance odor
Harding Senior High School	1442	1/13/2023	11:23:00 AM	857	0.1	71.4	16.4	1	
Harding Senior High School	1443	1/13/2023	11:21:00 AM	854	0.1	71	16.9	1	
Harding Senior High School	1444	1/13/2023	11:29:00 AM	789	0.1	70.8	15.9	0	
Harding Senior High School	1445	1/13/2023	11:30:00 AM	870	0.1	70.9	17	15	
Harding Senior High School	1446	1/13/2023	11:32:00 AM	863	0.1	71	17.1	20	
Harding Senior High School	1448	1/13/2023	11:35:00 AM	780	0.1	69.6	16.4	25	
Harding Senior High School	1450	1/13/2023	11:37:00 AM	771	0.1	69.9	17.5	8	
Harding Senior High School	1451	1/13/2023	11:39:00 AM	691	0.1	70.2	16.3	3	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1452	1/13/2023	11:33:00 AM	877	0.1	70.7		25	
Harding Senior High School	1453	1/13/2023	11:40:00 AM	774	0.2	70.2	17.2	15	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1454	1/13/2023	11:44:00 AM	755	0.1	70.1	17.4	20	
Harding Senior High School	1455	1/13/2023	11:42:00 AM	739	0.2	70	16.6	4	
Harding Senior High School	1456	1/13/2023	11:46:00 AM	809	0.1	70.2	17.7	30	
Harding Senior High School	1457	1/13/2023	11:48:00 AM	698	0.1	69.9	16.5	1	
Harding Senior High School	1458	1/13/2023	11:53:00 AM	744	0.1	70.5	17	1	
Harding Senior High School	1459	1/13/2023	11:51:00 AM	711	0.1	70.2	16.9	1	
Harding Senior High School	1460	1/13/2023	11:58:00 AM	606	0.3	69.6	14.9	0	
Harding Senior High School	1461	1/13/2023	11:56:00 AM	679	0.2	71.8	15.2	0	
Harding Senior High School	1462	1/13/2023	11:55:00 AM	725	0.1	72.1	16.4	0	
Harding Senior High School	1600	1/13/2023	10:03:00 AM	502	0.4	69.6	16.2	0	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1601	1/13/2023	10:11:00 AM	517	0.4	70	15.8	0	
Harding Senior High School	1605	1/13/2023	10:12:00 AM	537	0.4	69.8	16.4	0	
Harding Senior High School	1606	1/13/2023	10:14:00 AM	499	0.4	68.7	16.4	0	
Harding Senior High School	1609	1/13/2023	10:16:00 AM	529	0.4	69.1	16.1	0	
Harding Senior High School	1610	1/13/2023	10:18:00 AM	517	0.4	69.4	15.8	0	
Harding Senior High School	1615	1/13/2023	10:20:00 AM	449	0.4	70	14.9	0	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1616	1/13/2023	10:22:00 AM	457	0.4	70.2	15	0	
Harding Senior High School	1617	1/13/2023	10:23:00 AM	444	0.4	71.1	14.2	0	
Harding Senior High School	1618	1/13/2023	10:25:00 AM	459	0.4	71.6	14.2	0	
Harding Senior High School	1621	1/13/2023	10:28:00 AM	453	0.4	69.8	14.7	0	
Harding Senior High School	1622	1/13/2023	10:26:00 AM	445	0.5	70.7	14.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1627	1/13/2023	10:29:00 AM	458	0.4	70	14.9	0	
Harding Senior High School	1631	1/13/2023	10:37:00 AM	452	0.3	70.7	14.3	0	
Harding Senior High School	1632	1/13/2023	10:39:00 AM	463	0.4	70.5	14.4	0	
Harding Senior High School	1633	1/13/2023	10:42:00 AM	449	0.4	70.3	14.7	0	
Harding Senior High School	1112E	1/13/2023	1:21:00 PM	804	0.2	71	13.6	1	
Harding Senior High School	1112W	1/13/2023	1:23:00 PM	499	0.1	70.9	13.1	2	
Harding Senior High School	1118A	1/13/2023	1:09:00 PM	712	0.1	71.6	16.7	1	
Harding Senior High School	1126/1127	1/13/2023	12:19:00 PM	624	0.5	69.8	17.2	0	
Harding Senior High School	1205A	1/13/2023	9:08:00 AM	450	0.4	68.9	16.2	0	
Harding Senior High School	1244 ART	1/13/2023	9:49:00 AM	819	0.4	72.1	16.6	26	
Harding Senior High School	1244A	1/13/2023	9:52:00 AM	734	0.4	72.5	17.8	0	
Harding Senior High School	1340E	1/13/2023	12:49:00 PM	844	0.1	72.1	17.1	5	
Harding Senior High School	1340W	1/13/2023	12:50:00 PM	810	0.2	72.4	16.5	10	
Harding Senior High School	1352 OFFICE	1/13/2023	10:36:00 AM	699	0.2	73.9	13.9	0	
Harding Senior High School	1380 WAITING ROOM	1/13/2023	9:47:00 AM	701	0.1	70	16	1	
Harding Senior High School	AUDITORIUM	1/13/2023	9:12:00 AM	416	0.4	69.6	14.9	0	
Harding Senior High School	AUTO SHOP	1/13/2023	9:37:00 AM	431	0.4	70.5	15	0	
Harding Senior High School	CAFETERIA	1/13/2023	12:14:00 PM	786	0.5	71.8	21.3	75	
Harding Senior High School	CUSTODIAL OFFICE	1/13/2023	1:51:00 PM	613	0.5	72.5	18.3	3	
Harding Senior High School	KITCHEN	1/13/2023	12:17:00 PM	723	0.5	67.6	24.5	6	
Harding Senior High School	OUTDOORS	1/13/2023	8:23:00 AM	654	0.3	17.2	35.6		
Harding Senior High School	OUTDOORS	1/13/2023		501	0.3	21.1	80.1		
Harding Senior High School	PREK KITCHEN	1/13/2023	10:36:00 AM	457	0.4	70.3	4.4	0	
Harding Senior High School	ROOM ACROSS CROM PREK KIT	1/13/2023	10:34:00 AM	432	0.4	70.5	14.4	0	
Harding Senior High School	ROOM ACROSS FROM 1627	1/13/2023	10:34:00 AM	495	0.4	70.2	14.7	0	
Harding Senior High School	STAGE	1/13/2023	9:17:00 AM	414	0.4	69.3	15	0	
Hazel Park Academy	1002	1/12/2023	10:37:00 AM	672	0.5	71.8	19.8	2	
Hazel Park Academy	1003	1/12/2023	10:48:00 AM	631	0.6	71.1	19.4	0	
Hazel Park Academy	1004	1/12/2023	10:41:00 AM	599	0.5	74.8	17.2	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	1005	1/12/2023	10:45:00 AM	658	0.5	72.9	19	1	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	1006	1/12/2023	10:44:00 AM	672	0.5	72.5	19.3	0	
Hazel Park Academy	1007	1/12/2023	10:43:00 AM	768	0.5	73.8	20.9	1	
Hazel Park Academy	1008	1/12/2023	10:40:00 AM	630	0.5	70.9	19.6	0	
Hazel Park Academy	1011	1/12/2023	10:30:00 AM	783	0.5	71.2	20.6	2	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	1012	1/12/2023	10:26:00 AM	662	0.5	70.3	21	0	
Hazel Park Academy	1014	1/12/2023	10:34:00 AM	774	0.5	70.7	20.5	1	
Hazel Park Academy	1015	1/12/2023	10:36:00 AM	868	0.5	72.1	20.9	0	
Hazel Park Academy	1101	1/12/2023	10:49:00 AM	460	0.4	69.8	18.5	0	
Hazel Park Academy	1104	1/12/2023	10:25:00 AM	580	0.5	70	20.4	0	
Hazel Park Academy	1107	1/12/2023	10:22:00 AM	652	0.4	70	21.1	2	
Hazel Park Academy	1110	1/12/2023	10:58:00 AM	621	0.5	71.5	20.2	0	
Hazel Park Academy	1113	1/12/2023	10:57:00 AM	902	0.6	73	24.7	1	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	1114	1/12/2023	10:52:00 AM	888	0.4	73.9	23.1	32	
Hazel Park Academy	1201	1/12/2023	10:19:00 AM	622	0.5	70.5	20.9	1	
Hazel Park Academy	1202	1/12/2023	10:18:00 AM	770	0.5	70.9	22.1	2	
Hazel Park Academy	1205	1/12/2023	10:15:00 AM	978	0.6	69.8	22.5	2	
Hazel Park Academy	1302	1/12/2023	10:04:00 AM	623	0.5	70.7	20.1	0	
Hazel Park Academy	1305	1/12/2023	9:06:00 AM	913	0.4	69.3	23.7	17	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hazel Park Academy	1306	1/12/2023	10:02:00 AM	1054	0.6	70.9	23.4	15	
Hazel Park Academy	1307	1/12/2023	9:10:00 AM	869	0.4	70	22.8	12	
Hazel Park Academy	1308	1/12/2023	9:59:00 AM	1037	0.5	71.6	23	14	
Hazel Park Academy	1309	1/12/2023	9:12:00 AM	786	0.4	70.9	22.2	13	Stained ceiling tiles
Hazel Park Academy	1310	1/12/2023	9:55:00 AM	813	0.5	70.5	22.8	8	Aquariums (fish)
Hazel Park Academy	1311	1/12/2023	9:15:00 AM	923	0.4	70.7	22	9	Stained ceiling tiles
Hazel Park Academy	1312	1/12/2023	9:53:00 AM	613	0.5	69.8	20.6	0	
Hazel Park Academy	1313	1/12/2023	9:18:00 AM	647	0.4	70	21	2	Stained ceiling tiles
Hazel Park Academy	1315	1/12/2023	9:25:00 AM	1032	0.5	70.5	24.3	16	Stained ceiling tiles
Hazel Park Academy	1316	1/12/2023	9:43:00 AM	950	0.6	69.8	23.7	12	
Hazel Park Academy	1317	1/12/2023	9:27:00 AM	627	0.5	68.9	21.4	2	
Hazel Park Academy	1318	1/12/2023	9:41:00 AM	984	0.5	70.2	24.3	14	
Hazel Park Academy	1319	1/12/2023	9:30:00 AM	690	0.5	69.3	21.3	13	
Hazel Park Academy	1320	1/12/2023	9:37:00 AM	652	0.5	70.2	21.4	5	Musty odor, Stained ceiling tiles
Hazel Park Academy	1321	1/12/2023	9:35:00 AM	595	0.5	69.1	21.6	2	Stained ceiling tiles
Hazel Park Academy	1402	1/12/2023	10:10:00 AM	509	0.6	70.9	19.7	0	
Hazel Park Academy	1403	1/12/2023	10:12:00 AM	654	0.5	72.2	20.4	6	
Hazel Park Academy	1404	1/12/2023	10:14:00 AM	521	0.5	71.1	19.9	0	
Hazel Park Academy	2301	1/12/2023	11:01:00 AM	582	0.5	69.3	19.3	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2303	1/12/2023	11:10:00 AM	1013	0.5	70.7	23.7	14	
Hazel Park Academy	2304	1/12/2023	11:44:00 AM	638	0.5	69.8	20.6	0	
Hazel Park Academy	2304	1/12/2023	11:50:00 AM	842	0.5	68.9	23.5	12	
Hazel Park Academy	2305	1/12/2023	11:12:00 AM	1139	0.5	70.3	24.3	30	
Hazel Park Academy	2306	1/12/2023	11:46:00 AM	651	0.5	70.3	20.5	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2307	1/12/2023	11:14:00 AM	612	0.4	70.2	20.1	1	
Hazel Park Academy	2308	1/12/2023	11:40:00 AM	974	0.5	70.7	21.4	5	
Hazel Park Academy	2309	1/12/2023	11:16:00 AM	615	0.5	70.3	20.1	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2310	1/12/2023	11:39:00 AM	653	0.5	71.5	19.6	2	
Hazel Park Academy	2311	1/12/2023	11:17:00 AM	983	0.5	71.2	23.1	12	
Hazel Park Academy	2312	1/12/2023	11:37:00 AM	1252	0.5	72.1	24.5	8	
Hazel Park Academy	2313	1/12/2023	11:19:00 AM	972	0.5	72.3	23.8	11	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2314	1/12/2023	11:33:00 AM	912	0.5	71.4	25.9	12	
Hazel Park Academy	2315	1/12/2023	11:21:00 AM	761	0.5	72.1	20.4	9	Stained ceiling tiles
Hazel Park Academy	2317	1/12/2023	11:23:00 AM	869	0.5	71.8	21.9	14	
Hazel Park Academy	2318	1/12/2023	11:57:00 AM	995	0.5	69.8	23.8	15	
Hazel Park Academy	2319	1/12/2023	11:25:00 AM	629	0.5	70.2	19.8	1	
Hazel Park Academy	2320	1/12/2023	11:31:00 AM	983	0.5	70.7	22.8	16	
Hazel Park Academy	2321	1/12/2023	11:27:00 AM	615	0.5	70	19.8	0	
Hazel Park Academy	2322	1/12/2023	11:29:00 AM	678	0.4	71.1	20	0	
Hazel Park Academy	2401	1/12/2023	11:09:00 AM	547	0.4	70.7	19.2	0	
Hazel Park Academy	2402	1/12/2023	11:06:00 AM	519	0.4	70.2	19.9	0	
Hazel Park Academy	1013 COT ROOM	1/12/2023	10:32:00 AM	612	0.5	70	19.9	0	
Hazel Park Academy	1312A	1/12/2023	9:50:00 AM	982	0.5	69.8	24.5	22	
Hazel Park Academy	1314 STORAGE COMPUTER ROOM	1/12/2023	9:47:00 AM	695	0.5	69.1	23.4	1	
Hazel Park Academy	1314A	1/12/2023	9:44:00 AM	674	0.5	69.8	21.8	1	
Hazel Park Academy	2302A	1/12/2023	11:56:00 AM	887	0.4	69.6	23.5	7	
Hazel Park Academy	2302B	1/12/2023	11:52:00 AM	626	0.5	20.8	68.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hazel Park Academy	2306A	1/12/2023	11:48:00 AM	796	0.6	69.6	22.2	2	
Hazel Park Academy	COMPUTER LAB	1/12/2023	9:02:00 AM	489	0.4	68	21.1	0	Stained ceiling tiles
Hazel Park Academy	CUSTODIAL OFFICE	1/12/2023	12:08:00 PM	875	0.6	71.2	21.9	1	
Hazel Park Academy	KITCHEN	1/12/2023	10:56:00 AM	791	0.6	73.8	23.5	1	
Hazel Park Academy	MEDIA CENTER	1/12/2023	10:07:00 AM	983	0.5	70.7	22.5	20	
Hazel Park Academy	OUTDOORS	1/12/2023		432	0.2	23	31.6		
Hidden River Middle School	1001	12/14/2022	10:48:00 AM	582	0.2	75.2	25.4	3	Plants
Hidden River Middle School	1002	12/14/2022	10:49:00 AM	571	0.2	74.5	26	0	
Hidden River Middle School	1004	12/14/2022	10:52:00 AM	575	0.2	74.1	25.8	0	
Hidden River Middle School	1005	12/14/2022	10:51:00 AM	615	0.2	74.7	27.1	1	
Hidden River Middle School	1006	12/14/2022	10:54:00 AM	652	0.2	73.6	30.4	3	
Hidden River Middle School	1007	12/14/2022	10:47:00 AM	605	0.2	75.4	25.7	1	
Hidden River Middle School	1008	12/14/2022	10:42:00 AM	629	0.2	75	25.8	1	
Hidden River Middle School	1009	12/14/2022	10:43:00 AM	551	0.3	74.8	25	0	
Hidden River Middle School	1011	12/14/2022	10:37:00 AM	593	0.2	74.3	26.5	0	
Hidden River Middle School	1012	12/14/2022	10:40:00 AM	570	0.2	73.8	26.1	0	
Hidden River Middle School	1013	12/14/2022	10:39:00 AM	582	0.3	73.4	26.9	0	
Hidden River Middle School	1014	12/14/2022	10:30:00 AM	625	0.2	72.3	29	1	
Hidden River Middle School	1015	12/14/2022	10:32:00 AM	656	0.2	72.1	28.8	1	
Hidden River Middle School	1016	12/14/2022	10:33:00 AM	664	0.2	72.7	29	1	
Hidden River Middle School	1101	12/14/2022	10:58:00 AM	706	0.2	73.4	27.5	12	Stuffy odor
Hidden River Middle School	1102	12/14/2022	10:59:00 AM	825	0.2	74.3	28.9	25	Stuffy odor
Hidden River Middle School	1106	12/14/2022	10:28:00 AM	521	0.2	72.5	28.3	2	
Hidden River Middle School	1107	12/14/2022	10:20:00 AM	712	0.2	74.1	28.5	2	
Hidden River Middle School	1108	12/14/2022	10:27:00 AM	607	0.2	73.8	28.9	1	Plants
Hidden River Middle School	1204	12/14/2022	11:58:00 AM	629	0.2	71.4	28.9	1	
Hidden River Middle School	1205	12/14/2022	9:39:00 AM	589	0.3	71.1	29.1	15	
Hidden River Middle School	1206	12/14/2022	9:44:00 AM	515	0.3	71.1	27.7	0	Bubbling/peeling paint
Hidden River Middle School	1208	12/14/2022	9:47:00 AM	590	0.3	71.2	30.2	1	
Hidden River Middle School	1209	12/14/2022	9:50:00 AM	515	0.2	71.2	28.3	0	
Hidden River Middle School	1212	12/14/2022	9:52:00 AM	487	0.3	0.3	28.2	0	
Hidden River Middle School	1213	12/14/2022	9:56:00 AM	650	0.2	70	30.2	15	
Hidden River Middle School	1215	12/14/2022	9:58:00 AM	510	0.2	69.6	28.7	1	
Hidden River Middle School	1302	12/14/2022	11:59:00 AM	765	0.2	71.4	30.2	12	
Hidden River Middle School	1303	12/14/2022	12:02:00 PM	841	0.3	73.8	30.2	5	
Hidden River Middle School	1304	12/14/2022	12:04:00 PM	628	0.3	73.8	27.4	0	
Hidden River Middle School	1305	12/14/2022	9:59:00 AM	705	0.3	73	28.6	0	Bubbling/peeling paint
Hidden River Middle School	1306	12/14/2022	10:05:00 AM	595	0.2	73.4	26.7	0	
Hidden River Middle School	1308	12/14/2022	10:17:00 AM	725	0.2	73.9	28.7	0	
Hidden River Middle School	1310	12/14/2022	10:11:00 AM	671	0.3	73.9	26.5	1	
Hidden River Middle School	2101	12/14/2022	11:04:00 AM	896	0.2	72.9	30.5	12	
Hidden River Middle School	2103	12/14/2022	11:07:00 AM	621	0.2	71.4	28.3	0	
Hidden River Middle School	2103	12/14/2022	11:08:00 AM	746	0.2	71.1	29.7	6	Plants
Hidden River Middle School	2105	12/14/2022	12:19:00 PM	609	0.2	69.3	29.8	0	Stained ceiling tiles
Hidden River Middle School	2107	12/14/2022	11:15:00 AM	633	0.2	71.1	28	0	
Hidden River Middle School	2108	12/14/2022	11:10:00 AM	1089	0.2	70.7	33.7	22	Stuffy odor, Stained ceiling tiles
Hidden River Middle School	2109	12/14/2022	11:16:00 AM	826	0.2	70.9	33	28	Stained ceiling tiles
Hidden River Middle School	2111	12/14/2022	12:20:00 PM	775	0.2	71.2	36.7	19	Stuffy odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hidden River Middle School	2111	12/14/2022	11:18:00 AM	1062	0.3	72	31.3	22	Stuffy odor, Stained ceiling tiles
Hidden River Middle School	2112	12/14/2022	12:24:00 PM	764	0.2	73.6	29.1	22	Stuffy odor
Hidden River Middle School	2114	12/14/2022	11:26:00 AM	756	0.2	71.2	30.3	1	
Hidden River Middle School	2116	12/14/2022	11:23:00 AM	769	0.2	71.8	29.6	0	Stuffy odor
Hidden River Middle School	2119	12/14/2022	11:27:00 AM	778	0.2	71.6	31.4	3	Stained ceiling tiles
Hidden River Middle School	2201	12/14/2022	11:30:00 AM	749	0.2	72.1	30	1	Fragrance odor, Stained ceiling tiles
Hidden River Middle School	2202	12/14/2022	11:31:00 AM	890	0.3	72	30.2	21	
Hidden River Middle School	2204	12/14/2022	11:34:00 AM	679	0.2	71.4	32.6	22	Stained ceiling tiles
Hidden River Middle School	2302	12/14/2022	11:37:00 AM	736	0.2	70.3	30.7	21	
Hidden River Middle School	2303	12/14/2022	11:44:00 AM	872	0.2	68.9	35.1	11	
Hidden River Middle School	2304	12/14/2022	11:46:00 AM	739	0.2	68.7	32.4	2	
Hidden River Middle School	2305	12/14/2022	11:48:00 AM	798	0.2	68.5	32.9	21	Stained ceiling tiles
Hidden River Middle School	3101	12/14/2022	12:43:00 PM	717	0.2	72.5	29.9	26	
Hidden River Middle School	3103	12/14/2022	12:40:00 PM	739	0.2	70.7	31.1	24	
Hidden River Middle School	3105	12/14/2022	12:45:00 PM	960	0.3	72.3	31.5	3	
Hidden River Middle School	3107	12/14/2022	12:39:00 PM	920	0.2	71.2	34.6	15	Stained ceiling tiles
Hidden River Middle School	3110	12/14/2022	12:37:00 PM	34.1	0.2	70.2	34.6	20	Stained ceiling tiles
Hidden River Middle School	3112	12/14/2022	12:31:00 PM	561	0.3	70.9	28.9	0	
Hidden River Middle School	3114	12/14/2022	12:29:00 PM	833	0.2	72.5	34.4	26	
Hidden River Middle School	3116	12/14/2022	12:25:00 PM	808	0.3	71.6	30.4	22	
Hidden River Middle School	2303A	12/14/2022	11:38:00 AM	562	0.2	68.7	30.2	0	Stained ceiling tiles
Hidden River Middle School	OUTDOORS	12/14/2022		406	1.2	36	52.5		
Highland Park Elementary School	205	3/1/2023	11:35:00 AM	520		71.3	23.4	3	
Highland Park Elementary School	251	3/1/2023	11:36:00 AM	510		71.1	23.7	0	
Highland Park Elementary School	1101	3/1/2023	10:19:00 AM	553		72.2	23.8	2	
Highland Park Elementary School	1102	3/1/2023	10:23:00 AM	608		72.8	23	0	
Highland Park Elementary School	1104	3/1/2023	10:16:00 AM	830		71.9	25.5	20	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1105	3/1/2023	9:05:00 AM	1071		73.8	30	26	
Highland Park Elementary School	1106	3/1/2023	10:24:00 AM	523		72.9	22.6	0	
Highland Park Elementary School	1107	3/1/2023	10:27:00 AM	602		73.2	23.9	3	
Highland Park Elementary School	1108	3/1/2023	9:02:00 AM	601		74.5	22.7	1	
Highland Park Elementary School	1109	3/1/2023	9:13:00 AM	543		71.1	23.9	2	
Highland Park Elementary School	1110	3/1/2023	9:08:00 AM	720		72.1	24	21	
Highland Park Elementary School	1111	3/1/2023	9:11:00 AM	536		71.2	23.4	22	
Highland Park Elementary School	1112	3/1/2023	9:14:00 AM	511		72.1	23.8	18	
Highland Park Elementary School	1213	3/1/2023	9:30:00 AM	852		69.5	29.2	20	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1214	3/1/2023	9:38:00 AM	517		70.5	25.3	2	
Highland Park Elementary School	1215	3/1/2023	9:42:00 AM	722		71.3	26.6	28	
Highland Park Elementary School	1216	3/1/2023	9:46:00 AM	727		70.8	26.3	29	
Highland Park Elementary School	1217	3/1/2023	9:44:00 AM	691		71.1	26.4	22	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1218	3/1/2023	9:40:00 AM	691		70.7	26.6	17	
Highland Park Elementary School	1219	3/1/2023	9:36:00 AM	669		70.3	26.9	22	
Highland Park Elementary School	1220	3/1/2023	9:33:00 AM	570		70.2	26.4	4	Bubbling/peeling paint, Stained ceiling tiles
Highland Park Elementary School	1304	3/1/2023	9:52:00 AM	543		71.3	24.1	0	
Highland Park Elementary School	1305	3/1/2023	9:53:00 AM	523		71.5	24.3	2	
Highland Park Elementary School	1306	3/1/2023	9:55:00 AM	570		71.8	24.6	1	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	2001	3/1/2023	10:10:00 AM	616		71.9	24.6	2	Plants
Highland Park Elementary School	2002	3/1/2023	10:12:00 AM	524		72.2	23.5	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Elementary School	2003	3/1/2023	10:13:00 AM	660		69.8	24.7	12	Plants
Highland Park Elementary School	2005	3/1/2023	11:32:00 AM	632		72.2	24.9	0	
Highland Park Elementary School	2009	3/1/2023	10:04:00 AM	603		70.9	24.1	7	
Highland Park Elementary School	2010	3/1/2023	9:57:00 AM	644		71.8	23.3	0	
Highland Park Elementary School	2011	3/1/2023	10:00:00 AM	677		71.4	22.1	13	
Highland Park Elementary School	2012	3/1/2023	10:05:00 AM	820		71.1	22.9	14	
Highland Park Elementary School	2014	3/1/2023	10:08:00 AM	676		71.9	25.7	13	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	2101	3/1/2023	11:14:00 AM	664		72.3	24.8	4	
Highland Park Elementary School	2102	3/1/2023	10:29:00 AM	567		73.2	22.6	0	Plants
Highland Park Elementary School	2103	3/1/2023	10:33:00 AM	698		73.3	23.6	4	Plants
Highland Park Elementary School	2104	3/1/2023	10:46:00 AM	612		73.1	22.6	1	
Highland Park Elementary School	2105	3/1/2023	10:46:00 AM	506		73.5	22.2	0	
Highland Park Elementary School	2106	3/1/2023	10:48:00 AM	583		73.4	23.3	2	
Highland Park Elementary School	2109	3/1/2023	10:36:00 AM	513		73	22.8	0	
Highland Park Elementary School	2110	3/1/2023	10:35:00 AM	473		72.8	22.4	1	Stained ceiling tiles
Highland Park Elementary School	2111	3/1/2023	10:40:00 AM	449		72.5	22.4	0	
Highland Park Elementary School	2112	3/1/2023	10:38:00 AM	511		72.6	22.9	4	
Highland Park Elementary School	2115	3/1/2023	10:50:00 AM	606		72.6	24.5	6	
Highland Park Elementary School	2117	3/1/2023	10:51:00 AM	866		72.7	26.3	25	
Highland Park Elementary School	2118	3/1/2023	10:53:00 AM	1004		73.3	28.3	23	
Highland Park Elementary School	2123	3/1/2023	11:01:00 AM	502		72.7	24.3	0	
Highland Park Elementary School	2124	3/1/2023	11:04:00 AM	718		72.5	25.7	25	
Highland Park Elementary School	2125	3/1/2023	11:07:00 AM	668		72.2	24.1	6	Natural gas odor
Highland Park Elementary School	1101A	3/1/2023	10:21:00 AM	646		72.4	24.5	2	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1101B	3/1/2023	10:18:00 AM	559		71.8	23.3	1	Stained ceiling tiles
Highland Park Elementary School	1113 STAFF LOUNGE	3/1/2023	9:18:00 AM	743		72.1	27.4	3	
Highland Park Elementary School	1118 KITCHEN	3/1/2023	9:26:00 AM	542		68	27	5	
Highland Park Elementary School	1118A	3/1/2023	9:29:00 AM	459		69	26.5	1	
Highland Park Elementary School	1119 CAFETERIA	3/1/2023	9:23:00 AM	625		69.5	26.2	50	
Highland Park Elementary School	1120 GYM	3/1/2023	9:22:00 AM	560		69.9	24.6	18	
Highland Park Elementary School	1120C	3/1/2023	11:21:00 AM	526		70.4	26.1	1	
Highland Park Elementary School	1303 MEDIA CENTER	3/1/2023	9:49:00 AM	520		71.5	24.5	1	
Highland Park Elementary School	2109B	3/1/2023	10:42:00 AM	449		72.8	22.4	0	
Highland Park Elementary School	2115A	3/1/2023	10:59:00 AM	589		73	24.2	0	
Highland Park Elementary School	2122A	3/1/2023	10:59:00 AM	479		72.5	24.2	0	
Highland Park Elementary School	2122B	3/1/2023	11:11:00 AM	619	0.1	71.9	26.1	1	
Highland Park Elementary School	5TH GRADE COMMONS	3/1/2023	11:17:00 AM	531		71.3	25.1	0	
Highland Park Elementary School	OUTDOORS	3/1/2023		442	2.7	36	80		
Highland Park Middle School	105	1/6/2023	11:24:00 AM	727		71	17	0	
Highland Park Middle School	108	1/6/2023	11:27:00 AM	659	0.1	70.9	15.6	1	
Highland Park Middle School	1002	1/6/2023	9:13:00 AM	528		71.7	14.6	0	Stained ceiling tiles
Highland Park Middle School	1003	1/6/2023	11:19:00 AM	565	0.1	73.4	12.1	2	
Highland Park Middle School	1004	1/6/2023	9:15:00 AM	560	0.2	69.3	14.4	1	Stained ceiling tiles
Highland Park Middle School	1005	1/6/2023	11:18:00 AM	628	0.1	73.6	11.6	2	Plants: Kept Away From Return And Supply Vents
Highland Park Middle School	1006	1/6/2023	9:29:00 AM	543	0.1	70	13.5	1	
Highland Park Middle School	1007	1/6/2023	9:26:00 AM	570	0.2	72.9	13.3	1	Plants
Highland Park Middle School	1008	1/6/2023	9:16:00 AM	560		72.1	14.1	1	Stained ceiling tiles
Highland Park Middle School	1009	1/6/2023	9:24:00 AM	514		73.4	13.2	0	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Middle School	1010	1/6/2023	11:08:00 AM	520	0.1	73.6	11.5	0	Plants
Highland Park Middle School	1012	1/6/2023	9:21:00 AM	528	0.1	72.1	13.7	1	Stained ceiling tiles
Highland Park Middle School	1013	1/6/2023	9:20:00 AM	547		72.7	13.8	2	
Highland Park Middle School	1015	1/6/2023	9:28:00 AM	621	0.2	71	14.9	2	
Highland Park Middle School	1111	1/6/2023	4:09:00 PM	913		83.2	17.5	0	Stained ceiling tiles
Highland Park Middle School	1208	1/6/2023	9:34:00 AM	712	0.1	67.8	12.5	24	
Highland Park Middle School	1214	1/6/2023	9:37:00 AM	642	0.2	68.5	13.6	17	
Highland Park Middle School	1215	1/6/2023	9:39:00 AM	846		68.9	17.8	28	
Highland Park Middle School	1301	1/6/2023	10:52:00 AM	881	0.1	74.6	13	27	
Highland Park Middle School	1302	1/6/2023	10:51:00 AM	871		74	16.2	28	
Highland Park Middle School	1304	1/6/2023	10:49:00 AM	900	0.1	71.1	18.1	21	
Highland Park Middle School	1305	1/6/2023	10:44:00 AM	820	0.1	71.8	16.1	26	
Highland Park Middle School	1306	1/6/2023	10:47:00 AM	963	0.1	71.1	17.5	22	
Highland Park Middle School	1307	1/6/2023	10:40:00 AM	840	0.1	71.4	16.1	20	
Highland Park Middle School	1308	1/6/2023	10:41:00 AM	950	0.1	72	16.4	21	
Highland Park Middle School	1309	1/6/2023	10:36:00 AM	719	0.1	69.1	15.7	0	Fragrance odor, Stained ceiling tiles
Highland Park Middle School	1310	1/6/2023	9:43:00 AM	571	0.1	70.6	13.9	0	Plants
Highland Park Middle School	1311	1/6/2023	9:46:00 AM	816	0.2	72.9	16.3	26	
Highland Park Middle School	1312	1/6/2023	9:44:00 AM	638		72.4	14.4	5	Stained ceiling tiles, Plants
Highland Park Middle School	1313	1/6/2023	10:05:00 AM	752	0.2	75	13	11	
Highland Park Middle School	1314	1/6/2023	9:53:00 AM	815	0.1	73.3	15.8	28	Stained ceiling tiles, Plants
Highland Park Middle School	1315	1/6/2023	10:06:00 AM	569	0.2	74.4	13.1	1	
Highland Park Middle School	1316	1/6/2023	9:51:00 AM	745	0.1	72.1	14.8	19	
Highland Park Middle School	1317	1/6/2023	10:07:00 AM	638	0.1	72.3	14.3	2	
Highland Park Middle School	1319	1/6/2023	10:16:00 AM	650	0.2	69.5	12.5	3	
Highland Park Middle School	1320	1/6/2023	9:54:00 AM	708		73.2	15.5	25	Stained ceiling tiles
Highland Park Middle School	1321	1/6/2023	10:10:00 AM	468	0.1	70.1	9.8	0	
Highland Park Middle School	1323	1/6/2023	10:57:00 AM	790		71.6	18.6	23	
Highland Park Middle School	1325	1/6/2023	10:55:00 AM	595	0.1	71.8	8.9	8	
Highland Park Middle School	1401	1/6/2023	4:03:00 PM	1070	0.1	72.6	19.7	25	
Highland Park Middle School	1403	1/6/2023	11:05:00 AM	1398	0.1	72.5	14.1	22	Bubbling/peeling paint, Plants
Highland Park Middle School	1405	1/6/2023	11:00:00 AM	674		72.5	15.1	2	Bubbling/peeling paint
Highland Park Middle School	1406	1/6/2023	10:58:00 AM	555	0.1	71.4	13.2	0	
Highland Park Middle School	1408	1/6/2023	10:34:00 AM	536		70.3	15.3	1	
Highland Park Middle School	1409	1/6/2023	10:31:00 AM	570	0.3	69.8	15	1	Plants
Highland Park Middle School	1409	1/6/2023	1:05:00 PM	1062	0.1	72	19.5	21	Bubbling/peeling paint
Highland Park Middle School	1413	1/6/2023	10:01:00 AM	738	0.1	76.6	13.4	2	
Highland Park Middle School	1415	1/6/2023	9:56:00 AM	1480	0.1	73.4	20.6	22	Fragrance odor, Plants, Taxidermy
Highland Park Middle School	1416	1/6/2023	9:58:00 AM	1512	0.2	72.9	21.6	23	Stained ceiling tiles
Highland Park Middle School	2401	1/6/2023	12:20:00 PM	1282		71.7	21	28	
Highland Park Middle School	2403	1/6/2023	12:12:00 PM	1282		72.4	20.1	22	Bubbling/peeling paint
Highland Park Middle School	2405	1/6/2023	4:32:00 PM	1708	0.1	72.4	22.4	24	
Highland Park Middle School	2406	1/6/2023	12:18:00 PM	935		72	17.8	0	Bubbling/peeling paint
Highland Park Middle School	2407	1/6/2023	12:06:00 PM	1070		71.8	18.8	19	Live animals: Kept Away From Return And Supply Vents
Highland Park Middle School	2410	1/6/2023	11:48:00 AM	997	0.1	74.3	17.6	5	Bubbling/peeling paint, Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Highland Park Middle School	2411	1/6/2023	11:58:00 AM	1103		71.6	20	15	Bubbling/peeling paint, Moisture damage at Northern most sink
Highland Park Middle School	2413	1/6/2023	11:50:00 AM	2809	0.2	73.7	31.2	23	Bubbling/peeling paint, Condensation

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Middle School	2415	1/6/2023	11:46:00 AM	984		73.7	17.9	19	Stained ceiling tiles
Highland Park Middle School	2417	1/6/2023	11:44:00 AM	1810	0.1	72.8	23.7	1	Bubbling/peeling paint
Highland Park Middle School	3401	1/6/2023	12:24:00 PM	1186		72.8	23.2	23	
Highland Park Middle School	3403	1/6/2023	12:26:00 PM	1080		73	15.7	24	Moisture damage at NW corner by window, Plants: Kept Away From Return And Supply Vents
Highland Park Middle School	3405	1/6/2023	12:32:00 PM	1575		71.4	24.4	21	Fragrance odor, Bubbling/peeling paint
Highland Park Middle School	3406	1/6/2023	12:30:00 PM	783	0.2	71.8	16.5	1	
Highland Park Middle School	3407	1/6/2023	12:35:00 PM	996		71.2	16.5	21	Bubbling/peeling paint
Highland Park Middle School	3410	1/6/2023	12:57:00 PM	735		72.2	15.5	2	Bubbling/peeling paint
Highland Park Middle School	3411	1/6/2023	12:37:00 PM	1047	0.1	71.9	20.2	17	Bubbling/peeling paint
Highland Park Middle School	3413	1/6/2023	12:42:00 PM	1112		71.1	19.2	22	
Highland Park Middle School	3415	1/6/2023	12:53:00 PM	880	0.1	71.8	13	23	
Highland Park Middle School	3417	1/6/2023	12:55:00 PM	1290		71.8	17.2	25	
Highland Park Middle School	0106 LOWER GYM	1/6/2023	11:22:00 AM	678	0.1	71.5	15.3	12	Stained ceiling tiles
Highland Park Middle School	0109 ENGINEERS OFFICE	1/6/2023	11:29:00 AM	556		68.8	17.9	0	
Highland Park Middle School	1000 MAIN OFFICE	1/6/2023	9:11:00 AM	524	0.1	70.9	15.1	4	
Highland Park Middle School	1104 KITCHEN	1/6/2023	1:38:00 PM	1115		75.6	19.4	6	
Highland Park Middle School	1112 CAFETERIA	1/6/2023	1:37:00 PM	1055		73.2	25.4	8	Stained ceiling tiles, Suspect microbial growth: Ceiling
Highland Park Middle School	1305A	1/6/2023	10:45:00 AM	792	0.1	72	16.2	0	
Highland Park Middle School	1317A	1/6/2023	10:09:00 AM	619	0.3	72.6	16.4	0	
Highland Park Middle School	1319B	1/6/2023	10:17:00 AM	521	0.1	66.6	14.9	0	
Highland Park Middle School	1410 OFFICE	1/6/2023	10:27:00 AM	567		69.3	17	0	Plants
Highland Park Middle School	AUDITORIUM	1/6/2023	1:07:00 PM	543	0.2	71	11.9	32	Moisture damage at lower ceiling edge along stage
Highland Park Middle School	CAFETERIA	1/6/2023	1:11:00 PM	1075	0.1	70.9	25.2	85	Moisture damage at East wall of cafeteria, Stained ceiling tiles, Suspect microbial growth: Along the east wall of the cafeteria, Plants
Highland Park Middle School	EAST GYM	1/6/2023	9:31:00 AM	566	0.1	68.1	13.7	23	
Highland Park Middle School	KITCHEN OFFICE	1/6/2023	4:24:00 PM	1046		76.5	20.7	2	
Highland Park Middle School	MAIN OFFICE STAFF WORKROOM	1/6/2023	9:22:00 AM	548	0.1	72.7	14.2	1	
Highland Park Middle School	MEDIA CENTER	1/6/2023	10:24:00 AM	529		67.9	14.2	1	Stained ceiling tiles
Highland Park Middle School	OUTDOORS	1/6/2023		422	0.8	38.7	26.5		
Highland Park Senior High School	1211	1/6/2023	9:27:00 AM	708	0.5	70	19.5	19	
Highland Park Senior High School	1213	1/6/2023	9:25:00 AM	821	0.6	70.3	19.5	5	
Highland Park Senior High School	1215	1/6/2023	9:23:00 AM	596	0.6	70.3	16.9	5	
Highland Park Senior High School	1217	1/6/2023	9:14:00 AM	667	0.6	70.9	17.1	9	
Highland Park Senior High School	1310	1/6/2023	10:10:00 AM	919	0.5	72.3	14.7	5	
Highland Park Senior High School	1314	1/6/2023	10:01:00 AM	932	0.5	70.9	18	30	
Highland Park Senior High School	1328	1/6/2023	9:43:00 AM	738	0.5	68.9	19.3	18	
Highland Park Senior High School	1329	1/6/2023	9:39:00 AM	750	0.6	69.6	17.9	11	
Highland Park Senior High School	1401	1/6/2023	9:32:00 AM	678	0.5	68.4	15.9	5	
Highland Park Senior High School	2201	1/6/2023	11:35:00 AM	1540	0.5	68.9	25.8	35	Stuffy odor, Stained ceiling tiles
Highland Park Senior High School	2202	1/6/2023	11:37:00 AM	1247	5	70.3	19.6	24	Stained ceiling tiles
Highland Park Senior High School	2203	1/6/2023	11:38:00 AM	830	0.5	70.7	16.2	1	Coffee odor
Highland Park Senior High School	2204	1/6/2023	11:39:00 AM	1172	0.6	71.1	19.4	23	Stained ceiling tiles
Highland Park Senior High School	2205	1/6/2023	11:41:00 AM	832	0.6	70.9	16.1	1	
Highland Park Senior High School	2206	1/6/2023	11:43:00 AM	841	0.5	70.5	16.8	0	
Highland Park Senior High School	2207	1/6/2023	11:47:00 AM	1240	0.5	68.7	21.3	0	
Highland Park Senior High School	2208	1/6/2023	12:02:00 PM	1022	0.5	68.9	18.9	28	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Senior High School	2209	1/6/2023	12:03:00 PM	1147	0.6	69.6	22.1	28	
Highland Park Senior High School	2210	1/6/2023	12:05:00 PM	718	0.6	67.6	16.1	1	
Highland Park Senior High School	2211	1/6/2023	12:06:00 PM	835	0.5	66.4	17.3	9	Fragrance odor
Highland Park Senior High School	2213	1/6/2023	12:08:00 PM	1112	0.5	67.8	21	36	
Highland Park Senior High School	2214	1/6/2023	12:10:00 PM	1017	0.5	68.2	19.6	36	
Highland Park Senior High School	2216	1/6/2023	12:11:00 PM	990	0.6	67.3	19.5	26	
Highland Park Senior High School	2217	1/6/2023	12:13:00 PM	1045	0.6	66.9	21.4	24	
Highland Park Senior High School	2218	1/6/2023	12:16:00 PM	684	0.5	66.7	16.1	0	Stuffy odor
Highland Park Senior High School	2220	1/6/2023	12:18:00 PM	987	0.6	67.3	19.7	26	Stained ceiling tiles
Highland Park Senior High School	2222	1/6/2023	12:20:00 PM	950	0.6	67.3	19.8	34	
Highland Park Senior High School	2303	1/6/2023	12:21:00 PM	1362	0.6	70.7	25.5	30	
Highland Park Senior High School	2304	1/6/2023	12:24:00 PM	1284	0.6	71.6	21.5	33	
Highland Park Senior High School	2305	1/6/2023	12:26:00 PM	1107	0.7	71.4	18.4	19	
Highland Park Senior High School	2306	1/6/2023	12:27:00 PM	1101	0.7	71.2	20.9	28	
Highland Park Senior High School	2307	1/6/2023	12:28:00 PM	910	0.7	71.1	17.6	15	
Highland Park Senior High School	2308	1/6/2023	11:24:00 AM	1199	0.5	69.8	21.5	28	
Highland Park Senior High School	2309	1/6/2023	11:26:00 AM	946	0.5	69.3	18	25	
Highland Park Senior High School	2310	1/6/2023	11:27:00 AM	705	0.5	66.9	15.6	0	
Highland Park Senior High School	2311	1/6/2023	11:30:00 AM	829	0.5	66.2	18.1	24	
Highland Park Senior High School	2313	1/6/2023	11:31:00 AM	1024	0.4	67.3	19.4	32	
Highland Park Senior High School	2313	1/6/2023	11:32:00 AM	1047	0.5	68	18.5	23	
Highland Park Senior High School	2314	1/6/2023	11:33:00 AM	750	0.5	66.7	18.6	2	
Highland Park Senior High School	3201	1/6/2023	1:14:00 PM	899	0.6	69.1	18.4	29	
Highland Park Senior High School	3202	1/6/2023	1:10:00 PM	761	0.6	69.8	15.9	0	
Highland Park Senior High School	3203	1/6/2023	1:08:00 PM	819	0.6	69.8	17.8	21	Aquariums (fish), Taxidermy
Highland Park Senior High School	3204	1/6/2023	1:07:00 PM	944	0.6	70	19	20	Stained ceiling tiles
Highland Park Senior High School	3205	1/6/2023	12:58:00 PM	854	0.5	68	18.9	15	
Highland Park Senior High School	3206	1/6/2023	12:57:00 PM	932	0.6	70.2	19.2	20	
Highland Park Senior High School	3207	1/6/2023	12:55:00 PM	937	0.6	70.9	19.1	24	
Highland Park Senior High School	3208	1/6/2023	12:54:00 PM	812	0.6	70.5	16.7	8	
Highland Park Senior High School	3210	1/6/2023	12:51:00 PM	835	0.6	70.7	18.6	19	
Highland Park Senior High School	3211	1/6/2023	12:48:00 PM	740	0.6	69.6	16.7	17	
Highland Park Senior High School	3302	1/6/2023	12:47:00 PM	809	0.6	71.6	15.3	2	
Highland Park Senior High School	3303	1/6/2023	12:44:00 PM	95	0.6	71.4	19.5	32	
Highland Park Senior High School	3304	1/6/2023	12:43:00 PM	663	0.7	71.6	14.2	1	
Highland Park Senior High School	3305	1/6/2023	12:41:00 PM	921	0.7	72.7	15.8	2	
Highland Park Senior High School	3306	1/6/2023	12:40:00 PM	733	0.6	72.3	13.6	7	
Highland Park Senior High School	3307	1/6/2023	12:38:00 PM	774	0.5	72	14	8	Stained ceiling tiles
Highland Park Senior High School	3308	1/6/2023	12:36:00 PM	1090	0.6	70.2	19.8	27	
Highland Park Senior High School	3309	1/6/2023	12:35:00 PM	957	0.6	68.5	18.6	20	
Highland Park Senior High School	3310	1/6/2023	12:34:00 PM	948	0.6	68.9	20.1	33	
Highland Park Senior High School	3311	1/6/2023	12:32:00 PM	913	0.7	68.9	19.9	24	
Highland Park Senior High School	3312	1/6/2023	12:30:00 PM	946	0.7	69.1	17.2	20	
Highland Park Senior High School	0150 ART	1/6/2023	9:11:00 AM	1235	0.6	69.8	25.4	32	
Highland Park Senior High School	0154 WOODSHED FINISHING RO	1/6/2023	9:08:00 AM	739	0.5	68.7	25	1	
Highland Park Senior High School	0154 WOODSHOP	1/6/2023	9:06:00 AM	847	0.3	63.7	28.3	21	
Highland Park Senior High School	0159 ART	1/6/2023	9:13:00 AM	866	0.6	69.1	20.5	27	Stained ceiling tiles
Highland Park Senior High School	0401 GYMNASIUM	1/6/2023	11:08:00 AM	584	0.4	69.3	15.3	4	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Senior High School	0403 GYM OFFICE	1/6/2023	11:10:00 AM	814	0.5	72	15.8	2	
Highland Park Senior High School	0425 GYM OFFICE	1/6/2023	11:18:00 AM	655	0.5	72	16.7	1	
Highland Park Senior High School	1001 MAIN OFFICE	1/6/2023	10:43:00 AM	612	0.5	70	17.3	2	
Highland Park Senior High School	1001A WAITING	1/6/2023	10:47:00 AM	699	0.5	69.1	16.4	0	
Highland Park Senior High School	1002 OFFICE	1/6/2023	11:06:00 AM	622	0.4	69.1	16.1	1	
Highland Park Senior High School	1003 OFFICE	1/6/2023	10:51:00 AM	628	0.4	69.8	16.2	1	
Highland Park Senior High School	1004 OFFICE	1/6/2023	10:49:00 AM	599	0.4	69.6	15.7	1	
Highland Park Senior High School	1005 OFFICE	1/6/2023	10:48:00 AM	60	0.4	69.3	19.2	2	
Highland Park Senior High School	1006 OFFICE	1/6/2023	10:47:00 AM	609	0.5	68.9	16.9	1	
Highland Park Senior High School	1008 OFFICE	1/6/2023	10:45:00 AM	786	0.5	69.1	16.4	0	
Highland Park Senior High School	1009 WORKROOM	1/6/2023	10:52:00 AM	590	0.4	69.3	16.4	1	
Highland Park Senior High School	1101 AUDITORIUM	1/6/2023	10:41:00 AM	598	0.4	71.1	18.9	54	
Highland Park Senior High School	1115 PENTHOUSE	1/6/2023	10:38:00 AM	544	0.5	71.2	14.4	10	
Highland Park Senior High School	1117 OFFICE	1/6/2023	10:36:00 AM	651	0.5	71.4	18	3	
Highland Park Senior High School	1201 MAINTENANCE	1/6/2023	8:43:00 AM	599	0.6	73	18	2	
Highland Park Senior High School	1201 MAINTENANCE OFFICE	1/6/2023	8:54:00 AM	658	0.6	73.2	17.7	1	
Highland Park Senior High School	1204 OFFICE	1/6/2023	10:31:00 AM	622	0.5	73.4	16.6	2	Fragrance odor
Highland Park Senior High School	1205 MEDIA CENTER	1/6/2023	9:30:00 AM	604	0.5	68.5	17.8	6	
Highland Park Senior High School	1210 LIBRARY LEARNING ROOM	1/6/2023	9:28:00 AM	654	0.6	69.4	14.8	2	
Highland Park Senior High School	1215A	1/6/2023	9:24:00 AM	675	0.6	70.2	20	1	
Highland Park Senior High School	1216 OFFICE	1/6/2023	8:55:00 AM	615	0.6	71.4	17.8	0	
Highland Park Senior High School	1303 OFFICE	1/6/2023	10:11:00 AM	720	0.5	73	16.2	4	
Highland Park Senior High School	1304 OFFICE	1/6/2023	10:18:00 AM	560	0.5	72.3	12.8	0	
Highland Park Senior High School	1305 OFFICE	1/6/2023	10:19:00 AM	742	0.5	72.1	15	0	
Highland Park Senior High School	1306 OFFICE	1/6/2023	10:21:00 AM	644	0.4	73.9	12.8	0	
Highland Park Senior High School	1307 OFFICE	1/6/2023	10:25:00 AM	619	0.5	75.9	12.6	1	
Highland Park Senior High School	1308 OFFICE	1/6/2023	10:26:00 AM	559	0.5	75.4	12.1	0	
Highland Park Senior High School	1309 OFFICE	1/6/2023	10:28:00 AM	769	0.5	75	15.6	2	
Highland Park Senior High School	1311 OFFICE	1/6/2023	10:03:00 AM	551	0.5	71.4	14.1	0	
Highland Park Senior High School	1312 OFFICE	1/6/2023	10:08:00 AM	651	0.5	71.4	15.8	1	
Highland Park Senior High School	1315 CLINIC	1/6/2023	9:51:00 AM	834	0.6	72.3	17.9	1	
Highland Park Senior High School	1315 HEALTH SERVICES	1/6/2023	9:44:00 AM	920	0.5	72	15.7	0	
Highland Park Senior High School	1316 OFFICE	1/6/2023	9:57:00 AM	618	0.4	69.4	15.4	0	
Highland Park Senior High School	1317 OFFICE	1/6/2023	9:56:00 AM	606	0.6	70	14.4	0	
Highland Park Senior High School	1319 OFFICE	1/6/2023	10:14:00 AM	753	0.5	72.9	15.1	1	
Highland Park Senior High School	1320 OFFICE	1/6/2023	9:56:00 AM	595	0.5	70.5	14.2	0	
Highland Park Senior High School	1321 OFFICE	1/6/2023	9:54:00 AM	592	0.6	71.4	13.8	0	
Highland Park Senior High School	1322 OFFICE	1/6/2023	9:54:00 AM	590	0.6	70.7	14	0	
Highland Park Senior High School	1323 NURSE COT	1/6/2023	9:49:00 AM	620	0.5	72.7	13.6	0	
Highland Park Senior High School	1324 NURSE OFFICE	1/6/2023	9:50:00 AM	700	0.5	72.9	14.9	1	
Highland Park Senior High School	1325 NURSE COT	1/6/2023	9:48:00 AM	625	0.5	72.1	14.2	0	
Highland Park Senior High School	1405 FITNESS CENTER	1/6/2023	9:34:00 AM	933	0.5	70.3	22.7	30	
Highland Park Senior High School	1405 SMALL WORKOUT ROOM	1/6/2023	9:37:00 AM	956	0.5	70.3	24.5	2	
Highland Park Senior High School	2309A WORKROOM	1/6/2023	11:20:00 AM	867	0.5	70.2	16.2	0	
Highland Park Senior High School	2401 STAFF ROOM	1/6/2023	11:44:00 AM	696	0.6	69.3	15.7	0	
Highland Park Senior High School	3209 OFFICE	1/6/2023	12:53:00 PM	657	0.6	71.1	17.9	0	
Highland Park Senior High School	OUTDOORS	1/6/2023		419	0.8	17	22		
Highland Park Senior High School	SCHOOL HOUSE	1/6/2023	9:03:00 AM	1066	0.7	54.9	52.9	25	Fragrance odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highwood Hills Elementary School	754	2/17/2023	10:50:00 AM	588	0.1	70.9	7.1	0	
Highwood Hills Elementary School	1103	2/17/2023	11:14:00 AM	532	0.1	74.5	6.8	0	Stuffy odor
Highwood Hills Elementary School	1104	2/17/2023	11:20:00 AM	587	0.1	73.8	6.1	0	
Highwood Hills Elementary School	1107	2/17/2023	11:23:00 AM	545	0.1	73.8	6.8	0	
Highwood Hills Elementary School	1108	2/17/2023	11:24:00 AM	547	0.2	72.3	7.3	0	Musty odor
Highwood Hills Elementary School	1112	2/17/2023	11:18:00 AM	553	0.1	75.1	7	0	
Highwood Hills Elementary School	1502	2/17/2023	10:59:00 AM	589	0.1	71.8	7.5	0	
Highwood Hills Elementary School	1504	2/17/2023	11:02:00 AM	572	0.1	70.9	7.1	0	
Highwood Hills Elementary School	1505	2/17/2023	11:04:00 AM	572	0.1	70.9	7.1	2	
Highwood Hills Elementary School	1506	2/17/2023	11:06:00 AM	721	0.1	71.2	8.9	21	
Highwood Hills Elementary School	1507	2/17/2023	11:08:00 AM	551	0.1	71.3	6.9	0	
Highwood Hills Elementary School	1603	2/17/2023	10:45:00 AM	672	0.1	71.6	9	25	
Highwood Hills Elementary School	1604	2/17/2023	10:48:00 AM	570	0.1	71	7.7	0	
Highwood Hills Elementary School	1605	2/17/2023	10:52:00 AM	563	0.1	71.3	7.1	0	
Highwood Hills Elementary School	1606	2/17/2023	10:54:00 AM	572	0.1	71.1	7.1	0	
Highwood Hills Elementary School	1607	2/17/2023	10:57:00 AM	554	0.1	71.2	6.8	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2003	2/17/2023	9:27:00 AM	609	0.1	71.5	7.9	1	
Highwood Hills Elementary School	2005	2/17/2023	9:20:00 AM	622	0.1	72.5	7.3	1	
Highwood Hills Elementary School	2006	2/17/2023	9:23:00 AM	578	0.1	71.4	7.4	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2007	2/17/2023	9:36:00 AM	581	0.1	71	7.7	0	
Highwood Hills Elementary School	2011	2/17/2023	9:31:00 AM	714	0.1	72	8.3	2	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2101	2/17/2023	10:25:00 AM	637	0.1	71.1	8.4	0	
Highwood Hills Elementary School	2201	2/17/2023	10:28:00 AM	688	0.1	71.9	9	1	
Highwood Hills Elementary School	2203	2/17/2023	10:31:00 AM	679	0.1	71.3	8.7	1	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2221	2/17/2023	10:36:00 AM	665	0.1	71.1	9	0	
Highwood Hills Elementary School	2222	2/17/2023	10:37:00 AM	672	0.1	70.9	9.2	0	
Highwood Hills Elementary School	2223	2/17/2023	10:39:00 AM	649	0.1	70.7	9.1	0	
Highwood Hills Elementary School	2225	2/17/2023	10:40:00 AM	620	0.1	70.4	9.1	0	
Highwood Hills Elementary School	2230	2/17/2023	9:17:00 AM	816	0.1	73.4	9.5	18	
Highwood Hills Elementary School	2302	2/17/2023	8:49:00 AM	567	0.1	72	6.3	0	
Highwood Hills Elementary School	2303	2/17/2023	9:01:00 AM	554	0.1	71	7.6	0	
Highwood Hills Elementary School	2304	2/17/2023	8:52:00 AM	546	0.1	72.3	6.1	0	
Highwood Hills Elementary School	2306	2/17/2023	8:54:00 AM	870	0.1	72	9.2	1	
Highwood Hills Elementary School	2309	2/17/2023	8:59:00 AM	519	0.1	70.9	6	0	
Highwood Hills Elementary School	2310	2/17/2023	8:56:00 AM	552	0.1	72.1	6.8	0	
Highwood Hills Elementary School	2311	2/17/2023	8:46:00 AM	669		71	7.5	0	
Highwood Hills Elementary School	2312	2/17/2023	8:44:00 AM	504	0.1	70.8	6.4	0	
Highwood Hills Elementary School	2313	2/17/2023	8:38:00 AM	545	0.1	72.3	6.3	2	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2314	2/17/2023	8:42:00 AM	548	0.1	71.6	6.4	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2315	2/17/2023	8:36:00 AM	636	0.1	71.1	7.8	2	
Highwood Hills Elementary School	2316	2/17/2023	8:40:00 AM	568	0.1	72.1	7.2	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2317	2/17/2023	8:33:00 AM	502	0.2	70.1	6.3	0	
Highwood Hills Elementary School	2318	2/17/2023	8:27:00 AM	526	0.1	71.7	7.2	0	Taxidermy
Highwood Hills Elementary School	2402	2/17/2023	9:08:00 AM	617	0.1	71.6	7.9	0	
Highwood Hills Elementary School	2404	2/17/2023	9:04:00 AM	625	0.1	71.4	7.7	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2406	2/17/2023	9:10:00 AM	765	0.1	72.6	8.3	2	
Highwood Hills Elementary School	2416	2/17/2023	9:37:00 AM	569	0.1	70.5	7.5	0	
Highwood Hills Elementary School	2421	2/17/2023	9:44:00 AM	607	0.1	71.8	7.5	0	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highwood Hills Elementary School	2423	2/17/2023	9:47:00 AM	674	0.1	72.1	8.1	1	
Highwood Hills Elementary School	2424	2/17/2023	9:49:00 AM	625	0.1	71.7	7.8	2	
Highwood Hills Elementary School	2426	2/17/2023	9:50:00 AM	689	0.1	72.9	7.5	2	
Highwood Hills Elementary School	2502	2/17/2023	10:03:00 AM	547	0.1	71.4	6.8	0	
Highwood Hills Elementary School	2503	2/17/2023	10:01:00 AM	773	0.1	71.5	8.6	17	
Highwood Hills Elementary School	2504	2/17/2023	9:58:00 AM	601	0.1	71.4	7.3	6	
Highwood Hills Elementary School	2505	2/17/2023	9:56:00 AM	573	0.1	71.1	7.1	1	
Highwood Hills Elementary School	2506	2/17/2023	9:53:00 AM	591	0.1	71.5	7.2	0	
Highwood Hills Elementary School	2507	2/17/2023	11:35:00 AM	548	0.1	71.8	6.8	1	
Highwood Hills Elementary School	2602	2/17/2023	10:16:00 AM	538	0.1	72.3	6.6	0	
Highwood Hills Elementary School	2603	2/17/2023	10:13:00 AM	566	0.1	71.5	7.3	0	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2604	2/17/2023	11:33:00 AM	569	0.1	71.9	7.1	5	
Highwood Hills Elementary School	2605	2/17/2023	10:11:00 AM	600	0.1	71.2	7.4	7	
Highwood Hills Elementary School	2606	2/17/2023	10:09:00 AM	861	0.1	72.3	10.5	19	
Highwood Hills Elementary School	2607	2/17/2023	10:05:00 AM	538	0.1	71.1	6.8	0	
Highwood Hills Elementary School	2001 MAIN OFFICE	2/17/2023	9:29:00 AM	595	0.1	71.7	7.4	2	
Highwood Hills Elementary School	2004 PRINCIPALS	2/17/2023	9:24:00 AM	686	0.1	71.4	8.6	1	
Highwood Hills Elementary School	2009/OFFICE-2	2/17/2023	9:33:00 AM	603	0.1	71.7	7.4	0	
Highwood Hills Elementary School	2020A MEDIA OFFICE	2/17/2023	11:10:00 AM	586	0.1	70.9	8.2	0	
Highwood Hills Elementary School	2104 GYMNASIUM	2/17/2023	10:22:00 AM	731	0.1	71.2	9	19	Bubbling/peeling paint
Highwood Hills Elementary School	2104A	2/17/2023	10:18:00 AM	654	0.1	71.5	8.9	0	Taxidermy
Highwood Hills Elementary School	2220 NURSE	2/17/2023	10:34:00 AM	774	0.1	71.2	9.9	2	
Highwood Hills Elementary School	2318C	2/17/2023	8:31:00 AM	544	0.1	72.6	6.7	0	
Highwood Hills Elementary School	2407 KITCHEN	2/17/2023	9:12:00 AM	611	0.1	74.7	6.5	4	
Highwood Hills Elementary School	2410 CAFETERIA	2/17/2023	9:15:00 AM	607	0.1	74.8	6.5	29	
Highwood Hills Elementary School	2422/2427	2/17/2023	9:41:00 AM	598	0.1	70.9	7.9	1	
Highwood Hills Elementary School	CUSTODIAL OFFICE	2/17/2023	11:42:00 AM	602	0.1	73.3	8.1	1	
Highwood Hills Elementary School	MEDIA CENTER	2/17/2023	10:42:00 AM	597	0.1	70.6	7.9	3	
Highwood Hills Elementary School	OUTDOORS	2/17/2023		652	1.2	7.1	4.9		
Horace Mann School	105	2/17/2023	8:29:00 AM	596	0.1	69.5	11.7	1	
Horace Mann School	204	2/17/2023	8:21:00 AM	583	0.2	70	10.3	1	
Horace Mann School	206	2/17/2023	10:28:00 AM	543		72.1	8.5	0	
Horace Mann School	210	2/17/2023	10:25:00 AM	553	0.3	71.2	8.8	0	Stained ceiling tiles
Horace Mann School	1001	2/17/2023	8:23:00 AM	597	0.3	69.5	11.3	1	Plants: Kept Away From Return And Supply Vents
Horace Mann School	1002	2/17/2023	8:30:00 AM	628	0.2	69.9	11.7	1	
Horace Mann School	1003	2/17/2023	8:46:00 AM	860	0.4	68.7	11.7	20	Stained ceiling tiles
Horace Mann School	1101	2/17/2023	8:35:00 AM	846	0.2	70	32.7	28	Live animals: Kept Away From Return And Supply Vents, Plants
Horace Mann School	1102	2/17/2023	8:43:00 AM	764	0.1	70	12.3	28	Plants
Horace Mann School	1202	2/17/2023	9:12:00 AM	800	0.1	73.9	10.6	24	Plants
Horace Mann School	1203	2/17/2023	9:20:00 AM	700	0.7	74	8.8	2	Plants: Kept Away From Return And Supply Vents
Horace Mann School	1204	2/17/2023	9:18:00 AM	714	0.2	75.5	10	24	
Horace Mann School	1205	2/17/2023	9:15:00 AM	711	0.1	74.2	10	23	Plants
Horace Mann School	1303	2/17/2023	9:09:00 AM	685	0.1	72.7	9.4	0	
Horace Mann School	1306	2/17/2023	8:50:00 AM	768		71.2	10.4	19	
Horace Mann School	1307	2/17/2023	8:57:00 AM	801	0.3	70.7	11.8	18	Live animals
Horace Mann School	1501	2/17/2023	10:32:00 AM	484	0.3	71.6	7.1	0	
Horace Mann School	1504	2/17/2023	8:59:00 AM	623	0.1	71.1	8.8	50	
Horace Mann School	1601	2/17/2023	9:23:00 AM	555	0.3	72.6	7.9	2	Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Horace Mann School	1603	2/17/2023	9:26:00 AM	846	0.2	72.3	10.7	23	
Horace Mann School	1605	2/17/2023	9:28:00 AM	817	0.2	72.7	10.9	24	
Horace Mann School	2102	2/17/2023	10:06:00 AM	629	0.1	71.1	9.1	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Horace Mann School	2103	2/17/2023	10:09:00 AM	768		73.8	12.1	15	
Horace Mann School	2104	2/17/2023	10:11:00 AM	535	0.3	72.1	8	1	
Horace Mann School	2105	2/17/2023	10:14:00 AM	807	0.1	72.7	11.3	24	
Horace Mann School	2202	2/17/2023	9:40:00 AM	619	0.3	72.5	8.5	1	
Horace Mann School	2204	2/17/2023	10:51:00 AM	581	0.1	70.4	8.6	2	Taxidermy
Horace Mann School	2205	2/17/2023	9:34:00 AM	900	0.1	72	11.2	24	Plants: Kept Away From Return And Supply Vents
Horace Mann School	2206	2/17/2023	9:36:00 AM	887	0.1	73.2	11	26	Plants
Horace Mann School	2207	2/17/2023	9:39:00 AM	608		73.4	8.8	6	Stained ceiling tiles
Horace Mann School	2301	2/17/2023	9:46:00 AM	546	0.1	72.1	8.2	3	Stained ceiling tiles
Horace Mann School	2302	2/17/2023	9:52:00 AM	529	0.2	72.2	7.3	2	
Horace Mann School	2303	2/17/2023	9:47:00 AM	711	0.3	71.7	9.5	28	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Horace Mann School	2304	2/17/2023	9:56:00 AM	619	0.2	71.2	8.8	16	
Horace Mann School	2305	2/17/2023	9:49:00 AM	695	0.1	72.2	9.4	23	
Horace Mann School	2308	2/17/2023	9:59:00 AM	514	0.3	71.5	8	0	Essential oil odor
Horace Mann School	2309	2/17/2023	9:53:00 AM	623	0.3	71.9	8.1	5	
Horace Mann School	3201	2/17/2023	9:44:00 AM	652	0.2	71.8	8.3	2	
Horace Mann School	0210A	2/17/2023	10:26:00 AM	584	0.1	71.5	9.8	3	
Horace Mann School	1003 WORKROOM	2/17/2023	8:32:00 AM	617	0.4	69.4	10.8	1	
Horace Mann School	1505D	2/17/2023	9:07:00 AM	1378	1.3	71.2	15	1	
Horace Mann School	1600S LOCKER BAY WORK AREA	2/17/2023	9:31:00 AM	684	0.4	72.4	9.3	0	
Horace Mann School	2300S LOCKER BAY WORK AREA	2/17/2023	9:51:00 AM	627	0.3	72.5	8.7	40	
Horace Mann School	CUSTODIAL OFFICE	2/17/2023	8:16:00 AM	614	0.4	68.7	15.4	1	
Horace Mann School	GYMNASIUM	2/17/2023	8:53:00 AM	547	0.3	71.1	9.5	24	Bubbling/peeling paint
Horace Mann School	KITCHEN	2/17/2023	9:04:00 AM	1214	1.7	70.9	13.7	1	
Horace Mann School	MEDIA CENTER	2/17/2023	8:39:00 AM	714	0.3	69.1	10.7	24	
Horace Mann School	OUTDOORS	2/17/2023		420	9	7	74		
Horace Mann School	WORK AREA OUTSIDE 2102	2/17/2023	10:07:00 AM	601	0.2	71.3	9	0	Plants: Kept Away From Return And Supply Vents
Hubbs Lifelong Learning	1001	1/11/2023	10:36:00 AM	632	0.7	70.7	20.6	1	
Hubbs Lifelong Learning	1002	1/11/2023	10:35:00 AM	637	0.6	70.3	20.9	1	
Hubbs Lifelong Learning	1003	1/11/2023	10:33:00 AM	688	0.7	70.2	21.1	1	
Hubbs Lifelong Learning	1004	1/11/2023	10:37:00 AM	620	0.7	70.7	20.4	0	
Hubbs Lifelong Learning	1005	1/11/2023	10:32:00 AM	582	0.7	70.5	19.9	0	
Hubbs Lifelong Learning	1101	1/11/2023	10:38:00 AM	629	0.6	70.9	20	2	Fragrance odor
Hubbs Lifelong Learning	1102	1/11/2023	10:40:00 AM	628	0.7	70.9	20.1	1	Stained ceiling tiles
Hubbs Lifelong Learning	1103	1/11/2023	10:41:00 AM	630	0.6	71.1	20	1	
Hubbs Lifelong Learning	1104	1/11/2023	10:42:00 AM	596	0.7	70.9	19.9	0	
Hubbs Lifelong Learning	1105	1/11/2023	10:43:00 AM	597	0.6	70.7	20.1	0	
Hubbs Lifelong Learning	1106	1/11/2023	10:45:00 AM	593	0.6	70.5	20.1	0	
Hubbs Lifelong Learning	1107	1/11/2023	10:46:00 AM	616	0.6	70.7	20	0	
Hubbs Lifelong Learning	1108	1/11/2023	10:50:00 AM	578	0.6	70.7	19.7	0	
Hubbs Lifelong Learning	1109	1/11/2023	9:32:00 AM	617	0.8	73.4	20.5	1	
Hubbs Lifelong Learning	1110	1/11/2023	9:36:00 AM	573	0.8	72.7	20.3	1	
Hubbs Lifelong Learning	1203	1/11/2023	10:11:00 AM	611	0.9	72.3	19	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hubbs Lifelong Learning	1204	1/11/2023	10:08:00 AM	1313	0.9	72.3	25.3	22	
Hubbs Lifelong Learning	1205	1/11/2023	10:05:00 AM	627	0.9	72.3	20.5	1	
Hubbs Lifelong Learning	1206	1/11/2023	10:07:00 AM	1060	0.9	72	23.1	19	
Hubbs Lifelong Learning	1209	1/11/2023	9:37:00 AM	550	0.8	72.3	18.8	2	
Hubbs Lifelong Learning	1210	1/11/2023	9:54:00 AM	565	1.1	75.9	17.4	0	
Hubbs Lifelong Learning	1211	1/11/2023	9:56:00 AM	588	1.1	76.5	16.9	1	
Hubbs Lifelong Learning	1212	1/11/2023	9:40:00 AM	584	0.9	72.7	19.6	0	
Hubbs Lifelong Learning	1213	1/11/2023	9:49:00 AM	928	1.1	74.5	21.7	13	
Hubbs Lifelong Learning	1214	1/11/2023	9:44:00 AM	709	1.1	72.3	21.3	9	
Hubbs Lifelong Learning	1215	1/11/2023	9:41:00 AM	628	1	73.4	21.9	5	Stained ceiling tiles
Hubbs Lifelong Learning	1216	1/11/2023	9:48:00 AM	557	0.9	72.5	22.1	0	
Hubbs Lifelong Learning	1217	1/11/2023	9:57:00 AM	581	1.1	74.7	17.2	0	
Hubbs Lifelong Learning	1218	1/11/2023	9:59:00 AM	554	1.1	73.9	17.6	0	Fragrance odor
Hubbs Lifelong Learning	1219	1/11/2023	10:00:00 AM	517	1	73.4	17.4	0	
Hubbs Lifelong Learning	1220	1/11/2023	10:02:00 AM	563	1	72.9	18.2	0	
Hubbs Lifelong Learning	1302	1/11/2023	12:24:00 PM	726	0.5	70.7	21	1	Plants
Hubbs Lifelong Learning	1303	1/11/2023	12:25:00 PM	683	0.5	70.7	20.9	0	
Hubbs Lifelong Learning	1304	1/11/2023	12:27:00 PM	699	0.5	70.3	21	0	Plants
Hubbs Lifelong Learning	1305	1/11/2023	12:29:00 PM	680	0.5	70.5	20.7	0	
Hubbs Lifelong Learning	1306	1/11/2023	12:30:00 PM	704	0.5	70.7	21	0	
Hubbs Lifelong Learning	1308	1/11/2023	12:20:00 PM	697	0.5	69.6	21.3	0	
Hubbs Lifelong Learning	1309	1/11/2023	12:17:00 PM	812	0.4	68.9	23.3	6	
Hubbs Lifelong Learning	1310	1/11/2023	12:32:00 PM	934	0.5	70.7	21.8	3	
Hubbs Lifelong Learning	1311	1/11/2023	12:36:00 PM	1067	0.6	70.3	24.4	2	
Hubbs Lifelong Learning	1312	1/11/2023	12:33:00 PM	897	0.6	70.2	22.7	2	
Hubbs Lifelong Learning	1313	1/11/2023	12:19:00 PM	709	0.4	69.4	21.8	0	
Hubbs Lifelong Learning	1315	1/11/2023	12:15:00 PM	675	0.5	68.7	21.6	0	
Hubbs Lifelong Learning	1316	1/11/2023	12:05:00 PM	894	0.6	71.1	22	11	
Hubbs Lifelong Learning	1319	1/11/2023	12:11:00 PM	682	0.5	70.2	21.5	0	
Hubbs Lifelong Learning	1320	1/11/2023	12:09:00 PM	676	0.5	70.9	20.3	0	
Hubbs Lifelong Learning	1402	1/11/2023	11:00:00 AM	898	0.6	70.3	22.9	14	Stained ceiling tiles
Hubbs Lifelong Learning	1403	1/11/2023	11:05:00 AM	630	0.6	70	20.5	0	
Hubbs Lifelong Learning	1404	1/11/2023	11:02:00 AM	600	0.6	70.5	21.4	0	
Hubbs Lifelong Learning	1405	1/11/2023	11:07:00 AM	635	0.6	69.8	21.6	0	
Hubbs Lifelong Learning	1406	1/11/2023	11:12:00 AM	628	0.6	70.5	20.2	0	
Hubbs Lifelong Learning	1408	1/11/2023	11:15:00 AM	708	0.6	73.4	18.6	10	Moisture damage at Northwest corner area, Plants: Kept Away From Return And Supply Vents
Hubbs Lifelong Learning	1409	1/11/2023	11:14:00 AM	662	0.6	70.7	20.2	0	
Hubbs Lifelong Learning	1410	1/11/2023	11:33:00 AM	779	0.7	74.8	18.6	0	
Hubbs Lifelong Learning	1411	1/11/2023	11:30:00 AM	792	0.7	74.8	18.8	0	
Hubbs Lifelong Learning	1413	1/11/2023	11:20:00 AM	1223	0.8	73.2	23.9	21	Bubbling/peeling paint
Hubbs Lifelong Learning	1415	1/11/2023	11:24:00 AM	838	0.6	75.7	19.6	0	
Hubbs Lifelong Learning	1416	1/11/2023	11:28:00 AM	1123	0.9	76.1	20.4	18	
Hubbs Lifelong Learning	1417	1/11/2023	11:38:00 AM	681	0.7	72.3	18.9	0	
Hubbs Lifelong Learning	1418	1/11/2023	11:41:00 AM	696	0.6	72.7	19.2	0	
Hubbs Lifelong Learning	1419	1/11/2023	12:03:00 PM	823	0.5	71.6	21.3	1	Stained ceiling tiles
Hubbs Lifelong Learning	1420	1/11/2023	11:46:00 AM	663	0.6	73.8	18.4	0	
Hubbs Lifelong Learning	1421	1/11/2023	11:45:00 AM	713	0.6	73.4	18.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hubbs Lifelong Learning	1422	1/11/2023	11:44:00 AM	671	0.6	72.7	18.9	0	
Hubbs Lifelong Learning	1425	1/11/2023	11:49:00 AM	676	0.6	73.6	18.5	0	
Hubbs Lifelong Learning	1426	1/11/2023	11:50:00 AM	696	0.5	71.1	20	0	
Hubbs Lifelong Learning	1427	1/11/2023	11:59:00 AM	667	0.5	70.7	20.2	0	
Hubbs Lifelong Learning	1428	1/11/2023	12:00:00 PM	682	0.5	71.1	20.2	0	
Hubbs Lifelong Learning	1429	1/11/2023	12:02:00 PM	669	0.5	71.1	19.8	0	
Hubbs Lifelong Learning	1501	1/11/2023	10:25:00 AM	640	0.7	71.2	20.9	1	
Hubbs Lifelong Learning	1502	1/11/2023	10:28:00 AM	652	0.7	70.2	20.7	1	
Hubbs Lifelong Learning	1503	1/11/2023	10:26:00 AM	607	0.7	70.7	20.2	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Hubbs Lifelong Learning	1504	1/11/2023	10:24:00 AM	670	0.7	71.1	21	3	Stained ceiling tiles
Hubbs Lifelong Learning	1505	1/11/2023	10:20:00 AM	645	0.7	71.1	20.5	2	Stained ceiling tiles
Hubbs Lifelong Learning	1506	1/11/2023	10:48:00 AM	609	0.7	71.2	19.7	0	
Hubbs Lifelong Learning	1507	1/11/2023	10:19:00 AM	575	0.8	71.1	19.9	0	
Hubbs Lifelong Learning	1509	1/11/2023	10:52:00 AM	674	0.6	70.7	20.7	1	
Hubbs Lifelong Learning	1510	1/11/2023	10:53:00 AM	596	0.6	70.3	21	0	
Hubbs Lifelong Learning	1512	1/11/2023	10:54:00 AM	625	0.6	70	20.7	0	
Hubbs Lifelong Learning	1513	1/11/2023	10:57:00 AM	642	0.6	69.1	21.3	1	
Hubbs Lifelong Learning	1000 LOBBY	1/11/2023	10:29:00 AM	620	0.7	70.5	20.8	1	Plants: Kept Away From Return And Supply Vents
Hubbs Lifelong Learning	1201 LOUNGE	1/11/2023	10:15:00 AM	655	0.8	72.3	19.9	4	
Hubbs Lifelong Learning	1301/1401	1/11/2023	10:59:00 AM	901	0.6	69.3	24	13	
Hubbs Lifelong Learning	1307/1407	1/11/2023	11:10:00 AM	784	0.6	70.2	22.3	5	
Hubbs Lifelong Learning	1317/1318	1/11/2023	12:13:00 PM	674	0.5	69.4	21.1	0	
Hubbs Lifelong Learning	OUTDOORS	1/11/2023		439	0.9	32	84		
Humboldt Senior High School	1103	1/23/2023	12:08:00 PM	891	0.5	73.4	20.8	3	
Humboldt Senior High School	1104	1/23/2023	12:05:00 PM	1004	0.5	71.8	22.7	22	
Humboldt Senior High School	1105	1/23/2023	12:44:00 PM	994	0.6	71.8	21.4	20	
Humboldt Senior High School	1106	1/23/2023	12:04:00 PM	915	0.6	71.2	20.9	15	
Humboldt Senior High School	1107	1/23/2023	12:00:00 PM	944	0.5	71.2	20.9	17	
Humboldt Senior High School	1108	1/23/2023	12:41:00 PM	1038	0.5	71.4	23.5	25	
Humboldt Senior High School	1109	1/23/2023	11:01:00 AM	666	0.6	71.8	17.4	0	
Humboldt Senior High School	1112	1/23/2023	10:58:00 AM	822	0.6	71.8	19.7	14	
Humboldt Senior High School	1114	1/23/2023	10:50:00 AM	600	0.5	72.1	16.9	0	
Humboldt Senior High School	1115	1/23/2023	10:56:00 AM	667	0.5	72.3	17.4	7	Plants
Humboldt Senior High School	1201	1/23/2023	11:48:00 AM	647	0.5	70.7	20.3	0	
Humboldt Senior High School	1202	1/23/2023	11:49:00 AM	663	0.5	71.1	26.1	5	Aquariums (fish), Live animals, Plants
Humboldt Senior High School	1203	1/23/2023	11:50:00 AM	597	0.5	70.3	18	6	
Humboldt Senior High School	1204	1/23/2023	11:51:00 AM	644	0.3	68.5	21	5	Stained ceiling tiles, Plants
Humboldt Senior High School	1205	1/23/2023	11:46:00 AM	607	0.5	70.9	17.6	0	
Humboldt Senior High School	1207	1/23/2023	11:06:00 AM	714	0.4	72.7	17.7	14	
Humboldt Senior High School	1208	1/23/2023	11:04:00 AM	1036	2.2	72.1	20.9	14	
Humboldt Senior High School	1301	1/23/2023	11:40:00 AM	777	0.5	70.2	19.6	15	Plants
Humboldt Senior High School	1302	1/23/2023	11:39:00 AM	858	0.5	69.8	21.1	20	
Humboldt Senior High School	1303	1/23/2023	11:35:00 AM	657	0.3	68	19.8	11	
Humboldt Senior High School	1304	1/23/2023	11:08:00 AM	690	0.5	73	17.1	0	
Humboldt Senior High School	1701	1/23/2023	12:46:00 PM	771	0.6	70.7	19.5	5	
Humboldt Senior High School	1707	1/23/2023	12:50:00 PM	739	0.6	69.8	19.7	1	Plants
Humboldt Senior High School	1709	1/23/2023	12:48:00 PM	668	0.6	70.7	18.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	1802	1/23/2023	11:55:00 AM	880	0.5	69.8	21.1	5	
Humboldt Senior High School	1804	1/23/2023	11:58:00 AM	861	0.5	70.9	20.8	0	
Humboldt Senior High School	2102	1/23/2023	11:52:00 AM	754	0.6	72.3	18.7	1	
Humboldt Senior High School	2103	1/23/2023	11:54:00 AM	744	0.6	72.6	18.1	1	
Humboldt Senior High School	2104	1/23/2023	12:00:00 PM	805	0.6	72.1	19	10	
Humboldt Senior High School	2105	1/23/2023	11:58:00 AM	717	0.6	72.1	18	0	
Humboldt Senior High School	2106	1/23/2023	11:56:00 AM	734	0.6	72.1	18.4	1	
Humboldt Senior High School	2107	1/23/2023	11:55:00 AM	831	0.6	72.3	19	1	
Humboldt Senior High School	2108	1/23/2023	11:48:00 AM	706	0.6	71.6	18.1	0	
Humboldt Senior High School	2109	1/23/2023	11:46:00 AM	899	0.6	71.6	19.6	20	
Humboldt Senior High School	2201	1/23/2023	11:45:00 AM	749	0.6	71.6	19	25	
Humboldt Senior High School	2202	1/23/2023	11:41:00 AM	646	0.6	72	17.1	15	
Humboldt Senior High School	2302	1/23/2023	11:35:00 AM	670	0.5	70.5	17.6	0	
Humboldt Senior High School	2303	1/23/2023	11:37:00 AM	919	0.5	70.9	21.4	30	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	2304	1/23/2023	11:34:00 AM	623	0.5	70	18	1	
Humboldt Senior High School	2305	1/23/2023	11:32:00 AM	616	0.6	70	17.8	0	
Humboldt Senior High School	2306	1/23/2023	11:30:00 AM	718	0.5	70.5	18.9	10	
Humboldt Senior High School	2307	1/23/2023	11:29:00 AM	658	0.6	71.1	18	1	
Humboldt Senior High School	2308	1/23/2023	11:27:00 AM	689	0.6	71.4	17.8	0	
Humboldt Senior High School	2309	1/23/2023	11:26:00 AM	1184	0.6	71.4	24.1	4	
Humboldt Senior High School	2310	1/23/2023	11:22:00 AM	742	0.5	70.3	19.5	6	
Humboldt Senior High School	2311	1/23/2023	11:19:00 AM	667	0.5	69.6	18.9	1	
Humboldt Senior High School	2312	1/23/2023	11:16:00 AM	627	0.5	70.3	17.8	1	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	2314	1/23/2023	11:14:00 AM	622	0.6	71.2	17.2	0	
Humboldt Senior High School	2317	1/23/2023	11:38:00 AM	877	0.5	71.4	20.5	25	
Humboldt Senior High School	2402	1/23/2023	11:12:00 AM	718	0.6	72.1	18	1	
Humboldt Senior High School	2403	1/23/2023	11:09:00 AM	821	0.6	72.1	19.7	15	
Humboldt Senior High School	2404	1/23/2023	11:07:00 AM	734	0.6	72.1	18.4	0	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	2405	1/23/2023	11:05:00 AM	886	0.6	72	18.9	1	
Humboldt Senior High School	2406	1/23/2023	11:03:00 AM	700	0.5	72	18.4	0	
Humboldt Senior High School	2409	1/23/2023	11:00:00 AM	740	0.6	71.8	18.7	0	
Humboldt Senior High School	2501	1/23/2023	12:17:00 PM	786	0.6	69.6	20.1	0	
Humboldt Senior High School	2502	1/23/2023	12:16:00 PM	981	0.6	69.8	21.4	30	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	2503	1/23/2023	12:13:00 PM	936	0.5	70	22.2	25	
Humboldt Senior High School	2504	1/23/2023	12:09:00 PM	990	0.6	70.3	21.2	25	
Humboldt Senior High School	2505	1/23/2023	12:06:00 PM	962	0.6	70.3	21.9	35	
Humboldt Senior High School	2506	1/23/2023	12:03:00 PM	1169	0.6	72	23.6	30	
Humboldt Senior High School	2601	1/23/2023	11:40:00 AM	696	0.6	71.8	18.4	0	
Humboldt Senior High School	2606	1/23/2023	10:54:00 AM	730	0.5	71.4	18.8	0	
Humboldt Senior High School	3103	1/23/2023	10:29:00 AM	863	0.6	70.5	19.7	1	
Humboldt Senior High School	3104	1/23/2023	10:16:00 AM	800	0.7	73.4	18	1	
Humboldt Senior High School	3105	1/23/2023	10:27:00 AM	788	0.6	71.6	18.3	0	
Humboldt Senior High School	3106	1/23/2023	10:26:00 AM	886	0.6	72.6	19.2	1	
Humboldt Senior High School	3107	1/23/2023	10:24:00 AM	999	0.6	72.6	20	20	
Humboldt Senior High School	3108	1/23/2023	10:22:00 AM	722	0.6	72.5	17.3	0	
Humboldt Senior High School	3109	1/23/2023	10:20:00 AM	1034	0.7	72.9	20.9	3	
Humboldt Senior High School	3110	1/23/2023	10:14:00 AM	935	0.7	73.2	20	25	
Humboldt Senior High School	3111	1/23/2023	10:12:00 AM	980	0.7	72.5	19.9	30	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	3201	1/23/2023	10:05:00 AM	714	0.6	71.6	17.3	15	
Humboldt Senior High School	3202	1/23/2023	10:03:00 AM	771	0.6	70.9	18	35	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3203	1/23/2023	9:53:00 AM	697	0.7	71.6	17	20	
Humboldt Senior High School	3301	1/23/2023	9:51:00 AM	634	0.8	71.1	17.1	0	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3302	1/23/2023	9:48:00 AM	560	0.8	71.2	16.1	3	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3303	1/23/2023	9:46:00 AM	704	0.8	70.9	17.3	1	
Humboldt Senior High School	3305	1/23/2023	9:44:00 AM	662	0.9	70.9	17.5	12	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3306	1/23/2023	9:42:00 AM	843	0.9	70.5	19.5	25	
Humboldt Senior High School	3307	1/23/2023	9:39:00 AM	702	1	70.3	17.3	15	
Humboldt Senior High School	3308	1/23/2023	9:37:00 AM	785	1	70.3	19	3	
Humboldt Senior High School	3309	1/23/2023	9:35:00 AM	1094	1	69.6	22	30	Stained ceiling tiles
Humboldt Senior High School	3310	1/23/2023	9:33:00 AM	747	1	68.7	18.4	30	
Humboldt Senior High School	3312	1/23/2023	9:25:00 AM	591	1	69.1	17.1	1	
Humboldt Senior High School	3401	1/23/2023	10:46:00 AM	689	0.5	69.8	18.3	25	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3402	1/23/2023	10:43:00 AM	657	0.5	70	18.1	2	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3403	1/23/2023	10:39:00 AM	605	0.5	70.2	17.2	2	
Humboldt Senior High School	3404	1/23/2023	10:41:00 AM	561	0.4	69.4	17.3	0	
Humboldt Senior High School	3501	1/23/2023	10:36:00 AM	603	0.5	71.4	16.3	0	
Humboldt Senior High School	3502	1/23/2023	10:33:00 AM	742	0.5	72.3	18.1	0	Fragrance odor
Humboldt Senior High School	3503	1/23/2023	10:32:00 AM	580	0.5	71.4	16.7	4	
Humboldt Senior High School	3504	1/23/2023	10:10:00 AM	826	0.6	71.8	18.3	20	
Humboldt Senior High School	3505	1/23/2023	10:06:00 AM	580	0.6	71.8	15.7	0	
Humboldt Senior High School	3600	1/23/2023	9:55:00 AM	722	0.8	71.2	17.2	2	
Humboldt Senior High School	3601	1/23/2023	9:58:00 AM	616	0.7	70.5	16.4	5	
Humboldt Senior High School	3605	1/23/2023	10:00:00 AM	578	0.6	70.3	16.4	1	
Humboldt Senior High School	3606	1/23/2023	10:02:00 AM	559	0.6	70.5	16.3	1	
Humboldt Senior High School	3608	1/23/2023	9:57:00 AM	590	0.7	71.2	16.3	2	
Humboldt Senior High School	3609	1/23/2023	10:17:00 AM	911	0.7	73.4	18.8	1	
Humboldt Senior High School	1001 MAIN OFFICE	1/23/2023	12:09:00 PM	737	0.8	71.4	18.1	4	
Humboldt Senior High School	1004 CONFERENCE	1/23/2023	12:11:00 PM	703	0.7	71.2	17.9	0	
Humboldt Senior High School	1005 OFFICE	1/23/2023	12:12:00 PM	663	0.6	71.4	17.7	0	
Humboldt Senior High School	1006 OFFICE	1/23/2023	12:16:00 PM	779	0.6	71.6	19.4	1	
Humboldt Senior High School	1008 OFFICE	1/23/2023	12:17:00 PM	800	0.6	71.1	19.6	0	
Humboldt Senior High School	1009 OFFICE	1/23/2023	12:20:00 PM	654	0.6	70.5	18.4	0	
Humboldt Senior High School	1010 OFFICE	1/23/2023	12:24:00 PM	674	0.6	70.7	18.4	0	
Humboldt Senior High School	1011 OFFICE	1/23/2023	12:25:00 PM	670	0.6	71.2	22.5	0	Fragrance odor, Plants
Humboldt Senior High School	1012 OFFICE	1/23/2023	12:27:00 PM	876	0.6	71.2	20.5	2	
Humboldt Senior High School	1013 OFFICE	1/23/2023	12:29:00 PM	787	0.6	71.2	20.3	1	
Humboldt Senior High School	1015 OFFICE	1/23/2023	12:39:00 PM	778	0.6	71.4	19.4	0	
Humboldt Senior High School	1016 OFFICE	1/23/2023	12:37:00 PM	770	0.6	71.2	19.2	0	
Humboldt Senior High School	1017 OFFICE	1/23/2023	12:33:00 PM	782	0.6	71.1	19.3	0	
Humboldt Senior High School	1018 OFFICE	1/23/2023	12:32:00 PM	1030	0.7	71.6	23.9	3	
Humboldt Senior High School	1019 OFFICE	1/23/2023	12:31:00 PM	869	0.7	71.4	22.2	1	
Humboldt Senior High School	1020 OFFICE	1/23/2023	12:30:00 PM	988	0.6	71.4	23.7	1	
Humboldt Senior High School	1021 OFFICE	1/23/2023	12:22:00 PM	679	0.6	70.2	18.4	0	
Humboldt Senior High School	1022 OFFICE	1/23/2023	12:19:00 PM	680	0.6	70.9	18.2	0	
Humboldt Senior High School	1023 WORKROOM	1/23/2023	12:14:00 PM	719	0.6	71.4	18.7	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	1113 OFFICE	1/23/2023	10:53:00 AM	588	0.5	72.5	16.4	0	
Humboldt Senior High School	1114A KITCHEN OFFICE	1/23/2023	9:54:00 AM	613	1	67.9	17.8	0	
Humboldt Senior High School	1206 CUBICLES	1/23/2023	11:43:00 AM	662	0.5	70.5	18.8	0	
Humboldt Senior High School	1301B	1/23/2023	11:43:00 AM	869	0.5	71.1	20	1	
Humboldt Senior High School	1303B OFFICE	1/23/2023	11:38:00 AM	747	0.4	68.9	19.6	2	
Humboldt Senior High School	1304A OFFICE	1/23/2023	11:09:00 AM	625	0.5	72.9	16.8	0	
Humboldt Senior High School	1304B REPAIR OFFICE	1/23/2023	11:10:00 AM	590	0.5	73	16.1	0	
Humboldt Senior High School	1304C OFFICE	1/23/2023	11:12:00 AM	612	0.5	73.2	16.5	0	
Humboldt Senior High School	1401 GYMNASIUM	1/23/2023	9:45:00 AM	498	0.5	67.5	16.2	19	
Humboldt Senior High School	1402 PIANO ROOM	1/23/2023	11:30:00 AM	467	0.5	66.7	16.3	0	
Humboldt Senior High School	1403 BAND	1/23/2023	11:26:00 AM	561	0.2	68.5	16.1	9	Stained ceiling tiles
Humboldt Senior High School	1404 CONFERENCE	1/23/2023	11:24:00 AM	502	0.4	69.1	16.3	0	Fragrance odor, Plants
Humboldt Senior High School	1502 CHOIR	1/23/2023	11:13:00 AM	485	0.3	70.3	14.9	1	
Humboldt Senior High School	1502A LATTICE ROOM	1/23/2023	11:19:00 AM	580	0.3	69.6	15.3	0	
Humboldt Senior High School	1502B PRACTICE ROOM	1/23/2023	11:21:00 AM	514	0.4	69.3	15.7	0	
Humboldt Senior High School	1502C OFFICE	1/23/2023	11:23:00 AM	467	0.3	69.8	15.2	0	
Humboldt Senior High School	1505 AUDITORIUM	1/23/2023	10:11:00 AM	450	0.3	70.3	15.1	0	
Humboldt Senior High School	1608 CLINIC	1/23/2023	10:31:00 AM	716	0.5	70.7	18.5	1	
Humboldt Senior High School	1608A OFFICE	1/23/2023	10:36:00 AM	703	0.5	72.7	17.3	1	
Humboldt Senior High School	1608B OFFICE	1/23/2023	10:37:00 AM	635	0.5	72.9	16.6	0	
Humboldt Senior High School	1608C OFFICE	1/23/2023	10:39:00 AM	632	0.5	73	16.8	0	
Humboldt Senior High School	1608E OFFICE	1/23/2023	10:34:00 AM	639	0.5	71.6	17.3	0	
Humboldt Senior High School	1608F OFFICE	1/23/2023	10:35:00 AM	666	0.5	72.3	17.5	0	
Humboldt Senior High School	1703 OFFICE	1/23/2023	12:58:00 PM	769	0.6	69.1	20.1	3	
Humboldt Senior High School	1704 OFFICE	1/23/2023	12:57:00 PM	892	0.6	68.9	22.4	1	
Humboldt Senior High School	1705 OFFICE	1/23/2023	12:56:00 PM	836	0.6	69.3	21.1	1	
Humboldt Senior High School	1706 OFFICE	1/23/2023	12:53:00 PM	636	0.5	69.4	18.4	0	
Humboldt Senior High School	1708 OFFICE	1/23/2023	12:49:00 PM	966	0.5	71.1	20.9	3	
Humboldt Senior High School	1710 CUBICLES	1/23/2023	10:47:00 AM	638	0.5	72.3	17.3	0	
Humboldt Senior High School	1800D STAGE	1/23/2023	10:17:00 AM	445	0.4	69.8	14.7	0	
Humboldt Senior High School	1805 STAFF LOUNGE	1/23/2023	10:22:00 AM	624	0.4	69.6	18	3	Plants
Humboldt Senior High School	1807OFFICE	1/23/2023	10:30:00 AM	663	0.4	70.9	18.1	0	
Humboldt Senior High School	1810 HEALTH RECEPTION	1/23/2023	10:41:00 AM	667	0.5	71.8	17.7	1	
Humboldt Senior High School	1811 COT ROOM	1/23/2023	10:43:00 AM	684	0.5	72.5	17.9	0	
Humboldt Senior High School	1812 OFFICE	1/23/2023	10:42:00 AM	685	0.5	72.1	17.8	1	
Humboldt Senior High School	1813 OFFICE	1/23/2023	10:46:00 AM	765	0.5	72.9	18.6	1	
Humboldt Senior High School	1814 OFFICE	1/23/2023	10:44:00 AM	729	0.5	72.7	20.8	1	
Humboldt Senior High School	2300C GYM	1/23/2023	1:11:00 PM	681	0.5	69.3	20.9	18	
Humboldt Senior High School	2300F CAFETERIA	1/23/2023	9:59:00 AM	550	0.4	68.5	18.6	4	
Humboldt Senior High School	2300G GYMNASIUM	1/23/2023	10:01:00 AM	690	0.4	69.6	19.7	1	
Humboldt Senior High School	2300H POOL	1/23/2023	10:09:00 AM	539	0.6	78.1	55.2	0	
Humboldt Senior High School	2300L SHARED GYM OFFICE	1/23/2023	10:02:00 AM	563	0.5	71.1	18.4	1	
Humboldt Senior High School	2310A	1/23/2023	11:24:00 AM	643	0.5	70.7	17.9	0	
Humboldt Senior High School	2312A	1/23/2023	11:18:00 AM	627	0.5	70	18.1	0	
Humboldt Senior High School	2503A	1/23/2023	12:11:00 PM	806	0.6	70	20.7	0	
Humboldt Senior High School	2600 E	1/23/2023	10:57:00 AM	718	0.5	71.6	18.5	5	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	2600 W	1/23/2023	10:59:00 AM	722	0.5	71.6	18.7	4	
Humboldt Senior High School	2600C	1/23/2023	12:05:00 PM	579	0.5	71.2	16.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	3112 WRESTLING ROOM	1/23/2023	9:47:00 AM	541	0.4	68	17.3	0	
Humboldt Senior High School	3117 OFFICE	1/23/2023	9:53:00 AM	522	0.3	70	16.3	0	
Humboldt Senior High School	3126 SHARED GYM OFFICE	1/23/2023	9:29:00 AM	499	0.4	68	17	1	
Humboldt Senior High School	3131 ENGINEER OFFICE	1/23/2023	1:03:00 PM	541	0.5	68.7	19.8	0	
Humboldt Senior High School	3133 CUSTODIAN LOUNGE	1/23/2023	1:04:00 PM	556	0.5	69.1	19.7	1	
Humboldt Senior High School	3137 KITCHEN	1/23/2023	9:58:00 AM	591	0.6	67.1	21.6	6	
Humboldt Senior High School	3145 POOL OFFICE	1/23/2023	10:04:00 AM	608	0.6	76.1	19.4	0	
Humboldt Senior High School	AUDITORIUM SOUND ROOM	1/23/2023	10:19:00 AM	525	0.3	73.6	14	0	
Humboldt Senior High School	OUTDOORS	1/23/2023		415	1.1	12.1	81		
Humboldt Senior High School	WEIGHT ROOM	1/23/2023	1:10:00 PM	706	0.5	69.1	19	5	
J.J. Hill Magnet	1001	12/9/2022	10:02:00 AM	527	0.1	68.4	22.8	1	
J.J. Hill Magnet	1009	12/9/2022	10:01:00 AM	522	0.1	68.9	22.2	1	
J.J. Hill Magnet	1011	12/9/2022	10:12:00 AM	476	0.1	68.7	22.5	1	
J.J. Hill Magnet	1012	12/9/2022	10:09:00 AM	504	0.1	68.9	23.3	2	
J.J. Hill Magnet	1013	12/9/2022	10:08:00 AM	467	0.1	68.5	22.2	0	
J.J. Hill Magnet	1014	12/9/2022	10:07:00 AM	483	0.1	68	22.8	2	
J.J. Hill Magnet	1105	12/9/2022	10:57:00 AM	607	0.1	68.7	24.1	0	
J.J. Hill Magnet	1108	12/9/2022	9:54:00 AM	460	0.1	69.1	23.6	0	
J.J. Hill Magnet	1201	12/9/2022	10:37:00 AM	650	0.1	69.4	24	25	Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents, Taxidermy
J.J. Hill Magnet	1203	12/9/2022	10:44:00 AM	691	0.1	69.4	24.6	25	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1204	12/9/2022	10:42:00 AM	785	0.1	69.8	24.9	27	Stained ceiling tiles, Aquariums (fish), Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1207	12/9/2022	10:40:00 AM	685	0.1	69.4	23.9	21	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1208	12/9/2022	10:35:00 AM	568	0.1	69.4	22.8	2	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1209	12/9/2022	10:32:00 AM	567	0.1	69.3	23	4	Plants
J.J. Hill Magnet	1210	12/9/2022	10:30:00 AM	726	0.1	69.6	24.3	16	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1213	12/9/2022	10:28:00 AM	543	0.1	69.3	22.6	0	
J.J. Hill Magnet	1214	12/9/2022	10:24:00 AM	656	0.1	69.3	23.7	26	Plants: Kept Away From Return And Supply Vents, Taxidermy
J.J. Hill Magnet	1216	12/9/2022	10:22:00 AM	779	0.1	70	24.9	21	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1302	12/9/2022	8:50:00 AM	608	0.1	69.3	23	24	
J.J. Hill Magnet	1303	12/9/2022	8:53:00 AM	608	0.1	69.1	23.3	1	
J.J. Hill Magnet	1304	12/9/2022	8:54:00 AM	591	0.1	68.9	23	0	
J.J. Hill Magnet	1305	12/9/2022	9:15:00 AM	625	0.1	69.4	23.1	4	
J.J. Hill Magnet	1306	12/9/2022	9:14:00 AM	600	0.1	68.9	23	1	
J.J. Hill Magnet	1307	12/9/2022	9:12:00 AM	568	0.1	68.7	22.7	0	
J.J. Hill Magnet	1308	12/9/2022	9:09:00 AM	644	0.1	69.3	23.3	19	
J.J. Hill Magnet	1309	12/9/2022	9:17:00 AM	666	0.1	69.3	24	25	Plants
J.J. Hill Magnet	1401	12/9/2022	8:44:00 AM	589	0.1	69.1	22.8	19	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1402	12/9/2022	8:47:00 AM	622	0.1	69.4	23.5	18	
J.J. Hill Magnet	1403	12/9/2022	8:56:00 AM	650	0.1	68.5	23.6	21	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1404	12/9/2022	8:58:00 AM	650	0.1	71.4	22.3	20	Plants
J.J. Hill Magnet	1405	12/9/2022	9:02:00 AM	572	0.1	70	23.5	22	Plants
J.J. Hill Magnet	1407	12/9/2022	9:07:00 AM	564	0.1	69.3	22.4	2	
J.J. Hill Magnet	1409	12/9/2022	9:04:00 AM	707	0.1	69.4	23.7	27	Live animals: Kept Away From Return And Supply Vents, Plants
J.J. Hill Magnet	2200	12/9/2022	9:30:00 AM	679	0.1	69.3	23.8	4	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
J.J. Hill Magnet	2201	12/9/2022	9:20:00 AM	712	0.1	70	23.7	15	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	2203	12/9/2022	9:44:00 AM	573	0.1	68.7	22.6	0	
J.J. Hill Magnet	2204	12/9/2022	9:23:00 AM	747	0.1	70	23.8	21	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	2207	12/9/2022	9:24:00 AM	699	0.1	69.6	23.4	17	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	2208	12/9/2022	9:27:00 AM	620	0.1	68.9	23	14	
J.J. Hill Magnet	2209	12/9/2022	9:31:00 AM	685	0.1	69.4	24.1	13	Plants
J.J. Hill Magnet	2212	12/9/2022	9:35:00 AM	595	0.1	69.3	23.5	26	Plants
J.J. Hill Magnet	2213	12/9/2022	9:37:00 AM	567	0.1	68.5	22.6	0	
J.J. Hill Magnet	2215	12/9/2022	9:41:00 AM	750	0.1	69.4	24.7	19	Plants: Kept Away From Return And Supply Vents
J.J. Hill Magnet	1002/1003	12/9/2022	10:54:00 AM	495	0.1	69.2	23.3	4	
J.J. Hill Magnet	1004/1005	12/9/2022	10:04:00 AM	460	0.1	68.5	22.1	0	
J.J. Hill Magnet	130 COMMONS	12/9/2022	9:46:00 AM	660	0.1	68.9	23.5	19	
J.J. Hill Magnet	CAFETERIA	12/9/2022	9:57:00 AM	565	0.1	69.3	22.4	60	
J.J. Hill Magnet	GYMNASIUM	12/9/2022	9:53:00 AM	448	0.1	69.5	22.3	19	
J.J. Hill Magnet	KITCHEN	12/9/2022	9:59:00 AM	570	0.1	69.4	22.5	2	
J.J. Hill Magnet	OUTDOORS	12/9/2022		291	0.3	49.3	33.1		
Jie Ming Mandarin Immersion Academy	1001	1/18/2023	11:01:00 AM	674	0.4	71.4	24.2	1	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	1003	1/18/2023	11:03:00 AM	628	0.4	71.4	24	0	
Jie Ming Mandarin Immersion Academy	1004	1/18/2023	11:05:00 AM	733	0.4	71.1	24.9	4	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	1010	1/18/2023	11:07:00 AM	676	0.4	70.5	24.9	2	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	1012	1/18/2023	11:08:00 AM	654	0.4	69.8	25.1	0	
Jie Ming Mandarin Immersion Academy	1101	1/18/2023	11:00:00 AM	698	0.4	71.6	24.5	0	
Jie Ming Mandarin Immersion Academy	1105	1/18/2023	10:42:00 AM	607	0.4	68.9	25.5	0	
Jie Ming Mandarin Immersion Academy	1107	1/18/2023	10:41:00 AM	610	0.4	69.4	25.3	0	Fragrance odor
Jie Ming Mandarin Immersion Academy	1108	1/18/2023	10:44:00 AM	1075	0.4	69.8	29	24	
Jie Ming Mandarin Immersion Academy	1109	1/18/2023	10:47:00 AM	523	0.4	69.8	24.1	3	
Jie Ming Mandarin Immersion Academy	1110	1/18/2023	10:48:00 AM	1047	0.4	70.9	28.4	22	
Jie Ming Mandarin Immersion Academy	1111	1/18/2023	10:58:00 AM	962	0.4	71.6	26.8	24	
Jie Ming Mandarin Immersion Academy	1112	1/18/2023	10:56:00 AM	891	0.4	71.2	28	21	
Jie Ming Mandarin Immersion Academy	1113	1/18/2023	10:53:00 AM	1054	0.5	70.9	27.8	24	
Jie Ming Mandarin Immersion Academy	1114	1/18/2023	10:51:00 AM	631	0.4	70.9	26.2	18	
Jie Ming Mandarin Immersion Academy	1201	1/18/2023	10:35:00 AM	1194	0.5	72.3	29	26	
Jie Ming Mandarin Immersion Academy	1203	1/18/2023	10:33:00 AM	1162	0.5	71.4	28.7	28	
Jie Ming Mandarin Immersion Academy	1205	1/18/2023	10:30:00 AM	886	0.5	71.4	27.2	8	Moisture damage at top of the air supply, Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1304	1/18/2023	10:02:00 AM	674	0.5	71.8	24.7	23	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1315	1/18/2023	10:10:00 AM	604	0.5	72.7	25.5	6	Plants
Jie Ming Mandarin Immersion Academy	1316	1/18/2023	10:06:00 AM	715	0.5	70.7	25.7	20	Bubbling/peeling paint
Jie Ming Mandarin Immersion Academy	1404	1/18/2023	10:12:00 AM	575	0.5	68.9	27.2	16	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1406	1/18/2023	10:16:00 AM	480	0.4	68	26.3	0	
Jie Ming Mandarin Immersion Academy	2304	1/18/2023	11:12:00 AM	912	0.4	70.3	27.8	23	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	2307	1/18/2023	11:15:00 AM	663	0.4	71.2	26	22	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	2310	1/18/2023	11:17:00 AM	608	0.4	72	24.7	2	
Jie Ming Mandarin Immersion Academy	2315	1/18/2023	11:23:00 AM	635	0.4	71.6	24.8	23	
Jie Ming Mandarin Immersion Academy	2316	1/18/2023	11:20:00 AM	742	0.4	71.4	25.3	21	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Jie Ming Mandarin Immersion Academy	3304	1/18/2023	11:40:00 AM	26	0.4	70.7	27.6	21	
Jie Ming Mandarin Immersion Academy	3305	1/18/2023	11:38:00 AM	727	0.4	71.1	25.6	20	
Jie Ming Mandarin Immersion Academy	3311	1/18/2023	11:35:00 AM	642	0.4	71.8	24.3	0	
Jie Ming Mandarin Immersion Academy	3312	1/18/2023	11:32:00 AM	763	0.4	72.9	25.4	1	Bubbling/peeling paint
Jie Ming Mandarin Immersion Academy	3315	1/18/2023	11:26:00 AM	712	0.4	70.5	26	19	Bubbling/peeling paint, Plants
Jie Ming Mandarin Immersion Academy	3316	1/18/2023	11:29:00 AM	834	0.4	70.2	27.1	16	Bubbling/peeling paint
Jie Ming Mandarin Immersion Academy	1103 MEDIA CENTER	1/18/2023	10:39:00 AM	612	0.5	70.3	24.5	1	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	1305 CUSTODIAL OFFICE	1/18/2023	9:56:00 AM	610	0.5	74.5	22.4	1	
Jie Ming Mandarin Immersion Academy	1401 KITCHEN	1/18/2023	10:18:00 AM	536	0.4	69.3	24.8	1	Stained ceiling tiles
Jie Ming Mandarin Immersion Academy	EAST 1402 GYMNASIUM	1/18/2023	10:20:00 AM	500	0.5	73.8	21.8	17	Areas of rust throughout ceiling
Jie Ming Mandarin Immersion Academy	OUTDOORS	1/18/2023		400	0.6	33	78		
Jie Ming Mandarin Immersion Academy	WEST 1402 GYMNASIUM	1/18/2023	10:27:00 AM	453	0.5	72.5	22.1	0	Various areas of rust throughout ceiling
Johnson Senior High School	201	2/8/2023	1:51:00 PM	475	0.3	69.8	22.7	0	
Johnson Senior High School	204	2/8/2023	1:50:00 PM	575	0.3	70.2	22.2	0	
Johnson Senior High School	208	2/8/2023	1:48:00 PM	556	0.3	71.2	22.3	1	
Johnson Senior High School	211	2/8/2023	1:45:00 PM	723	0.3	71.1	24.6	22	
Johnson Senior High School	214	2/8/2023	1:44:00 PM	840	0.3	71.6	25.9	9	
Johnson Senior High School	215	2/8/2023	1:42:00 PM	980	0.4	71.4	27.2	7	
Johnson Senior High School	216	2/8/2023	1:27:00 PM	745	0.4	72	24.4	0	
Johnson Senior High School	217	2/8/2023	1:41:00 PM	765	0.4	71.1	26.1	8	
Johnson Senior High School	218	2/8/2023	1:39:00 PM	747	0.4	71.2	28.4	21	
Johnson Senior High School	1010	2/8/2023	11:00:00 AM	892	0.5	72.1	22.2	24	
Johnson Senior High School	1011	2/8/2023	2:37:00 PM	734	0.3	72.7	24.1	2	
Johnson Senior High School	1012	2/8/2023	2:39:00 PM	702	0.3	23.7	692	1	
Johnson Senior High School	1013	2/8/2023	2:40:00 PM	658	0.3	73.4	23.1	2	
Johnson Senior High School	1017	2/8/2023	11:24:00 AM	626	0.4	70.9	22.7	6	
Johnson Senior High School	1018	2/8/2023	2:34:00 PM	516	0.37	0.6	22.9	0	
Johnson Senior High School	1027	2/8/2023	2:26:00 PM	654	0.3	71.8	24.1	2	
Johnson Senior High School	1101	2/8/2023	11:21:00 AM	527	0.4	71.1	21.3	1	
Johnson Senior High School	1102	2/8/2023	11:22:00 AM	1007	0.4	70.9	25.3	16	
Johnson Senior High School	1103	2/8/2023	11:18:00 AM	751	0.4	71.4	23	17	Fragrance odor
Johnson Senior High School	1104	2/8/2023	11:19:00 AM	1212	0.5	71.2	26.1	16	Baby powder odor
Johnson Senior High School	1107	2/8/2023	11:16:00 AM	1052	0.4	71.6	26.4	33	Stuffy odor
Johnson Senior High School	1109	2/8/2023	11:14:00 AM	831	0.4	71.2	24	29	
Johnson Senior High School	1111	2/8/2023	11:12:00 AM	632	0.4	71.2	21.9	2	
Johnson Senior High School	1112	2/8/2023	11:03:00 AM	764	0.4	71.2	21.9	1	Plants
Johnson Senior High School	1113	2/8/2023	11:08:00 AM	518	0.4	71.4	20.4	0	
Johnson Senior High School	1113	2/8/2023	11:10:00 AM	839	0.4	71.2	23.8	12	
Johnson Senior High School	1117	2/8/2023	11:05:00 AM	520	0.3	71.2	20.4	0	
Johnson Senior High School	1119	2/8/2023	10:59:00 AM	556	0.4	71.8	20.4	1	
Johnson Senior High School	1201	2/8/2023	10:58:00 AM	614	0.4	71.4	21.3	2	
Johnson Senior High School	1203	2/8/2023	10:56:00 AM	1130	0.4	71.6	25.6	29	Plants
Johnson Senior High School	1204	2/8/2023	10:54:00 AM	790	0.4	71.1	22.9	12	Stained ceiling tiles
Johnson Senior High School	1206	2/8/2023	10:47:00 AM	686	0.4	70.9	21.2	0	
Johnson Senior High School	1207	2/8/2023	10:52:00 AM	953	0.5	71.1	24.4	26	Musty odor
Johnson Senior High School	1208	2/8/2023	10:44:00 AM	919	0.5	71.1	23.1	23	
Johnson Senior High School	1209	2/8/2023	10:49:00 AM	1208	0.4	71.4	26.2	32	
Johnson Senior High School	1210	2/8/2023	11:31:00 AM	554	0.4	71.6	20.4	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	1212	2/8/2023	10:40:00 AM	699	0.5	71.1	22.1	4	
Johnson Senior High School	1213	2/8/2023	10:46:00 AM	586	0.4	71.1	20.6	1	
Johnson Senior High School	1215	2/8/2023	10:42:00 AM	626	0.4	70.9	21.2	0	
Johnson Senior High School	1217	2/8/2023	10:38:00 AM	777	0.5	72	22.2	9	
Johnson Senior High School	1218	2/8/2023	10:35:00 AM	854	0.5	72.1	23.2	17	Plants
Johnson Senior High School	1219	2/8/2023	10:36:00 AM	26	0.5	72.5	21.8	26	
Johnson Senior High School	1221	2/8/2023	10:32:00 AM	603	0.5	73.4	20	0	
Johnson Senior High School	1310	2/8/2023	10:27:00 AM	578	1.9	72.9	19.9	0	
Johnson Senior High School	1311	2/8/2023	10:24:00 AM	542	3.5	73.9	24.2	1	
Johnson Senior High School	1501	2/8/2023	11:27:00 AM	439	0.3	72.7	18.7	0	
Johnson Senior High School	1601	2/8/2023	11:35:00 AM	593	0.4	72	22.1	26	
Johnson Senior High School	2102	2/8/2023	1:25:00 PM	485	0.3	71.4	21.6	0	
Johnson Senior High School	2103	2/8/2023	1:18:00 PM	623	0.3	72	23.1	7	
Johnson Senior High School	2107	2/8/2023	1:01:00 PM	1076	0.4	72.5	25.1	15	
Johnson Senior High School	2108	2/8/2023	1:19:00 PM	518	0.3	71.6	21.7	2	
Johnson Senior High School	2109	2/8/2023	12:59:00 PM	889	0.3	71.8	23.3	0	
Johnson Senior High School	2110	2/8/2023	1:10:00 PM	597	0.3	72.9	21.8	3	
Johnson Senior High School	2111	2/8/2023	12:56:00 PM	781	0.3	71.6	23.5	9	
Johnson Senior High School	2112	2/8/2023	1:04:00 PM	937	0.3	72.7	24.8	12	Plants
Johnson Senior High School	2113	2/8/2023	12:55:00 PM	733	0.4	71.4	22.7	27	
Johnson Senior High School	2114	2/8/2023	1:03:00 PM	1685	0.4	72.5	31	30	
Johnson Senior High School	2115	2/8/2023	12:51:00 PM	801	0.4	72.7	22.6	12	
Johnson Senior High School	2117	2/8/2023	12:49:00 PM	800	0.4	71.8	23.4	18	
Johnson Senior High School	2118	2/8/2023	12:53:00 PM	941	0.4	72.9	23.9	24	Plants
Johnson Senior High School	2119	2/8/2023	12:44:00 PM	657	0.4	72.1	21.8	0	
Johnson Senior High School	2120	2/8/2023	12:50:00 PM	835	0.4	72.1	23	4	
Johnson Senior High School	2121	2/8/2023	12:43:00 PM	822	0.4	72.5	23.1	18	Stained ceiling tiles
Johnson Senior High School	2122	2/8/2023	12:45:00 PM	820	0.4	72.3	22.7	0	
Johnson Senior High School	2125	2/8/2023	12:42:00 PM	742	0.4	72.7	21.7	18	
Johnson Senior High School	2201	2/8/2023	12:40:00 PM	675	0.4	73.2	72.1	0	
Johnson Senior High School	2203	2/8/2023	12:39:00 PM	635	0.4	73.8	20.5	0	
Johnson Senior High School	2205	2/8/2023	12:37:00 PM	833	0.4	73.6	21.2	0	
Johnson Senior High School	2206	2/8/2023	12:38:00 PM	906	0.5	73.6	24.5	0	
Johnson Senior High School	2207	2/8/2023	12:35:00 PM	1143	0.4	73.9	26.4	24	
Johnson Senior High School	2208	2/8/2023	12:36:00 PM	1135	0.5	73.8	24.9	0	
Johnson Senior High School	2209	2/8/2023	12:30:00 PM	1092	0.5	73.4	25.9	1	Stuffy odor
Johnson Senior High School	2210	2/8/2023	12:33:00 PM	1946	0.5	73.4	31.6	20	
Johnson Senior High School	2211	2/8/2023	12:29:00 PM	535	0.4	72.3	20.7	1	
Johnson Senior High School	2212	2/8/2023	1:08:00 PM	695	0.4	73.6	21.3	2	Plants: Kept Away From Return And Supply Vents
Johnson Senior High School	2218	2/8/2023	12:27:00 PM	542	0.4	72.1	20.9	1	
Johnson Senior High School	2220	2/8/2023	12:24:00 PM	600	0.4	72.3	21.4	2	
Johnson Senior High School	2222	2/8/2023	12:22:00 PM	562	0.4	72	21.1	1	
Johnson Senior High School	2401	2/8/2023	12:14:00 PM	603	0.5	72.5	22.3	1	
Johnson Senior High School	2413	2/8/2023	12:16:00 PM	610	0.6	72.7	20.9	0	
Johnson Senior High School	2420	2/8/2023	12:13:00 PM	655	0.4	71.1	22.3	1	
Johnson Senior High School	2421	2/8/2023	12:10:00 PM	543	0.4	71.2	20.8	0	
Johnson Senior High School	2422	2/8/2023	12:08:00 PM	686	0.4	71.6	22.5	0	
Johnson Senior High School	2423	2/8/2023	12:07:00 PM	678	0.4	72	21.3	1	Fragrance odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	2424	2/8/2023	12:01:00 PM	755	0.4	72.1	21.8	1	
Johnson Senior High School	2426	2/8/2023	11:46:00 AM	781	0.5	72.7	22.5	21	
Johnson Senior High School	1.00E+05	2/8/2023	2:15:00 PM	643	0.3	74.8	23.1	1	
Johnson Senior High School	0202A	2/8/2023	1:54:00 PM	495	0.3	70.2	22.9	12	
Johnson Senior High School	0202B	2/8/2023	1:53:00 PM	455	0.3	70	22.5	0	
Johnson Senior High School	0208C	2/8/2023	1:49:00 PM	578	0.3	70.9	22.8	0	Stained ceiling tiles
Johnson Senior High School	0216 OFFICE	2/8/2023	1:38:00 PM	714	0.4	71.6	23.8	0	
Johnson Senior High School	1001 OFFICE	2/8/2023	2:09:00 PM	598	0.3	71.8	23.7	2	
Johnson Senior High School	1003A	2/8/2023	2:16:00 PM	472	0.3	74.7	20.6	0	Fragrance odor
Johnson Senior High School	1003B	2/8/2023	2:13:00 PM	624	0.3	75	23	1	Stuffy odor
Johnson Senior High School	1003C	2/8/2023	2:10:00 PM	568	0.3	72	23.3	0	
Johnson Senior High School	1003D	2/8/2023	2:12:00 PM	772	0.3	72.3	26	1	
Johnson Senior High School	1005A	2/8/2023	2:17:00 PM	655	0.4	73.2	23	1	
Johnson Senior High School	1005B	2/8/2023	2:20:00 PM	542	0.3	72.7	22.6	1	
Johnson Senior High School	1005C	2/8/2023	2:21:00 PM	535	0.4	72.5	22.8	1	
Johnson Senior High School	1005D	2/8/2023	2:22:00 PM	804	0.3	72.1	25.6	2	
Johnson Senior High School	1005E	2/8/2023	2:23:00 PM	659	0.3	72	25	1	
Johnson Senior High School	1005F	2/8/2023	2:25:00 PM	525	0.3	72	23.2	0	
Johnson Senior High School	1006A	2/8/2023	2:05:00 PM	612	0.3	71.4	24.1	0	
Johnson Senior High School	1006B	2/8/2023	2:04:00 PM	511	0.3	70.6	23.6	0	
Johnson Senior High School	1006C	2/8/2023	2:01:00 PM	479	0.3	70.9	23.1	0	
Johnson Senior High School	1006D	2/8/2023	2:01:00 PM	482	0.3	71.1	22.6	0	
Johnson Senior High School	1006E	2/8/2023	2:00:00 PM	532	0.3	70.9	23.8	2	
Johnson Senior High School	1007B	2/8/2023	1:56:00 PM	515	0.3	70.5	23.4	0	
Johnson Senior High School	1010A	2/8/2023	2:35:00 PM	694	0.3	71.8	24.3	2	
Johnson Senior High School	1018 NURSE	2/8/2023	2:30:00 PM	620	0.3	71.4	23.9	0	
Johnson Senior High School	1019 NURSE	2/8/2023	2:29:00 PM	636	0.3	71.4	24.6	2	
Johnson Senior High School	1027 NURSE	2/8/2023	2:32:00 PM	719	0.3	71.6	24.9	2	
Johnson Senior High School	1407 KITCHEN OFFICE	2/8/2023	11:42:00 AM	506	0.4	72.3	19.6	1	
Johnson Senior High School	1410 KITCHEN	2/8/2023	11:40:00 AM	494	0.5	72.3	20.7	6	
Johnson Senior High School	2101A	2/8/2023	1:20:00 PM	562	0.3	71.2	23.1	2	
Johnson Senior High School	2101B	2/8/2023	1:22:00 PM	566	0.3	70.9	23.3	2	
Johnson Senior High School	2101C	2/8/2023	1:24:00 PM	508	0.3	70.9	23.1	0	
Johnson Senior High School	2105A	2/8/2023	1:12:00 PM	541	0.3	72.5	22	2	
Johnson Senior High School	2105B	2/8/2023	1:15:00 PM	528	0.3	72.7	22	1	
Johnson Senior High School	2105C	2/8/2023	1:16:00 PM	532	0.3	72.3	22	0	
Johnson Senior High School	2107A	2/8/2023	12:58:00 PM	940	0.3	72	23.6	0	
Johnson Senior High School	2120B OFFICE	2/8/2023	12:48:00 PM	783	0.4	71.6	22.6	0	
Johnson Senior High School	2212B	2/8/2023	1:06:00 PM	654	0.3	74.3	20.6	2	
Johnson Senior High School	222B	2/8/2023	12:23:00 PM	711	0.4	71.8	22.1	2	
Johnson Senior High School	2402 CHOIR	2/8/2023	11:53:00 AM	629	0.4	72.1	22.2	21	
Johnson Senior High School	2407 CHOIR OFFICE	2/8/2023	11:58:00 AM	550	0.3	71.2	22.1	0	
Johnson Senior High School	2409 BAND	2/8/2023	11:58:00 AM	464	0.3	71.6	21.1	0	
Johnson Senior High School	2418 BAND OFFICE	2/8/2023	12:00:00 PM	462	0.3	71.8	21.1	0	
Johnson Senior High School	AUDITORIUM 1502	2/8/2023	11:30:00 AM	482	0.4	73	18.7	#	
Johnson Senior High School	CAFETERIA 1401	2/8/2023	11:44:00 AM	714	0.5	73.9	23.2	185	
Johnson Senior High School	CONFERENCE ROOM	2/8/2023	2:02:00 PM	639	0.3	70.7	24.7	3	
Johnson Senior High School	GYMNASIUM 1302	2/8/2023	10:30:00 AM	939	0.5	73	32	32	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	OUTDOORS	2/8/2023		430	0.7	32	79		
Journeys Secondary School	1001	1/17/2023	9:40:00 AM	494	0.6	74.5	24.2	2	
Journeys Secondary School	1003	1/17/2023	9:42:00 AM	481	0.6	74.1	24.3	0	
Journeys Secondary School	1004	1/17/2023	9:45:00 AM	464	0.5	74.1	24.3	0	
Journeys Secondary School	1005	1/17/2023	9:43:00 AM	504	0.5	74.3	24.5	1	
Journeys Secondary School	1006	1/17/2023	9:47:00 AM	476	0.6	73.9	24.3	0	
Journeys Secondary School	1101	1/17/2023	9:48:00 AM	502	0.5	73.9	24.8	1	Bubbling/peeling paint
Journeys Secondary School	1104	1/17/2023	9:38:00 AM	462	0.5	74.5	23.9	0	
Journeys Secondary School	1106	1/17/2023	9:34:00 AM	460	0.6	74.1	24.1	0	Bubbling/peeling paint
Journeys Secondary School	1109	1/17/2023	9:31:00 AM	517	0.6	73.8	25	1	
Journeys Secondary School	1111	1/17/2023	9:25:00 AM	603	0.6	73.9	25.9	5	Bubbling/peeling paint
Journeys Secondary School	1112	1/17/2023	9:22:00 AM	464	0.5	73.4	24.6	0	Bubbling/peeling paint
Journeys Secondary School	1114	1/17/2023	9:19:00 AM	454	0.6	74.5	24.4	1	Bubbling/peeling paint
Journeys Secondary School	1116	1/17/2023	9:54:00 AM	459	0.5	73.6	24.7	0	Bubbling/peeling paint
Journeys Secondary School	1118	1/17/2023	9:59:00 AM	503	0.5	73.9	24.7	4	
Journeys Secondary School	2101	1/17/2023	10:40:00 AM	544	0.5	75.4	25.7	6	Bubbling/peeling paint
Journeys Secondary School	2102	1/17/2023	10:37:00 AM	534	0.5	74.7	24.7	2	Bubbling/peeling paint
Journeys Secondary School	2104	1/17/2023	10:31:00 AM	460	0.5	73.4	24.3	0	
Journeys Secondary School	2105	1/17/2023	10:33:00 AM	490	0.5	73.6	25	1	Bubbling/peeling paint, Moisture damage at West side of windows, Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	2106	1/17/2023	10:29:00 AM	453	0.5	73.6	24.3	0	
Journeys Secondary School	2107	1/17/2023	11:40:00 AM	590	0.5	73.4	26.4	2	Stained ceiling tiles
Journeys Secondary School	2108	1/17/2023	10:25:00 AM	507	0.5	73.4	25.1	2	
Journeys Secondary School	2114	1/17/2023	10:11:00 AM	477	0.5	72.3	25.6	1	Bubbling/peeling paint
Journeys Secondary School	2115	1/17/2023	10:14:00 AM	478	0.5	72.5	25.5	1	
Journeys Secondary School	3101	1/17/2023	10:46:00 AM	470	0.5	73.8	24.8	5	Bubbling/peeling paint, Stained ceiling tiles
Journeys Secondary School	3102	1/17/2023	10:49:00 AM	456	0.5	74.8	23.7	0	Bubbling/peeling paint, Moisture damage at East Wall
Journeys Secondary School	3104	1/17/2023	10:57:00 AM	446	0.5	74.7	23.6	0	Bubbling/peeling paint, Moisture damage at throughout ceiling
Journeys Secondary School	3105	1/17/2023	10:53:00 AM	484	0.5	75.4	23.7	2	Bubbling/peeling paint
Journeys Secondary School	3106	1/17/2023	11:03:00 AM	522	0.5	74.1	24.8	5	Bubbling/peeling paint, Plants
Journeys Secondary School	3107	1/17/2023	11:00:00 AM	455	0.5	73.9	24.3	1	Bubbling/peeling paint
Journeys Secondary School	3108	1/17/2023	11:07:00 AM	524	0.5	73.9	25.1	4	Bubbling/peeling paint
Journeys Secondary School	3111	1/17/2023	11:31:00 AM	486	0.6	74.3	24.3	1	Bubbling/peeling paint
Journeys Secondary School	3112	1/17/2023	11:12:00 AM	464	0.5	73.6	24.4	0	Bubbling/peeling paint
Journeys Secondary School	3113	1/17/2023	11:21:00 AM	437	0.6	70.7	26.1	3	
Journeys Secondary School	3114	1/17/2023	11:24:00 AM	505	0.4	72.5	25.9	0	
Journeys Secondary School	3115	1/17/2023	11:27:00 AM	468	0.5	74.1	24.1	3	Bubbling/peeling paint
Journeys Secondary School	3116	1/17/2023	11:34:00 AM	460	0.5	73.8	24.5	1	Bubbling/peeling paint
Journeys Secondary School	1104A	1/17/2023	9:51:00 AM	469	0.5	73.9	24.5	0	
Journeys Secondary School	1110 WOODSHOP	1/17/2023	9:29:00 AM	453	0.6	73.8	24.3	0	Bubbling/peeling paint
Journeys Secondary School	1115 CAFETERIA	1/17/2023	10:02:00 AM	468	0.5	73.2	25.1	6	Bubbling/peeling paint
Journeys Secondary School	1116A OFFICE	1/17/2023	9:57:00 AM	451	0.5	72.9	24.8	0	Bubbling/peeling paint
Journeys Secondary School	1117 KITCHEN	1/17/2023	10:06:00 AM	455	0.5	72.7	27.7	2	
Journeys Secondary School	2112 MEDIA CENTER	1/17/2023	10:17:00 AM	459	0.5	73.2	24.8	1	Bubbling/peeling paint
Journeys Secondary School	2112A	1/17/2023	10:19:00 AM	463	0.5	73.4	25.2	0	
Journeys Secondary School	2112B	1/17/2023	10:22:00 AM	508	0.5	73.4	24.8	1	
Journeys Secondary School	3114A	1/17/2023	11:25:00 AM	498	0.5	72.5	25.8	1	Bubbling/peeling paint
Journeys Secondary School	CUSTODIAL OFFICE	1/17/2023	9:13:00 AM	542	0.6	77.6	25.3	1	Moisture damage above entrance from stairs

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Journeys Secondary School	OUTDOORS	1/17/2023		382	0.9	34	85		
Journeys Secondary School	STAGE	1/17/2023	10:05:00 AM	431	0.5	72.3	25.6	0	Bubbling/peeling paint
LEAP High School	1001	1/12/2023	11:43:00 AM	618	0.1	71	18.8	6	
LEAP High School	1002	1/12/2023	11:45:00 AM	576	0.1	71.3	17.6	0	
LEAP High School	1003	1/12/2023	11:47:00 AM	634	0.1	71.8	17.9	0	
LEAP High School	1101	1/12/2023	11:41:00 AM	710	0.1	70.1	19.8	8	
LEAP High School	1102	1/12/2023	11:39:00 AM	601	0.1	70	18.9	1	
LEAP High School	1103	1/12/2023	11:37:00 AM	593	0.1	69.4	20	1	
LEAP High School	1105	1/12/2023	11:35:00 AM	559	0.1	68.7	18.8	0	
LEAP High School	1106	1/12/2023	11:34:00 AM	525	0.1	68.6	18.8	1	
LEAP High School	1107	1/12/2023	11:31:00 AM	549	0.1	69.9	17.6	0	
LEAP High School	1108	1/12/2023	11:24:00 AM	553	0.1	70.8	17.3	2	
LEAP High School	1109	1/12/2023	11:23:00 AM	620	0.1	69.8	18.9	0	
LEAP High School	1201	1/12/2023	12:14:00 PM	630	0.1	70.1	18.2	15	
LEAP High School	1202	1/12/2023	12:12:00 PM	496	0.1	70	71.6	0	
LEAP High School	1204	1/12/2023	11:27:00 AM	452	0.1	69.8	16	3	Bubbling/peeling paint
LEAP High School	1302	1/12/2023	11:48:00 AM	570	0.1	71.1	17.6	0	Bubbling/peeling paint
LEAP High School	1303	1/12/2023	11:52:00 AM	564	0.1	70.4	18.4	0	
LEAP High School	1304	1/12/2023	11:53:00 AM	628	0.1	73.1	17.9	5	Bubbling/peeling paint
LEAP High School	1406	1/12/2023	12:04:00 PM	545	0.1	68	18.7	0	Stained ceiling tiles
LEAP High School	2001	1/12/2023	10:57:00 AM	558	0.1	71	17.5	0	
LEAP High School	2002	1/12/2023	10:55:00 AM	622	0.1	71.1	18.6	2	Bubbling/peeling paint
LEAP High School	2003	1/12/2023	10:47:00 AM	585	0.4	70.5	18.6	1	
LEAP High School	2102	1/12/2023	11:06:00 AM	593	0.1	72.5	17.1	5	
LEAP High School	2103	1/12/2023	11:08:00 AM	675	0.4	71.6	18	15	
LEAP High School	2104	1/12/2023	11:12:00 AM	625	0.1	73.1	16.3	5	
LEAP High School	2106	1/12/2023	11:14:00 AM	457	0.2	71.6	15	0	
LEAP High School	2107	1/12/2023	11:09:00 AM	498	0.1	73.4	14.6	0	
LEAP High School	2303	1/12/2023	10:43:00 AM	638	0.1	70	19.4	8	
LEAP High School	2304	1/12/2023	10:42:00 AM	606	0.1	69	19.1	0	
LEAP High School	2304	1/12/2023	10:45:00 AM	692	0.1	70.6	19.7	20	
LEAP High School	2305	1/12/2023	10:35:00 AM	544	0.1	68.3	19.7	0	
LEAP High School	3102	1/12/2023	10:08:00 AM	566	0.2	72.4	16.5	6	Stained ceiling tiles
LEAP High School	3103	1/12/2023	9:45:00 AM	577	1.6	71.8	0.5	0	
LEAP High School	3104	1/12/2023	10:06:00 AM	899	0.2	72.6	18.3	12	Plants: Kept Away From Return And Supply Vents
LEAP High School	3201	1/12/2023	10:13:00 AM	473	0.2	70.5	17	0	Stained ceiling tiles
LEAP High School	3202	1/12/2023	10:11:00 AM	549	0.3	71.9	17	0	
LEAP High School	3203	1/12/2023	10:18:00 AM	1002	0.1	70.3	21.8	20	Stained ceiling tiles
LEAP High School	3204	1/12/2023	10:15:00 AM	577	0.2	70.1	18	1	
LEAP High School	3205	1/12/2023	10:19:00 AM	618	0.1	70.7	18.9	10	
LEAP High School	3206	1/12/2023	10:21:00 AM	623	0.1	70.8	18.6	15	
LEAP High School	3302	1/12/2023	10:24:00 AM	608	0.3	73	17.8	0	Bubbling/peeling paint
LEAP High School	3304	1/12/2023	10:27:00 AM	690	0.3	72.3	18	2	
LEAP High School	3306	1/12/2023	10:30:00 AM	590	0.1	71.6	17.6	0	Bubbling/peeling paint
LEAP High School	3307	1/12/2023	10:33:00 AM	507	0.3	67.7	18.7	0	
LEAP High School	1102A	1/12/2023	11:40:00 AM	587	0.1	69.6	18.3	0	
LEAP High School	1204B	1/12/2023	11:29:00 AM	451	0.1	69.6	16.4	1	
LEAP High School	1205N	1/12/2023	11:59:00 AM	452	0.1	71.5	14.4	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
LEAP High School	1205S	1/12/2023	11:56:00 AM	509	0.1	71.6	14.2	1	
LEAP High School	1401N	1/12/2023	12:01:00 PM	535	0.3	69.3	17.6	2	
LEAP High School	1401S	1/12/2023	12:03:00 PM	510	0.2	68.8	17.5	1	
LEAP High School	2001B	1/12/2023	11:04:00 AM	549	0.1	72.6	16.6	0	
LEAP High School	2001C	1/12/2023	11:03:00 AM	567	0.1	72.4	16.6	0	
LEAP High School	2001D	1/12/2023	11:01:00 AM	555	0.1	72.2	17	0	
LEAP High School	2001E	1/12/2023	10:59:00 AM	578	0.1	71.6	17.1	0	
LEAP High School	2003A	1/12/2023	10:54:00 AM	568	0.2	71.5	17.5	0	
LEAP High School	2003B	1/12/2023	10:53:00 AM	569	0.1	71.6	17.4	0	
LEAP High School	2003C	1/12/2023	10:51:00 AM	603	0.1	71.1	17.8	1	
LEAP High School	2003D	1/12/2023	10:49:00 AM	589	0.1	71.3	17.5	0	
LEAP High School	2003E	1/12/2023	10:48:00 AM	610	0.1	70.8	18.8	3	
LEAP High School	CAFETERIA	1/12/2023	12:17:00 PM	729	0.1	72	20.5	45	
LEAP High School	KITCHEN	1/12/2023	12:20:00 PM	703	0.1	72.5	20.1	3	
LEAP High School	KITCHEN OFFICE	1/12/2023	12:22:00 PM	714	0.1	72.4	20.4	2	
LEAP High School	OUTDOORS	1/12/2023		444	0.2	24.1	79.9		
L'Etoile du Nord Upper	1101	1/20/2023	12:18:00 PM	648	0.5	70.5	22.6	1	
L'Etoile du Nord Upper	2101	1/20/2023	1:33:00 PM	661	0.4	72.1	20.6	14	
L'Etoile du Nord Upper	2102	1/20/2023	2:19:00 PM	581	0.4	72.9	20.5	17	
L'Etoile du Nord Upper	2106	1/20/2023	1:57:00 PM	638	0.4	72.9	20.4	20	
L'Etoile du Nord Upper	2107	1/20/2023	1:20:00 PM	646	0.5	73	21.4	17	
L'Etoile du Nord Upper	2214	1/20/2023	2:21:00 PM	609	0.5	71.4	21.5	20	
L'Etoile du Nord Upper	2215	1/20/2023	1:51:00 PM	611	0.4	71.4	20.8	12	
L'Etoile du Nord Upper	2216	1/20/2023	1:56:00 PM	615	0.4	70.3	22.3	22	
L'Etoile du Nord Upper	2217	1/20/2023	12:45:00 PM	832	0.5	71.2	23.1	21	
L'Etoile du Nord Upper	2218	1/20/2023	2:23:00 PM	756	0.4	69.8	23.6	22	
L'Etoile du Nord Upper	3101	1/20/2023	1:07:00 PM	600	0.3	73.8	22.2	18	
L'Etoile du Nord Upper	3102	1/20/2023	1:06:00 PM	765	0.4	70.5	24.2	17	Plants
L'Etoile du Nord Upper	3106	1/20/2023	1:09:00 PM	849	0.7	73.4	22.9	25	Plants
L'Etoile du Nord Upper	3107	1/20/2023	1:11:00 PM	737	0.5	72.9	22.5	24	
L'Etoile du Nord Upper	3202	1/20/2023	1:02:00 PM	658	0.5	70.2	22.7	1	
L'Etoile du Nord Upper	3212	1/20/2023	1:00:00 PM	723	0.4	70.2	23.6	3	Food odor
L'Etoile du Nord Upper	3215	1/20/2023	12:55:00 PM	700	0.4	70.5	23.4	1	
L'Etoile du Nord Upper	3216	1/20/2023	12:54:00 PM	739	0.4	70.5	22.9	14	
L'Etoile du Nord Upper	3217	1/20/2023	12:53:00 PM	936	0.4	70.5	26	21	Plants
L'Etoile du Nord Upper	3218	1/20/2023	12:47:00 PM	983	0.4	70.2	25.1	16	
L'Etoile du Nord Upper	1101A OFFICE	1/20/2023	12:19:00 PM	641	0.6	70.2	22.9	0	
L'Etoile du Nord Upper	1103 WORKROOM	1/20/2023	12:17:00 PM	557	0.4	70.9	20.8	0	
L'Etoile du Nord Upper	1105 STAFF LOUNGE	1/20/2023	12:15:00 PM	795	0.4	72	25.8	8	
L'Etoile du Nord Upper	1106 MEDIA CENTER	1/20/2023	12:12:00 PM	559	0.4	68.2	22.4	0	
L'Etoile du Nord Upper	1107A CUSTODIAL OFFICE	1/20/2023	12:10:00 PM	569	0.5	71.4	21.1	1	
L'Etoile du Nord Upper	1109 OFFICE	1/20/2023	12:26:00 PM	535	0.4	68.5	22.2	0	
L'Etoile du Nord Upper	1111 NURSE	1/20/2023	12:29:00 PM	595	0.5	69.3	22.9	1	
L'Etoile du Nord Upper	1118 MAIN OFFICE	1/20/2023	12:31:00 PM	773	0.4	70.2	26.2	4	
L'Etoile du Nord Upper	1122 CONFERENCE	1/20/2023	12:32:00 PM	599	0.5	69.8	25	0	
L'Etoile du Nord Upper	1123 OFFICE	1/20/2023	12:33:00 PM	628	0.5	70	25.9	0	
L'Etoile du Nord Upper	1124 OFFICE	1/20/2023	12:34:00 PM	610	0.5	69.3	25.6	0	Stained ceiling tiles
L'Etoile du Nord Upper	1125 WORKROOM	1/20/2023	12:35:00 PM	622	0.6	68.7	26	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
L'Etoile du Nord Upper	1201 CAFETERIA	1/20/2023	12:22:00 PM	745	0.5	70.3	25.4	80	
L'Etoile du Nord Upper	1201A KITCHEN	1/20/2023	12:20:00 PM	891	0.5	70.2	26.5	1	
L'Etoile du Nord Upper	1221 GYMNASIUM	1/20/2023	12:23:00 PM	604	0.5	68.5	24.8	0	
L'Etoile du Nord Upper	1226 STAGE OFFICE	1/20/2023	12:25:00 PM	562	0.5	68.2	24.4	0	
L'Etoile du Nord Upper	2202 WORKROOM	1/20/2023	12:36:00 PM	741	0.6	72.9	22.1	1	Food odor, Stained ceiling tiles
L'Etoile du Nord Upper	2212 OFFICE	1/20/2023	12:42:00 PM	680	0.6	72.3	21.5	1	
L'Etoile du Nord Upper	3201 OFFICE	1/20/2023	1:04:00 PM	714	0.5	70.2	23.9	0	
L'Etoile du Nord Upper	3202A OFFICE	1/20/2023	1:04:00 PM	669	0.5	70.5	23	0	
L'Etoile du Nord Upper	3214 OFFICE	1/20/2023	12:57:00 PM	700	0.6	70	23.7	1	Plants
L'Etoile du Nord Upper	3214A OFFICE	1/20/2023	12:58:00 PM	679	0.5	70	23	1	
L'Etoile du Nord Upper	3214B OFFICE	1/20/2023	12:59:00 PM	606	0.5	70	22.5	0	
L'Etoile du Nord Upper	OUTDOORS	1/20/2023		1	1	1	1		
Maxfield Elementary School	1001	12/13/2022	12:03:00 PM	1025	0.2	68.9	28.6	2	Stained ceiling tiles, Plants
Maxfield Elementary School	1002	12/13/2022	12:07:00 PM	760	0.2	68.7	27.9	0	
Maxfield Elementary School	1003	12/13/2022	12:08:00 PM	752	0.2	69.3	27.5	0	
Maxfield Elementary School	1007	12/13/2022	12:10:00 PM	787	0.2	69.4	28.3	0	Stained ceiling tiles
Maxfield Elementary School	1102	12/13/2022	10:10:00 AM	928	0.2	68	29.3	17	
Maxfield Elementary School	1103	12/13/2022	10:12:00 AM	1143	0.2	69.3	29.7	17	
Maxfield Elementary School	1104	12/13/2022	10:15:00 AM	734	0.3	70.3	25.8	14	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1105	12/13/2022	12:18:00 PM	833	0.3	68.5	28.4	0	Stained ceiling tiles
Maxfield Elementary School	1106	12/13/2022	12:21:00 PM	872	0.3	68.2	29.4	0	Plants
Maxfield Elementary School	1110	12/13/2022	12:15:00 PM	1345	0.3	68	32	2	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1111	12/13/2022	12:12:00 PM	1365	0.2	68.9	32	0	Fragrance odor
Maxfield Elementary School	1112	12/13/2022	10:02:00 AM	899	0	69.8	26.5	3	Rust on floor tile, Stained ceiling tiles
Maxfield Elementary School	1113	12/13/2022	10:06:00 AM	591	0.2	68.9	25.7	0	
Maxfield Elementary School	1203	12/13/2022	10:42:00 AM	817	0.3	70	28.9	50	
Maxfield Elementary School	1209	12/13/2022	10:47:00 AM	807	0.3	71.6	27.9	0	
Maxfield Elementary School	1210	12/13/2022	12:32:00 PM	1075	0.2	72	30.1	2	
Maxfield Elementary School	1302	12/13/2022	10:56:00 AM	715	0.3	69.4	27.5	12	
Maxfield Elementary School	1303	12/13/2022	11:00:00 AM	955	0.3	70.2	27.3	17	
Maxfield Elementary School	1304	12/13/2022	11:02:00 AM	572	0.3	68.9	26.3	3	
Maxfield Elementary School	1305	12/13/2022	11:57:00 AM	511	0.2	69.1	25.5	2	
Maxfield Elementary School	1306	12/13/2022	12:01:00 PM	760	0.2	69.1	27.6	14	
Maxfield Elementary School	1307	12/13/2022	11:04:00 AM	521	0.2	68.2	26.3	6	
Maxfield Elementary School	1308	12/13/2022	11:08:00 AM	571	0.2	68.2	27	0	
Maxfield Elementary School	1401	12/13/2022	11:11:00 AM	522	0.2	69.1	25.1	0	Stained ceiling tiles
Maxfield Elementary School	1402	12/13/2022	11:13:00 AM	733	0.3	69.8	26.6	8	
Maxfield Elementary School	1403	12/13/2022	11:15:00 AM	523	0.3	68.7	26.1	2	
Maxfield Elementary School	1404	12/13/2022	11:18:00 AM	619	0.2	69.3	26.9	3	Stained ceiling tiles
Maxfield Elementary School	1405	12/13/2022	11:19:00 AM	595	0.2	70.3	25.5	1	Stained ceiling tiles
Maxfield Elementary School	1406	12/13/2022	11:25:00 AM	572	0.2	68.5	26.4	0	
Maxfield Elementary School	1407	12/13/2022	11:21:00 AM	775	0.3	70.3	27.4	2	
Maxfield Elementary School	1408	12/13/2022	11:22:00 AM	633	0.3	69.4	27.5	1	
Maxfield Elementary School	1409	12/13/2022	11:27:00 AM	774	0.02	68.9	28.1	16	
Maxfield Elementary School	1410	12/13/2022	11:31:00 AM	505	0.02	68.5	26.4	0	Stuffy odor
Maxfield Elementary School	1411	12/13/2022	11:30:00 AM	558	0.2	68.4	26.9	8	
Maxfield Elementary School	1413	12/13/2022	11:33:00 AM	624	0.2	69.3	26.6	16	Aquariums (fish)
Maxfield Elementary School	1501	12/13/2022	11:51:00 AM	494	0.3	69.6	25.2	0	Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Maxfield Elementary School	1502	12/13/2022	11:53:00 AM	516	0.02	70.3	25.1	0	
Maxfield Elementary School	1503	12/13/2022	11:54:00 AM	509	0.2	70.7	24.1	0	Stuffy odor, Stained ceiling tiles, Suspect microbial growth: Ceiling tile
Maxfield Elementary School	1504	12/13/2022	10:50:00 AM	581	0.02	68.9	26.5	19	Live animals, Plants, Taxidermy
Maxfield Elementary School	1505	12/13/2022	11:49:00 AM	715	0.2	70.3	25.5	3	
Maxfield Elementary School	1506	12/13/2022	11:45:00 AM	635	0.02	68.5	26.3	15	
Maxfield Elementary School	1507	12/13/2022	11:47:00 AM	525	0.02	70.9	24.6	2	
Maxfield Elementary School	1508	12/13/2022	11:43:00 AM	630	0.02	68.4	27.7	0	
Maxfield Elementary School	1509	12/13/2022	11:40:00 AM	494	0.02	68.4	25.6	0	
Maxfield Elementary School	1512	12/13/2022	11:36:00 AM	560	0.02	70.2	25.4	0	Musty odor
Maxfield Elementary School	1602	12/13/2022	12:24:00 PM	1015	0.2	70.2	29.1	15	
Maxfield Elementary School	1603	12/13/2022	12:26:00 PM	745	0.3	71.4	25.9	15	
Maxfield Elementary School	2101	12/13/2022	12:31:00 PM	633	0.3	69.3	26.5	0	
Maxfield Elementary School	2102	12/13/2022	12:29:00 PM	755	0.2	70	27.6	3	
Maxfield Elementary School	2103	12/13/2022	10:35:00 AM	1610	0.3	68.5	33.2	22	Fragrance odor, Stained ceiling tiles
Maxfield Elementary School	2104	12/13/2022	10:27:00 AM	1726	0.3	69.1	33.7	21	Stuffy odor
Maxfield Elementary School	2105	12/13/2022	10:25:00 AM	1451	0.2	68	34.1	21	
Maxfield Elementary School	2106	12/13/2022	10:19:00 AM	921	0.3	67.3	29.6	14	
Maxfield Elementary School	2110	12/13/2022	10:30:00 AM	1083	0.3	68.2	29.9	2	Fragrance odor, Bubbling/peeling paint
Maxfield Elementary School	2111	12/13/2022	10:38:00 AM	981	0.3	70	28.1	0	
Maxfield Elementary School	OUTDOORS	12/13/2022		482	0.4	36	36		
Mississippi Elementary School	1004	11/21/2022	1:03:00 PM	750	0.5	73.2	18.3	2	
Mississippi Elementary School	1005	11/21/2022	1:05:00 PM	694	0.5	73.8	17.7	0	Stained ceiling tiles
Mississippi Elementary School	1010	11/21/2022	1:01:00 PM	656	0.5	71.2	18.1	9	Stained ceiling tiles
Mississippi Elementary School	1103	11/21/2022	12:54:00 PM	590	0.5	71.2	18	1	
Mississippi Elementary School	1110	11/21/2022	1:08:00 PM	990	0.5	72.7	34.4	60	Stained ceiling tiles
Mississippi Elementary School	1111	11/21/2022	1:16:00 PM	495	0.3	72.1	16.9	5	Stained ceiling tiles
Mississippi Elementary School	1113	11/21/2022	1:15:00 PM	664	0.4	3.8	18.1	1	Stained ceiling tiles
Mississippi Elementary School	1211	11/21/2022	1:27:00 PM	950	0.3	73.8	21.3	19	Fragrance odor, Bubbling/peeling paint
Mississippi Elementary School	1212	11/21/2022	1:33:00 PM	906	0.3	74.5	0.1	21	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1213	11/21/2022	1:37:00 PM	1400	0.3	75	24.4	5	
Mississippi Elementary School	1214	11/21/2022	1:39:00 PM	914	0.3	72	20.7	22	
Mississippi Elementary School	1215	11/21/2022	1:42:00 PM	2122	0.4	70.5	33.5	19	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1216	11/21/2022	1:45:00 PM	927	0.3	72.9	22	1	
Mississippi Elementary School	1218	11/21/2022	1:51:00 PM	982	0.2	71.6	21.4	1	
Mississippi Elementary School	1219	11/21/2022	1:49:00 PM	879	0.3	72.3	21.8	0	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1220	11/21/2022	1:55:00 PM	640	0.1	73.2	20.7	0	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1221	11/21/2022	1:58:00 PM	1135	0.2	72.5	28.7	1	Bubbling/peeling paint, Plants
Mississippi Elementary School	1223	11/21/2022	2:01:00 PM	1044	0.2	72.1	24.5	1	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1225	11/21/2022	2:08:00 PM	774	0.2	72.3	22.7	0	
Mississippi Elementary School	1230	11/21/2022	2:04:00 PM	637	0.2	71.8	20.2	1	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1304	11/21/2022	2:34:00 PM	1030	0.2	70.9	23	11	
Mississippi Elementary School	1309	11/21/2022	2:36:00 PM	842	0.1	71.8	22.3	1	Stained ceiling tiles
Mississippi Elementary School	1310	11/21/2022	2:38:00 PM	1130	0.2	71.4	23.9	18	
Mississippi Elementary School	1311	11/21/2022	2:40:00 PM	1558	0.3	70.2	26.4	0	
Mississippi Elementary School	1313	11/21/2022	2:42:00 PM	975	0.1	69.3	24.2	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Mississippi Elementary School	1314	11/21/2022	2:44:00 PM	804	0.1	70	22	12	Paint odor
Mississippi Elementary School	1315	11/21/2022	2:46:00 PM	845	0.1	68.5	21.8	0	
Mississippi Elementary School	1316	11/21/2022	2:49:00 PM	1187	0.1	69.3	24.8	13	
Mississippi Elementary School	1318	11/21/2022	2:51:00 PM	1002	0.1	69.3	24.2	2	
Mississippi Elementary School	1320	11/21/2022	2:54:00 PM	1305	0.2	70.2	25.8	7	Stained ceiling tiles
Mississippi Elementary School	1321	11/21/2022	2:59:00 PM	978	0.2	69.8	24.7	1	Stained ceiling tiles
Mississippi Elementary School	1322	11/21/2022	2:53:00 PM	1525	0.3	70	28	15	
Mississippi Elementary School	1323	11/21/2022	2:58:00 PM	1450	0.3	69.4	27.1	2	Stained ceiling tiles
Mississippi Elementary School	1325	11/21/2022	2:55:00 PM	2273	0.3	70.3	32.7	15	Stained ceiling tiles
Mississippi Elementary School	2211	11/21/2022	3:05:00 PM	1370	0.3	73.2	24.8	0	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2212	11/21/2022	3:09:00 PM	1270	0.5	73.5	27.4	21	
Mississippi Elementary School	2213	11/21/2022	3:07:00 PM	1425	0.4	74.8	26.1	21	
Mississippi Elementary School	2214	11/21/2022	3:13:00 PM	1213	0.4	72.7	26.8	22	Plants: Kept Away From Return And Supply Vents, Taxidermy
Mississippi Elementary School	2215	11/21/2022	3:11:00 PM	1267	0.4	71.4	25	13	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2216	11/21/2022	3:16:00 PM	1113	0.4	73	22.4	1	
Mississippi Elementary School	2217	11/21/2022	3:17:00 PM	973	0.3	73.8	21.1	1	
Mississippi Elementary School	2218	11/21/2022	3:19:00 PM	886	0.3	73.9	19.5	10	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2219	11/21/2022	3:20:00 PM	1346	0.4	73.2	24.4	7	
Mississippi Elementary School	2220	11/21/2022	2:30:00 PM	1724	0.3	73	27.5	22	
Mississippi Elementary School	2221	11/21/2022	2:27:00 PM	1320	0.4	73	25.4	22	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2222	11/21/2022	2:25:00 PM	1254	0.2	72.7	22	3	Musty odor
Mississippi Elementary School	2223	11/21/2022	3:24:00 PM	1165	0.4	72.3	23.8	4	
Mississippi Elementary School	2225	11/21/2022	3:25:00 PM	1170	0.3	72.7	24.6	23	
Mississippi Elementary School	2228	11/21/2022	2:22:00 PM	1744	0.3	73.8	26.5	20	
Mississippi Elementary School	1110A	11/21/2022	1:13:00 PM	1072	0.6	75.2	31.3	2	Stained ceiling tiles
Mississippi Elementary School	1111A	11/21/2022	1:23:00 PM	492	0.3	70.7	17.1	0	
Mississippi Elementary School	1315 NORTH	11/21/2022	2:48:00 PM	978	0.1	68.5	23.8	2	Stained ceiling tiles
Mississippi Elementary School	GYM	11/21/2022	12:59:00 PM	820	0.5	71.6	19	12	
Mississippi Elementary School	KITCHEN	11/21/2022	1:10:00 PM	965	0.5	76.8	37.7	2	Moisture damage under dish sink
Mississippi Elementary School	OUTDOORS	11/21/2022		400	1	32	75		
Mississippi Elementary School	OUTDOORS	11/21/2022	3:28:00 PM	462	0.3	31	65		
Murray Middle School	203	11/28/2022	9:08:00 AM	1218	0.3	70.3	23.3	15	
Murray Middle School	206	11/28/2022	9:13:00 AM	464	0.3	72.1	19.4	1	
Murray Middle School	209	11/28/2022	9:17:00 AM	1190	0.4	72.3	22.5	13	
Murray Middle School	211	11/28/2022	9:19:00 AM	997	0.3	72	23.7	22	
Murray Middle School	212	11/28/2022	9:11:00 AM	634	0.3	70.2	22.5	0	
Murray Middle School	215	11/28/2022	9:25:00 AM	1451	0.3	70.9	27.6	24	Plants: Kept Away From Return And Supply Vents
Murray Middle School	216	11/28/2022	9:21:00 AM	675	0.3	71.2	21.9	0	Essential oil odor
Murray Middle School	217	11/28/2022	9:27:00 AM	1055	0.3	70.5	24.9	23	Musty odor
Murray Middle School	405	11/28/2022	9:49:00 AM	730	0.3	70.9	22.9	0	
Murray Middle School	406	11/28/2022	9:36:00 AM	1092	0.4	75.6	24	0	
Murray Middle School	407	11/28/2022	9:47:00 AM	1128	0.3	71.1	26.3	19	
Murray Middle School	408	11/28/2022	9:39:00 AM	1440	0.4	73.9	28.8	28	
Murray Middle School	409	11/28/2022	10:25:00 AM	991	0.3	71.4	25.5	20	Plants
Murray Middle School	410	11/28/2022	10:22:00 AM	1375	0.3	72.7	24.9	21	
Murray Middle School	412	11/28/2022	9:43:00 AM	698	0.3	71.8	22.3	6	
Murray Middle School	1001	11/28/2022	8:43:00 AM	703	0.1	72	32.8	3	Stained ceiling tiles
Murray Middle School	1003	11/28/2022	8:50:00 AM	975	0.2	69.4	22.6	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Murray Middle School	1004	11/28/2022	8:51:00 AM	587	0.2	70	22.3	1	Stained ceiling tiles
Murray Middle School	1005	11/28/2022	8:53:00 AM	582	0.3	71.1	22.5	1	
Murray Middle School	1006	11/28/2022	8:54:00 AM	624	0.3	70.5	22.2	1	Fragrance odor, Plants: Kept Away From Return And Supply Vents
Murray Middle School	1007	11/28/2022	8:56:00 AM	607	0.3	69.8	22.9	2	
Murray Middle School	1008	11/28/2022	11:13:00 AM	616	0.2	69.1	23.3	1	
Murray Middle School	1009	11/28/2022	8:57:00 AM	634	0.3	69.4	23	1	
Murray Middle School	1010	11/28/2022	8:59:00 AM	579	0.3	69.4	22.6	0	
Murray Middle School	1011	11/28/2022	11:11:00 AM	934	0.3	70.7	23.5	1	Diffuser odor
Murray Middle School	1012	11/28/2022	9:04:00 AM	647	0.3	70.3	22.4	1	Stained ceiling tiles
Murray Middle School	1105	11/28/2022	11:44:00 AM	899	0.3	71.4	22.4	14	
Murray Middle School	1108	11/28/2022	11:29:00 AM	568	0.2	71.1	22.4	0	
Murray Middle School	1202	11/28/2022	12:04:00 PM	901	0.3	72	24.9	25	Plants: Kept Away From Return And Supply Vents
Murray Middle School	1203	11/28/2022	12:07:00 PM	680	0.2	72.1	22	0	
Murray Middle School	1204	11/28/2022	12:00:00 PM	908	0.3	73.8	22.9	0	
Murray Middle School	1205	11/28/2022	12:12:00 PM	774	0.2	72.9	22.4	0	
Murray Middle School	1206	11/28/2022	11:58:00 AM	1106	0.5	73.6	26.7	2	Plants
Murray Middle School	1207	11/28/2022	12:18:00 PM	673	0.1	71.8	22.1	0	Stained ceiling tiles
Murray Middle School	1209	11/28/2022	12:25:00 PM	783	0.1	72.9	23	9	
Murray Middle School	1211	11/28/2022	12:32:00 PM	532	0.1	69.8	22.3	0	
Murray Middle School	1212	11/28/2022	12:14:00 PM	666	0.5	72.3	21.7	0	
Murray Middle School	1214	11/28/2022	12:16:00 PM	734	0.2	71.6	23	1	Plants: Kept Away From Return And Supply Vents
Murray Middle School	1216	11/28/2022	12:28:00 PM	525	0.2	72.1	20.9	0	
Murray Middle School	1218	11/28/2022	12:34:00 PM	589	0.1	68.9	23.9	1	
Murray Middle School	1301	11/28/2022	11:51:00 AM	437	0.2	69.4	22	2	
Murray Middle School	1401	11/28/2022	12:37:00 PM	937	0.2	72.5	23.7	0	
Murray Middle School	1403	11/28/2022	12:39:00 PM	1145	0.2	72.7	23.8	1	
Murray Middle School	2102	11/28/2022	11:08:00 AM	880	0.2	71.6	23.8	24	
Murray Middle School	2103	11/28/2022	11:05:00 AM	702	0.2	71.8	23.4	21	Plants: Kept Away From Return And Supply Vents
Murray Middle School	2104	11/28/2022	11:03:00 AM	823	0.3	71.2	24.4	30	Plants: Kept Away From Return And Supply Vents, Taxidermy
Murray Middle School	2105	11/28/2022	10:54:00 AM	516	0.2	71.1	21.5	0	Stained ceiling tiles
Murray Middle School	2108	11/28/2022	10:51:00 AM	1308	0.3	70.9	25.1	13	
Murray Middle School	2109	11/28/2022	10:46:00 AM	1032	0.3	70	24.6	16	Plants: Kept Away From Return And Supply Vents, Taxidermy
Murray Middle School	2202	11/28/2022	10:31:00 AM	725	0.2	70.7	22.8	1	
Murray Middle School	2203	11/28/2022	10:33:00 AM	1128	0.3	70.2	25.6	10	
Murray Middle School	2205	11/28/2022	10:35:00 AM	633	0.1	70.2	22.3	0	
Murray Middle School	2207	11/28/2022	10:30:00 AM	1407	0.4	71.4	25.3	24	
Murray Middle School	2208	11/28/2022	10:10:00 AM	622	0.5	71.8	21.2	0	
Murray Middle School	2209	11/28/2022	10:14:00 AM	818	0.2	71.4	24.6	19	
Murray Middle School	2210	11/28/2022	10:08:00 AM	748	0.3	71.4	24.8	12	
Murray Middle School	2210	11/28/2022	10:45:00 AM	990	0.2	70.3	27.7	30	Aquariums (fish), Taxidermy
Murray Middle School	2211	11/28/2022	10:41:00 AM	541	0.2	67.8	23.9	0	
Murray Middle School	2212	11/28/2022	10:05:00 AM	902	0.3	72	25	15	Plants: Kept Away From Return And Supply Vents
Murray Middle School	2213	11/28/2022	10:07:00 AM	1053	0.3	72	23.3	22	
Murray Middle School	2214	11/28/2022	10:01:00 AM	830	0.3	72	22.5	18	
Murray Middle School	2215	11/28/2022	10:03:00 AM	805	0.3	71.4	22.9	30	Plants: Kept Away From Return And Supply Vents
Murray Middle School	2216	11/28/2022	9:59:00 AM	870	0.3	73	26.2	2	
Murray Middle School	2217	11/28/2022	10:19:00 AM	1760	0.3	72.1	25.7	2	Plants: Kept Away From Return And Supply Vents
Murray Middle School	2402	11/28/2022	9:54:00 AM	652	0.3	70.3	22.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Murray Middle School	2403	11/28/2022	10:28:00 AM	1062	0.3	72.3	23.6	4	
Murray Middle School	0206A	11/28/2022	9:15:00 AM	581	0.3	74.5	22.1	1	Stuffy odor
Murray Middle School	0404A	11/28/2022	9:30:00 AM	553	0.3	74.1	21.3	1	
Murray Middle School	1105B	11/28/2022	11:37:00 AM	549	0.3	72	21.8	0	
Murray Middle School	1105C	11/28/2022	11:28:00 AM	652	0.2	71.8	24.7	1	
Murray Middle School	1105D	11/28/2022	11:42:00 AM	592	0.3	72.5	22.8	0	
Murray Middle School	1108A	11/28/2022	11:35:00 AM	594	0.3	72.3	22	0	Stained ceiling tiles
Murray Middle School	1108B	11/28/2022	11:32:00 AM	583	0.3	72.1	21.9	0	
Murray Middle School	1108C	11/28/2022	11:41:00 AM	577	0.2	71.6	22.8	0	
Murray Middle School	1301A	11/28/2022	11:48:00 AM	470	0.1	70	22.3	0	
Murray Middle School	1301B	11/28/2022	11:49:00 AM	483	0.1	70	22.7	1	Stained ceiling tiles
Murray Middle School	1301D	11/28/2022	11:54:00 AM	525	0.1	71.2	21.3	1	
Murray Middle School	2105A	11/28/2022	10:58:00 AM	634	0.3	71.4	22.4	0	
Murray Middle School	2108A	11/28/2022	11:01:00 AM	517	0.2	72.7	20.9	0	
Murray Middle School	2109D	11/28/2022	10:48:00 AM	519	0.2	69.1	22.7	0	
Murray Middle School	AUDITORIUM	11/28/2022	9:57:00 AM	533	0.1	71.8	22.6	0	
Murray Middle School	CAFETERIA	11/28/2022	11:45:00 AM	646	0.2	69.1	25.3	100	Stained ceiling tiles
Murray Middle School	GYM EAST	11/28/2022	12:42:00 PM	541	0.3	68.7	24	0	
Murray Middle School	GYM WEST	11/28/2022	12:44:00 PM	553	0.2	67.8	23.8	0	
Murray Middle School	KITCHEN	11/28/2022	11:21:00 AM	614	0.1	69.1	26.8	3	
Murray Middle School	KITCHEN OFFICE	11/28/2022	11:22:00 AM	572	0.3	68.7	24.6	1	
Murray Middle School	OUTDOORS	11/28/2022		380	0.4	29	78		
Murray Middle School	OUTDOORS	11/28/2022	12:45:00 PM	398	0.3	39	58		
Nokomis Montessori North	1001	11/15/2022	10:42:00 AM	510	0.1	70.5	26.4	2	
Nokomis Montessori North	1003	11/15/2022	10:45:00 AM	557	0.1	71.2	27.1	2	
Nokomis Montessori North	1004	11/15/2022	10:47:00 AM	613	0.1	71.4	26.6	1	Stained ceiling tiles
Nokomis Montessori North	1005	11/15/2022	10:49:00 AM	515	0.2	71.1	26.1	2	Aquariums (fish), Plants
Nokomis Montessori North	1007	11/15/2022	10:52:00 AM	633	0.1	70.9	26	1	Plants
Nokomis Montessori North	1008	11/15/2022	10:54:00 AM	500	0.1	70.3	25.4	1	
Nokomis Montessori North	1009	11/15/2022	10:57:00 AM	915	0.2	70.3	28.2	2	Fragrance odor
Nokomis Montessori North	1010	11/15/2022	10:59:00 AM	1106	0.2	71.1	29.7	2	Plants
Nokomis Montessori North	1101	11/15/2022	11:11:00 AM	491	0.2	70	29.2	4	Condensation
Nokomis Montessori North	1107	11/15/2022	11:01:00 AM	555	0.2	70.9	26.6	1	
Nokomis Montessori North	1109	11/15/2022	11:04:00 AM	482	0.3	71.1	25.3	1	
Nokomis Montessori North	1112	11/15/2022	11:07:00 AM	490	0.3	69.8	26	0	
Nokomis Montessori North	1113	11/15/2022	12:29:00 PM	529	0.3	69.8	26.7	0	Stained ceiling tiles
Nokomis Montessori North	1114	11/15/2022	11:16:00 AM	818	0.3	70.7	29.6	0	
Nokomis Montessori North	1115	11/15/2022	11:18:00 AM	552	0.1	71.8	71.8	3	
Nokomis Montessori North	1203	11/15/2022	11:21:00 AM	1540	0.3	70.9	30.4	25	Stained ceiling tiles
Nokomis Montessori North	1204	11/15/2022	11:29:00 AM	1441	0.3	70	31.5	25	
Nokomis Montessori North	1205	11/15/2022	11:24:00 AM	1558	0.3	70.5	31.3	15	Stained ceiling tiles
Nokomis Montessori North	1206	11/15/2022	12:24:00 PM	825	0.3	69.4	29.2	12	
Nokomis Montessori North	1207	11/15/2022	11:26:00 AM	1388	0.3	69.6	32.2	20	Stained ceiling tiles, Plants
Nokomis Montessori North	1301	11/15/2022	11:32:00 AM	729	0.3	70.7	26.7	2	Plants
Nokomis Montessori North	1303	11/15/2022	11:35:00 AM	853	0.3	70.5	28.3	2	Plants
Nokomis Montessori North	1305	11/15/2022	11:41:00 AM	1617	0.4	71.2	31.5	20	Plants
Nokomis Montessori North	1307	11/15/2022	11:44:00 AM	1550	0.4	71.2	32	25	Food odor
Nokomis Montessori North	1401	11/15/2022	11:47:00 AM	800	0.3	70.3	28.3	4	Food odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Nokomis Montessori North	1402	11/15/2022	11:49:00 AM	1298	0.3	70.5	29.1	12	Plants
Nokomis Montessori North	1403	11/15/2022	11:52:00 AM	915	0.3	70.5	26	16	Food odor, Condensation, Plants
Nokomis Montessori North	1404	11/15/2022	11:54:00 AM	1472	0.4	70.7	31.8	22	Aquariums (fish), Plants
Nokomis Montessori North	1405	11/15/2022	11:57:00 AM	780	0.3	70.3	29.3	11	Fragrance odor, Plants
Nokomis Montessori North	1407	11/15/2022	11:59:00 AM	952	0.3	70.5	32.2	16	Fragrance odor, Condensation
Nokomis Montessori North	2203	11/15/2022	12:08:00 PM	2175	0.4	70.9	36.6	16	
Nokomis Montessori North	2205	11/15/2022	12:13:00 PM	934	0.3	69.2	29.8	0	Plants
Nokomis Montessori North	2206	11/15/2022	12:14:00 PM	1246	0.3	68.7	32.5	16	Plants
Nokomis Montessori North	2207	11/15/2022	12:16:00 PM	1276	0.3	69.3	34.4	8	Fragrance odor, Plants
Nokomis Montessori North	2208	11/15/2022	12:18:00 PM	910	0.3	69.4	30.4	0	Fragrance odor, Plants
Nokomis Montessori North	2404	11/15/2022	12:10:00 PM	838	0.3	69.6	28.9	0	Plants
Nokomis Montessori North	OUTDOORS	11/15/2022		406	0.4	34	24		
Nokomis Montessori South	1003	1/6/2023	2:39:00 PM	673	0.7	70	17.2	1	
Nokomis Montessori South	1006	1/6/2023	2:42:00 PM	806	0.7	70.2	18.3	0	
Nokomis Montessori South	1102	1/6/2023	2:48:00 PM	610	0.6	68.9	15.7	3	
Nokomis Montessori South	1105	1/6/2023	2:50:00 PM	753	0.6	69.6	17.1	8	Fragrance odor
Nokomis Montessori South	1201	1/6/2023		884	0.7	69.4	19.9	0	
Nokomis Montessori South	1202	1/6/2023	2:33:00 PM	724	0.7	69.4	17.2	22	Plants
Nokomis Montessori South	1203	1/6/2023	2:32:00 PM	1063	0.8	69.8	20.2	21	
Nokomis Montessori South	1204	1/6/2023	2:30:00 PM	1185	0.8	70	20.5	28	
Nokomis Montessori South	1305	1/6/2023	2:21:00 PM	995	1.9	69.1	20.5	10	Plants
Nokomis Montessori South	1402	1/6/2023	2:20:00 PM	1138	3.3	70.3	23.9	10	
Nokomis Montessori South	1502	1/6/2023	2:51:00 PM	792	0.7	69.1	22.1	22	Plants
Nokomis Montessori South	1504	1/6/2023	2:54:00 PM	775	0.7	69.4	20.7	20	
Nokomis Montessori South	2100	1/6/2023	2:56:00 PM	846	1	68.9	21.7	1	
Nokomis Montessori South	2201	1/6/2023	3:00:00 PM	1618	0.8	68.5	25.5	21	Plants
Nokomis Montessori South	2202	1/6/2023	3:05:00 PM	1649	0.8	70	26.6	20	Plants
Nokomis Montessori South	2203	1/6/2023	3:09:00 PM	81	0.7	70.2	20.2	27	Fragrance odor
Nokomis Montessori South	2204	1/6/2023	3:10:00 PM	768	0.6	69.6	17.2	18	
Nokomis Montessori South	2205	1/6/2023	3:07:00 PM	705	0.7	70.2	16.1	8	Plants
Nokomis Montessori South	2206	1/6/2023	3:03:00 PM	1055	0.7	70.3	20.9	20	Plants
Nokomis Montessori South	2207	1/6/2023	3:02:00 PM	1666	0.8	69.3	25.3	23	
Nokomis Montessori South	2304	1/6/2023	3:12:00 PM	1146	1.2	69.4	23	11	
Nokomis Montessori South	2305	1/6/2023	3:16:00 PM	1181	1.2	69.6	23.7	7	Stained ceiling tiles
Nokomis Montessori South	2306	1/6/2023	3:14:00 PM	1211	1	69.8	25.7	27	Plants
Nokomis Montessori South	1001 MAIN OFFICE	1/6/2023	2:35:00 PM	664	0.7	69.4	16.9	5	
Nokomis Montessori South	1002 OFFICE	1/6/2023	2:37:00 PM	668	0.7	69.8	17.1	1	
Nokomis Montessori South	1004 NURSE	1/6/2023	2:40:00 PM	684	0.7	70.2	17.4	2	
Nokomis Montessori South	1005 COT ROOM	1/6/2023	2:41:00 PM	655	0.7	70.3	17	0	
Nokomis Montessori South	1007 WORKROOM	1/6/2023	2:38:00 PM	697	0.7	70.2	17.4	1	
Nokomis Montessori South	1303 OFFICE	1/6/2023	2:28:00 PM	866	1.7	70.5	19.1	0	Plants
Nokomis Montessori South	1304 OFFICE	1/6/2023	2:27:00 PM	1039	1.7	69.6	21.5	2	
Nokomis Montessori South	1404 KITCHEN	1/6/2023	2:19:00 PM	1320	5.3	71.1	20.8	1	
Nokomis Montessori South	1408 HEAD ENGINEER	1/6/2023	2:15:00 PM	904	2.1	70.7	19.8	1	
Nokomis Montessori South	MEDIA CENTER	1/6/2023	2:46:00 PM	551	0.7	68.9	15.4	1	
Nokomis Montessori South	OUTDOORS	1/6/2023		422	0.8	17	26.5		
Obama Elementary School	1001	12/6/2022	11:53:00 AM	568	0.1	70.5	14.9	1	
Obama Elementary School	1003	12/6/2022	11:59:00 AM	561	0.1	71.2	14.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Obama Elementary School	1005	12/6/2022	12:01:00 PM	501	0.1	70.3	13.9	0	
Obama Elementary School	1006	12/6/2022	12:03:00 PM	677	0.1	71.8	16.5	1	
Obama Elementary School	1007	12/6/2022	12:02:00 PM	676	0.1	70.7	15.5	2	
Obama Elementary School	1010	12/6/2022	12:11:00 PM	506	0.1	69.3	14.8	0	
Obama Elementary School	1013	12/6/2022	12:10:00 PM	551	0.1	69.3	16.2	0	
Obama Elementary School	1015	12/6/2022	12:07:00 PM	557	0.1	70.3	15.1	0	
Obama Elementary School	1015	12/6/2022	12:09:00 PM	553	0.1	69.8	14.7	0	
Obama Elementary School	1016	12/6/2022	12:05:00 PM	554	0.2	71.1	14.9	1	
Obama Elementary School	1101	12/6/2022	10:14:00 AM	459	0.1	67.5	13.1	0	Stained ceiling tiles
Obama Elementary School	1102	12/6/2022	10:18:00 AM	445	0.1	68.5	12.5	0	
Obama Elementary School	1104	12/6/2022	10:08:00 AM	496	0.1	67.6	19.3	3	
Obama Elementary School	1106	12/6/2022	10:12:00 AM	534	0.1	67.6	19.7	1	
Obama Elementary School	1111	12/6/2022	9:57:00 AM	488	0.1	69.6	13.3	1	
Obama Elementary School	1112	12/6/2022	9:59:00 AM	464	0.1	68.7	13.2	0	
Obama Elementary School	1113	12/6/2022	10:01:00 AM	456	0.1	67.5	13.6	0	
Obama Elementary School	1114	12/6/2022	9:46:00 AM	456	0.1	68.7	13.2	0	
Obama Elementary School	1116	12/6/2022	9:34:00 AM	455	0.1	69.4	13.2	0	
Obama Elementary School	1119	12/6/2022	9:43:00 AM	491	0.1	73	11.9	0	
Obama Elementary School	1120	12/6/2022	10:04:00 AM	743	0.1	70.7	17.3	16	
Obama Elementary School	1206	12/6/2022	10:30:00 AM	537	0.1	69.6	14.5	0	
Obama Elementary School	1207	12/6/2022	10:33:00 AM	573	0.1	71.4	15.2	22	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	1209	12/6/2022	10:38:00 AM	532	0.1	73.9	13.5	0	
Obama Elementary School	1210	12/6/2022	10:43:00 AM	542	0.1	71.6	14.4	0	
Obama Elementary School	1211	12/6/2022	10:51:00 AM	538	0.1	70.5	15	0	
Obama Elementary School	1212	12/6/2022	10:48:00 AM	544	0.1	71.1	14.8	0	
Obama Elementary School	1215	12/6/2022	10:52:00 AM	488	0.1	69.4	15.1	0	
Obama Elementary School	1216	12/6/2022	10:58:00 AM	488	0.1	68.4	15.5	0	
Obama Elementary School	1217	12/6/2022	11:00:00 AM	502	0.1	68.4	15.4	0	
Obama Elementary School	1220	12/6/2022	11:09:00 AM	480	0.1	67.3	16	0	
Obama Elementary School	1301	12/6/2022	8:42:00 AM	642	0.3	70.7	15.9	0	
Obama Elementary School	1302	12/6/2022	8:55:00 AM	603	0.3	69.4	16	1	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	1303	12/6/2022	8:58:00 AM	760	0.2	69.8	17.7	6	
Obama Elementary School	1304	12/6/2022	9:01:00 AM	680	0.2	69.1	16.7	0	
Obama Elementary School	1305	12/6/2022	9:05:00 AM	609	0.1	67.6	17	0	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
Obama Elementary School	1306	12/6/2022	9:08:00 AM	658	0.1	67.1	17.6	0	Bubbling/peeling paint
Obama Elementary School	1307	12/6/2022	9:11:00 AM	832	0.1	70.5	16.9	13	
Obama Elementary School	1308	12/6/2022	9:15:00 AM	852	0.2	70	17.9	12	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	1309	12/6/2022	9:19:00 AM	857	0.2	70.7	17.1	10	Fragrance odor
Obama Elementary School	1310	12/6/2022	9:22:00 AM	683	0.1	69.8	17	0	
Obama Elementary School	1312	12/6/2022	9:25:00 AM	677	0.1	69.8	16.3	0	
Obama Elementary School	1618	12/6/2022	9:40:00 AM	518	0.1	71.4	12.5	0	
Obama Elementary School	2203	12/6/2022	12:51:00 PM	509	0.1	71.4	15.2	1	
Obama Elementary School	2204	12/6/2022	12:52:00 PM	493	0.1	71.4	14.9	0	
Obama Elementary School	2205	12/6/2022	12:54:00 PM	510	0.1	71.8	15	1	
Obama Elementary School	2207	12/6/2022	12:56:00 PM	520	0.1	71.6	14.9	1	
Obama Elementary School	2208	12/6/2022	12:58:00 PM	511	0.1	72	14.8	1	Bubbling/peeling paint
Obama Elementary School	2209	12/6/2022	1:00:00 PM	503	0.1	70.3	15.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Obama Elementary School	2210	12/6/2022	1:03:00 PM	517	0.1	69.8	16	0	
Obama Elementary School	2211	12/6/2022	1:06:00 PM	505	0.1	69.8	15.9	0	
Obama Elementary School	2212	12/6/2022	1:05:00 PM	502	0.1	69.1	15.9	0	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	2216	12/6/2022	1:08:00 PM	517	0.1	69.4	16.3	0	
Obama Elementary School	2217	12/6/2022	1:11:00 PM	506	0.1	69.6	15.8	1	
Obama Elementary School	2219	12/6/2022	1:14:00 PM	508	0.1	72.9	14.5	0	
Obama Elementary School	2220	12/6/2022	1:16:00 PM	498	0.2	72.7	14.3	0	
Obama Elementary School	2221	12/6/2022	1:24:00 PM	497	0.2	72.9	14.3	0	
Obama Elementary School	2222	12/6/2022	1:25:00 PM	521	0.1	73.2	14.3	0	
Obama Elementary School	2223	12/6/2022	1:27:00 PM	524	0.1	73.2	14.4	1	
Obama Elementary School	2224	12/6/2022	1:28:00 PM	461	0.2	70.7	14.6	0	Bubbling/peeling paint, Stained ceiling tiles
Obama Elementary School	2228	12/6/2022	1:22:00 PM	610	0.1	73.6	14.6	0	
Obama Elementary School	2229	12/6/2022	1:20:00 PM	521	0.1	73.6	14.5	0	Bubbling/peeling paint
Obama Elementary School	2230	12/6/2022	1:18:00 PM	495	0.1	73.6	14.1	0	Bubbling/peeling paint
Obama Elementary School	2301	12/6/2022	11:52:00 AM	625	0.1	70.5	16	0	
Obama Elementary School	2302	12/6/2022	11:48:00 AM	610	0.1	70	16.1	0	
Obama Elementary School	2303	12/6/2022	11:25:00 AM	623	0.1	70.2	16	0	
Obama Elementary School	2305	12/6/2022	11:29:00 AM	612	0.1	69.6	16.3	0	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	2307	12/6/2022	11:31:00 AM	800	0.1	70.5	17.1	6	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	2308	12/6/2022	11:35:00 AM	638	0.1	70.3	16	0	
Obama Elementary School	2309	12/6/2022	11:37:00 AM	619	0.1	70.3	15.9	1	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	2310	12/6/2022	11:39:00 AM	628	0.1	70.2	16.3	0	Bubbling/peeling paint
Obama Elementary School	2311	12/6/2022	11:43:00 AM	618	0.1	69.8	16.1	0	
Obama Elementary School	2312	12/6/2022	11:44:00 AM	646	0.1	70.2	16.2	0	
Obama Elementary School	2313	12/6/2022	11:46:00 AM	642	0.1	70.3	16.1	2	
Obama Elementary School	3203	12/6/2022	1:49:00 PM	472	0.1	67.7	16.4	0	
Obama Elementary School	3204	12/6/2022	1:47:00 PM	465	0.1	66.2	16.7	0	
Obama Elementary School	3205	12/6/2022	1:45:00 PM	474	0.1	66	16.8	0	
Obama Elementary School	3207	12/6/2022	1:44:00 PM	475	0.1	67.5	16.3	0	
Obama Elementary School	3208	12/6/2022	1:41:00 PM	471	0.1	67.6	16.1	0	
Obama Elementary School	3209	12/6/2022	1:40:00 PM	487	1	68.4	16.2	0	
Obama Elementary School	3210	12/6/2022	1:38:00 PM	493	0.1	68.9	16.2	0	
Obama Elementary School	3213	12/6/2022	1:37:00 PM	492	0.1	68.7	16	0	
Obama Elementary School	3214	12/6/2022	1:35:00 PM	486	0.1	68.7	16.1	0	Bubbling/peeling paint
Obama Elementary School	3215	12/6/2022	1:33:00 PM	557	0.1	68.7	16.3	0	
Obama Elementary School	3216	12/6/2022	1:30:00 PM	512	0.1	70.1	15.9	0	Bubbling/peeling paint
Obama Elementary School	3301	12/6/2022	12:44:00 PM	614	0.1	71.1	16.5	0	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	3302	12/6/2022	12:41:00 PM	586	0.1	71.6	15.8	0	
Obama Elementary School	3303	12/6/2022	12:16:00 PM	613	0.1	71.1	16	0	
Obama Elementary School	3304	12/6/2022	12:17:00 PM	598	0.2	69.3	16.8	0	
Obama Elementary School	3305	12/6/2022	12:20:00 PM	601	0.1	68.4	16.9	0	
Obama Elementary School	3306	12/6/2022	12:23:00 PM	631	0.1	68.9	17.1	2	
Obama Elementary School	3307	12/6/2022	12:25:00 PM	654	0.1	70.3	17	15	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	3308	12/6/2022	12:28:00 PM	654	0.1	70.2	16.9	0	Plants: Kept Away From Return And Supply Vents
Obama Elementary School	3309	12/6/2022	12:30:00 PM	793	0.1	71.4	18	16	Fragrance odor, Bubbling/peeling paint
Obama Elementary School	3310	12/6/2022	12:39:00 PM	684	0.1	71.4	16.6	0	Musty odor
Obama Elementary School	3311	12/6/2022	12:33:00 PM	582	0.1	71.2	15.7	0	
Obama Elementary School	3312	12/6/2022	12:35:00 PM	582	0.1	70.9	15.9	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Obama Elementary School	5518	12/6/2022	1:12:00 PM	497	0.1	72.5	14.4	1	
Obama Elementary School	1103A	12/6/2022	10:21:00 AM	456	0.1	70.5	12.2	0	Stained ceiling tiles
Obama Elementary School	1201 GYMNASIUM	12/6/2022	10:24:00 AM	494	0.1	70.2	13.4	1	Bubbling/peeling paint
Obama Elementary School	1219 EAST	12/6/2022	11:07:00 AM	476	0.1	63.1	19.1	0	
Obama Elementary School	1219 WEST	12/6/2022	11:03:00 AM	473	0.1	64	18.5	0	
Obama Elementary School	1220A	12/6/2022	11:13:00 AM	490	0.1	68.2	15.6	0	
Obama Elementary School	1317 GYMNASIUM	12/6/2022	9:29:00 AM	784	0.2	71.2	15.4	0	
Obama Elementary School	AUDITORIUM	12/6/2022	11:15:00 AM	455	0.1	68.7	13.9	0	
Obama Elementary School	CAFETERIA	12/6/2022	11:22:00 AM	550	0.2	69.8	17.6	60	
Obama Elementary School	MEDIA CENTER EAST	12/6/2022	9:51:00 AM	443	0.1	67.8	13.1	1	
Obama Elementary School	MEDIA CENTER WEST	12/6/2022	9:55:00 AM	444	0.1	67.6	13.2	0	Stained ceiling tiles
Obama Elementary School	OUTDOORS	12/6/2022		401	0.6	12	78		
Open World Learning	1001	2/7/2023	10:38:00 AM	708	0.1	76.3	18.8	3	
Open World Learning	1002	2/7/2023	10:35:00 AM	659	0.1	76.1	17	0	
Open World Learning	1003	2/7/2023	10:30:00 AM	670	0.1	77.3	16.6	1	
Open World Learning	1004	2/7/2023	10:28:00 AM	709	0.1	78.4	16.1	1	
Open World Learning	1005	2/7/2023	10:33:00 AM	695	0.1	77.1	17.4	0	
Open World Learning	1007	2/7/2023	10:24:00 AM	717	0.1	79.4	15.9	1	
Open World Learning	1008	2/7/2023	10:12:00 AM	730	0.1	79.4	17.4	1	
Open World Learning	1103	2/7/2023	8:56:00 AM	741	0.1	71.6	22.2	1	
Open World Learning	1106	2/7/2023	9:23:00 AM	592	0.1	70.3	20.3	2	Bubbling/peeling paint
Open World Learning	1108	2/7/2023	9:32:00 AM	730	0.1	67.8	23.8	24	
Open World Learning	1110	2/7/2023	9:35:00 AM	568	0.1	68.7	20.6	0	
Open World Learning	1112	2/7/2023	9:38:00 AM	1238	0.1	70.9	26.5	26	
Open World Learning	1114	2/7/2023	9:41:00 AM	489	0.1	71.3	18.4	2	
Open World Learning	1116	2/7/2023	9:44:00 AM	497	0.1	69.6	19	0	
Open World Learning	1207	2/7/2023	9:58:00 AM	647	0.1	76.7	17.8	1	
Open World Learning	1208	2/7/2023	10:05:00 AM	776	0.1	79.1	17	2	Plants
Open World Learning	1212	2/7/2023	10:08:00 AM	644	0.2	77.8	16	0	
Open World Learning	1221	2/7/2023	9:56:00 AM	1247	0.1	75.3	23.9	34	
Open World Learning	1301	2/7/2023	11:17:00 AM	816	0.1	73.3	26.2	0	Stained ceiling tiles
Open World Learning	1304	2/7/2023	10:40:00 AM	0.652	0.1	75.3	17.4	0	
Open World Learning	1503	2/7/2023	11:27:00 AM	578	0.1	71.8	16.2	0	
Open World Learning	1504	2/7/2023	11:21:00 AM	470	0.1	72.7	15.6	0	
Open World Learning	1601	2/7/2023	10:59:00 AM	527	0.1	73.9	18.2	0	
Open World Learning	1602	2/7/2023	10:53:00 AM	654	0.1	79.5	15.3	0	
Open World Learning	1604	2/7/2023	11:06:00 AM	507	0.1	72.1	17.2	0	Musty odor
Open World Learning	1608	2/7/2023	11:12:00 AM	573	0.1	75.4	17.8	3	
Open World Learning	2103	2/7/2023	12:18:00 PM	720	0.1	72.3	19.3	0	
Open World Learning	2105	2/7/2023	12:15:00 PM	742	0.1	75.1	19.2	3	Stained ceiling tiles
Open World Learning	2106	2/7/2023	12:09:00 PM	689	0.3	74.6	16.6	0	
Open World Learning	2107	2/7/2023	12:20:00 PM	707	0.1	72	19	0	
Open World Learning	2108	2/7/2023	12:11:00 PM	851	0.1	73	19.2	0	
Open World Learning	2109	2/7/2023	12:25:00 PM	726	0.1	70.2	20.1	0	
Open World Learning	2110	2/7/2023	12:13:00 PM	1551	0.1	73.3	27.8	18	
Open World Learning	2111	2/7/2023	12:27:00 PM	698	0.1	70.4	20	0	
Open World Learning	2112	2/7/2023	12:23:00 PM	1438	0.1	71.8	24.6	26	Taxidermy
Open World Learning	2114	2/7/2023	12:29:00 PM	881	0.1	70.6	23.5	27	Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Open World Learning	2115	2/7/2023	12:37:00 PM	743	0.1	72.5	20.6	0	
Open World Learning	2116	2/7/2023	12:30:00 PM	873	0.1	71.1	22.8	1	
Open World Learning	2116	2/7/2023	12:32:00 PM	843	0.1	71.4	21.6	0	
Open World Learning	2118	2/7/2023	12:36:00 PM	905	0.1	71.7	22.8	12	
Open World Learning	2202	2/7/2023	12:07:00 PM	1017	0.1	78.4	21.1	18	Taxidermy
Open World Learning	2204	2/7/2023	12:04:00 PM	808	0.1	77.8	18.2	0	
Open World Learning	2205	2/7/2023	12:51:00 PM	761	0.1	75	18.9	0	
Open World Learning	2206	2/7/2023	12:03:00 PM	675	0.1	77.6	16.5	0	
Open World Learning	2207	2/7/2023	12:43:00 PM	917	0.1	77.1	20.7	7	
Open World Learning	2208	2/7/2023	12:00:00 PM	726	0.1	77.3	16.9	1	
Open World Learning	2209	2/7/2023	12:39:00 PM	991	0.1	73.7	22.4	26	
Open World Learning	2210	2/7/2023	11:52:00 AM	668	0.1	76.4	17.7	0	Stained ceiling tiles
Open World Learning	2215	2/7/2023	12:41:00 PM	1187	0.1	74	24.8	26	
Open World Learning	2300	2/7/2023	12:47:00 PM	509	0.4	73.5	16.4	0	
Open World Learning	2602	2/7/2023	11:47:00 AM	705	0.1	74.5	19.3	1	
Open World Learning	2606	2/7/2023	11:45:00 AM	617	0.1	71.9	18.8	11	
Open World Learning	2608	2/7/2023	11:42:00 AM	518	0.1	71.5	17.8	0	
Open World Learning	2609	2/7/2023	11:31:00 AM	50	0.1	69.4	18.4	0	
Open World Learning	2610	2/7/2023	11:40:00 AM	537	0.1	70.5	18.2	1	Bubbling/peeling paint, Stained ceiling tiles
Open World Learning	3201	2/7/2023	1:03:00 PM	718	0.2	75.9	17.8	0	
Open World Learning	3202	2/7/2023	12:55:00 PM	689	0.1	77.3	17.1	11	
Open World Learning	3203	2/7/2023	1:07:00 PM	566	0.1	75.2	15.9	0	
Open World Learning	3204	2/7/2023	12:58:00 PM	988	0.1	77.6	18.6	12	
Open World Learning	3205	2/7/2023	1:10:00 PM	751	0.1	74.6	19	5	
Open World Learning	3206	2/7/2023	1:00:00 PM	903	0.1	78.1	19.9	14	
Open World Learning	3209	2/7/2023	1:22:00 PM	1017	0.3	79.1	18.3	16	Aquariums (fish)
Open World Learning	3210	2/7/2023	1:05:00 PM	841	0.1	75.6	20.1	16	Stained ceiling tiles
Open World Learning	3212	2/7/2023	1:12:00 PM	674	0.1	74.9	17.3	1	
Open World Learning	3214	2/7/2023	1:14:00 PM	679	0.1	74.8	17.5	0	
Open World Learning	3215	2/7/2023	1:16:00 PM	895	0.1	74.6	21.6	16	Stained ceiling tiles
Open World Learning	1008A	2/7/2023	10:16:00 AM	687	0.1	79.4	16.2	2	
Open World Learning	1101 CAFETERIA	2/7/2023	9:49:00 AM	740	0.1	71.6	23.2	27	
Open World Learning	1104 ART	2/7/2023	9:16:00 AM	639	0.1	72.1	19.5	5	
Open World Learning	1104A	2/7/2023	9:21:00 AM	582	0.2	70.5	20.1	0	
Open World Learning	1106 KILN	2/7/2023	9:27:00 AM	66.3	0.1	68.3	22.7	0	
Open World Learning	1106 STORAGE	2/7/2023	9:29:00 AM	601	0.1	65.8	22.9	0	
Open World Learning	1207A	2/7/2023	10:03:00 AM	722	0.1	78.9	17	2	Taxidermy
Open World Learning	1304A	2/7/2023	10:45:00 AM	592	0.1	75.1	15.8	0	
Open World Learning	1305A	2/7/2023	10:47:00 AM	447	0.1	74.4	15	0	
Open World Learning	1305B	2/7/2023	10:51:00 AM	493	0.1	74.1	15.1	0	Bubbling/peeling paint
Open World Learning	1504A	2/7/2023	11:26:00 AM	453	0.1	73	15.2	0	
Open World Learning	1601A	2/7/2023	11:04:00 AM	506	0.1	73.3	16.1	0	Musty odor, Stained ceiling tiles
Open World Learning	2105A	2/7/2023	12:54:00 PM	823	0.1	76.9	18.6	0	
Open World Learning	2116A	2/7/2023	12:34:00 PM	889	0.1	71.6	21.7	0	
Open World Learning	2116B	2/7/2023	12:33:00 PM	886	0.1	71.4	22.1	0	
Open World Learning	2601 STAFF LOUNGE	2/7/2023	11:50:00 AM	553	0.1	74.9	16	0	
Open World Learning	GREENHOUSE	2/7/2023	1:21:00 PM	719	0.1	82.1	17.1	1	Plants: Kept Away From Return And Supply Vents
Open World Learning	KITCHEN	2/7/2023	9:52:00 AM	72.9	0.1	22.8	23	4	Taxidermy

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Open World Learning	KITCHEN OFFICE	2/7/2023	9:53:00 AM	834	0.1	74.6	22.5	1	
Open World Learning	OUTDOORS	2/7/2023		422	0.4	40.2	38.3		
Open World Learning	STAGE	2/7/2023	12:50:00 PM	504	0.1	73	16.7	0	Taxidermy
Parkway Montessori	1001	1/18/2023	12:58:00 PM	499	0.4	70.5	23.6	2	Stained ceiling tiles
Parkway Montessori	1004	1/18/2023	1:00:00 PM	500	0.3	69.4	24.4	0	
Parkway Montessori	1005	1/18/2023	12:56:00 PM	483	0.4	71.2	23.2	1	
Parkway Montessori	1101	1/18/2023	1:03:00 PM	423	0.3	68.1	24.6	0	Stained ceiling tiles
Parkway Montessori	1102	1/18/2023	1:08:00 PM	429	0.3	68.4	24.4	1	
Parkway Montessori	1103	1/18/2023	1:10:00 PM	417	0.3	67.6	24.4	1	
Parkway Montessori	1107	1/18/2023	1:14:00 PM	479	0.3	69.1	23.5	1	
Parkway Montessori	1109	1/18/2023	1:46:00 PM	533	0.4	67.8	26.3	19	
Parkway Montessori	1111	1/18/2023	1:50:00 PM	651	0.3	66.7	25.7	18	
Parkway Montessori	1112	1/18/2023	1:54:00 PM	634	0.4	69.5	26.4	20	
Parkway Montessori	1113	1/18/2023	1:57:00 PM	412	0.3	66.7	25.4	0	
Parkway Montessori	1114	1/18/2023	2:00:00 PM	623	0.3	68	26.2	21	
Parkway Montessori	1115	1/18/2023	1:17:00 PM	428	0.3	68.5	23.9	0	
Parkway Montessori	1116	1/18/2023	1:11:00 PM	485	0.3	68.7	24.9	1	
Parkway Montessori	1119	1/18/2023	1:07:00 PM	528	0.3	68.7	25.4	1	
Parkway Montessori	1203	1/18/2023	1:24:00 PM	433	0.4	68.4	24.4	0	
Parkway Montessori	1204	1/18/2023	1:29:00 PM	488	0.4	68.4	25.3	0	
Parkway Montessori	1206	1/18/2023	1:28:00 PM	475	0.3	68.4	25.1	0	
Parkway Montessori	1207	1/18/2023	1:26:00 PM	482	0.3	68.2	25.4	1	
Parkway Montessori	1208	1/18/2023	1:31:00 PM	461	0.3	68.4	24.9	2	Stained ceiling tiles
Parkway Montessori	1215	1/18/2023	1:35:00 PM	599	0.5	69.5	25.5	18	Stuffy odor
Parkway Montessori	1221	1/18/2023	1:41:00 PM	680	0.8	69.8	27.7	0	
Parkway Montessori	1223	1/18/2023	1:39:00 PM	702	1.1	69.3	27.5	0	
Parkway Montessori	1224	1/18/2023	1:44:00 PM	543	0.5	68.9	25.6	0	
Parkway Montessori	1301	1/18/2023	12:53:00 PM	456	0.4	71.6	26.6	2	
Parkway Montessori	1304	1/18/2023	12:50:00 PM	453	0.4	72.7	25	1	Bubbling/peeling paint
Parkway Montessori	1308	1/18/2023	12:43:00 PM	536	0.3	71.4	24.8	0	
Parkway Montessori	1309	1/18/2023	12:46:00 PM	664	0.4	73	24.2	0	Stuffy odor
Parkway Montessori	1310	1/18/2023	12:46:00 PM	531	0.4	72.3	23.7	0	
Parkway Montessori	1311	1/18/2023	12:41:00 PM	532	0.4	69.6	25.6	1	
Parkway Montessori	1312	1/18/2023	1:21:00 PM	564	0.3	69.1	24.9	35	
Parkway Montessori	1315	1/18/2023	1:19:00 PM	618	0.4	69.1	28	23	
Parkway Montessori	2101	1/18/2023	2:13:00 PM	416	0.3	67.8	24.2	0	
Parkway Montessori	2103	1/18/2023	2:20:00 PM	416	0.4	68.4	23.8	0	
Parkway Montessori	2107	1/18/2023	2:07:00 PM	472	0.3	69.1	23.8	0	
Parkway Montessori	2111	1/18/2023	2:32:00 PM	412	0.4	68.4	23.9	0	Bubbling/peeling paint
Parkway Montessori	2112	1/18/2023	2:28:00 PM	441	0.4	68.2	24.3	0	
Parkway Montessori	2113	1/18/2023	2:27:00 PM	440	0.4	68.7	24.1	0	
Parkway Montessori	2114	1/18/2023	2:24:00 PM	444	0.4	68.7	24	0	Plants: Kept Away From Return And Supply Vents
Parkway Montessori	2115	1/18/2023	2:23:00 PM	443	0.4	68.4	24.6	0	
Parkway Montessori	2116	1/18/2023	2:19:00 PM	439	0.4	68.4	24.3	0	
Parkway Montessori	2117	1/18/2023	2:17:00 PM	440	0.4	68.2	24.4	0	
Parkway Montessori	2118	1/18/2023	2:16:00 PM	448	0.4	68	24.6	0	
Parkway Montessori	2301	1/18/2023	2:41:00 PM	463	0.4	71.8	24.3	0	Bubbling/peeling paint
Parkway Montessori	2303	1/18/2023	2:39:00 PM	452	0.4	70.3	25.5	0	Bubbling/peeling paint, Moisture damage along windowsill

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Parkway Montessori	2307	1/18/2023	2:37:00 PM	408	0.4	68.7	23.3	0	Stained ceiling tiles
Parkway Montessori	2409	1/18/2023	2:34:00 PM	404	0.3	68.7	23.3	0	
Parkway Montessori	3301	1/18/2023	2:49:00 PM	442	0.4	73.4	23.5	0	Bubbling/peeling paint
Parkway Montessori	3303	1/18/2023	2:46:00 PM	456	0.4	73.2	23.8	0	Bubbling/peeling paint
Parkway Montessori	1110 FLEX	1/18/2023	1:49:00 PM	436	0.4	66.4	25.8	0	
Parkway Montessori	1222 KITCHEN	1/18/2023	12:38:00 PM	485	0.4	70	25.6	3	
Parkway Montessori	1312A	1/18/2023	12:35:00 PM	677	0.4	70.2	26	1	
Parkway Montessori	1314 STAGE	1/18/2023	3:02:00 PM	405	0.4	71.2	22	0	
Parkway Montessori	OUTDOORS	1/18/2023		379	0.4	32	80		
Phalen Lake Elementary School	111	2/17/2023	8:55:00 AM	499	1.1	69.4	9.5	0	
Phalen Lake Elementary School	1001	2/17/2023	8:41:00 AM	520	0.9	66.7	11.2	2	
Phalen Lake Elementary School	1002	2/17/2023	8:43:00 AM	509	1	67.8	11.5	1	
Phalen Lake Elementary School	1003	2/17/2023	8:44:00 AM	595	1	68.5	13.4	3	
Phalen Lake Elementary School	1004	2/17/2023	8:46:00 AM	487	1.1	69.1	10	0	
Phalen Lake Elementary School	1006	2/17/2023	8:50:00 AM	487	1.1	68.9	9.9	0	
Phalen Lake Elementary School	1007	2/17/2023	8:47:00 AM	483	1.1	69.1	9.2	0	
Phalen Lake Elementary School	1014	2/17/2023	8:52:00 AM	468	1	69.6	9.3	0	
Phalen Lake Elementary School	1104	2/17/2023	9:03:00 AM	584	1.1	68.4	12.3	1	
Phalen Lake Elementary School	1107	2/17/2023	9:04:00 AM	520	1	68.4	10.5	0	
Phalen Lake Elementary School	1108	2/17/2023	9:09:00 AM	536	1	68.7	10.1	0	
Phalen Lake Elementary School	1111	2/17/2023	9:11:00 AM	558	1	69.8	10.9	4	
Phalen Lake Elementary School	1112	2/17/2023	9:09:00 AM	554	1	69.3	10.2	1	Plants: Kept Away From Return And Supply Vents
Phalen Lake Elementary School	1203	2/17/2023	10:51:00 AM	1128	0.8	72.5	11.5	15	
Phalen Lake Elementary School	1204	2/17/2023	10:50:00 AM	842	0.8	71.8	10.5	1	
Phalen Lake Elementary School	1205	2/17/2023	10:49:00 AM	938	0.8	71.1	11.3	22	
Phalen Lake Elementary School	1206	2/17/2023	10:46:00 AM	984	0.8	70.9	11.4	25	
Phalen Lake Elementary School	1207	2/17/2023	10:43:00 AM	962	0.8	70.3	11.8	22	Live animals: Kept Away From Return And Supply Vents, Plants: Kept Away From Return And Supply Vents
Phalen Lake Elementary School	1208	2/17/2023	10:42:00 AM	734	0.8	69.8	9.9	2	
Phalen Lake Elementary School	1209	2/17/2023	10:39:00 AM	715	0.8	70.9	9.9	1	
Phalen Lake Elementary School	1210	2/17/2023	10:37:00 AM	833	0.7	70.3	11	23	
Phalen Lake Elementary School	1211	2/17/2023	10:35:00 AM	562	0.7	69.4	8.1	0	
Phalen Lake Elementary School	1213	2/17/2023	10:32:00 AM	514	0.7	70.3	8.4	0	
Phalen Lake Elementary School	1214	2/17/2023	10:24:00 AM	544	0.7	71.1	8.3	0	
Phalen Lake Elementary School	1215	2/17/2023	10:21:00 AM	623	0.8	71.1	8.8	7	
Phalen Lake Elementary School	1216	2/17/2023	10:19:00 AM	709	0.8	71.8	9.7	18	
Phalen Lake Elementary School	1217	2/17/2023	10:17:00 AM	798	0.8	71.4	9.7	17	
Phalen Lake Elementary School	1218	2/17/2023	10:13:00 AM	714	0.7	70	9.4	18	
Phalen Lake Elementary School	1219	2/17/2023	10:10:00 AM	557	0.8	69.6	8.4	3	
Phalen Lake Elementary School	1220	2/17/2023	10:08:00 AM	836	0.8	70	10.8	24	
Phalen Lake Elementary School	1221	2/17/2023	10:05:00 AM	757		70	10.5	16	
Phalen Lake Elementary School	1222	2/17/2023	10:03:00 AM	854	0.8	69.8	10.7	21	
Phalen Lake Elementary School	1223	2/17/2023	10:01:00 AM	790	0.8	70.2	10.3	24	Plants: Kept Away From Return And Supply Vents
Phalen Lake Elementary School	1301	2/17/2023	9:58:00 AM	750	0.8	70.7	15	23	
Phalen Lake Elementary School	1302	2/17/2023	9:55:00 AM	741	0.8	70.5	10.2	19	
Phalen Lake Elementary School	1303	2/17/2023	9:43:00 AM	632	0.9	70.9	9.4	20	
Phalen Lake Elementary School	1304	2/17/2023	10:00:00 AM	765	0.8	70.3	10.2	21	
Phalen Lake Elementary School	1401	2/17/2023	9:16:00 AM	473	1	69.8	8.1	5	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Phalen Lake Elementary School	1403	2/17/2023	9:21:00 AM	555	0.9	68.9	9	15	
Phalen Lake Elementary School	1403	2/17/2023	9:22:00 AM	561	0.9	68.4	8.8	15	
Phalen Lake Elementary School	1404	2/17/2023	9:28:00 AM	611	0.9	68.4	9.4	19	
Phalen Lake Elementary School	1405	2/17/2023	9:20:00 AM	570	1	68.9	9	11	
Phalen Lake Elementary School	1406	2/17/2023	9:31:00 AM	557	0.9	69.4	8.8	1	
Phalen Lake Elementary School	1407	2/17/2023	9:32:00 AM	557	0.9	68.9	8.7	4	Condensation
Phalen Lake Elementary School	1409	2/17/2023	9:30:00 AM	586		68.5	8.7	19	
Phalen Lake Elementary School	1410	2/17/2023	9:25:00 AM	583	0.9	68.9	8.9	19	
Phalen Lake Elementary School	1411	2/17/2023	9:34:00 AM	662	0.8	69.4	9.4	20	
Phalen Lake Elementary School	1412	2/17/2023	9:48:00 AM	794	0.9	71.2	10.5	7	
Phalen Lake Elementary School	1413	2/17/2023	9:45:00 AM	634	0.9	70.9	10.4	0	
Phalen Lake Elementary School	1414	2/17/2023	9:53:00 AM	618	0.8	70.7	8.2	9	
Phalen Lake Elementary School	1415	2/17/2023	9:51:00 AM	516	0.8	71.2	7.9	1	
Phalen Lake Elementary School	1416	2/17/2023	9:37:00 AM	765	0.8	69.3	9.9	24	
Phalen Lake Elementary School	1417	2/17/2023	9:40:00 AM	648	0.8	70	9.5	19	
Phalen Lake Elementary School	1418	2/17/2023	9:41:00 AM	869	0.8	71.1	12	18	
Phalen Lake Elementary School	1502	2/17/2023	10:36:00 AM	554	0.7	69.3	8.3	0	
Phalen Lake Elementary School	1504	2/17/2023	9:54:00 AM	612	0.8	70.7	9	1	
Phalen Lake Elementary School	1505	2/17/2023	9:18:00 AM	457	1	69	7.5	0	
Phalen Lake Elementary School	2001	2/17/2023	10:52:00 AM	683	0.8	69.4	11.2	0	
Phalen Lake Elementary School	2002	2/17/2023	10:57:00 AM	951	0.8	69.3	12.4	23	
Phalen Lake Elementary School	2003	2/17/2023	11:01:00 AM	801	0.7	69.6	11.9	19	Plants
Phalen Lake Elementary School	2004	2/17/2023	10:59:00 AM	852	0.7	69.4	12.5	24	
Phalen Lake Elementary School	2005	2/17/2023	11:03:00 AM	789	0.7	70	11.8	1	Plants: Kept Away From Return And Supply Vents
Phalen Lake Elementary School	2005	2/17/2023	11:06:00 AM	818	0.7	69.6	12.8	1	
Phalen Lake Elementary School	2006	2/17/2023	11:02:00 AM	794	0.7	70	11.8	0	
Phalen Lake Elementary School	2007	2/17/2023	11:08:00 AM	864	0.7	70.5	13.2	20	
Phalen Lake Elementary School	2009	2/17/2023	11:04:00 AM	731	0.8	68.9	12.2	0	Plants: Kept Away From Return And Supply Vents
Phalen Lake Elementary School	1006A	2/17/2023	8:48:00 AM	493	1.1	69.1	10.9	0	
Phalen Lake Elementary School	1218A	2/17/2023	10:14:00 AM	745	0.8	70.9	9.7	0	
Phalen Lake Elementary School	1219A	2/17/2023	10:10:00 AM	635	0.8	70.3	9.2	0	
Phalen Lake Elementary School	1403A	2/17/2023	9:24:00 AM	564	0.9	68.4	9	0	
Phalen Lake Elementary School	1404A	2/17/2023	9:29:00 AM	616	0.9	68.2	9	0	
Phalen Lake Elementary School	1411A	2/17/2023	9:36:00 AM	621	0.8	69.4	9.2	0	
Phalen Lake Elementary School	1412A	2/17/2023	9:50:00 AM	511	0.9	72.1	10.3	0	
Phalen Lake Elementary School	CAFETERIA	2/17/2023	9:13:00 AM	663	1	70	10.7	80	
Phalen Lake Elementary School	GYMNASIUM	2/17/2023	9:00:00 AM	596	1	68.4	10.9	19	
Phalen Lake Elementary School	OUTDOORS	2/17/2023		418	1	11	75		
Randolph Heights Elementary School	1014	1/17/2023	12:30:00 PM	722	0.7	71.8	28.1	1	
Randolph Heights Elementary School	1204	1/17/2023	12:50:00 PM	935	0.8	71.6	32	22	Stained ceiling tiles
Randolph Heights Elementary School	1403	1/17/2023	12:42:00 PM	848	0.8	72.1	28.6	18	Bubbling/peeling paint
Randolph Heights Elementary School	1407	1/17/2023	12:39:00 PM	702	0.7	72	27.5	17	Bubbling/peeling paint
Randolph Heights Elementary School	1409	1/17/2023	12:36:00 PM	815	0.7	69.8	30.4	22	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	1411	1/17/2023	12:34:00 PM	810	0.7	70.3	30.8	23	Bubbling/peeling paint
Randolph Heights Elementary School	1415	1/17/2023	12:31:00 PM	801	0.7	71.6	28.7	26	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2001	1/17/2023	1:22:00 PM	688	0.6	70	29	27	Bubbling/peeling paint, Stained ceiling tiles, Plants
Randolph Heights Elementary School	2002	1/17/2023	1:56:00 PM	669	0.6	70.7	28.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Randolph Heights Elementary School	2003	1/17/2023	2:13:00 PM	685	0.6	70.7	28.4	0	Bubbling/peeling paint
Randolph Heights Elementary School	2004	1/17/2023	1:18:00 PM	677	0.6	70.7	29	2	Bubbling/peeling paint
Randolph Heights Elementary School	2005	1/17/2023	1:16:00 PM	739	0.7	70	30.3	0	
Randolph Heights Elementary School	2202	1/17/2023	1:13:00 PM	706	0.6	70.3	30.1	1	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2204	1/17/2023	1:09:00 PM	777	0.7	71.6	29.8	34	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2205	1/17/2023	2:00:00 PM	895	0.6	71.1	30.7	4	
Randolph Heights Elementary School	2206	1/17/2023	1:03:00 PM	938	0.7	69.4	33.2	19	
Randolph Heights Elementary School	2207	1/17/2023	1:06:00 PM	675	0.7	71.2	29	0	
Randolph Heights Elementary School	2208	1/17/2023	1:02:00 PM	842	0.7	68.5	32.8	1	
Randolph Heights Elementary School	2210	1/17/2023	12:59:00 PM	1076	0.8	68.7	35.4	20	
Randolph Heights Elementary School	2211	1/17/2023	12:56:00 PM	964	0.8	69.1	34.5	22	Bubbling/peeling paint
Randolph Heights Elementary School	2212	1/17/2023	12:54:00 PM	870	0.8	69.6	29.7	1	Bubbling/peeling paint, Moisture damage at ceiling around hatch
Randolph Heights Elementary School	2230	1/17/2023	1:07:00 PM	721	0.7	72.3	27.9	2	
Randolph Heights Elementary School	2312	1/17/2023	1:26:00 PM	1151	0.6	71.6	32.7	21	
Randolph Heights Elementary School	2313	1/17/2023	1:29:00 PM	1150	0.7	72.9	31.5	21	
Randolph Heights Elementary School	2315	1/17/2023	1:32:00 PM	1041	0.7	75.2	29.4	25	
Randolph Heights Elementary School	2401	1/17/2023	1:51:00 PM	856	0.5	72.1	27.9	0	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2402	1/17/2023	1:35:00 PM	1350	0.7	72.9	33.6	23	
Randolph Heights Elementary School	2405	1/17/2023	1:38:00 PM	1052	0.6	73.6	29.3	21	Stained ceiling tiles, Taxidermy
Randolph Heights Elementary School	2407	1/17/2023	1:40:00 PM	1055	0.6	73.2	29.3	20	
Randolph Heights Elementary School	2409	1/17/2023	1:41:00 PM	660	0.6	71.4	27.1	5	
Randolph Heights Elementary School	2410	1/17/2023	1:47:00 PM	592	0.6	71.2	26.8	1	
Randolph Heights Elementary School	2411	1/17/2023	1:43:00 PM	599	0.5	73	25.6	0	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2415	1/17/2023	1:45:00 PM	655	0.5	74.5	25.2	3	
Randolph Heights Elementary School	2003 A PRINCIPALS OFFICE	1/17/2023	2:18:00 PM	651	0.6	69.4	29.4	0	
Randolph Heights Elementary School	2004A	1/17/2023	1:21:00 PM	657	0.6	70.7	29.2	0	
Randolph Heights Elementary School	2004B	1/17/2023	1:58:00 PM	779	0.6	70.9	30.7	1	
Randolph Heights Elementary School	2100 CAFETERIA	1/17/2023	1:12:00 PM	690	0.6	70.7	29.2	55	
Randolph Heights Elementary School	2221 KITCHEN	1/17/2023	1:53:00 PM	713	0.6	71.8	28.8	0	
Randolph Heights Elementary School	GYMNASIUM	1/17/2023	12:46:00 PM	895	0.9	70.9	32.2	24	Bubbling/peeling paint
Randolph Heights Elementary School	GYMNASIUM OFFICE	1/17/2023	12:47:00 PM	861	0.8	70.9	32	0	
Randolph Heights Elementary School	OUTDOORS	1/17/2023		415	0.9	34	85		
RiverEast School	1102	2/6/2023	8:44:00 AM	464	0.1	72	11.1	0	
RiverEast School	1103	2/6/2023	8:58:00 AM	455	0.1	72.9	10.5	0	
RiverEast School	1105	2/6/2023	9:00:00 AM	461	0.1	72.7	10.6	0	Condensation
RiverEast School	1106	2/6/2023	9:01:00 AM	451	0.1	72.6	10.4	0	
RiverEast School	1107	2/6/2023	9:03:00 AM	481	0.1	73	10.8	1	
RiverEast School	1108	2/6/2023	11:20:00 AM	495	0.1	72.7	12.5	0	
RiverEast School	1109	2/6/2023	11:22:00 AM	516	0.1	72.4	11.8	0	
RiverEast School	1110	2/6/2023	9:09:00 AM	484	0.1	74	10.5	0	
RiverEast School	1112	2/6/2023	9:07:00 AM	485	0.2	73.9	10.1	0	
RiverEast School	1120	2/6/2023	9:14:00 AM	583	0.2	75.6	10.2	1	
RiverEast School	1121	2/6/2023	9:15:00 AM	475	0.2	73.8	9.7	0	
RiverEast School	1125	2/6/2023	11:13:00 AM	517	0.1	72.2	12.5	0	
RiverEast School	1126	2/6/2023	11:14:00 AM	482	0.1	72.5	12.2	0	
RiverEast School	1127	2/6/2023	11:17:00 AM	457	0.1	72.3	11.7	0	
RiverEast School	1133	2/6/2023	11:11:00 AM	476	0.1	72	12.1	1	
RiverEast School	1142	2/6/2023	11:10:00 AM	625	0.1	72.8	14.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
RiverEast School	1145	2/6/2023	11:06:00 AM	727	0.1	71.1	15.5	7	
RiverEast School	1146	2/6/2023	11:04:00 AM	499	0.1	70.2	12	1	
RiverEast School	1147	2/6/2023	11:02:00 AM	499	0.1	70.3	12.2	1	
RiverEast School	1148	2/6/2023	11:00:00 AM	536	0.1	69.8	13.7	1	
RiverEast School	1303	2/6/2023	9:55:00 AM	524	0.1	71.4	11.6	0	Fragrance odor
RiverEast School	1304	2/6/2023	9:57:00 AM	469	0.1	10.7	10.6	0	
RiverEast School	1305	2/6/2023	9:59:00 AM	604	0.1	70.5	11.9	0	Stuffy odor
RiverEast School	1306	2/6/2023	10:53:00 AM	488	0.1	72	11.9	1	
RiverEast School	1307	2/6/2023	10:52:00 AM	483	0.1	72	12.5	1	
RiverEast School	1308	2/6/2023	10:50:00 AM	480	0.1	72	12.2	1	
RiverEast School	1309	2/6/2023	10:48:00 AM	756	0.1	71.7	15.8	6	
RiverEast School	1401	2/6/2023	10:30:00 AM	553	0.1	72.3	12.9	5	
RiverEast School	1402	2/6/2023	10:35:00 AM	488	0.1	73.5	11.5	4	
RiverEast School	1403	2/6/2023	10:39:00 AM	480	0.1	73.1	11.7	1	Plants: Kept Away From Return And Supply Vents
RiverEast School	1404	2/6/2023	10:47:00 AM	463	0.1	71.5	11	0	
RiverEast School	1405	2/6/2023	10:46:00 AM	529	0.1	71.9	11.6	0	
RiverEast School	1406	2/6/2023	10:43:00 AM	572	0.1	72.2	12.5	0	
RiverEast School	1407	2/6/2023	10:41:00 AM	525	0.1	72.4	11.7	0	
RiverEast School	1411	2/6/2023	10:29:00 AM	735	0.1	71.7	13.1	0	
RiverEast School	1412	2/6/2023	10:28:00 AM	485	0.1	81.8	11.8	0	Stuffy odor
RiverEast School	1413	2/6/2023	10:27:00 AM	438	0.1	72.2	10.7	0	
RiverEast School	1415	2/6/2023	10:24:00 AM	628	0.1	72.4	12.3	0	Taxidermy
RiverEast School	1501	2/6/2023	10:14:00 AM	495	0.1	72.4	11.8	2	
RiverEast School	1502	2/6/2023	10:12:00 AM	483	0.1	71.8	11.3	1	
RiverEast School	1503	2/6/2023	10:06:00 AM	629	0.1	71.3	13.3	6	
RiverEast School	1504	2/6/2023	10:01:00 AM	493	0.1	70.3	10.5	0	
RiverEast School	1505	2/6/2023	10:02:00 AM	465	0.1	70.5	11.6	0	
RiverEast School	1507	2/6/2023	10:04:00 AM	479	0.1	70.6	12	0	
RiverEast School	1510	2/6/2023	10:05:00 AM	475	0.1	70.9	11.9	0	
RiverEast School	1511	2/6/2023	10:18:00 AM	652	0.1	72.7	12.4	0	
RiverEast School	1512	2/6/2023	10:20:00 AM	525	0.1	72.1	11.8	0	
RiverEast School	1513	2/6/2023	10:21:00 AM	478	0.1	71.8	11.2	0	
RiverEast School	1515	2/6/2023	10:23:00 AM	491	0.1	72	10.8	0	
RiverEast School	1601	2/6/2023	9:44:00 AM	574	0.1	71.5	12.1	3	
RiverEast School	1602	2/6/2023	9:46:00 AM	506	0.1	72.6	11.4	1	
RiverEast School	1603	2/6/2023	9:52:00 AM	532	0.1	71.6	11.8	0	Fragrance odor
RiverEast School	1606	2/6/2023	9:54:00 AM	466	0.1	71.1	12.7	0	
RiverEast School	1607	2/6/2023	9:49:00 AM	456	0.1	71.9	11.2	0	
RiverEast School	1608	2/6/2023	9:51:00 AM	722	0.1	71.7	42.8	0	
RiverEast School	1611	2/6/2023	9:39:00 AM	453	0.1	71.3	10.8	0	
RiverEast School	1612	2/6/2023	9:36:00 AM	498	0.1	71.6	10.9	0	
RiverEast School	1701	2/6/2023	9:22:00 AM	578	0.1	72	12.3	4	
RiverEast School	1702	2/6/2023	9:27:00 AM	731	0.1	71.6	0.1	6	
RiverEast School	1703	2/6/2023	9:30:00 AM	521	0.1	71.4	11.3	0	
RiverEast School	1705	2/6/2023	9:20:00 AM	552	0.1	71.6	11.5	0	Stuffy odor, Bubbling/peeling paint
RiverEast School	1706	2/6/2023	11:18:00 AM	669	0.1	72.7	13.6	0	
RiverEast School	1707	2/6/2023	9:34:00 AM	548	0.1	71.2	11.9	0	
RiverEast School	1708	2/6/2023	9:35:00 AM	537	0.1	71.3	12.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
RiverEast School	1710	2/6/2023	9:18:00 AM	462	0.1	71.8	0.2	0	
RiverEast School	1711	2/6/2023	9:17:00 AM	450	0.2	72.4	10.3	0	
RiverEast School	1713	2/6/2023	9:32:00 AM	475	0.1	71.1	11.6	0	
RiverEast School	1104A	2/6/2023	9:04:00 AM	492	0.1	73.5	11	4	
RiverEast School	1104B	2/6/2023	9:06:00 AM	495	0.1	74.6	10.8	3	
RiverEast School	1120A	2/6/2023	9:12:00 AM	510	0.1	75.7	9.9	1	Fragrance odor
RiverEast School	1401A	2/6/2023	10:32:00 AM	523	0.1	72.7	12.7	0	
RiverEast School	1402A	2/6/2023	10:37:00 AM	459	0.1	73.1	11.5	1	
RiverEast School	1402B	2/6/2023	10:33:00 AM	482	0.1	73.7	12.6	1	Fragrance odor
RiverEast School	1402B	2/6/2023	10:38:00 AM	498	0.1	73.1	11.1	1	
RiverEast School	1403A	2/6/2023	10:40:00 AM	466	0.1	83	12.1	0	
RiverEast School	1501A	2/6/2023	10:16:00 AM	508	0.1	72.2	12.3	0	
RiverEast School	1501B	2/6/2023	10:17:00 AM	484	0.1	72.9	11.7	0	
RiverEast School	1502A	2/6/2023	10:13:00 AM	507	0.1	72.3	11.9	0	
RiverEast School	1503A	2/6/2023	10:08:00 AM	617	0.1	71.8	12.4	0	
RiverEast School	1503B	2/6/2023	10:09:00 AM	452	0.1	71.6	11	1	
RiverEast School	1601A	2/6/2023	9:41:00 AM	606	0.1	70.6	12.4	0	
RiverEast School	1601B	2/6/2023	9:45:00 AM	898	0.1	71.9	14.1	3	
RiverEast School	1602A	2/6/2023	9:48:00 AM	476	0.1	72.9	11.1	0	
RiverEast School	1701A	2/6/2023	9:24:00 AM	526	0.1	72.1	11.6	0	
RiverEast School	1701B	2/6/2023	9:25:00 AM	460	0.1	71.7	11.2	1	
RiverEast School	1702A	2/6/2023	9:29:00 AM	623	0.1	71.6	0.1	2	
RiverEast School	GYMNASIUM	2/6/2023	10:55:00 AM	558	0.2	69.4	11.7	4	
RiverEast School	KITCHEN	2/6/2023	11:09:00 AM	506	0.1	72.2	13.7	3	
RiverEast School	OUTDOORS	2/6/2023		800	0.5	21.6	16.7		
Riverview West Side School of Excellence	1201	12/8/2022	10:19:00 AM	430	0.3	69.6	16.2	4	
Riverview West Side School of Excellence	1202	12/8/2022	10:21:00 AM	735	0.4	70	19.3	21	
Riverview West Side School of Excellence	1204	12/8/2022	10:22:00 AM	530	0.4	69.8	17.2	16	
Riverview West Side School of Excellence	1206	12/8/2022	10:23:00 AM	687	0.5	69.4	19.2	16	
Riverview West Side School of Excellence	1207	12/8/2022	10:25:00 AM	623	0.4	68.7	17.7	17	
Riverview West Side School of Excellence	1301	12/8/2022	10:27:00 AM	409	0.4	68.2	16.5	0	
Riverview West Side School of Excellence	1302	12/8/2022		428	0.3	68.7	17.4	0	
Riverview West Side School of Excellence	1303	12/8/2022	10:43:00 AM	450	0.3	68.9	17	0	
Riverview West Side School of Excellence	1304	12/8/2022	10:28:00 AM	690	0.4	68.9	19.3	25	
Riverview West Side School of Excellence	1306	12/8/2022	10:37:00 AM	415	0.3	68.7	16.4	0	
Riverview West Side School of Excellence	1307	12/8/2022	10:41:00 AM	415	0.4	68.7	18	0	
Riverview West Side School of Excellence	1308	12/8/2022	10:39:00 AM	611	0.3	69.1	18.7	27	
Riverview West Side School of Excellence	1320	12/8/2022	10:47:00 AM	454	0.3	68.5	17.3	1	
Riverview West Side School of Excellence	2105	12/8/2022	11:08:00 AM	442	0.3	68	17.5	0	
Riverview West Side School of Excellence	2119	12/8/2022	11:04:00 AM	445	0.3	68.7	17.1	0	
Riverview West Side School of Excellence	2120	12/8/2022	11:00:00 AM	436	0.3	67.5	17.5	0	
Riverview West Side School of Excellence	2201	12/8/2022	11:10:00 AM	428	0.3	68	17.3	0	
Riverview West Side School of Excellence	2202	12/8/2022	11:12:00 AM	545	0.3	68	18.4	16	Fragrance odor
Riverview West Side School of Excellence	2204	12/8/2022	11:17:00 AM	833	0.3	69.1	21.1	25	Fragrance odor
Riverview West Side School of Excellence	2205	12/8/2022	11:23:00 AM	436	0.3	68.9	17	0	
Riverview West Side School of Excellence	2206	12/8/2022	11:19:00 AM	449	0.3	69.4	17.1	1	
Riverview West Side School of Excellence	2207	12/8/2022	11:21:00 AM	450	0.3	69.3	17.6	1	Fragrance odor
Riverview West Side School of Excellence	2208	12/8/2022	11:20:00 AM	431	0.3	69.3	17.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Riverview West Side School of Excellence	2301	12/8/2022	10:49:00 AM	483	0.3	69.1	17.3	6	
Riverview West Side School of Excellence	2302	12/8/2022	10:51:00 AM	507	0.3	69.1	17.7	0	
Riverview West Side School of Excellence	2304	12/8/2022	10:52:00 AM	471	0.3	67.8	17.3	1	
Riverview West Side School of Excellence	2305	12/8/2022	10:59:00 AM	431	0.2	67.6	17.3	0	
Riverview West Side School of Excellence	2306	12/8/2022	10:55:00 AM	530	0.3	68.4	17.9	2	
Riverview West Side School of Excellence	2307	12/8/2022	10:58:00 AM	427	0.3	67.8	17.2	0	
Riverview West Side School of Excellence	2308	12/8/2022	10:56:00 AM	428	0.3	68.2	16.9	0	Plants
Riverview West Side School of Excellence	3105	12/8/2022	11:51:00 AM	529	0.3	69.3	18.5	0	
Riverview West Side School of Excellence	3109	12/8/2022	11:48:00 AM	574	0.3	68.2	20.3	20	Plants
Riverview West Side School of Excellence	3111	12/8/2022	11:43:00 AM	505	0.2	69.1	18.1	18	
Riverview West Side School of Excellence	3119	12/8/2022	11:40:00 AM	567	0.2	69.4	18.9	0	
Riverview West Side School of Excellence	3120	12/8/2022	11:27:00 AM	438	0.3	68.7	17.2	0	
Riverview West Side School of Excellence	3201	12/8/2022	11:52:00 AM	433	0.3	68.4	17.5	0	
Riverview West Side School of Excellence	3202	12/8/2022	11:55:00 AM	438	0.3	67.5	18	1	
Riverview West Side School of Excellence	3204	12/8/2022	11:56:00 AM	441	0.2	67.5	18.5	0	
Riverview West Side School of Excellence	3205	12/8/2022	12:03:00 PM	430	0.2	67.8	17.9	0	
Riverview West Side School of Excellence	3206	12/8/2022	11:58:00 AM	429	0.2	68	18.4	0	Plants
Riverview West Side School of Excellence	3207	12/8/2022	12:02:00 PM	426	0.3	67.5	18.2	0	
Riverview West Side School of Excellence	3208	12/8/2022	11:59:00 AM	429	0.3	67.1	18	0	
Riverview West Side School of Excellence	3301	12/8/2022	11:38:00 AM	460	0.3	68.7	17.9	0	Plants
Riverview West Side School of Excellence	3302	12/8/2022	11:36:00 AM	432	0.3	68.5	17.3	0	
Riverview West Side School of Excellence	3304	12/8/2022	11:34:00 AM	584	0.3	68.5	19.5	14	
Riverview West Side School of Excellence	3305	12/8/2022	11:28:00 AM	460	0.3	68.5	17.6	1	
Riverview West Side School of Excellence	3306	12/8/2022	11:32:00 AM	564	0.3	68.4	19.2	18	
Riverview West Side School of Excellence	3307	12/8/2022	11:30:00 AM	451	0.3	68.5	17.6	2	
Riverview West Side School of Excellence	3308	12/8/2022	11:31:00 AM	440	0.3	68.5	17.3	1	
Riverview West Side School of Excellence	1000 MAIN OFFICE	12/8/2022	10:05:00 AM	468	0.2	62.8	20.9	3	
Riverview West Side School of Excellence	1001 NURSE	12/8/2022	10:06:00 AM	430	0.2	65.8	79.1	1	
Riverview West Side School of Excellence	1002 OFFICE	12/8/2022	10:07:00 AM	394	0.2	67.5	17.1	0	Stuffy odor
Riverview West Side School of Excellence	1003 CONFERENCE ROOM	12/8/2022	10:08:00 AM	392	0.3	68.4	16.6	0	Stained ceiling tiles
Riverview West Side School of Excellence	1004 OFFICE	12/8/2022	10:10:00 AM	430	0.3	70.2	16.4	1	Plants
Riverview West Side School of Excellence	1005 WORKROOM	12/8/2022	10:11:00 AM	407	0.4	70.7	15.9	0	
Riverview West Side School of Excellence	1101 FOOD STORAGE	12/8/2022	10:16:00 AM	490	0.5	68.9	17.3	2	
Riverview West Side School of Excellence	1108 KITCHEN	12/8/2022	10:15:00 AM	440	0.6	70.3	16.1	0	
Riverview West Side School of Excellence	1110 CAFETERIA	12/8/2022	10:13:00 AM	421	0.5	69.8	15.7	1	
Riverview West Side School of Excellence	1205 NUTRITIONAL SERVICE	12/8/2022	10:18:00 AM	420	0.4	68.4	16.5	0	
Riverview West Side School of Excellence	1305 CUSTODIAL OFFICE	12/8/2022	10:42:00 AM	435	0.3	68.9	16.9	0	
Riverview West Side School of Excellence	2106 WORKROOM	12/8/2022	11:07:00 AM	439	0.3	68.7	16.9	0	
Riverview West Side School of Excellence	2111 MEDIA CENTER	12/8/2022	11:05:00 AM	472	0.3	69.4	17.3	1	
Riverview West Side School of Excellence	3114 GYMNASIUM	12/8/2022	11:44:00 AM	658	0.4	69.1	20.6	16	
Riverview West Side School of Excellence	3114A OFFICE	12/8/2022	11:47:00 AM	607	0.4	68.4	20.3	0	Musty odor
Riverview West Side School of Excellence	OUTDOORS	12/8/2022		280	1.1	27	21		
Rondo Education Center	1101	12/13/2022	9:25:00 AM	513	0.3	73.6	24.1	15	
Rondo Education Center	1102	12/13/2022	9:27:00 AM	699	0.3	73	26	18	Musty odor
Rondo Education Center	1103	12/13/2022	9:30:00 AM	513	0.3	73	24.4	9	Stained ceiling tiles
Rondo Education Center	1104	12/13/2022	9:32:00 AM	560	0.2	73.2	24.9	8	
Rondo Education Center	1105	12/13/2022	9:45:00 AM	689	0.2	71.2	27.2	15	
Rondo Education Center	1106	12/13/2022	9:43:00 AM	620	0.2	71.4	26.5	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	1107	12/13/2022	9:42:00 AM	550	0.2	71.2	25.8	14	
Rondo Education Center	1108	12/13/2022	9:39:00 AM	600	0.2	71.1	26.1	15	
Rondo Education Center	1112	12/13/2022	10:19:00 AM	404	0.2	70	25.9	6	
Rondo Education Center	1113	12/13/2022	10:21:00 AM	442	0.2	70	26.7	3	
Rondo Education Center	1115	12/13/2022	9:33:00 AM	370	0.2	72.1	24	1	
Rondo Education Center	1116	12/13/2022	9:36:00 AM	393	0.2	72.3	23.9	1	
Rondo Education Center	1117	12/13/2022	9:37:00 AM	326	0.2	71.8	23.6	0	
Rondo Education Center	1119	12/13/2022	9:48:00 AM	444	0.2	71.2	25.2	1	
Rondo Education Center	1201	12/13/2022	9:20:00 AM	366	0.2	72.7	23.5	1	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1202	12/13/2022	9:19:00 AM	400	0.3	72.9	23.9	0	Stained ceiling tiles
Rondo Education Center	1203	12/13/2022	9:03:00 AM	467	0.3	72.7	24.6	19	
Rondo Education Center	1204	12/13/2022	1:57:00 PM	474	0.2	72.3	25.5	0	
Rondo Education Center	1205	12/13/2022	2:00:00 PM	478	0.2	72	25.8	0	
Rondo Education Center	1206	12/13/2022	2:02:00 PM	611	0.2	71.8	26.6	6	
Rondo Education Center	1207	12/13/2022	1:55:00 PM	475	0.2	71.2	26.2	0	
Rondo Education Center	1208	12/13/2022	1:43:00 PM	472	0.3	71.2	26	0	
Rondo Education Center	1209	12/13/2022	2:10:00 PM	479	0.2	71.6	25.9	0	
Rondo Education Center	1210	12/13/2022	2:08:00 PM	481	0.2	71.6	26.3	0	
Rondo Education Center	1211	12/13/2022	2:04:00 PM	477	0.2	71.6	26.1	0	
Rondo Education Center	1212	12/13/2022	2:06:00 PM	487	0.3	71.6	26.1	0	
Rondo Education Center	1213	12/13/2022	1:35:00 PM	470	0.2	71.6	25.9	0	
Rondo Education Center	1214	12/13/2022	1:39:00 PM	475	0.2	71.4	26.8	0	
Rondo Education Center	1217	12/13/2022	1:42:00 PM	470	0.2	71.4	26.2	1	
Rondo Education Center	1224	12/13/2022	12:41:00 PM	469	0.2	73.2	24.7	0	
Rondo Education Center	1226	12/13/2022	12:48:00 PM	476	0.2	73.4	25	0	
Rondo Education Center	1227	12/13/2022	9:28:00 AM	381	0.2	73.8	23.4	0	
Rondo Education Center	1228	12/13/2022	9:21:00 AM	375	0.2	73.2	23.5	0	
Rondo Education Center	1229	12/13/2022	8:51:00 AM	364	0.4	74.7	22.8	1	Stained ceiling tiles
Rondo Education Center	1230	12/13/2022	9:01:00 AM	378	0.3	75.7	21.9	0	Stained ceiling tiles
Rondo Education Center	1231	12/13/2022	8:59:00 AM	376	0.3	75	22.8	1	
Rondo Education Center	1232	12/13/2022	8:57:00 AM	384	0.3	74.8	22.6	1	
Rondo Education Center	1233	12/13/2022	8:55:00 AM	324	0.3	74.5	22.2	0	Stained ceiling tiles
Rondo Education Center	1234	12/13/2022	8:41:00 AM	304	0.2	72.5	24.1	2	
Rondo Education Center	1242	12/13/2022	10:29:00 AM	452	0.2	72.3	25.1	2	
Rondo Education Center	1243	12/13/2022	10:44:00 AM	450	0.2	72.3	25.3	2	
Rondo Education Center	1246	12/13/2022	10:24:00 AM	369	0.2	70	25.5	0	Fragrance odor
Rondo Education Center	1301	12/13/2022	11:05:00 AM	453	0.2	72.5	24.3	1	
Rondo Education Center	1302	12/13/2022	11:07:00 AM	452	0.2	72	24.5	0	
Rondo Education Center	1303	12/13/2022	11:06:00 AM	477	0.2	72.3	24.6	1	
Rondo Education Center	1304	12/13/2022	11:03:00 AM	445	0.2	72.1	24.5	0	
Rondo Education Center	1305	12/13/2022	11:02:00 AM	434	0.2	72.3	24.3	0	
Rondo Education Center	1306	12/13/2022	10:58:00 AM	463	0.3	73.4	23.8	0	
Rondo Education Center	1307	12/13/2022	11:01:00 AM	439	0.3	72.7	24	0	
Rondo Education Center	1308	12/13/2022	11:08:00 AM	445	0.2	71.2	24.8	0	
Rondo Education Center	1313	12/13/2022	10:55:00 AM	450	0.3	73	24.1	0	
Rondo Education Center	1314	12/13/2022	10:57:00 AM	448	0.3	73.2	23.7	0	
Rondo Education Center	1316	12/13/2022	10:56:00 AM	524	0.3	73.2	24.3	0	
Rondo Education Center	1317	12/13/2022	10:53:00 AM	499	0.2	72.9	24.9	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	1318	12/13/2022	10:52:00 AM	442	0.2	72.5	24.5	0	
Rondo Education Center	1319	12/13/2022	10:47:00 AM	444	0.2	72.3	24.7	3	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1320	12/13/2022	10:49:00 AM	449	0.3	72.1	24.6	0	Stained ceiling tiles
Rondo Education Center	1322	12/13/2022	10:50:00 AM	450	0.3	71.8	24.9	2	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1323	12/13/2022	11:09:00 AM	478	0.2	70.9	25.6	2	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1324	12/13/2022	11:11:00 AM	457	0.2	70.7	25.5	0	
Rondo Education Center	1326	12/13/2022	11:12:00 AM	436	0.2	71.1	25.8	1	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1327	12/13/2022	11:13:00 AM	451	0.2	71.4	25.1	0	
Rondo Education Center	1328	12/13/2022	11:14:00 AM	525	0.2	71.4	25.8	1	
Rondo Education Center	1329	12/13/2022	11:16:00 AM	462	0.2	71.6	24.9	0	
Rondo Education Center	1331	12/13/2022	11:23:00 AM	455	0.2	71.4	25.2	0	
Rondo Education Center	1332	12/13/2022	11:24:00 AM	471	0.2	71.6	25.2	2	
Rondo Education Center	1334	12/13/2022	11:25:00 AM	524	0.2	71.4	26	6	
Rondo Education Center	1335	12/13/2022	11:27:00 AM	445	0.2	71.8	25	4	
Rondo Education Center	1336	12/13/2022	11:27:00 AM	479	0.2	71.6	25.7	0	
Rondo Education Center	1337	12/13/2022	11:29:00 AM	486	0.2	70.9	26.5	4	
Rondo Education Center	1339	12/13/2022	11:30:00 AM	457	0.2	70.5	26	1	
Rondo Education Center	1340	12/13/2022	11:33:00 AM	455	0.2	71.2	25.3	1	
Rondo Education Center	1341	12/13/2022	11:34:00 AM	447	0.2	71.1	25.3	1	
Rondo Education Center	1343	12/13/2022	11:35:00 AM	449	0.2	70.5	25.6	1	
Rondo Education Center	1344	12/13/2022	11:18:00 AM	450	0.2	71.6	25	0	
Rondo Education Center	1402	12/13/2022	11:47:00 AM	345	0.2	67.1	27.5	15	
Rondo Education Center	1406	12/13/2022	11:46:00 AM	369	0.2	68.2	26.9	0	
Rondo Education Center	1410	12/13/2022	11:49:00 AM	377	0.2	67.8	26.9	20	
Rondo Education Center	1412	12/13/2022	11:52:00 AM	535	0.2	68.7	27.4	0	
Rondo Education Center	1413	12/13/2022	12:06:00 PM	560	0.2	70.7	26.7	0	Stained ceiling tiles
Rondo Education Center	1414	12/13/2022	12:50:00 PM	390	0.2	70.7	24.8	0	
Rondo Education Center	1501	12/13/2022	11:36:00 AM	496	0.2	70.9	25.9	4	
Rondo Education Center	1502	12/13/2022	11:39:00 AM	499	0.2	71.2	25.6	0	Fragrance odor
Rondo Education Center	1503	12/13/2022	11:40:00 AM	591	0.2	72	28.1	1	
Rondo Education Center	1504	12/13/2022	11:42:00 AM	498	0.2	72.1	25.2	0	
Rondo Education Center	1506	12/13/2022	1:21:00 PM	505	0.2	71.8	26.4	23	
Rondo Education Center	1507	12/13/2022	12:12:00 PM	435	0.4	71.1	25.5	7	
Rondo Education Center	1508	12/13/2022	12:37:00 PM	412	0.2	71.8	24.9	2	
Rondo Education Center	1511	12/13/2022	12:39:00 PM	415	0.2	70.7	25.7	10	
Rondo Education Center	1512	12/13/2022	12:55:00 PM	437	0.3	71.2	25.7	22	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1513	12/13/2022	1:19:00 PM	494	0.2	70.7	27.2	21	
Rondo Education Center	1514	12/13/2022	1:24:00 PM	415	0.2	70.2	25.9	13	
Rondo Education Center	1515	12/13/2022	12:04:00 PM	828	0.3	71.2	28.7	25	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1516	12/13/2022	12:03:00 PM	822	0.3	71.8	28.3	20	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1517	12/13/2022	12:02:00 PM	725	0.2	72.1	28	8	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1518	12/13/2022	11:59:00 AM	788	0.2	71.2	29	20	
Rondo Education Center	1523	12/13/2022	11:58:00 AM	777	0.2	69.8	30.2	17	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1524	12/13/2022	11:56:00 AM	796	0.3	70	29.5	18	Aquariums (fish)
Rondo Education Center	1525	12/13/2022	11:55:00 AM	1022	0.2	70	31.7	25	
Rondo Education Center	1526	12/13/2022	11:53:00 AM	733	0.2	69.4	28.3	18	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	1704	12/13/2022	10:01:00 AM	376	0.2	70.3	24.8	1	
Rondo Education Center	1705	12/13/2022	10:00:00 AM	391	0.2	70.7	24.9	0	
Rondo Education Center	1706	12/13/2022	9:58:00 AM	392	0.2	71.1	24.5	1	
Rondo Education Center	1707	12/13/2022	9:55:00 AM	350	0.2	71.2	24.1	0	
Rondo Education Center	1710	12/13/2022	10:17:00 AM	415	0.2	69.8	25.4	0	
Rondo Education Center	1711	12/13/2022	10:15:00 AM	402	0.2	69.6	25.1	0	
Rondo Education Center	1712	12/13/2022	10:03:00 AM	620	0.2	70.7	27.4	18	
Rondo Education Center	1714	12/13/2022	10:04:00 AM	611	0.2	72	27.5	20	
Rondo Education Center	1715	12/13/2022	10:06:00 AM	619	0.2	71.8	27.1	16	
Rondo Education Center	1716	12/13/2022	9:54:00 AM	498	0.2	71.2	25.7	10	
Rondo Education Center	1717	12/13/2022	9:53:00 AM	650	0.2	70.7	27.9	19	
Rondo Education Center	1718	12/13/2022	9:51:00 AM	409	0.3	69.6	25.5	6	
Rondo Education Center	1719	12/13/2022	10:14:00 AM	403	0.2	70	25.4	1	Fragrance odor, Stained ceiling tiles
Rondo Education Center	1720	12/13/2022	10:12:00 AM	661	0.2	70.5	27.6	11	
Rondo Education Center	1722	12/13/2022	10:09:00 AM	479	0.2	70.5	26.1	0	
Rondo Education Center	1724	12/13/2022	10:08:00 AM	533	0.3	71.6	25.9	4	
Rondo Education Center	1801	12/13/2022	9:49:00 AM	546	0.2	71.6	26.4	17	
Rondo Education Center	2001	12/13/2022	8:45:00 AM	575	0.1	72	30.9	2	
Rondo Education Center	2002	12/13/2022	8:48:00 AM	856	0.1	68.9	27	3	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2003	12/13/2022	8:50:00 AM	640	0.1	71.1	26	3	Fragrance odor
Rondo Education Center	2004	12/13/2022	8:53:00 AM	574	0.3	71.1	25.2	1	Fragrance odor
Rondo Education Center	2005	12/13/2022	8:56:00 AM	487	0.2	72.5	23.1	1	
Rondo Education Center	2007	12/13/2022	9:18:00 AM	499	0.2	72.5	22.7	2	Stained ceiling tiles
Rondo Education Center	2009	12/13/2022	9:13:00 AM	480	0.2	71.6	23.1	0	
Rondo Education Center	2010	12/13/2022	9:09:00 AM	515	0.2	71.1	23.9	1	
Rondo Education Center	2012	12/13/2022	9:03:00 AM	504	0.3	71.4	23.4	0	
Rondo Education Center	2013	12/13/2022	9:12:00 AM	495	0.2	71.8	23.8	0	Fragrance odor
Rondo Education Center	2015	12/13/2022	9:17:00 AM	495	0.2	72.3	23	1	
Rondo Education Center	2016	12/13/2022	8:51:00 AM	504	0.2	72.5	23.4	1	
Rondo Education Center	2101	12/13/2022	12:00:00 PM	977	0.3	71.2	28.8	17	
Rondo Education Center	2102	12/13/2022	10:59:00 AM	741	0.3	71.6	26	4	Stained ceiling tiles
Rondo Education Center	2103	12/13/2022	10:57:00 AM	540	0.2	70.7	24.5	0	Stained ceiling tiles
Rondo Education Center	2104	12/13/2022	10:54:00 AM	858	0.2	72.7	26.3	15	
Rondo Education Center	2105	12/13/2022	11:57:00 AM	1079	0.2	71.8	31.3	18	
Rondo Education Center	2106	12/13/2022	11:52:00 AM	561	0.1	69.4	25.8	0	
Rondo Education Center	2107	12/13/2022	11:50:00 AM	807	0.2	69.3	30.2	23	
Rondo Education Center	2108	12/13/2022	11:48:00 AM	860	0.2	68.9	27.9	25	
Rondo Education Center	2201	12/13/2022	9:21:00 AM	497	0.2	73.4	22.4	1	
Rondo Education Center	2202	12/13/2022	9:28:00 AM	530	0.2	72.7	23.5	1	
Rondo Education Center	2203	12/13/2022	9:23:00 AM	491	0.3	73.4	22	0	Return air vent is beginning to rust, Stained ceiling tiles
Rondo Education Center	2204	12/13/2022	9:25:00 AM	481	0.3	73.2	22.1	0	
Rondo Education Center	2206	12/13/2022	9:26:00 AM	494	0.2	72.3	22.7	0	
Rondo Education Center	2211	12/13/2022	8:58:00 AM	480	0.3	72.5	22.8	0	
Rondo Education Center	2212	12/13/2022	9:00:00 AM	468	0.3	71.8	22.9	0	
Rondo Education Center	2214	12/13/2022	9:35:00 AM	507	0.2	73.4	22.4	0	Stained ceiling tiles
Rondo Education Center	2215	12/13/2022	9:38:00 AM	526	0.2	73	22.5	0	
Rondo Education Center	2216	12/13/2022	9:40:00 AM	537	0.1	75.9	21	1	
Rondo Education Center	2217	12/13/2022	9:42:00 AM	526	0.2	75	21.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	2218	12/13/2022	10:01:00 AM	610	0.2	72.5	23.6	0	
Rondo Education Center	2219	12/13/2022	10:04:00 AM	577	0.1	72.1	23.8	0	
Rondo Education Center	2220	12/13/2022	10:32:00 AM	681	0.1	72.1	23.8	8	
Rondo Education Center	2223	12/13/2022	10:10:00 AM	904	0.1	72.7	29.3	31	Stained ceiling tiles
Rondo Education Center	2224	12/13/2022	10:19:00 AM	1135	0.3	74.3	26.3	31	
Rondo Education Center	2225	12/13/2022	10:20:00 AM	911	0.2	74.7	25.5	32	
Rondo Education Center	2226	12/13/2022	10:22:00 AM	1040	0.3	75	30.2	25	
Rondo Education Center	2227	12/13/2022	10:27:00 AM	811	0.3	73.4	25.3	30	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2232	12/13/2022	10:35:00 AM	584	0.1	72.5	23.4	0	
Rondo Education Center	2235	12/13/2022	10:39:00 AM	585	0.1	72.7	23.4	0	Stained ceiling tiles
Rondo Education Center	2236	12/13/2022	10:38:00 AM	633	0.1	72.7	23.8	1	Dirty or dusty carpet odor
Rondo Education Center	2237	12/13/2022	10:13:00 AM	842	0.1	74.7	24.8	34	
Rondo Education Center	2239	12/13/2022	10:17:00 AM	597	0.2	73.6	22.9	0	
Rondo Education Center	2240	12/13/2022	10:15:00 AM	741	0.2	74.5	24	1	
Rondo Education Center	2241	12/13/2022	10:16:00 AM	631	0.2	73.9	22.8	0	
Rondo Education Center	2243	12/13/2022	9:31:00 AM	494	0.2	72.5	22.9	0	
Rondo Education Center	2246	12/13/2022	9:33:00 AM	554	0.2	72.9	23.2	1	
Rondo Education Center	2301	12/13/2022	10:29:00 AM	610	0.1	72.5	24	0	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2302	12/13/2022	1:18:00 PM	621	0.3	71.8	24.8	0	
Rondo Education Center	2303	12/13/2022	1:22:00 PM	606	0.2	71.6	25	0	
Rondo Education Center	2304	12/13/2022	1:28:00 PM	802	0.2	72.3	27	26	Stained ceiling tiles
Rondo Education Center	2305	12/13/2022	1:15:00 PM	842	0.3	73	27	25	
Rondo Education Center	2306	12/13/2022	1:36:00 PM	599	0.3	72.7	24.1	0	
Rondo Education Center	2307	12/13/2022	1:38:00 PM	938	0.3	72.9	27.2	28	
Rondo Education Center	2308	12/13/2022	2:31:00 PM	1003	0.2	72.5	24.6	27	
Rondo Education Center	2309	12/13/2022	1:42:00 PM	991	0.3	72.5	28.9	32	
Rondo Education Center	2310	12/13/2022	1:44:00 PM	773	0.3	73	26.5	17	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2311	12/13/2022	1:46:00 PM	588	0.3	72.7	24.4	0	Stained ceiling tiles
Rondo Education Center	2312	12/13/2022	2:29:00 PM	770	0.3	69.4	26.7	27	Stained ceiling tiles
Rondo Education Center	2313	12/13/2022	1:51:00 PM	1226	0.2	70.7	30.9	20	
Rondo Education Center	2314	12/13/2022	1:53:00 PM	979	0.2	70.7	29.4	33	
Rondo Education Center	2315	12/13/2022	1:55:00 PM	860	0.2	70.7	28.3	29	
Rondo Education Center	2317	12/13/2022	1:58:00 PM	733	0.3	72.1	26.3	9	
Rondo Education Center	2320	12/13/2022	2:00:00 PM	673	0.2	72.5	25.5	29	Stained ceiling tiles
Rondo Education Center	2501	12/13/2022	12:31:00 PM	712	0.2	69.6	26.8	0	Stained ceiling tiles
Rondo Education Center	2502	12/13/2022	12:33:00 PM	775	0.2	70	27.1	0	Fragrance odor, Stained ceiling tiles
Rondo Education Center	2504	12/13/2022	1:06:00 PM	540	0.1	68.2	26.4	0	
Rondo Education Center	2505	12/13/2022	1:07:00 PM	925	0.1	69.3	28.6	24	
Rondo Education Center	2506	12/13/2022	1:30:00 PM	1025	0.3	71.6	29.5	39	Stained ceiling tiles
Rondo Education Center	2507	12/13/2022	2:26:00 PM	935	0.2	72.9	28	28	
Rondo Education Center	2508	12/13/2022	1:33:00 PM	1524	0.3	73.4	34.1	37	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2511	12/13/2022	12:56:00 PM	953	0.3	71.8	28.4	24	
Rondo Education Center	2512	12/13/2022	12:58:00 PM	775	0.2	72.9	27.4	27	
Rondo Education Center	2514	12/13/2022	12:53:00 PM	991	0.2	71.8	28.4	29	
Rondo Education Center	2515	12/13/2022	12:35:00 PM	1078	0.2	70.9	29.9	30	
Rondo Education Center	2516	12/13/2022	12:36:00 PM	1138	0.2	72.5	30.2	27	Stained ceiling tiles
Rondo Education Center	2517	12/13/2022	12:40:00 PM	995	0.3	72	28	30	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	2518	12/13/2022	12:51:00 PM	833	0.3	72.1	26	25	
Rondo Education Center	2523	12/13/2022	12:14:00 PM	784	0.2	70	27.1	0	
Rondo Education Center	2524	12/13/2022	12:17:00 PM	942	0.3	70.5	28.3	29	
Rondo Education Center	2525	12/13/2022	12:19:00 PM	1116	0.2	70.7	37.1	29	
Rondo Education Center	2525	12/13/2022	12:21:00 PM	1039	0.3	71.6	31.5	33	
Rondo Education Center	2601	12/13/2022	10:44:00 AM	542	0.1	70.2	25	0	Stained ceiling tiles
Rondo Education Center	2602	12/13/2022	10:43:00 AM	777	0.2	71.2	26.3	28	
Rondo Education Center	2605	12/13/2022	10:51:00 AM	526	0.1	72.7	23.3	0	Stained ceiling tiles
Rondo Education Center	2607	12/13/2022	11:01:00 AM	595	0.1	71.2	24.9	3	
Rondo Education Center	2608	12/13/2022	11:04:00 AM	607	0.1	71.2	24.4	8	
Rondo Education Center	2611	12/13/2022	11:22:00 AM	861	0.2	70	28.6	24	
Rondo Education Center	2612	12/13/2022	11:29:00 AM	581	0.1	70	24.6	0	
Rondo Education Center	2613	12/13/2022	11:24:00 AM	710	0.1	70.2	26.5	24	Stained ceiling tiles
Rondo Education Center	2614	12/13/2022	11:17:00 AM	989	0.2	71.6	28.8	23	
Rondo Education Center	2704	12/13/2022	12:08:00 PM	585	0.3	71.1	25.2	3	
Rondo Education Center	2705	12/13/2022	12:10:00 PM	549	0.2	71.1	24.9	0	Stained ceiling tiles
Rondo Education Center	2706	12/13/2022	11:34:00 AM	729	0.2	70.3	26.9	0	
Rondo Education Center	2707	12/13/2022	11:33:00 AM	787	0.1	71.1	28.7	16	Stained ceiling tiles
Rondo Education Center	2708	12/13/2022	11:46:00 AM	511	0.1	69.4	25.4	0	
Rondo Education Center	2709	12/13/2022	11:44:00 AM	624	0.2	69.6	27	4	
Rondo Education Center	2710	12/13/2022	12:45:00 PM	1006	0.3	71.6	28.4	20	
Rondo Education Center	2711	12/13/2022	11:39:00 AM	539	0.1	70	24.9	0	
Rondo Education Center	2714	12/13/2022	11:37:00 AM	848	0.3	70.7	29.3	13	
Rondo Education Center	1114 RED CAFETERIA	12/13/2022	12:08:00 PM	611	0.2	70.7	31.1	40	
Rondo Education Center	1118 GYM	12/13/2022	9:46:00 AM	590	0.2	70.9	28	4	
Rondo Education Center	1235 OFFICE	12/13/2022	8:45:00 AM	323	0.4	74.3	22.8	0	
Rondo Education Center	1344A	12/13/2022	11:20:00 AM	560	0.2	71.4	26	2	
Rondo Education Center	1344B	12/13/2022	11:21:00 AM	502	0.2	71.2	25.3	0	
Rondo Education Center	1401 GYM	12/13/2022	11:43:00 AM	353	0.3	68.2	26.7	15	
Rondo Education Center	1707A	12/13/2022	9:57:00 AM	348	0.2	71.4	23.7	0	
Rondo Education Center	1709 YELLOW CAFETERIA	12/13/2022	12:10:00 PM	582	0.2	70.9	28.4	70	
Rondo Education Center	2220B	12/13/2022	10:08:00 AM	569	0.2	71.6	23.9	0	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2304A	12/13/2022	1:25:00 PM	611	0.2	71.8	24.8	1	Stained ceiling tiles
Rondo Education Center	2610 CAFETERIA	12/13/2022	11:11:00 AM	1243	0.3	73.2	30.6	85	
Rondo Education Center	2611A	12/13/2022	11:23:00 AM	830	0.2	69.8	27.9	0	
Rondo Education Center	2614A	12/13/2022	11:20:00 AM	734	0.2	70.9	25.8	3	
Rondo Education Center	KITCHEN	12/13/2022	11:09:00 AM	585	0.1	72	27	1	
Rondo Education Center	LIBRARY ENTRANCE	12/13/2022	10:49:00 AM	660	0.1	71.8	25.3	4	
Rondo Education Center	LIBRARY SOUTEAST CORNER	12/13/2022	10:48:00 AM	646	0.1	71.1	25.3	10	
Rondo Education Center	OUTDOORS	12/13/2022		466	0.6	32	78		
Rondo Education Center	OUTDOORS	12/13/2022	2:33:00 PM	374	0.5	36	80		
Saint Anthony Park Elementary School	1001	11/29/2022	9:09:00 AM	694	0.4	70.9	25.5	1	
Saint Anthony Park Elementary School	1002	11/29/2022	9:14:00 AM	749	0.4	72.5	25.2	2	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1003	11/29/2022	9:10:00 AM	774	0.4	71.2	27.6	1	
Saint Anthony Park Elementary School	1005	11/29/2022	11:14:00 AM	1045	0.3	72.7	26.9	1	
Saint Anthony Park Elementary School	1006	11/29/2022	9:13:00 AM	679	0.4	71.4	24.9	0	
Saint Anthony Park Elementary School	1109	11/29/2022	9:03:00 AM	1157	0.4	70.2	28.4	35	
Saint Anthony Park Elementary School	1112	11/29/2022	11:08:00 AM	851	0.5	70.9	26.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Anthony Park Elementary School	1201	11/29/2022	9:21:00 AM	875	0.4	70.7	27.8	23	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1203	11/29/2022	9:24:00 AM	765	0.5	70.3	25.6	5	
Saint Anthony Park Elementary School	1204	11/29/2022	11:11:00 AM	941	0.5	71.6	24.5	1	
Saint Anthony Park Elementary School	1205	11/29/2022	9:27:00 AM	966	0.4	70.3	26.9	25	
Saint Anthony Park Elementary School	1207	11/29/2022	9:30:00 AM	814	0.4	70	27.2	20	
Saint Anthony Park Elementary School	1216	11/29/2022	9:32:00 AM	965	0.4	72.5	29.4	3	
Saint Anthony Park Elementary School	1218	11/29/2022	9:35:00 AM	933	0	72.7	24.4	20	
Saint Anthony Park Elementary School	1220	11/29/2022	9:37:00 AM	727	0.5	71.2	25.8	20	
Saint Anthony Park Elementary School	1302	11/29/2022	9:56:00 AM	936	0.2	69.3	26.7	28	
Saint Anthony Park Elementary School	1303	11/29/2022	10:24:00 AM	736	0.3	70	24.7	2	
Saint Anthony Park Elementary School	1304	11/29/2022	10:18:00 AM	704	0.2	71.2	22.6	23	
Saint Anthony Park Elementary School	1305	11/29/2022	10:57:00 AM	851	0.2	69.6	23.5	18	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1306	11/29/2022	10:20:00 AM	1333	0.3	69.3	25.4	24	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1307	11/29/2022	10:21:00 AM	704	0.2	70.2	24.5	2	
Saint Anthony Park Elementary School	1308	11/29/2022	9:41:00 AM	1075	0.3	71.2	25.1	25	
Saint Anthony Park Elementary School	1309	11/29/2022	10:11:00 AM	801	0.2	70.3	24.9	5	
Saint Anthony Park Elementary School	1310	11/29/2022	9:39:00 AM	873	0.3	71.1	26.2	21	
Saint Anthony Park Elementary School	1311	11/29/2022	9:43:00 AM	884	0.3	71.4	25	20	Aquariums (fish), Live animals: Kept Away From Return And Supply Vents, Taxidermy
Saint Anthony Park Elementary School	1401	11/29/2022	10:07:00 AM	586	0.2	69.8	23.6	2	
Saint Anthony Park Elementary School	1402	11/29/2022	11:12:00 AM	735	0.5	71.8	26.9	0	
Saint Anthony Park Elementary School	1402	11/29/2022	10:09:00 AM	670	0.3	69.6	24.6	0	Fragrance odor
Saint Anthony Park Elementary School	1403	11/29/2022	10:01:00 AM	696	0.3	70.3	27.7	2	
Saint Anthony Park Elementary School	1405	11/29/2022	10:05:00 AM	534	0.3	70.2	22.3	0	
Saint Anthony Park Elementary School	1407	11/29/2022	10:02:00 AM	585	0.3	70.5	23.4	1	
Saint Anthony Park Elementary School	1409	11/29/2022	10:03:00 AM	575	0.2	70.5	25.4	0	
Saint Anthony Park Elementary School	1411	11/29/2022	10:06:00 AM	720	0.3	70.2	24.7	2	
Saint Anthony Park Elementary School	1413	11/29/2022	9:58:00 AM	832	0.2	70.5	24.9	21	
Saint Anthony Park Elementary School	2201	11/29/2022	10:52:00 AM	800	1.9	69.8	29.4	2	
Saint Anthony Park Elementary School	2202	11/29/2022	11:05:00 AM	1021	0.5	70.2	30.9	5	
Saint Anthony Park Elementary School	2203	11/29/2022	10:53:00 AM	764	0.4	69.6	26.6	1	
Saint Anthony Park Elementary School	2205	11/29/2022	11:01:00 AM	1450	0.4	69.6	33.1	25	
Saint Anthony Park Elementary School	2207	11/29/2022	11:02:00 AM	989	0.4	70.2	32.6	27	
Saint Anthony Park Elementary School	2209	11/29/2022	10:46:00 AM	812	0.4	69.7	27.6	0	
Saint Anthony Park Elementary School	2211	11/29/2022	10:44:00 AM	970	0.4	70.7	29.5	1	
Saint Anthony Park Elementary School	2212	11/29/2022	10:42:00 AM	740	0.3	70.5	25.3	0	
Saint Anthony Park Elementary School	2401	11/29/2022	10:40:00 AM	802	0.2	70.9	25	3	
Saint Anthony Park Elementary School	2403	11/29/2022	10:50:00 AM	988	0.2	70.5	26.8	20	
Saint Anthony Park Elementary School	2404	11/29/2022	10:38:00 AM	736	0.2	71.1	24.8	0	
Saint Anthony Park Elementary School	2405	11/29/2022	10:48:00 AM	944	0.2	70	26.3	26	
Saint Anthony Park Elementary School	2406	11/29/2022	10:36:00 AM	1001	0.4	71.1	27.3	24	
Saint Anthony Park Elementary School	2408	11/29/2022	10:34:00 AM	1126	0.3	70.7	27	28	
Saint Anthony Park Elementary School	2409	11/29/2022	10:30:00 AM	1250	0.3	71.1	29.2	23	
Saint Anthony Park Elementary School	2410	11/29/2022	10:33:00 AM	958	0.3	70.7	26.6	24	
Saint Anthony Park Elementary School	2412	11/29/2022	10:32:00 AM	1035	0.3	71.1	28.1	20	
Saint Anthony Park Elementary School	CAFETERIA	11/29/2022	10:26:00 AM	1100	0.3	70.7	28	65	
Saint Anthony Park Elementary School	CUSTODIAL OFFICE	11/29/2022	9:01:00 AM	607	0.2	70	25.2	2	
Saint Anthony Park Elementary School	KITCHEN	11/29/2022	9:07:00 AM	1330	0.6	71.4	27.2	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Anthony Park Elementary School	KITCHEN OFFICE	11/29/2022	9:06:00 AM	825	0.8	70	25.8	1	
Saint Anthony Park Elementary School	MEDIA CENTER	11/29/2022	9:59:00 AM	721	0.3	70.2	24.4	21	
Saint Anthony Park Elementary School	OUTDOORS	11/29/2022		400	0.3	26	92		
Saint Anthony Park Elementary School	OUTDOORS	11/29/2022	11:27:00 AM	385	0.4	26	92		
Saint Paul Music Academy	1103	11/30/2022	9:48:00 AM	969	0	70.8	20.2	15	Plants: Kept Away From Return And Supply Vents
Saint Paul Music Academy	1104	11/30/2022	9:44:00 AM	992	0	71.3	18.2	18	
Saint Paul Music Academy	1105	11/30/2022	9:51:00 AM	1143	0.1	69.6	23.5	19	Aquariums (fish)
Saint Paul Music Academy	1108	11/30/2022	9:54:00 AM	699	0	70.9	16.8	0	
Saint Paul Music Academy	1110	11/30/2022	9:55:00 AM	727	0	70.4	17.1	2	
Saint Paul Music Academy	1111	11/30/2022	9:59:00 AM	929	0	67.8	19.3	2	
Saint Paul Music Academy	1116	11/30/2022	9:56:00 AM	568	0.6	67.6	14.9	0	
Saint Paul Music Academy	1201	11/30/2022	9:40:00 AM	903	0	72.2	18	17	
Saint Paul Music Academy	1202	11/30/2022	9:39:00 AM	840	0	72	17.1	23	
Saint Paul Music Academy	1203	11/30/2022	9:35:00 AM	666	0	71.5	14.6	2	
Saint Paul Music Academy	1204	11/30/2022	9:08:00 AM	534	0	70.9	12.7	3	
Saint Paul Music Academy	1205	11/30/2022	9:09:00 AM	3	0	71.1	12.8	3	
Saint Paul Music Academy	1206	11/30/2022	9:01:00 AM	802	0.1	71.1	13.6	0	
Saint Paul Music Academy	1207	11/30/2022	9:04:00 AM	626	0	71.5	14.1	0	
Saint Paul Music Academy	1209	11/30/2022	8:59:00 AM	1333	0	72.4	19.4	24	
Saint Paul Music Academy	1210	11/30/2022	11:25:00 AM	866	0.6	69.8	13.3	15	
Saint Paul Music Academy	1211	11/30/2022	8:53:00 AM	675	0.1	71.7	12.2	6	
Saint Paul Music Academy	1216	11/30/2022	9:41:00 AM	812	0	72.4	18.1	0	
Saint Paul Music Academy	1219	11/30/2022	9:59:00 AM	748	0	68.8	17.1	0	
Saint Paul Music Academy	1301	11/30/2022	11:19:00 AM	1212	0	71.9	18.3	8	
Saint Paul Music Academy	1302	11/30/2022	9:28:00 AM	995	0.1	69	17.5	3	
Saint Paul Music Academy	1303	11/30/2022	9:27:00 AM	1618	0.1	70.2	26.7	32	
Saint Paul Music Academy	1303	11/30/2022	11:10:00 AM	1306	0	72.4	20	22	
Saint Paul Music Academy	1304	11/30/2022	9:25:00 AM	1166	0.2	69.1	15.9	20	
Saint Paul Music Academy	1305	11/30/2022	9:23:00 AM	914	0.1	71.4	16.8	8	
Saint Paul Music Academy	1306	11/30/2022	9:22:00 AM	881	0	72.1	14.7	11	
Saint Paul Music Academy	1307	11/30/2022	9:20:00 AM	1071	0	71.1	16.7	12	
Saint Paul Music Academy	1308	11/30/2022	11:16:00 AM	1119	0.1	71.8	16.5	0	
Saint Paul Music Academy	1309	11/30/2022	9:19:00 AM	947	0	71.1	17.4	4	
Saint Paul Music Academy	1311	11/30/2022	9:16:00 AM	683	0	70.3	17.3	0	
Saint Paul Music Academy	1312	11/30/2022	9:12:00 AM	570	0.2	69.7	13.9	0	
Saint Paul Music Academy	1313	11/30/2022	9:15:00 AM	671	0	70.1	16.6	0	
Saint Paul Music Academy	1317	11/30/2022	9:29:00 AM	1239	0	70.4	23.9	0	
Saint Paul Music Academy	1320	11/30/2022	9:31:00 AM	867	0	71.1	16.2	0	
Saint Paul Music Academy	1321	11/30/2022	9:33:00 AM	787	0.8	71.2	16.8	0	
Saint Paul Music Academy	2002	11/30/2022	10:14:00 AM	840	0	70	17.7	2	
Saint Paul Music Academy	2005	11/30/2022	10:07:00 AM	809	0	69.9	15.9	0	
Saint Paul Music Academy	2006	11/30/2022	10:08:00 AM	860	0	69.7	16.8	3	
Saint Paul Music Academy	2007	11/30/2022	10:09:00 AM	808	0	69.8	16.3	0	
Saint Paul Music Academy	2008	11/30/2022	10:10:00 AM	800	0	69.8	15.9	0	
Saint Paul Music Academy	2009	11/30/2022	10:11:00 AM	792	0	69	15.7	0	
Saint Paul Music Academy	2016	11/30/2022	10:17:00 AM	885	0	71.5	17.6	1	
Saint Paul Music Academy	2101	11/30/2022	10:19:00 AM	1018	0.1	71.3	19	2	
Saint Paul Music Academy	2102	11/30/2022	10:18:00 AM	1018	0	71.5	18	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Paul Music Academy	2103	11/30/2022	10:16:00 AM	972	0	70.6	17.9	1	
Saint Paul Music Academy	2104	11/30/2022	10:41:00 AM	1290	0.1	70.7	19.9	9	
Saint Paul Music Academy	2105	11/30/2022	10:44:00 AM	1750	0	71.5	26.5	20	
Saint Paul Music Academy	2106	11/30/2022	10:47:00 AM	1503	0	71.6	23.4	23	
Saint Paul Music Academy	2107	11/30/2022	10:46:00 AM	1762	0.1	71.2	25.5	20	
Saint Paul Music Academy	2201	11/30/2022	10:21:00 AM	1269	0	71.5	20.4	15	Plants: Kept Away From Return And Supply Vents
Saint Paul Music Academy	2202	11/30/2022	10:23:00 AM	1256	0	71.3	19.7	20	
Saint Paul Music Academy	2204	11/30/2022	10:38:00 AM	701	0.2	70.5	13.1	2	
Saint Paul Music Academy	2207	11/30/2022	10:37:00 AM	682	0	70.6	11.9	0	
Saint Paul Music Academy	2208	11/30/2022	10:36:00 AM	1028	0.1	71.6	15.9	15	
Saint Paul Music Academy	2209	11/30/2022	10:34:00 AM	1160	0.2	72	16.6	13	
Saint Paul Music Academy	2210	11/30/2022	10:33:00 AM	844	0.1	73.3	13.7	0	
Saint Paul Music Academy	2211	11/30/2022	10:31:00 AM	989	0.2	74.1	14.1	0	
Saint Paul Music Academy	2212	11/30/2022	10:29:00 AM	984	0	74.7	14.5	0	
Saint Paul Music Academy	2213	11/30/2022	10:26:00 AM	904	0.1	76	14.1	0	
Saint Paul Music Academy	2300	11/30/2022	11:16:00 AM	1064	0	72.8	18.4	2	
Saint Paul Music Academy	2301	11/30/2022	11:12:00 AM	1052	0	72.2	16.7	5	
Saint Paul Music Academy	2302	11/30/2022	11:11:00 AM	1290	0	72.4	18.3	3	
Saint Paul Music Academy	2304	11/30/2022	11:09:00 AM	1361	0	72.6	18.5	23	
Saint Paul Music Academy	2305	11/30/2022	11:08:00 AM	921	0	72.5	16.6	24	
Saint Paul Music Academy	2306	11/30/2022	11:04:00 AM	1251	0	72.4	20.4	23	
Saint Paul Music Academy	2307	11/30/2022	11:03:00 AM	1580	0	71.8	20.4	26	
Saint Paul Music Academy	2308	11/30/2022	11:01:00 AM	684	0.1	71.3	11.2	0	
Saint Paul Music Academy	2309	11/30/2022	10:59:00 AM	1359	0	71.2	21.7	17	
Saint Paul Music Academy	2310	11/30/2022	10:55:00 AM	1060	0	70.1	16.2	0	
Saint Paul Music Academy	2311	11/30/2022	10:58:00 AM	1114	0	69.3	17	0	
Saint Paul Music Academy	2312	11/30/2022	10:52:00 AM	960	0	71	14.6	1	
Saint Paul Music Academy	2313	11/30/2022	10:49:00 AM	990	0	70.6	18.9	0	
Saint Paul Music Academy	2317	11/30/2022	11:14:00 AM	1318	0.1	72.2	21.3	4	
Saint Paul Music Academy	2319	11/30/2022	11:15:00 AM	1016	0	72.5	15.9	0	
Saint Paul Music Academy	1106 GYMNASIUM	11/30/2022	9:42:00 AM	812	0	70.6	14.9	36	
Saint Paul Music Academy	1218 CUSTODIAL OFFICE	11/30/2022	8:41:00 AM	660	0.2	73	15.5	0	
Saint Paul Music Academy	2001 MAIN OFFICE	11/30/2022	10:01:00 AM	879	0	69.9	17	3	
Saint Paul Music Academy	2010 NURSE	11/30/2022	10:13:00 AM	860	0	69.2	18.6	3	
Saint Paul Music Academy	CAFETERIA	11/30/2022	11:21:00 AM	1012	0	69.7	20.8	89	
Saint Paul Music Academy	MEDIA CENTER	11/30/2022	10:40:00 AM	785	0	70.8	14.6	15	
Saint Paul Music Academy	OUTDOORS	11/30/2022		427	0.2	17	75		
Saint Paul Music Academy	PRINCIPAL'S OFFICE 2	11/30/2022	10:06:00 AM	813	0	70	16	2	
Student Placement Center	1110	11/29/2022	1:06:00 PM	590	0.3	71.2	22.9	1	Plants: Kept Away From Return And Supply Vents
Student Placement Center	1112	11/29/2022	1:04:00 PM	694	0.2	70.3	27.9	2	
Student Placement Center	1113	11/29/2022	1:03:00 PM	681	0.2	69.3	28	1	
Student Placement Center	1118	11/29/2022	1:02:00 PM	610	0.2	68.9	24.8	0	
Student Placement Center	1119	11/29/2022	1:00:00 PM	664	0.3	69.3	25.9	0	
Student Placement Center	1120	11/29/2022	12:47:00 PM	682	0.3	71.8	24.2	0	
Student Placement Center	1121	11/29/2022	12:44:00 PM	651	0.3	70.2	24.3	0	
Student Placement Center	1122	11/29/2022	12:49:00 PM	621	0.3	71.4	23.4	0	
Student Placement Center	1123	11/29/2022	12:45:00 PM	678	0.4	71.6	26.9	1	
Student Placement Center	1124	11/29/2022	12:43:00 PM	644	0.3	70	24.8	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Student Placement Center	2201	11/29/2022	12:23:00 PM	545	0.3	69.6	24.2	4	Plants: Kept Away From Return And Supply Vents
Student Placement Center	2206	11/29/2022	12:25:00 PM	659	0.4	70.2	26.5	2	
Student Placement Center	2211	11/29/2022	12:20:00 PM	531	0.2	68.9	27.4	1	Condensation, Stained ceiling tiles
Student Placement Center	2218	11/29/2022	12:28:00 PM	592	0.4	70.5	24.2	0	Stained ceiling tiles
Student Placement Center	2219	11/29/2022	12:29:00 PM	589	0.3	70.9	24	0	
Student Placement Center	2220	11/29/2022	12:30:00 PM	559	0.4	71.2	23.4	0	
Student Placement Center	2221	11/29/2022	12:31:00 PM	546	0.4	70.5	23.2	0	
Student Placement Center	2222	11/29/2022	12:32:00 PM	554	0.4	70.3	23.7	0	
Student Placement Center	2223	11/29/2022	12:33:00 PM	561	0.4	70.2	23.9	0	Stained ceiling tiles
Student Placement Center	2229	11/29/2022	12:35:00 PM	664	0.3	70.7	24.8	1	
Student Placement Center	2230	11/29/2022	12:38:00 PM	644	0.4	70.3	25.2	0	Plants: Kept Away From Return And Supply Vents
Student Placement Center	2232	11/29/2022	12:36:00 PM	596	0.4	71.2	23.2	0	
Student Placement Center	2233	11/29/2022	12:37:00 PM	601	0.4	70.9	23.4	0	
Student Placement Center	2234	11/29/2022	12:40:00 PM	603	0.3	69.6	24	1	Moisture damage at North wall windows, Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
Student Placement Center	3301	11/29/2022	1:13:00 PM	556	0.4	71.4	22.7	1	
Student Placement Center	3302	11/29/2022	1:27:00 PM	505	0.2	70.5	23.4	0	Bubbling/peeling paint
Student Placement Center	3303	11/29/2022	1:15:00 PM	519	0.3	72	22.4	0	
Student Placement Center	3305	11/29/2022	1:16:00 PM	549	0.2	71.4	22.6	0	Bubbling/peeling paint
Student Placement Center	3306	11/29/2022	1:26:00 PM	538	0.2	71.4	22.2	0	
Student Placement Center	1101B	11/29/2022	1:08:00 PM	600	0.3	76.3	22.2	1	
Student Placement Center	3301B	11/29/2022	1:14:00 PM	534	0.3	72.9	21.5	0	
Student Placement Center	OUTDOORS	11/29/2022		399	0.4	26	91		
Student Placement Center	OUTDOORS	11/29/2022	1:28:00 PM	386	0.3	23	91		
The Heights Community School	1102	1/20/2023	11:22:00 AM	606	0.5	75.4	27.7	3	
The Heights Community School	1105	1/20/2023	11:26:00 AM	706	0.5	71.2	21.2	10	Bubbling/peeling paint, Moisture damage at West window curtain, Suspect microbial growth: West window curtain
The Heights Community School	1107	1/20/2023	11:31:00 AM	501	0.4	71.8	20.3	6	
The Heights Community School	1109	1/20/2023	11:34:00 AM	401	0.4	72.3	17.6	0	
The Heights Community School	1111	1/20/2023	11:37:00 AM	815	0.4	71.6	19.8	22	Bubbling/peeling paint, Stained ceiling tiles
The Heights Community School	1114	1/20/2023	11:40:00 AM	479	0.4	71.1	21	0	Stained ceiling tiles
The Heights Community School	1251	1/20/2023	10:26:00 AM	592	0.4	72.3	23.4	24	
The Heights Community School	1346	1/20/2023	10:23:00 AM	735	0.5	73	20.2	10	Stained ceiling tiles
The Heights Community School	1351	1/20/2023	8:44:00 AM	491	0.5	80.4	17.1	0	
The Heights Community School	2000	1/20/2023	12:03:00 PM	583	0.5	72.7	21.2	2	
The Heights Community School	2002	1/20/2023	12:08:00 PM	542	0.4	70.5	21.8	0	
The Heights Community School	2003	1/20/2023	12:06:00 PM	475	0.5	72	20.1	0	
The Heights Community School	2004	1/20/2023	12:04:00 PM	593	0.5	72.5	21.7	1	Stained ceiling tiles
The Heights Community School	2102	1/20/2023	10:44:00 AM	756	0.5	74.5	19.9	16	Plants: Kept Away From Return And Supply Vents
The Heights Community School	2104	1/20/2023	10:57:00 AM	615	0.5	72.1	19.2	18	Stained ceiling tiles
The Heights Community School	2109	1/20/2023	11:03:00 AM	421	0.4	72.5	17.5	0	Bubbling/peeling paint
The Heights Community School	2111	1/20/2023	11:16:00 AM	519	0.4	70.2	21	0	
The Heights Community School	2113	1/20/2023	11:12:00 AM	667	0.4	68.5	27.1	17	Bubbling/peeling paint
The Heights Community School	2114	1/20/2023	11:05:00 AM	680	0.4	69.6	21.7	17	
The Heights Community School	2115	1/20/2023	11:10:00 AM	572	0.4	67.8	21.2	8	Bubbling/peeling paint, Stained ceiling tiles
The Heights Community School	2116	1/20/2023	11:09:00 AM	550	0.4	68.9	21.2	2	
The Heights Community School	2241	1/20/2023	10:08:00 AM	448	0.4	70.3	19.5	0	Stained ceiling tiles
The Heights Community School	2244	1/20/2023	10:12:00 AM	571	0.3	70.3	19.9	21	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
The Heights Community School	2245	1/20/2023	10:05:00 AM	855	0.4	72.1	22.7	21	Bubbling/peeling paint, Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
The Heights Community School	2254	1/20/2023	9:58:00 AM	517	0.4	72	19.2	3	Fragrance odor, Bubbling/peeling paint
The Heights Community School	2255	1/20/2023	10:01:00 AM	582	0.4	70.7	18.7	14	Bubbling/peeling paint, Stained ceiling tiles
The Heights Community School	2301	1/20/2023	12:11:00 PM	494	0.4	70	21.7	0	
The Heights Community School	2303	1/20/2023	10:39:00 AM	449	0.4	76.8	16.7	0	Bubbling/peeling paint
The Heights Community School	2304	1/20/2023	10:42:00 AM	511	0.5	77.5	16.7	1	
The Heights Community School	2305	1/20/2023	10:47:00 AM	513	0.4	74.3	18.5	0	Moisture damage at NW corner
The Heights Community School	2307	1/20/2023	10:46:00 AM	505	0.4	74.4	18	1	
The Heights Community School	2309	1/20/2023	10:54:00 AM	481	0.4	73.8	17.1	1	Stained ceiling tiles
The Heights Community School	3243	1/20/2023	9:46:00 AM	584	0.4	71.8	20.4	11	Plants: Kept Away From Return And Supply Vents
The Heights Community School	3244	1/20/2023	9:47:00 AM	450	0.4	69.4	19.9	0	
The Heights Community School	3245	1/20/2023	9:44:00 AM	790	0.4	72.3	20.4	22	
The Heights Community School	3248	1/20/2023	9:40:00 AM	675	0.4	72.9	19.4	20	Condensation, Plants: Kept Away From Return And Supply Vents
The Heights Community School	3250	1/20/2023	9:37:00 AM	463	0.4	73.2	17	0	
The Heights Community School	3251	1/20/2023	9:35:00 AM	558	0.4	73.8	19.6	0	Bubbling/peeling paint
The Heights Community School	3252	1/20/2023	9:30:00 AM	708	0.3	72.3	18.6	21	Condensation
The Heights Community School	3253	1/20/2023	9:32:00 AM	458	0.3	74.1	17.1	0	Condensation, Stained ceiling tiles
The Heights Community School	3254	1/20/2023	9:23:00 AM	440	0.4	72.1	18.4	0	Bubbling/peeling paint
The Heights Community School	3257	1/20/2023	9:28:00 AM	526	0.3	71.6	18	5	Bubbling/peeling paint
The Heights Community School	4245	1/20/2023	9:17:00 AM	547	0.3	72	19.7	8	Bubbling/peeling paint, Moisture damage at top window ledge on window on West wall, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4247	1/20/2023	9:13:00 AM	1261	0.5	70.3	28.6	23	Stained ceiling tiles, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4250	1/20/2023	8:49:00 AM	998	0.5	73.9	24	19	Plants: Kept Away From Return And Supply Vents
The Heights Community School	4252	1/20/2023	8:53:00 AM	978	0.4	71.8	26	28	Condensation
The Heights Community School	4255	1/20/2023	8:55:00 AM	1368	0.5	73.6	28.5	21	Condensation, Stained ceiling tiles
The Heights Community School	4256	1/20/2023	8:59:00 AM	685	0.4	71.4	22.9	2	Condensation
The Heights Community School	4257	1/20/2023	12:26:00 PM	502	0.4	72.3	19.6	0	
The Heights Community School	4258	1/20/2023	9:08:00 AM	442	0.4	72	18.7	0	Bubbling/peeling paint, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4259	1/20/2023	9:01:00 AM	479	0.4	71.8	18.5	4	Bubbling/peeling paint, Condensation, Wood in the windowsill is degrading
The Heights Community School	1110 CAFETERIA	1/20/2023	11:20:00 AM	629	0.4	72	22.2	38	Stained ceiling tiles
The Heights Community School	1248 GYMNASIUM OFFICE	1/20/2023	10:31:00 AM	579	0.4	74.3	33	1	Bubbling/peeling paint
The Heights Community School	1253 STAGE	1/20/2023	10:36:00 AM	554	0.4	73.4	21.9	0	Bubbling/peeling paint
The Heights Community School	2102A	1/20/2023	10:59:00 AM	1005	0.4	73	23.3	1	Food odor
The Heights Community School	2104A	1/20/2023	10:55:00 AM	975	0.4	73	22.7	1	Food odor
The Heights Community School	2109A	1/20/2023	11:46:00 AM	577	0.4	73.6	19.9	7	
The Heights Community School	2250 MEDIA CENTER	1/20/2023	10:13:00 AM	402	0.4	71.8	17.5	0	Bubbling/peeling paint, Stained ceiling tiles
The Heights Community School	3250A	1/20/2023	9:38:00 AM	458	0.4	72.3	17.4	1	
The Heights Community School	CUSTODIAL OFFICE	1/20/2023	8:41:00 AM	706	0.4	74.3	26.5	1	Bubbling/peeling paint
The Heights Community School	OUTDOORS	1/20/2023		381	1	25	76		
Transportation Department	1002	1/12/2023	1:17:00 PM	726	0.5	68	22.3	1	
Transportation Department	1003	1/12/2023	1:29:00 PM	743	0.6	72.3	20.2	1	
Transportation Department	1004	1/12/2023	1:32:00 PM	832	0.6	72	21.5	1	
Transportation Department	1001 CONFERENCE	1/12/2023	1:12:00 PM	687	0.4	65.8	23.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Transportation Department	1003 BREAK ROOM	1/12/2023	1:18:00 PM	852	0.6	69.1	21.7	1	
Transportation Department	COPY ROOM	1/12/2023	1:25:00 PM	747	0.6	71.6	20	0	
Transportation Department	CUBICLES	1/12/2023	1:34:00 PM	838	0.6	71.4	20.8	9	
Transportation Department	DISPATCH	1/12/2023	1:22:00 PM	715	0.6	69.6	21.9	1	
Transportation Department	OUTDOORS	1/12/2023		438	0.6	34	24.6		
Washington Technology Magnet	1170	1/9/2023	10:27:00 AM	888	0.8	70.2	18.6	16	
Washington Technology Magnet	1201	1/9/2023	10:29:00 AM	738	0.8	70.2	17.4	6	
Washington Technology Magnet	1270	1/9/2023	11:05:00 AM	914	0.8	71.1	19.4	18	
Washington Technology Magnet	1301	1/9/2023	11:08:00 AM	999	0.8	71.2	19	20	
Washington Technology Magnet	1622	1/9/2023	10:22:00 AM	639	0.9	70.7	18.2	0	
Washington Technology Magnet	1630	1/9/2023	10:34:00 AM	672	0.9	70	17.7	3	Stained ceiling tiles
Washington Technology Magnet	1640	1/9/2023	10:35:00 AM	667	0.9	69.8	17.1	0	
Washington Technology Magnet	1651	1/9/2023	10:43:00 AM	765	0.9	70	18	3	Stained ceiling tiles
Washington Technology Magnet	1652	1/9/2023	10:41:00 AM	694	0.9	70.3	17.8	2	
Washington Technology Magnet	1662	1/9/2023	10:50:00 AM	748	0.8	70.7	17.5	1	
Washington Technology Magnet	1669	1/9/2023	10:56:00 AM	751	0.8	70.7	17.9	2	
Washington Technology Magnet	1670	1/9/2023	10:57:00 AM	660	0.8	70	16.9	0	
Washington Technology Magnet	1710	1/9/2023	11:12:00 AM	1079	0.9	70.7	20.1	21	Stained ceiling tiles
Washington Technology Magnet	1720	1/9/2023	11:10:00 AM	842	0.6	70.7	21.1	19	
Washington Technology Magnet	1730	1/9/2023	11:14:00 AM	937	0.8	70.7	18.9	5	
Washington Technology Magnet	1740	1/9/2023	11:19:00 AM	812	0.8	70.9	17.7	1	
Washington Technology Magnet	1760	1/9/2023	11:21:00 AM	1102	0.8	70.9	19.6	17	
Washington Technology Magnet	2032	1/9/2023	11:36:00 AM	526	0.2	71.2	26.4	0	
Washington Technology Magnet	2050	1/9/2023	11:53:00 AM	675	0.3	72.5	27.3	3	Stained ceiling tiles
Washington Technology Magnet	2110	1/9/2023	12:26:00 PM	602	0.1	69.1	19.6	0	
Washington Technology Magnet	2120	1/9/2023	12:36:00 PM	868	0.1	70.2	25.3	35	
Washington Technology Magnet	2121	1/9/2023	12:40:00 PM	709	0.1	70	20.8	2	
Washington Technology Magnet	2130	1/9/2023	12:38:00 PM	1093	0.1	69.6	24.8	30	
Washington Technology Magnet	2140	1/9/2023	12:42:00 PM	693	0.1	70	20.2	1	
Washington Technology Magnet	2141	1/9/2023	12:44:00 PM	697	0.1	69.8	20.5	0	
Washington Technology Magnet	2150	1/9/2023	12:45:00 PM	720	0.1	69.8	21.5	3	
Washington Technology Magnet	2170	1/9/2023	12:48:00 PM	635	0.1	69.6	21	3	Stained ceiling tiles
Washington Technology Magnet	2173	1/9/2023	12:50:00 PM	598	0.1	70.2	20.2	0	Stained ceiling tiles
Washington Technology Magnet	2208	1/9/2023	12:53:00 PM	684	0.1	69.6	23.2	20	
Washington Technology Magnet	2210	1/9/2023	12:56:00 PM	574	0.1	69.4	20.2	0	
Washington Technology Magnet	2220	1/9/2023	12:59:00 PM	466	0.1	67.6	20.7	0	
Washington Technology Magnet	2222	1/9/2023	12:57:00 PM	470	0.1	68.5	20.3	0	
Washington Technology Magnet	2230	1/9/2023	1:01:00 PM	517	0.1	67.6	21.7	1	
Washington Technology Magnet	2240	1/9/2023	1:03:00 PM	840	0.1	69.3	24.1	30	
Washington Technology Magnet	2241	1/9/2023	1:02:00 PM	667	0.1	68.5	21.5	1	
Washington Technology Magnet	2250	1/9/2023	1:05:00 PM	898	0.1	69.8	24.6	35	
Washington Technology Magnet	2270	1/9/2023	1:07:00 PM	454	0.1	70.2	19.5	0	
Washington Technology Magnet	2273	1/9/2023	1:09:00 PM	506	0.1	70.2	19.9	1	
Washington Technology Magnet	2274	1/9/2023	1:10:00 PM	665	0.1	70.5	20.9	2	
Washington Technology Magnet	2308	1/9/2023	1:12:00 PM	809	0.1	70.2	22.4	7	
Washington Technology Magnet	2310	1/9/2023	1:16:00 PM	843	0.1	70.9	21.1	1	
Washington Technology Magnet	2311	1/9/2023	1:15:00 PM	649	0.1	70.9	19.9	1	
Washington Technology Magnet	2320	1/9/2023	1:19:00 PM	1106	0.1	71.1	24.2	35	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2321	1/9/2023	1:21:00 PM	985	0.1	71.4	27.6	6	
Washington Technology Magnet	2330	1/9/2023	1:22:00 PM	889	0.1	71.2	22.5	20	
Washington Technology Magnet	2340	1/9/2023	1:23:00 PM	1010	0.1	70.9	23.7	30	
Washington Technology Magnet	2340	1/9/2023	1:39:00 PM	795	0.2	72	17.4	1	
Washington Technology Magnet	2341	1/9/2023	1:25:00 PM	774	0.1	70.9	21.1	1	
Washington Technology Magnet	2350	1/9/2023	1:26:00 PM	885	0.1	70.7	23	30	
Washington Technology Magnet	2361	1/9/2023	1:42:00 PM	674		72.3	17	0	
Washington Technology Magnet	2362	1/9/2023	1:48:00 PM	687	0.1	71.3	16.7	0	
Washington Technology Magnet	2370	1/9/2023	1:30:00 PM	704	0.1	70.9	21.1	2	Stained ceiling tiles
Washington Technology Magnet	2373	1/9/2023	1:34:00 PM	682	0.1	71.2	20.7	1	
Washington Technology Magnet	2408	1/9/2023	1:44:00 PM	696	0.1	71.5	17.3	0	
Washington Technology Magnet	2410	1/9/2023	1:11:00 PM	654	0.1	70.9	18.2	5	
Washington Technology Magnet	2420	1/9/2023	1:25:00 PM	715		71.2	16.9	2	
Washington Technology Magnet	2421	1/9/2023	1:23:00 PM	648	0.1	71.1	16.2	0	
Washington Technology Magnet	2422	1/9/2023	1:27:00 PM	664	0.2	71.5	17	0	Moisture damage at ceiling tile in center of room, Stained ceiling tiles
Washington Technology Magnet	2423	1/9/2023	1:46:00 PM	678		71.4	17.1	0	
Washington Technology Magnet	2430	1/9/2023	1:21:00 PM	903	0.1	71.2	19.5	11	
Washington Technology Magnet	2440	1/9/2023	1:19:00 PM	845	0.1	71.2	18.6	10	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	2441	1/9/2023	1:17:00 PM	738		72.2	17.9	1	
Washington Technology Magnet	2450	1/9/2023	1:15:00 PM	800	0.1	71.1	17.8	5	
Washington Technology Magnet	2460	1/9/2023	1:13:00 PM	673		70.5	17.2	5	
Washington Technology Magnet	2470	1/9/2023	1:04:00 PM	669		70.5	16.4	1	Stained ceiling tiles
Washington Technology Magnet	2473	1/9/2023	1:01:00 PM	715		70	17.4	1	
Washington Technology Magnet	2510	1/9/2023	12:43:00 PM	778	0.2	68.4	18.2	2	
Washington Technology Magnet	2520	1/9/2023	12:46:00 PM	842		67	18.6	2	Stained ceiling tiles
Washington Technology Magnet	2530	1/9/2023	12:47:00 PM	1004		69.1	21.4	5	
Washington Technology Magnet	2540	1/9/2023	12:50:00 PM	1026	0.1	69.7	19	1	
Washington Technology Magnet	2550	1/9/2023	12:54:00 PM	789	0.1	70.8	15	0	
Washington Technology Magnet	2560	1/9/2023	12:52:00 PM	909	0.2	70.2	15.8	0	Plants
Washington Technology Magnet	2570	1/9/2023	12:57:00 PM	865	0.1	70	15.4	0	
Washington Technology Magnet	2607	1/9/2023	9:51:00 AM	568	0.5	68.4	18.4	0	
Washington Technology Magnet	2609	1/9/2023	9:50:00 AM	698	0.5	69.1	19.4	1	
Washington Technology Magnet	2610	1/9/2023	9:59:00 AM	840	0.5	69.8	19.8	5	
Washington Technology Magnet	2611	1/9/2023	9:49:00 AM	772	0.5	69.4	19.4	1	Stained ceiling tiles
Washington Technology Magnet	2612	1/9/2023	9:48:00 AM	641	0.4	69.1	18.7	0	
Washington Technology Magnet	2613	1/9/2023	9:59:00 AM	783	0.4	69.4	18.9	3	
Washington Technology Magnet	2616	1/9/2023	9:46:00 AM	614	0.5	68.7	19.6	2	
Washington Technology Magnet	2617	1/9/2023	10:13:00 AM	699	0.4	69.3	19.8	1	
Washington Technology Magnet	2619	1/9/2023	10:01:00 AM	660	0.5	69.4	19	1	Stained ceiling tiles
Washington Technology Magnet	2620	1/9/2023	10:05:00 AM	652	0.4	69.4	19.3	0	Stained ceiling tiles
Washington Technology Magnet	2621	1/9/2023	10:06:00 AM	546	0.4	68.9	17.4	0	
Washington Technology Magnet	2623	1/9/2023	10:08:00 AM	699	0.4	69.4	19.5	2	
Washington Technology Magnet	2624	1/9/2023	10:10:00 AM	527	0.4	69.4	16.8	0	
Washington Technology Magnet	2626	1/9/2023	9:42:00 AM	639	0.6	70	19	2	
Washington Technology Magnet	2628	1/9/2023	10:19:00 AM	603	0.4	68.9	19	0	Stained ceiling tiles
Washington Technology Magnet	2629	1/9/2023	9:41:00 AM	951	0.6	70.2	18.8	4	
Washington Technology Magnet	2630	1/9/2023	10:20:00 AM	547	0.3	69.3	17.4	0	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2634	1/9/2023	10:49:00 AM	712	0.2	70.3	18.7	0	
Washington Technology Magnet	2635	1/9/2023	10:25:00 AM	747	0.4	70	18.8	7	
Washington Technology Magnet	2636	1/9/2023	10:27:00 AM	529	0.3	70	16.9	0	
Washington Technology Magnet	2637	1/9/2023	10:28:00 AM	653	0.3	70.9	18.1	0	
Washington Technology Magnet	2639	1/9/2023	10:34:00 AM	771	0.4	71.2	19.1	0	
Washington Technology Magnet	2640	1/9/2023	10:33:00 AM	701	0.4	71.1	18.7	0	
Washington Technology Magnet	2641	1/9/2023	10:37:00 AM	589	0.4	71.1	17	0	
Washington Technology Magnet	2642	1/9/2023	10:35:00 AM	816	0.4	71.2	18.7	0	
Washington Technology Magnet	2643	1/9/2023	10:42:00 AM	685	0.3	70.9	18.3	2	
Washington Technology Magnet	2644	1/9/2023	10:40:00 AM	808	0.4	70.7	20.4	1	
Washington Technology Magnet	2645	1/9/2023	10:45:00 AM	868	0.3	71.2	19.9	3	
Washington Technology Magnet	2646	1/9/2023	10:46:00 AM	710	0.3	70.9	18.5	1	
Washington Technology Magnet	2647	1/9/2023	10:47:00 AM	758	0.3	70.5	19.3	1	
Washington Technology Magnet	2650	1/9/2023	9:43:00 AM	517	0.5	69.4	16.5	1	
Washington Technology Magnet	2658	1/9/2023	11:18:00 AM	895	0.2	70.2	18.9	2	
Washington Technology Magnet	2659	1/9/2023	11:17:00 AM	704	0.2	70.2	19.1	0	
Washington Technology Magnet	2660	1/9/2023	11:16:00 AM	625	0.1	70.2	18.3	0	
Washington Technology Magnet	2661	1/9/2023	9:45:00 AM	537	0.5	68.7	17.3	0	
Washington Technology Magnet	2662	1/9/2023	11:22:00 AM	642	0.1	70.3	18.8	1	
Washington Technology Magnet	2663	1/9/2023	10:55:00 AM	758	0.2	70.3	19.6	2	
Washington Technology Magnet	2664	1/9/2023	10:59:00 AM	541	0.1	69.6	17.3	0	
Washington Technology Magnet	2665	1/9/2023	11:01:00 AM	574	0.1	69.8	17.4	0	
Washington Technology Magnet	2666	1/9/2023	11:03:00 AM	721	0.1	70	18.7	2	
Washington Technology Magnet	2667	1/9/2023	11:15:00 AM	771	0.1	70	18.8	1	
Washington Technology Magnet	2670	1/9/2023	11:20:00 AM	664	0.2	70.2	18.4	1	
Washington Technology Magnet	2671	1/9/2023	11:23:00 AM	627	0.1	70.5	18.3	0	
Washington Technology Magnet	2674	1/9/2023	11:27:00 AM	683	0.1	71.1	18.5	2	
Washington Technology Magnet	2675	1/9/2023	11:30:00 AM	625	0.2	70.5	17.8	0	
Washington Technology Magnet	2677	1/9/2023	11:29:00 AM	629	0.1	70.9	18.2	0	
Washington Technology Magnet	2678	1/9/2023	11:32:00 AM	649	0.1	70.2	18.5	0	
Washington Technology Magnet	2679	1/9/2023	11:33:00 AM	559	0.1	70.2	17.8	0	
Washington Technology Magnet	2710	1/9/2023	2:09:00 PM	687	0.1	68.5	23.4	8	
Washington Technology Magnet	2720	1/9/2023	2:03:00 PM	675	0.1	70.3	20.8	12	
Washington Technology Magnet	2724	1/9/2023	2:05:00 PM	659	0.1	70	20.9	1	Stained ceiling tiles
Washington Technology Magnet	2727	1/9/2023	2:07:00 PM	612	0.1	69.6	20.8	0	Stained ceiling tiles
Washington Technology Magnet	2730	1/9/2023	1:57:00 PM	800	0.1	70.3	22.6	20	
Washington Technology Magnet	2731	1/9/2023	2:01:00 PM	643	0.1	70.7	20.6	1	Stained ceiling tiles
Washington Technology Magnet	2733	1/9/2023	1:59:00 PM	639	0.1	70	20.7	0	
Washington Technology Magnet	2740	1/9/2023	1:52:00 PM	827	0.1	70.7	22.7	15	
Washington Technology Magnet	2750	1/9/2023	1:40:00 PM	795	0.1	70.5	21.9	35	
Washington Technology Magnet	2751	1/9/2023	1:43:00 PM	772	0.1	70	21.4	0	
Washington Technology Magnet	2752	1/9/2023	1:54:00 PM	664	0.1	70.5	20.9	0	
Washington Technology Magnet	2760	1/9/2023	1:44:00 PM	699	0.1	70.3	21	20	
Washington Technology Magnet	2761	1/9/2023	1:50:00 PM	630	0.1	70.5	20.6	0	
Washington Technology Magnet	2764	1/9/2023	1:48:00 PM	600	0.1	69.8	20.5	0	
Washington Technology Magnet	2765	1/9/2023	1:46:00 PM	583	0.1	70	20.6	0	
Washington Technology Magnet	2813	1/9/2023	1:59:00 PM	754	0.1	72.2	18.2	0	
Washington Technology Magnet	2814	1/9/2023	2:16:00 PM	764	0.1	71.3	17.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2834	1/9/2023	1:07:00 PM	1040	0.1	71.3	20.1	1	
Washington Technology Magnet	2854	1/9/2023	2:17:00 PM	941	0.1	72.2	18.7	0	
Washington Technology Magnet	2864	1/9/2023	2:18:00 PM	1067		73	19.8	5	
Washington Technology Magnet	2880	1/9/2023	2:22:00 PM	670	0.2	71	17.4	0	
Washington Technology Magnet	3110	1/9/2023	1:08:00 PM	625	0.6	70.2	20.3	0	
Washington Technology Magnet	3120	1/9/2023	1:30:00 PM	701	0.6	71.2	19.6	25	
Washington Technology Magnet	3121	1/9/2023	1:29:00 PM	999	0.6	71.2	21	1	Fragrance odor
Washington Technology Magnet	3130	1/9/2023	1:27:00 PM	1101	0.7	71.6	22.9	25	
Washington Technology Magnet	3140	1/9/2023	1:26:00 PM	943	0.5	72.9	22.3	30	
Washington Technology Magnet	3141	1/9/2023	1:24:00 PM	733	0.6	71.1	19.9	1	
Washington Technology Magnet	3150	1/9/2023	1:22:00 PM	915	0.6	71.1	21.8	16	
Washington Technology Magnet	3160	1/9/2023	1:21:00 PM	901	0.6	70.5	22.1	18	
Washington Technology Magnet	3170	1/9/2023	1:07:00 PM	617	0.6	70	19.4	0	
Washington Technology Magnet	3174	1/9/2023	1:05:00 PM	727	0.5	69.4	20.8	2	
Washington Technology Magnet	3208	1/9/2023	1:03:00 PM	535	0.6	69.6	19.1	31	
Washington Technology Magnet	3210	1/9/2023	1:01:00 PM	1041	0.6	70.5	23.1	22	
Washington Technology Magnet	3220	1/9/2023	1:00:00 PM	1003	0.6	70.2	23.5	23	
Washington Technology Magnet	3230	1/9/2023	12:57:00 PM	1081	0.6	70.2	24.3	20	
Washington Technology Magnet	3240	1/9/2023	12:56:00 PM	1213	0.6	70.9	24.4	17	Fragrance odor
Washington Technology Magnet	3250	1/9/2023	12:51:00 PM	1103	0.5	69.8	24.9	22	
Washington Technology Magnet	3261	1/9/2023	12:28:00 PM	1445	0.8	71.6	25.8	12	
Washington Technology Magnet	3270	1/9/2023	12:50:00 PM	516	0.4	68.9	19.1	0	
Washington Technology Magnet	3274	1/9/2023	12:47:00 PM	609	0.4	67.5	21.1	1	
Washington Technology Magnet	3308	1/9/2023	12:27:00 PM	1024	0.7	71.6	20.3	10	Stained ceiling tiles
Washington Technology Magnet	3310	1/9/2023	12:24:00 PM	1235	0.7	72	22	17	
Washington Technology Magnet	3320	1/9/2023	12:22:00 PM	973	0.7	71.6	20.1	23	Fragrance odor
Washington Technology Magnet	3330	1/9/2023	12:20:00 PM	1065	0.7	71.4	20.6	5	
Washington Technology Magnet	3340	1/9/2023	12:19:00 PM	938	0.7	71.2	19.4	6	
Washington Technology Magnet	3341	1/9/2023	12:17:00 PM	910	0.7	71.1	19.3	0	
Washington Technology Magnet	3350	1/9/2023	12:16:00 PM	1099	0.7	71.2	22	27	
Washington Technology Magnet	3360	1/9/2023	12:15:00 PM	1023	0.7	71.4	19.7	17	
Washington Technology Magnet	3361	1/9/2023	11:57:00 AM	1093	0.7	72.5	20.1	5	
Washington Technology Magnet	3408	1/9/2023	11:55:00 AM	850	0.7	72.3	17.8	9	Stained ceiling tiles
Washington Technology Magnet	3410	1/9/2023	11:52:00 AM	910	0.7	71.4	18.6	10	
Washington Technology Magnet	3420	1/9/2023	11:50:00 AM	912	0.7	71.1	19.1	26	
Washington Technology Magnet	3430	1/9/2023	11:49:00 AM	1157	0.7	70.7	23.1	25	
Washington Technology Magnet	3440	1/9/2023	11:47:00 AM	1069	0.7	70.2	20.9	15	
Washington Technology Magnet	3450	1/9/2023	11:44:00 AM	840	0.7	69.8	18.1	4	
Washington Technology Magnet	3460	1/9/2023	11:43:00 AM	953	0.7	69.3	19.1	18	
Washington Technology Magnet	4110	1/9/2023	11:57:00 AM	775	0.2	71.8	17	0	Bubbling/peeling paint
Washington Technology Magnet	4120	1/9/2023	12:00:00 PM	1060	0.1	70.8	20.5	19	Bubbling/peeling paint
Washington Technology Magnet	4121	1/9/2023	12:08:00 PM	781	0.2	72.8	18.5	2	
Washington Technology Magnet	4130	1/9/2023	12:12:00 PM	796	0.1	72.1	16.7	16	
Washington Technology Magnet	4140	1/9/2023	12:02:00 PM	806		71.4	18.2	25	
Washington Technology Magnet	4141	1/9/2023	12:11:00 PM	661	0.1	71.9	15.5	0	
Washington Technology Magnet	4150	1/9/2023	12:05:00 PM	866	0.1	73.2	18.2	22	Stained ceiling tiles
Washington Technology Magnet	4160	1/9/2023	12:07:00 PM	1080	0.1	73.6	21.3	21	
Washington Technology Magnet	4173	1/9/2023	12:22:00 PM	650	0.2	73.6	14.5	0	Stained ceiling tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	4208	1/9/2023	12:24:00 PM	769	0.1	72.3	17.4	1	Stained ceiling tiles, Aquariums (fish), Plants: Kept Away From Return And Supply Vents, Taxidermy
Washington Technology Magnet	4210	1/9/2023	10:45:00 AM	1021	0.2	69.8	12.1	23	Stained ceiling tiles, Aquariums (fish), Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	4220	1/9/2023	10:39:00 AM	1112	0.3	69.8	18.8	30	Bubbling/peeling paint
Washington Technology Magnet	4221	1/9/2023	10:42:00 AM	950	0.1	70.3	17.4	0	Stained ceiling tiles
Washington Technology Magnet	4230	1/9/2023	10:43:00 AM	903	0.2	69.1	15.8	21	
Washington Technology Magnet	4240	1/9/2023	10:37:00 AM	1056	0.2	70.7	17.3	19	
Washington Technology Magnet	4241	1/9/2023	10:35:00 AM	807	0.1	70.9	14.9	1	
Washington Technology Magnet	4250	1/9/2023	10:34:00 AM	1025	0.1	71.1	17.6	22	
Washington Technology Magnet	4260	1/9/2023	10:33:00 AM	779	0.3	70.2	15.3	0	
Washington Technology Magnet	4261	1/9/2023	10:25:00 AM	825	0.1	72	14.3	1	Bubbling/peeling paint, Plants
Washington Technology Magnet	4273	1/9/2023	10:28:00 AM	825	0.2	70.8	15.4	11	Stained ceiling tiles
Washington Technology Magnet	4308	1/9/2023	10:21:00 AM	1330	0.1	71.7	20.1	22	Stained ceiling tiles, Plants
Washington Technology Magnet	4310	1/9/2023	10:17:00 AM	963	0.2	70.4	15.1	27	
Washington Technology Magnet	4320	1/9/2023	10:11:00 AM	1048	0.2	70.8	16.5	29	Bubbling/peeling paint
Washington Technology Magnet	4321	1/9/2023	10:14:00 AM	803	0.2	69.8	14.2	0	
Washington Technology Magnet	4330	1/9/2023	10:10:00 AM	1060	0.3	70.6	16.6	14	
Washington Technology Magnet	4340	1/9/2023	10:09:00 AM	1242	0.1	71.7	18.2	28	
Washington Technology Magnet	4341	1/9/2023	10:15:00 AM	835	0.3	70.2	14.3	0	
Washington Technology Magnet	4350	1/9/2023	10:07:00 AM	1084	0.2	71	17.3	12	
Washington Technology Magnet	4360	1/9/2023	10:05:00 AM	1314	0.1	70.8	15.6	22	
Washington Technology Magnet	4373	1/9/2023	10:00:00 AM	795	0.3	71	13.8	0	Stained ceiling tiles
Washington Technology Magnet	4408	1/9/2023	9:57:00 AM	859	0.2	71.3	14.7	0	Aquariums (fish)
Washington Technology Magnet	4410	1/9/2023	9:51:00 AM	715	0.2	70.5	13.6	11	
Washington Technology Magnet	4420	1/9/2023	9:49:00 AM	791	0.3	70.4	15	17	
Washington Technology Magnet	4421	1/9/2023	12:38:00 PM	671	0.2	69.6	16.1	1	
Washington Technology Magnet	4430	1/9/2023	9:43:00 AM	855	0.2	70.2	16.2	25	Bubbling/peeling paint
Washington Technology Magnet	4440	1/9/2023	9:45:00 AM	793	0.2	70.5	13.7	24	
Washington Technology Magnet	4441	1/9/2023	9:47:00 AM	636	0.2	70.2	12	0	
Washington Technology Magnet	4450	1/9/2023	9:39:00 AM	818	0.2	71.2	14.3	16	Stained ceiling tiles
Washington Technology Magnet	4460	1/9/2023	9:37:00 AM	813	0.4	70.4	14.6	18	Bubbling/peeling paint
Washington Technology Magnet	4473	1/9/2023	9:35:00 AM	715	0.3	73.1	12.3	4	Stained ceiling tiles
Washington Technology Magnet	1000 GYMNASIUM	1/9/2023	9:36:00 AM	627	0.9	69.3	17.8	68	
Washington Technology Magnet	1013 MEN'S LOCKER ROOM OFF	1/9/2023	9:43:00 AM	567	0.9	69.3	20.1	0	Stained ceiling tiles
Washington Technology Magnet	1035 WOMEN'S LOCKER ROOM	1/9/2023	9:39:00 AM	565	0.8	69.1	19.4	0	
Washington Technology Magnet	1050 GYMNASIUM	1/9/2023	9:30:00 AM	601	0.9	70.3	18.3	45	
Washington Technology Magnet	1060 POOL	1/9/2023	9:45:00 AM	510	0.9	71.6	53.2	0	
Washington Technology Magnet	1064 POOL OFFICE	1/9/2023	10:00:00 AM	541	0.9	73	37.7	0	
Washington Technology Magnet	1271 OFFICE	1/9/2023	11:07:00 AM	944	0.8	71.2	18.1	0	Stained ceiling tiles
Washington Technology Magnet	1602 OFFICE	1/9/2023	10:01:00 AM	766	1	70.2	22.4	2	
Washington Technology Magnet	1604 OFFICE	1/9/2023	10:06:00 AM	586	0.9	69.6	16.8	0	
Washington Technology Magnet	1605 OFFICE	1/9/2023	10:06:00 AM	967	1	70.7	25.5	2	
Washington Technology Magnet	1607 OFFICE	1/9/2023	10:10:00 AM	644	0.9	70.2	20.2	0	
Washington Technology Magnet	1610 CONFERENCE	1/9/2023	10:14:00 AM	574	0.8	70.3	15.8	0	
Washington Technology Magnet	1611 OFFICE	1/9/2023	10:15:00 AM	568	0.8	71.1	15.8	0	
Washington Technology Magnet	1613 OFFICE	1/9/2023	10:16:00 AM	628	0.9	71.1	17.8	1	
Washington Technology Magnet	1620 CONFERENCE	1/9/2023	10:18:00 AM	640	0.9	70.2	16.9	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	1626 OFFICE	1/9/2023	10:23:00 AM	627	0.9	68.9	18.9	0	
Washington Technology Magnet	1631 OFFICE	1/9/2023	10:26:00 AM	650	0.9	68.7	17.3	0	
Washington Technology Magnet	1632 OFFICE	1/9/2023	10:36:00 AM	836	0.9	70	19.3	1	
Washington Technology Magnet	1633 OFFICE	1/9/2023	10:39:00 AM	689	0.8	70.3	17	0	
Washington Technology Magnet	1653 OFFICE	1/9/2023	10:44:00 AM	680	0.8	69.8	17.4	0	
Washington Technology Magnet	1654 OFFICE	1/9/2023	10:46:00 AM	686	0.8	70.2	17.1	0	
Washington Technology Magnet	1660 MEDIA CENTER	1/9/2023	10:31:00 AM	749	0.9	69.1	18	6	
Washington Technology Magnet	1667 OFFICE	1/9/2023	10:55:00 AM	744	0.8	7.5	17.5	0	
Washington Technology Magnet	1671 OFFICE	1/9/2023	10:59:00 AM	778	0.8	68.5	18.9	1	Stained ceiling tiles
Washington Technology Magnet	1672 OFFICE	1/9/2023	11:04:00 AM	754	0.7	69.8	18.5	1	
Washington Technology Magnet	1731 OFFICE	1/9/2023	11:18:00 AM	851	0.8	70.9	17.9	0	
Washington Technology Magnet	1750 OFFICE	1/9/2023	11:23:00 AM	817	0.8	70.3	17.7	0	
Washington Technology Magnet	3221 OFFICE	1/9/2023	12:59:00 PM	571	0.5	70	18.4	0	
Washington Technology Magnet	3241 OFFICE	1/9/2023	12:54:00 PM	544	0.5	70.5	18.2	1	
Washington Technology Magnet	3273 OFFICE	1/9/2023	12:29:00 PM	525	0.6	70.9	17.3	0	
Washington Technology Magnet	3309 OFFICE	1/9/2023	12:25:00 PM	945	0.7	71.8	19.4	1	Stained ceiling tiles
Washington Technology Magnet	3321 OFFICE	1/9/2023	12:21:00 PM	1010	0.7	71.6	19.7	1	
Washington Technology Magnet	3370 OFFICE	1/9/2023	12:01:00 PM	803	0.6	71.2	18.1	1	
Washington Technology Magnet	3373 OFFICE	1/9/2023	11:59:00 AM	818	0.7	72	17.4	0	
Washington Technology Magnet	3374 OFFICE	1/9/2023	11:58:00 AM	913	0.7	72.7	18.1	1	
Washington Technology Magnet	3409 OFFICE	1/9/2023	11:53:00 AM	932	0.7	72.3	18.7	0	
Washington Technology Magnet	3441 OFFICE	1/9/2023	11:45:00 AM	668	0.7	70	16.8	0	
Washington Technology Magnet	3470 OFFICE	1/9/2023	11:33:00 AM	761	0.7	69.1	18.1	1	
Washington Technology Magnet	3473 OFFICE	1/9/2023	11:26:00 AM	762	0.7	70.3	17	3	
Washington Technology Magnet	4170/4171	1/9/2023	12:16:00 PM	647		73.1	17.3	0	Stained ceiling tiles
Washington Technology Magnet	4270/4271	1/9/2023	10:31:00 AM	595	0.2	70.9	14.6	1	Stained ceiling tiles
Washington Technology Magnet	4370/4371	1/9/2023	10:03:00 AM	866	0.2	69.8	14.4	1	
Washington Technology Magnet	4470/4471	1/9/2023	9:33:00 AM	835	0.2	74	14.2	2	Stained ceiling tiles
Washington Technology Magnet	CAFETERIA	1/9/2023	1:06:00 PM	1045		71.2	20.5	85	
Washington Technology Magnet	KITCHEN	1/9/2023	1:08:00 PM	977	0.2	70.5	21.2	9	
Washington Technology Magnet	OUTDOORS	1/9/2023		667	1.1	27.5	30.1		
Washington Technology Magnet	STAGE/THEATER ARTS	1/9/2023	1:55:00 PM	872	0.1	72	17.3	0	
Wellstone Elementary School	122	12/9/2022	10:40:00 AM	360	0.2	73.8	19.7	1	
Wellstone Elementary School	1026	12/9/2022	9:08:00 AM	396	0.2	73	19.2	0	
Wellstone Elementary School	1028	12/9/2022	9:12:00 AM	359	0.2	74.5	18	0	
Wellstone Elementary School	1051	12/9/2022	10:23:00 AM	299	0.2	72.3	19.3	0	
Wellstone Elementary School	1062	12/9/2022	10:19:00 AM	294	0.2	71.4	19.6	0	
Wellstone Elementary School	1064	12/9/2022	10:16:00 AM	307	0.2	72.1	19.4	0	
Wellstone Elementary School	1071	12/9/2022	9:59:00 AM	406	0.3	69.1	21.5	2	
Wellstone Elementary School	1110	12/9/2022	9:48:00 AM	405	0.2	70	20.4	0	
Wellstone Elementary School	1111	12/9/2022	9:50:00 AM	414	0.2	71.4	19.9	0	
Wellstone Elementary School	1113	12/9/2022	9:39:00 AM	598	0.3	72.1	21.9	0	
Wellstone Elementary School	1130	12/9/2022	9:51:00 AM	326	0.2	70.9	19.9	0	
Wellstone Elementary School	1150	12/9/2022	9:58:00 AM	720	0.2	70.7	23.8	27	
Wellstone Elementary School	1203	12/9/2022	9:33:00 AM	650	0.2	72.7	22.4	20	
Wellstone Elementary School	1207	12/9/2022	9:32:00 AM	462	0.2	70.5	21.8	0	
Wellstone Elementary School	2005	12/9/2022	11:49:00 AM	432	0.2	71.1	22.6	0	
Wellstone Elementary School	2015	12/9/2022	11:51:00 AM	533	0.3	71.1	23.9	17	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Wellstone Elementary School	2027	12/9/2022	11:54:00 AM	592	0.2	71.1	24.5	17	
Wellstone Elementary School	2028	12/9/2022	11:56:00 AM	469	0.2	72.7	22.4	1	
Wellstone Elementary School	2050	12/9/2022	11:05:00 AM	502	0.3	71.1	22.2	0	Plants
Wellstone Elementary School	2052	12/9/2022	11:09:00 AM	530	0.2	69.4	23.9	23	
Wellstone Elementary School	2058	12/9/2022	11:11:00 AM	567	0.2	69.3	24.4	19	Stuffy odor
Wellstone Elementary School	2063	12/9/2022	11:13:00 AM	497	0.2	69.1	25.3	3	Stuffy odor
Wellstone Elementary School	2106	12/9/2022	11:15:00 AM	516	0.2	70	22.7	22	Fragrance odor
Wellstone Elementary School	2107	12/9/2022	11:17:00 AM	488	0.2	70.9	33.6	0	
Wellstone Elementary School	2110	12/9/2022	11:20:00 AM	552	0.2	71.1	22.6	3	Fragrance odor
Wellstone Elementary School	2111	12/9/2022	9:29:00 AM	461	0.2	68.4	22.8	1	
Wellstone Elementary School	2130	12/9/2022	11:22:00 AM	723	0.2	70.5	21.6	1	
Wellstone Elementary School	2203	12/9/2022	11:30:00 AM	830	0.3	70.9	25.8	24	
Wellstone Elementary School	2206	12/9/2022	11:37:00 AM	441	0.2	70.7	22.7	0	
Wellstone Elementary School	2207	12/9/2022	11:33:00 AM	484	0.2	70.3	23	1	
Wellstone Elementary School	2208	12/9/2022	11:39:00 AM	441	0.2	70.7	22.2	1	
Wellstone Elementary School	2211	12/9/2022	11:35:00 AM	663	0.2	70.5	24.6	19	
Wellstone Elementary School	2215	12/9/2022	11:41:00 AM	470	0.2	70.5	23	0	
Wellstone Elementary School	2217	12/9/2022	11:46:00 AM	462	0.2	69.3	23.2	0	
Wellstone Elementary School	2220	12/9/2022	11:47:00 AM	587	0.2	71.1	24.2	25	
Wellstone Elementary School	3005	12/9/2022	12:23:00 PM	483	0.3	71.8	22.7	0	
Wellstone Elementary School	3015	12/9/2022	12:28:00 PM	708	0.2	71.4	25.8	21	
Wellstone Elementary School	3027	12/9/2022	12:32:00 PM	866	0.3	69.8	27.7	21	
Wellstone Elementary School	3028	12/9/2022	12:33:00 PM	461	0.2	69.4	24.1	1	
Wellstone Elementary School	3030	12/9/2022	12:35:00 PM	808	0.2	70.3	27.1	16	
Wellstone Elementary School	3031	12/9/2022	1:01:00 PM	668	0.2	71.4	25.6	0	
Wellstone Elementary School	3050	12/9/2022	12:00:00 PM	447	0.3	72.1	22.5	0	
Wellstone Elementary School	3051	12/9/2022	12:08:00 PM	612	0.3	73.6	22	18	
Wellstone Elementary School	3052	12/9/2022	12:04:00 PM	445	0.2	74.1	21.5	0	
Wellstone Elementary School	3054	12/9/2022	12:14:00 PM	434	0.3	72	22.3	0	
Wellstone Elementary School	3058	12/9/2022	12:18:00 PM	613	0.2	71.8	24.6	22	
Wellstone Elementary School	3060	12/9/2022	12:20:00 PM	562	0.2	71.6	25.3	3	
Wellstone Elementary School	3063	12/9/2022	12:22:00 PM	602	0.2	72	24.6	23	
Wellstone Elementary School	3112	12/9/2022	12:39:00 PM	905	0.3	71.1	25.4	0	
Wellstone Elementary School	3113	12/9/2022	12:37:00 PM	646	0.2	71.6	24.5	16	
Wellstone Elementary School	3115	12/9/2022	12:11:00 PM	467	0.2	72.7	20.5	0	
Wellstone Elementary School	3203	12/9/2022	12:40:00 PM	502	0.2	71.1	24.6	19	Fragrance odor
Wellstone Elementary School	3205	12/9/2022	12:43:00 PM	392	0.2	71.1	22.2	0	
Wellstone Elementary School	3207	12/9/2022	12:45:00 PM	693	0.2	72	25.4	0	Plants
Wellstone Elementary School	3209	12/9/2022	12:57:00 PM	980	0.3	74.7	28.1	0	Stuffy odor, Plants
Wellstone Elementary School	3214	12/9/2022	12:47:00 PM	501	0.3	71.8	22.5	2	
Wellstone Elementary School	3215	12/9/2022	12:49:00 PM	702	0.2	71.8	24.7	20	
Wellstone Elementary School	3216	12/9/2022	12:51:00 PM	510	0.2	71.1	22.7	0	
Wellstone Elementary School	3220	12/9/2022	12:52:00 PM	543	0.2	72.5	23.2	20	Live animals, Plants
Wellstone Elementary School	0045 CAFETERIA	12/9/2022	10:27:00 AM	613	0.2	73.8	29.4	90	
Wellstone Elementary School	0047 KITCHEN OFFICE	12/9/2022	10:33:00 AM	557	0.3	75.4	25.5	0	
Wellstone Elementary School	0111 LOBBY	12/9/2022	10:34:00 AM	396	0.6	72.9	20.7	2	
Wellstone Elementary School	0117 COPY ROOM	12/9/2022	10:55:00 AM	355	0.4	72.1	20.2	0	
Wellstone Elementary School	0118 OFFICE	12/9/2022	11:03:00 AM	380	0.4	74.8	19	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Wellstone Elementary School	0119 OFFICE	12/9/2022	11:02:00 AM	342	0.2	74.5	18.6	0	
Wellstone Elementary School	0120 OFFICE	12/9/2022	11:00:00 AM	373	0.3	73.8	19.9	0	
Wellstone Elementary School	0121 LOUNGE	12/9/2022	10:58:00 AM	363	0.2	73.2	19.8	4	Stained ceiling tiles
Wellstone Elementary School	0124 OFFICE	12/9/2022	10:54:00 AM	377	0.3	75	19.3	1	Plants
Wellstone Elementary School	0125 OFFICE	12/9/2022	10:52:00 AM	408	0.2	74.7	19.7	1	
Wellstone Elementary School	0126 OFFICE	12/9/2022	10:51:00 AM	378	0.2	73.4	20	1	
Wellstone Elementary School	0127 OFFICE	12/9/2022	10:49:00 AM	396	0.3	73	20.3	1	Fragrance odor
Wellstone Elementary School	0130 OFFICE	12/9/2022	10:47:00 AM	339	0.3	73	20.5	0	
Wellstone Elementary School	0131 SMALL KITCHEN	12/9/2022	10:46:00 AM	341	0.2	73.2	19.6	0	
Wellstone Elementary School	0135 OFFICE	12/9/2022	10:44:00 AM	340	0.3	72.7	19.7	0	
Wellstone Elementary School	0136 OFFICE	12/9/2022	10:42:00 AM	351	0.3	73	19.7	0	
Wellstone Elementary School	046 KITCHEN	12/9/2022	10:32:00 AM	607	0.2	75.2	27.9	3	
Wellstone Elementary School	1005 MAIN RECEPTION	12/9/2022	8:34:00 AM	376	0.2	68.7	22.5	3	
Wellstone Elementary School	1006 PRINCIPAL	12/9/2022	8:44:00 AM	302	0.2	70.3	20.2	1	
Wellstone Elementary School	1007 CONFERENCE	12/9/2022	8:42:00 AM	305	0.2	69.8	20.7	0	
Wellstone Elementary School	1012 NURSE	12/9/2022	8:45:00 AM	341	0.2	72.3	20	0	
Wellstone Elementary School	1014 NURSE OFFICE	12/9/2022	8:48:00 AM	451	0.3	73	20.2	1	
Wellstone Elementary School	1019 OFFICE	12/9/2022	9:03:00 AM	338	0.2	71.6	19.2	0	Fragrance odor
Wellstone Elementary School	1020 STORAGE	12/9/2022	9:04:00 AM	307	0.2	72.3	18.7	0	
Wellstone Elementary School	1021 ASSISTANT PRINCIPAL	12/9/2022	9:06:00 AM	326	0.2	7.7	18.8	0	
Wellstone Elementary School	1022 QUIET ROOM	12/9/2022	9:01:00 AM	299	0.3	72	18.6	0	
Wellstone Elementary School	1023 ISOLATION ROOM	12/9/2022	9:00:00 AM	304	0.2	73.4	18.4	0	
Wellstone Elementary School	1024 OFFICE	12/9/2022	8:49:00 AM	361	0.2	73.4	19.6	0	Fragrance odor
Wellstone Elementary School	1025 OFFICE	12/9/2022	8:58:00 AM	333	0.3	73.2	18.7	0	
Wellstone Elementary School	1026 CUSTODIAL OFFICE	12/9/2022	10:07:00 AM	429	0.2	70.3	21.9	1	
Wellstone Elementary School	1027 OFFICE	12/9/2022	9:10:00 AM	325	0.2	73.6	18.1	0	
Wellstone Elementary School	1033 OFFICE	12/9/2022	9:17:00 AM	323	0.3	73	18.4	0	
Wellstone Elementary School	1034 STAFF LOUNGE	12/9/2022	9:15:00 AM	329	0.3	74.3	17.9	1	
Wellstone Elementary School	1053 OFFICE	12/9/2022	10:21:00 AM	314	0.2	71.8	19.6	0	
Wellstone Elementary School	1059 LOBBY	12/9/2022	10:24:00 AM	310	0.2	72.9	20.1	0	
Wellstone Elementary School	1065 GYMNASIUM	12/9/2022	10:13:00 AM	288	0.3	72	19	0	
Wellstone Elementary School	1070 BREAKROOM	12/9/2022	10:11:00 AM	433	0.2	70	21.9	3	
Wellstone Elementary School	1128 RECIEVING	12/9/2022	10:06:00 AM	396	0.2	70.9	21	0	
Wellstone Elementary School	1215 MUSIC	12/9/2022	9:28:00 AM	325	0.2	69.8	20.3	0	
Wellstone Elementary School	1217 COMPUTER LAB	12/9/2022	9:24:00 AM	359	0.2	70	20.9	2	
Wellstone Elementary School	1220 OFFICE	12/9/2022	9:23:00 AM	332	0.2	71.1	20.1	0	
Wellstone Elementary School	2108 OFFICE	12/9/2022	11:19:00 AM	791	0.2	71.6	22.8	1	Fragrance odor
Wellstone Elementary School	2115 LOBBY	12/9/2022	11:28:00 AM	481	0.2	71.4	22	0	
Wellstone Elementary School	2120 GYMNASIUM	12/9/2022	11:24:00 AM	408	0.2	70	21.6	19	
Wellstone Elementary School	2132 GYMNASIUM OFFICE	12/9/2022	11:26:00 AM	399	0.2	70.7	21.1	0	
Wellstone Elementary School	3016 OFFICE	12/9/2022	12:30:00 PM	572	0.2	71.1	24.2	0	
Wellstone Elementary School	3110 MEDIA CENTER	12/9/2022	12:10:00 PM	463	0.3	72.3	21	0	Plants
Wellstone Elementary School	3201 OFFICE	12/9/2022	12:58:00 PM	436	0.4	73	20.8	0	
Wellstone Elementary School	OFFICE CONNECTED TO 2115	12/9/2022	11:44:00 AM	476	0.2	70.2	22.7	0	Fragrance odor
Wellstone Elementary School	OUTDOORS	12/9/2022		223	0.4	28	33.1		
Wheelock Early Education	1001	3/7/2023	12:16:00 PM	538		74.3	19.4	0	
Wheelock Early Education	1002	3/7/2023	12:19:00 PM	483		73.9	17.3	0	
Wheelock Early Education	1003	3/7/2023	12:17:00 PM	502		74.4	17.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temp- erature °F	Relative Humidity %RH	Number of Occupants	Notes
Wheelock Early Education	1004	3/7/2023	12:15:00 PM	498		74	20.4	0	
Wheelock Early Education	1005	3/7/2023	12:14:00 PM	504		73	21.4	0	
Wheelock Early Education	1006	3/7/2023	12:12:00 PM	508		73.9	20.4	0	
Wheelock Early Education	1100	3/7/2023	12:20:00 PM	491		73.8	20.3	0	
Wheelock Early Education	1103	3/7/2023	12:19:00 PM	498		74.1	17.7	0	
Wheelock Early Education	1203	3/7/2023	12:23:00 PM	495		73	23.9	0	
Wheelock Early Education	1204	3/7/2023	12:25:00 PM	518		73.2	21	0	
Wheelock Early Education	1205	3/7/2023	12:26:00 PM	476		72.3	20.9	0	
Wheelock Early Education	1206	3/7/2023	12:28:00 PM	494		73.6	18.7	4	
Wheelock Early Education	1301	3/7/2023	12:30:00 PM	495		73	17.7	1	
Wheelock Early Education	1302	3/7/2023	12:34:00 PM	476		72.8	18.7	1	
Wheelock Early Education	1303	3/7/2023	12:36:00 PM	496		72.7	17.6	0	
Wheelock Early Education	1304	3/7/2023	12:32:00 PM	466		72.8	19.1	1	
Wheelock Early Education	1105 CUSTODIAL	3/7/2023	12:37:00 PM	474		75.2	16.5	0	
Wheelock Early Education	OUTDOORS	3/7/2023		469	1	37	59		