

**Saint Paul Public Schools
Water Sample Results
Battle Creek Elementary
Building Number: 422**

**Sample Date: July 30th, 2020
Sampled by: Ally Peters, Brenda Kappel,
Chelsea Moody, Tod Eckberg**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type	Comments
422-001	Kitchen 1202 left - KS	<2		Sink	
422-002	Kitchen 1202 right - KS	<2		Sink	
422-003	Kitchen 1202 - SPR	34		Sprayer	
422-004	Dish Room - SPR	<2		Sprayer	
422-005	Kitchen 1202 Hand Sink - SNK	<2		Sink	
422-003.5	Kitchen 1202 - SPR (flush)		<2	Sprayer	
422-006	Kitchen Bathroom - SNK	<2		Sink	
422-007	Cafeteria - WC	<2		Cooler/Water Bottle Filler	
422-008	1200 Corridor Restroom (left) - SNK	<2		Sink	
422-009	1200 Corridor Restroom (left middle) - SNK	<2		Sink	
422-010	1200 Corridor Restroom (right middle) - SNK	<2		Sink	
422-011	1200 Corridor Restroom (right) - SNK	<2		Sink	
422-012	Room 1206 - SNK	24		Sink	
422-013	Outside Restroom Corridor 1200 - WC	3		Water Cooler	
422-014	Room 1208 - SNK	<2		Sink	
422-015	Janitor's Closet 1200C - Slop	<2		Slop Sink	
422-016	Room 1211 - SNK	<2		Sink	
422-012.5	Room 1206 - SNK (flush)		<2	Sink	
422-017	Room 1213 - SNK	21		Sink	
422-018	Room 1210 - SNK	<2		Sink	
422-017.5	Room 1213 - SNK (flush)		<2	Sink	
422-019	Room 1212 - SNK	30		Sink	
422-020	Faculty Workroom 1215 Restroom - SNK	15		Sink	
422-021	Faculty Workroom 1215 - SNK	<2		Sink	
422-019.5	Room 1212 - SNK (flush)		<2	Sink	
422-022	Room 1106 - SNK	<2		Sink	
422-023	Room 1106 - DF	<2		Fountain	
422-024	Room 1105 - SNK	6		Sink	
422-025	Room 1105 - DF	<2		Fountain	
422-026	Room 1104 - SNK	6		Sink	
422-027	Room 1104 - DF	<2		Fountain	
422-028	Room 1103 - SNK	61		Sink	
422-029	Room 1103 - DF	<2		Fountain	
422-030	Room 1102 - Slop	<2		Slop Sink	
422-028.5	Room 1103 - SNK (flush)		<2	Sink	
422-031	Room 1102 - SNK	<2		Sink	
422-032	Women's Restroom 1101B - SNK	<2		Sink	
422-033	Outside 1101A/B Restrooms (left) - WC	<2		Water Cooler	
422-034	Outside 1101A/B Restrooms (right) - WC	<2		Water Cooler	
422-035	Men's Restroom 1101A - SNK	<2		Sink	
422-036	Mechanical Room 1101 North Wall - SNK	<2		Sink	
422-037	Mechanical Room 1101 South Wall - SNK	<2		Sink	
422-038	Nurse's Office 1006 - SNK	60		Sink	
422-039	Nurse's Office 1006 Restroom - SNK	<2		Sink	
422-038.5	Nurse's Office 1006 - SNK (flush)		<2	Sink	
422-040	1003 Workroom - SNK	<2		Sink	
422-041	1113 Media Center - SNK	<2		Sink	
422-042	Outside Media Center (left) - WC	<2		Water Cooler	
422-043	Outside Media Center (right) - WC	<2		Water Cooler	
422-044	Restroom 1113 - SNK	<2		Sink	
422-045	Room 1300B - Slop	<2		Slop Sink	
422-046	Girl's Restroom 1327 (left) - SNK	<2		Sink	
422-047	Girl's Restroom 1327 (middle) - SNK	<2		Sink	
422-048	Girl's Restroom 1327 (right) - SNK	<2		Sink	
422-049	Outside Girl's Restroom 1327 (left) - WC	23		Water Cooler	usually runs, so d
422-050	Outside Girl's Restroom 1327 (right) - WC	13		Water Cooler	
422-051	Boy's Restroom 1328 (right) - SNK	<2		Sink	
422-052	Boy's Restroom 1328 (middle) - SNK	14		Sink	
422-053	Boy's Restroom 1328 (left) - SNK	<2		Sink	
422-054	Room 1330 - SNK	<2		Sink	
422-055	Room 1330 - DF	14		Drinking Fountain	
422-056	Room 1331 (west) - SNK	4		Sink	
422-057	Room 1331 (east) - SNK	<2		Sink	
422-058	Room 1332 - SNK	18		Sink	
422-059	Room 1332 - DF	<2		Drinking Fountain	

422-060	Room 1334 - DF	17		Drinking Fountain	
422-061	Room 1334 - SNK	<2		Sink	
422-062	Room 1335 - SNK	<2		Sink	
422-063	Room 1335 - DF	<2		Drinking Fountain	
422-064	Room 1336 - DF	<2		Drinking Fountain	
422-065	Room 1336 - SNK	4		Sink	
422-066	Room 1337 - SNK	<2		Sink	
422-067	Room 1337 - DF	<2		Drinking Fountain	
422-068	Room 1325 - SNK	<2		Sink	
422-069	Room 1325 - DF	<2		Drinking Fountain	
422-070	Room 1326 - SNK	16		Sink	
422-071	Room 1326 - DF	<2		Drinking Fountain	
422-072	Room 1323 - SNK	30		Sink	
422-073	Room 1323 - DF (Broken)			Drinking Fountain	oken - Did not te
422-074	Room 1324 - SNK	<2		Sink	
422-075	Room 1324 - DF	<2		Drinking Fountain	
422-072.5	Room 1323 - SNK (flush)		<2	Sink	
422-076	Room 1321 - SNK	22		Sink	
422-077	Room 1321 - DF	<2		Drinking Fountain	
422-078	Room 1322 - SNK	<2		Sink	
422-079	Room 1322 - DF	<2		Drinking Fountain	
422-076.5	Room 1321 - SNK (flush)	<2		Sink	
422-080	Girl's Restroom 1319 (left) - SNK	<2		Sink	
422-081	Girl's Restroom 1319 (middle) - SNK	<2		Sink	
422-082	Girl's Restroom 1319 (right) - SNK	<2		Sink	
422-083	Outside Girl's Restroom 1319 (left) - WC	<2		Water Cooler	
422-084	Outside Girl's Restroom 1319 (right) - WC	<2		Water Cooler	
422-085	Boy's Restroom 1318 (left) - SNK	<2		Sink	
422-086	Boy's Restroom 1318 (middle) - SNK	<2		Sink	
422-087	Boy's Restroom 1318 (right) - SNK	<2		Sink	
422-088	Room 1317 - SNK	<2		Sink	
422-089	Room 1317 - DF	<2		Drinking Fountain	
422-090	Room 1316 - SNK	19		Sink	
422-091	Room 1316 - DF	13		Drinking Fountain	
422-092	Room 1315 - SNK	8		Sink	
422-093	Room 1315 - DF	<2		Drinking Fountain	
422-094	Room 1314 Bathroom- SNK	18		Sink	
422-095	Room 1314 - SNK	13		Sink	
422-096	Room 1314 - DF	10		Drinking Fountain	
422-097	Room 1312 Restroom - SNK	77		Sink	
422-098	Room 1312 - DF	21		Drinking Fountain	
422-099	Room 1312 - SNK	<2		Sink	
422-100	Room 1309 - SNK	22		Sink	
422-101	Room 1309 - DF	<2		Drinking Fountain	
422-102	Room 1310 Restroom - SNK	93		Sink	
422-103	Room 1310 - SNK	25		Sink	
422-104	Room 1310 - DF	<2		Drinking Fountain	
422-105	Room 1305 - SNK	<2		Sink	
422-106	Room 1305 - DF	<2		Drinking Fountain	
422-107	Room 1303 - SNK	<2		Sink	
422-108	Rom 1303 - DF	<2		Drinking Fountain	
422-109	Room 1301 - SNK	<2		Sink	
422-110	Room 1301 - DF	-		Drinking Fountain	oken - did not te
422-098.5	Room 1312 - DF (flush)		<2	Drinking Fountain	
422-100.5	Room 1309 - SNK (flush)		52	Sink	
422-102.5	Room 1310 Restroom - SNK (flush)		<2	Sink	
422-097.5	Room 1312 Restroom - SNK (flush)		2	Sink	
422-103.5	Room 1310 - SNK		<2	Sink	
422-111	Kitchen - Bunn	42		Bunn	

**Saint Paul Public Schools
Water Sample Results
Battle Creek Junior High
Building Number: 310**

**Sample Date: July 30th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Mood**

Sample #	Location	Fixture Type	Comments	Sample Results 2020	2020 flush sample
310-001	South Kitchen 2106 - KS	Kitchen Sink		<2	
310-002	Kitchen 2105 Hand Sink - SNK	Sink		<2	
310-003	Hand Sink West Wall 2106 - SNK	Sink		<2	
310-004	2106 North (left) - KS	Kitchen Sink		<2	
310-005	2106 North (right) - KS	Kitchen Sink		<2	

310-006	North Hand Sink - SNK	Sink		<2	
310-007	Dishroom - SPR	Sprayer		<2	
310-008	Cafeteria East - WC	Water Cooler		<2	
310-009	Cafeteria West - WC	Water Cooler	REMOVED	n/a	
310-010	2110 Mechanical	Slop		<2	
310-011	Nutrition Services Restroom (next to 2110) - SNK	Sink		<2	
310-012	2000 Cooridor West (left) - WC	Water Cooler		<2	
310-013	2000 Cooridor West (right) - WC	Water Cooler		<2	
310-014	Room 2205 - SNK	Sink		<2	
310-015	Room 2206 - SNK	Sink		<2	
310-016	Girl's Restroom 2103 (left) - SNK	Sink		<2	
310-017	Girl's Restroom 2103 (right) - SNK	Sink		<2	
310-018	Boy's Restroom 2101 (left) - SNK	Sink		<2	
310-019	Boy's Restroom 2101 (right) - SNK	Sink		<2	
310-020	Room 2611 - SNK	Sink		<2	
310-021	Room 2614 - SNK	Sink		<2	
310-022	Room 2617 - SNK	Sink		<2	
310-023	2000 Cooridor East (left) - WC	Water Cooler		<2	
310-024	2000 Cooridor East (right) - WC	Water Cooler		<2	
310-025	2300 Cooridor East - WC	Water Cooler		<2	
310-026	Room 2502 - SNK	Sink		<2	
310-027	Room 2503 North Wall - SNK	Sink		<2	
310-028	Room 2503 East Wall - SNK	Sink		<2	
310-029	Room 2503A Restroom (left) - SNK	Sink		<2	
310-030	Room 2503A Restroom (right) - SNK	Sink		<2	
310-031	Room 2504 North Wall (east) - SNK	Sink		<2	
310-032	Room 2504 North Wall (west) - SNK	Sink		n/a	
310-033	Room 2504 West Wall (north) - SNK	Sink		<2	
310-034	Room 2504 West Wall (south) - SNK	Sink		n/a	
310-035	Room 2504 South Wall - SNK	Sink		n/a	
310-036	Room 933 Custodian - SNK	Slop		<2	
310-037	Girl's Restroom 2506 (left) - SNK	Sink		<2	
310-038	Girl's Restroom 2506 (right) - SNK	Sink		<2	
310-039	Outside Girl's Restroom 2506 - WC	Water Cooler		<2	
310-040	Outside Boy's Restroom 2301 - WC	Water Cooler		<2	
310-041	Boy's Restroom 2301 (left) - SNK	Sink		<2	
310-042	Boy's Restroom 2301 (right) - SNK	Sink	very red, probably iron	<2	
310-043	2300 Cooridor West - WC	Water Cooler		<2	
310-044	1100 Cooridor West (left) - WC	Water Cooler		n/a	
310-045	1100 Cooridor West (right) - WC	Water Cooler		<2	
310-046	Room 1203 West Wall - SNK	Sink		n/a	
310-047	Room 1203 North Wall (west) - SNK	Sink		n/a	
310-048	Room 1203 North Wall (east) - SNK	Sink		n/a	
310-049	Room 1203 South Wall - SNK	Sink		<2	
310-050	Room 1203 Eastern Island - SNK	Sink		n/a	
310-051	Room 1202 Western Island - SNK	Sink		<2	
310-052	Room 1202 North Wall - SNK	Sink		n/a	
310-053	Room 1202 East Wall (left) - SNK	Sink		<2	
310-054	Room 1202 East Wall (right) - SNK	Sink		<2	
310-055	Room 1201 North Wall (west) - SNK	Sink		<2	
310-056	Room 1201 North Wall (east) - SNK	Sink		n/a	
310-057	Room 1201 East Wall - SNK	Sink		n/a	
310-058	Room 1201 South Wall - SNK	Sink		<2	
310-059	Room 1103 (left) - SNK	Sink		<2	
310-060	Room 1103 (right) - SNK	Sink		<2	
310-061	Boy's Restroom 900 (left) - SNK	Sink		<2	
310-062	Boy's Restroom 900 (right) - SNK	Sink		<2	
310-063	Girl's Restroom 1101 (left) - SNK	Sink		<2	
310-064	Girl's Restroom 1101 (right) - SNK	Sink		<2	
310-065	Room 1101B Custodial - SNK	Slop		<2	
310-066	Men's Restroom 915 Offices - SNK	Sink		<2	
310-067	Women's Restroom 914 Offices - SNK	Sink		<2	
310-068	Room 1014 Lounge - SNK	Sink		<2	
310-069	Restroom 1014C (Women's) (left) - SNK	Sink		<2	
310-070	Restroom 1014C (Women's) (Right) - SNK	Sink		<2	
310-071	Restroom 1014B Men's - SNK	Sink		<2	
310-072	1014A Cooridor - WC	Water Cooler		<2	
310-073	1106 Cooridor (left) - WC	Water Cooler		n/a	
310-074	1106 Cooridor (right) - WC	Water Cooler		<2	
310-075	Room 1003 Nurse's - SNK	Sink		<2	
310-076	Girl's Restroom 913 - SNK	Sink		<2	
310-077	Boy's Restroom 912 - SNK	Sink		<2	
310-078	Cooridor H100 - WC	Water Cooler		<2	

310-079	Room 1502 Mechanical - SNK	Slop		<2	
310-080	Room 1406 Mechanical - SNK	Slop		<2	
310-081	Outside Restroom 1405 - WC	Water Cooler		<2	
310-082	Girl's Restroom 1405 (left) - SNK	Sink		<2	
310-083	Girl's Restroom 1405 (right) - SNK	Sink		<2	
310-084	Outside Restroom 1401 - WC	Water Cooler		<2	
310-085	Boy's Restroom 1401 (left) - SNK	Sink		<2	
310-086	Boy's Restroom 1401 (right) - SNK	Sink		<2	
310-087	Room 1208 North Wall - SNK	Sink		<2	
310-088	Room 1208 East Wall - SNK	Sink		n/a	
310-089	Room 1208 South Wall - SNK	Sink		n/a	
310-090	Room 1207 - SNK	Sink		<2	
310-091	Room 1206 North Wall (east) - SNK	Sink		<2	
310-092	Room 1206 North Wall (middle) - SNK	Sink		<2	
310-093	Room 1206 North Wall (west) - SNK	Sink		n/a	
310-094	Room 1206 West Wall (north) - SNK	Sink		n/a	
310-095	Room 1206 West Wall (middle) - SNK	Sink		n/a	
310-096	Room 1206 West Wall (south) - SNK	Sink		n/a	
310-097	Room 1206 South Wall (west) - SNK	Sink		n/a	
310-098	Room 1206 South Wall (middle) - SNK	Sink		<2	
310-099	Room 1206 South Wall (east) - SNK	Sink		<2	
310-100	Room 1206 East Wall - SNK	Sink		n/a	
310-101	Room 1306 Boy's Locker - WC	Water Cooler		<2	
310-102	Room 1306 Boy's Locker - SNK	Sink		<2	
310-103	Room 1311 Girl's Locker - WC	Water Cooler		<2	
310-104	Room 1311 Girl's Locker - SNK	Sink		<2	
310-105	Gymnasium 1304 (right) - WC	Water Cooler		<2	
310-106	Cooridor 109 - WC	Water Cooler		<2	
310-107	Gymnasium 1304 (left) - WC	Water Cooler		<2	
310-108	Gymnasium 2303 - WC	Water Cooler		n/a	
310-109	Kitchen - Bunn	Bunn			21 <2

Saint Paul Public Schools

**Water Sample Results
Cherokee Heights
Building Number: 428**

**October
14, 2020
Sampled
by: ESG**

Sample #	Location	Fixture Type	Sample results 2020
428-001	Kitchen Hand sink	Sink	<2
428-002	N Dish Sink Sprayer	Sprayer	OFF
428-003	N Dish Sink	Sink	<2
428-004	South Sink	Sink	<2
428-005	Bunn	Bunn	26 ppb
428-006	Gym West WC	Water Cooler	<2
428-007	Gym East WC	Water Cooler	<2
428-008	1106 Hallway DF Left	Drinking Fountain	<2
428-009	1106 Hallway DF Right	Drinking Fountain	<2
428-010	Pool DF	Drinking Fountain	<2
428-011	Boy Locker Room Sink Left	Sink	<2
428-012	Boy Locker Room Sink Right	Sink	<2
428-013	Boy's Locker Room DF	Drinking Fountain	<2
428-014	Girl's Locker Room Left	Sink	3 ppb
428-015	Girl's Locker Room Right	Sink	<2
428-016	Girl's Locker Room DF	Drinking Fountain	<2
428-017	1103 Utility Sink	Sink	<2
428-018	1103 Sink	Sink	<2
428-019	1104 Bathroom Sink	Sink	<2
428-020	3101A Boys Left	Sink	<2
428-021	3101A Boys Left Middle	Sink	<2
428-022	3101A Boys Right Middle	Sink	<2
428-023	3101A Boys Right	Sink	<2
428-024	3101A Girls Left	Sink	<2
428-025	3101A Girls Left Middle	Sink	<2
428-026	3101A Girls Right Middle	Sink	<2
428-027	3101A Girls Right	Sink	<2
428-028	3103 Sink Left	Sink	<2
428-029	3103 Sink Right	Sink	<2
428-030	3114 Sink	Sink	<2
428-031	3105 Sink	Sink	5ppb
428-031A	3106	sink	<2
428-032	3101A Hallway DF	Drinking Fountain	<2

428-033	3101A maintenance	slop sink	<2	
428-034	3203 Hallway DF Left	Drinking Fountain	<2	
428-035	3203 Hallway DF Right	Drinking Fountain	<2	
428-036	Bathroom Near 1104	Sink	<2	
428-037	3000 Staff Men Left	Sink	<2	
428-038	3000 Staff Men Right	Sink	<2	
428-039	3206 Sink	Sink	<2	
428-040	2nd Floor Boys by Elevator Left	Sink	<2	
428-041	2nd Floor Boy's Bathroom by Elevator Middle Left	Sink	<2	
428-042	2nd Floor Boys Bathroom by Elevator Middle Right	Sink	<2	
428-043	2nd Floor Boy's Bathroom by Elevator Right	Sink	<2	
428-044	Girl's Bathroom by Elevator 2nd Floor Left	Sink	<2	
428-045	Girl's Bathroom by Elevator 2nd Floor Middle Left	Sink	<2	
428-046	Girl's Bathroom by Elevator 2nd Floor Middle Right	Sink	5ppb	
428-047	Girl's Bathroom by Elevator 2nd Floor Right	Sink	<2	
428-048	2204 DF Left	Drinking Fountain	<2	
428-049	2204 DF Right	Drinking Fountain	<2	
428-050	2nd Floor Staff Girl's Left	Sink	<2	
428-051	2nd Floor Staff Girl's Right	Sink	<2	
428-052	2203 Sink	Sink	<2	
428-053	2202 Nurse's Sink	Sink	<2	
428-054	2208 SK	Sink	<2	
428-055	2207 Sink	Sink	<2	
428-056	2211 Hallway DF	Drinking Fountain	<2	
428-057	2007 Storage Sink	Sink	<2	
428-058	2101A Hallway DF	Drinking Fountain	<2	
428-059	2103 Sink	Sink	<2	
428-060	2104 Sink	Sink	<2	
428-061	2105 Sink	Sink	<2	
428-062	2106 Sink	Sink	<2	
428-063	2107 Sink	Sink	<2	
428-064	2108 Sink	Sink	<2	
428-065	1101 Utility Sink	Sink	moved	
428-066	4203A Utility Sink	Sink	<2	
428-067	4204 Hallway DF	Drinking Fountain	off	
428-068	2110 Sink	Sink	<2	
428-069	2109 Sink	Sink	<2	
428-070	1207 Left Sink	Sink		
428-071	1207 Right Sink	Sink		
428-072	1205 Hallway DF	Drinking Fountain		
428-073	C109A Men's Left	Sink	<2	
428-074	C109A Men's Right	Sink	<2	
428-075	C109B Women's Left	Sink	3ppb	
428-076	C109B Women's Right	Sink	3ppb	
428-077	C109 Sink	Sink	<2	
428-078	C108 Sink	Sink	<2	
428-079	C106 Hallway WC Left	Water Cooler	<2	
428-080	C106 Hallway WC Right	Water Cooler	<2	
428-081	1113 Sink left	Sink	<2	
428-081A	1113 sink right		<2	
428-082	1208 Hallway Left	Water Cooler	<2	
428-083	1208 Hallway Right	Water Cooler	<2	
428-084	All Gender Left	Sink	<2	
428-085	All Gender Right	Sink	<2	
428-086	C201 Sink	Sink	<2	
428-087	C200 WC Left	Water Cooler	<2	
428-088	C200 WC Right	Water Cooler	<2	
428-089	C202A Sink	Sink	rented office	
428-090	C203 Slop Sink	Slop Sink	<2	
428-091	Locker room bathroom	sink	<2	
428-092	1113A maintenance	slop sink	<2	
428-093	1115 pool office	sink	<2	
428-094	1105 restroom	sink	<2	
428-095	1105	sink	<2	
428-096	1101 storage	slop sink	<2	
428-097	custodial office	sink	<2	
428-098	1208 girls left	sink	<2	
428-099	1208 girls right	sink	<2	
428-100	1205 unisex	sink	<2	
428-101	1207 boys left	sink	<2	
428-102	1207 boys right	sink	<2	
428-103	2201A principal bathroom	sink	<2	
428-104	2211	sink	<2	

428-105	2214	sink	<2	
428-106	3107	sink	<2	
428-107	3108	sink	<2	
428-108	3109	sink	<2	
428-109	3110	sink	<2	

Saint Paul Public Schools
Water Sample Results
Eastern Heights
Building Number: 452

Sample Date: July 29th, 2020

Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample #	Location	Sample Type	Comments	Sample Results 2020
452-001	Café hydration station			<2
452-002	North Kitchen Hand Sink			4
452-003	Kitchen Bathroom Sink			<2
452-004	East Kitchen Hand Sink by dishroom			<2
452-005	1108B Utility Sink	custodial		<2
452-006	South Kitchen Dish Sink	Sprayer		<2
452-007	1207 Hallway DF			<2
452-008	1202 Sink			<2
452-009	BUNN			<2
452-010	1101 Hallway DF			<2
452-011	Boy's Near 1205			<2
452-012	Girl's Near 1205			<2
452-013	1303 Sink			<2
452-014	1209 Sink			<2
452-015	1404			8
452-016	1305 sink			<2
452-017	1305 Hallway DF			<2
452-018	1205 Utility Sink			<2
452-019	1301 Sink			<2
452-020	1311 Sink			<2
452-021	1309 Sink			<2
452-022	1304 Sink			<2
452-023	1307 Sink			<2
452-024	1315 Utility Sink			<2
452-025	1302 Sink			<2
452-026	1304 Hallway DF			<2
452-027	Boy's Left by 1313			<2
452-028	Boy's Right by 1313			<2
452-029	DF Near 1313			
452-030	Girl's Right by 1313			3
452-031	Girl's Left by 1313			<2
452-032	Boy's Left Near 2101			16
452-033	Boy's Right Near 2101			<2
452-034	2315A Utility Sink			<2
452-035	2102 Sink			<2
452-036	2304 Sink			<2
452-037	1010 Restroom Left Sink			<2
452-038	1010 Restroom Right Sink			<2
452-039	2307 Sink			<2
452-040	Nurse's Sink			<2
452-041	2309 Sink			<2
452-042	2313 Sink			<2
452-043	Girl's Left near 2101			<2
452-044	Girl's Right near 2101			<2
452-045	2301 Sink			<2
452-046	2305 Sink			<2
452-047	2303			<2
452-048	Nurse's Bathroom Sink			<2
452-049	2206 Sink			<2
452-050	2102 Hallway - DF			<2
452-051	2204 Sink			<2
452-052	2207 Sink			<2
452-053	2311 Sink			<2
452-054	2304 Hallway DF			<2
452-055	2306 Sink			<2
452-056	2202 Sink			<2
452-057	2302 DF			<2
452-058	2207 Boy's			<2
452-059	2207 Girl's			<2
452-060	2302 Sink			<2
452-061	3106 Hallway DF			<2

452-062	2108b Utility Sink		Does not exist	n/a
452-063	3108 Restroom			<2
452-064	3rd Floor Main Room Sink			<2
452-065	Basement Restroom			n/a
452-066	2nd Floor Teacher's Break Room		Does not exist	n/a
452-067	kitchen sink left (north wall, dishroom)			3
452-068	kitchen sink right (north wall, dishroom)			<2
452-069	1303 A			<2
452-070	1301 A RR			<2
452-071	1313A custodial RR			<2
452-072	1011 Staff break rm			<2
452-073	2101			<2
452-074	2313 DF			<2
452-075	2207 DF			<2

**Saint Paul Public Schools
Water Sample Results
Farnsworth Lower
Building Number: 458**

Sample Date: August 6th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample #	Location	Fixture Type	Comments	2020 Sample Results	flush
458-001	Kitchen - NE corner - Left	Large Sink		<2	
458-001.5	Kitchen - Restroom	Sink		<2	
458-002	Kitchen - NE corner - Right	Large Sink		<2	
458-003	Kitchen	Hand Sink		<2	
458-004	Kitchen - Bunn Machine	Sink		4	
458-005	Rm 108	Sink		5	
458-006	Rm 108	Fountain		13	
458-007	Rm 107	Sink		<2	
458-008	Rm 107	Fountain		<2	
458-009	Rm 106	Sink		<2	
458-010	Rm 106	Fountain		9	
458-011	First Floor Hallway North	Cooler		<2	
458-012	Nurse's Office	Sink		<2	
458-013	Nurse's Office	Fountain		n/a	
458-014	Restroom off Nurse's cot Room	Sink		<2	
458-015	Admin Office	Sink		11	
458-016	First Floor Hallway South	Cooler		<2	
458-017	Room 105	Sink		<2	
458-018	Room 105	Fountain		4	
458-019	Room 104	Sink		<2	
458-020	Room 104	Fountain		<2	
458-021	Room 103	Sink		<2	
458-022	Room 103	Fountain		4	
458-023	Room 102	Sink		<2	
458-024	Room 102	Fountain		<2	
458-025	Room 101	Sink		<2	
458-026	Room 101	Fountain		<2	
458-027	First Floor Janitor's Closet	Utility Sink		<2	
458-028	Rm 206 - Left	Sink		<2	
458-029	Rm 206 - Right	Sink		<2	
458-030	IMC Workroom	Sink		<2	
458-031	Outside Media Center - North	Cooler	not operable	<2	
458-032	Outside Media Center - South	Cooler		2	
458-033	Second floor Janitor's Closet	Utility Sink	cold	<2	
458-033.5	Second floor Janitor's Closet	Utility Sink	hot		
458-034	Science Rm 201 - Left	Sink		<2	
458-035	Science Rm 201 - Left Middle	Sink		<2	
458-036	Science Rm 201 - Right Middle	Sink		<2	
458-037	Science Rm 201 - right	Sink		<2	
458-038	Second floor girl's restroom - L	Sink		<2	
458-039	Second floor girl's restroom - LM	Sink		<2	
458-040	Second floor girl's restroom - Midd	Sink		<2	
458-040.5	Second floor girl's restroom -Midd	Sink			
458-041	Second floor girl's restroom - RM	Sink		6	
458-042	Second floor girl's restroom - Right	Sink		<2	
458-043	Second floor boy's restroom - Left	Sink		<2	
458-044	Second floor boy's restroom - Middle	Sink		<2	
458-045	Second floor boy's restroom - Right	Sink			
458-046	Staff Room	Sink		<2	
458-046.5	Staff Restroom	Sink			
458-047	Room 313	Sink		<2	
458-048	Room 310	Sink		17	5

458-049	Outside Rm 308	Cooler		<2	
458-050	Outside Rm 306	Cooler		<2	
458-051	Third Floor Janitor's Closet	Utility Sink		<2	
458-052	Third Floor Girl's Restroom - Left	Sink		<2	
458-053	Third Floor Girl's Restroom - LM	Sink		<2	
458-054	Third Floor Girl's Restroom - Middle	Sink		3	
458-055	Third Floor Girl's Restroom - RM	Sink		6	
458-056	Third Floor Girl's Restroom - Right	Sink		5	
458-057	Third Floor Boy's Restroom - Left	Sink		2	
458-058	Third Floor Boy's Restroom - Middle	Sink		<2	
458-059	Third Floor Boy's Restroom - Right	Sink		<2	
458-060	Custodial Office Utility Sink	Utility Sink		<2	
458-061	Custodial Office Restroom	Sink		<2	
458-062	Custodial Office - First Draw	Utility Sink		<2	
458-063	Outside Room 1301B Hallway	Fountain		<2	
458-064	Kitchen 1304A - Left	sink	Large sink faucet	<2	
458-065	Kitchen 1304A - Right	sink	Large sink faucet	<2	
458-066	Hyd station outside Rm 1307	hydration station	Cafeteria hall kitchen	<2	
458-067	Third floor girls - Middle	sink		2	
458-068	Third floor girls - Right Middle	sink		<2	
458-069	Third floor girls - Right	sink	Cold water broken	<2	

**Saint Paul Public Schools
Water Sample Results
Farnsworth Upper
Building Number: 315**

Sample Date: August 6th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample Number	Location	SampleType	Comments	Sample results 2020
315-001	Kitchen 1104 large- left	sink		<2
315-002	Kitchen 1104 large- right	sink		<2
315-003	kitchen 1104	bunn		<2
315-004	kitchen 1104	hand sink		<2
315-005	kitchen 1106 restroom	sink		<2
315-006	cafeteria 1102 left	water cooler		<2
315-007	cafeteria 1102 right	water cooler		<2
315-008	room 1006 restroom	sink		<2
315-009	hallway by room 1304	drinking fountain		<2
315-010	staff restroom by Room 1001	sink		<2
315-011	staff lounge Room 1205	sink		<2
315-012	room 1203	sinnk		<2
315-013	custodial closet by Room 1006	utility sink		<2
315-014	boys restroom by Room 1304- left	sink		<2
315-015	boys restroom by Room 1304- middle	sink		<2
315-016	boys restroom by Room 1304- right	sink		<2
315-017	girls restroom by Room 1304- left	sink		<2
315-018	girls restroom by Room 1304- middle	sink		<2
315-019	girls restroom by Room 1304- right	sink		<2
315-020	Nurse Room 1303	sink		<2
315-021	Nurse Room 1303 restroom	sink		<2
315-022	room 1311	sink		<2
315-023	hallway by Room 1314	drinking fountain		<2
315-024	room 1314 restroom	sink		<2
315-025	room 1403 left	sink		<2
315-026	room 1403 right	sink		<2
315-027	girls restroom by Room 1405 left	sink		<2
315-028	girls restroom by Room 1405 right	sink		<2
315-029	Room 1405	sink		<2
315-030	Room 1407	sink		<2
315-031	hallway by Room 1405 left	water cooler		<2
315-032	hallway by Room 1405 right	water cooler		<2
315-033	boys restroom by Room 1405 left	sink		<2
315-034	boys restroom by Room 1405 right	sink		<2
315-035	Room 1406 maintenance	utility sink		<2
315-036	room 1409 left	sink		<2
315-037	room 1409 right	sink		<2
315-038	room 1402	sink		<2
315-039	hallway by Room 2312	drinking fountain		<2
315-040	room 2312 restroom	sink		<2
315-041	room 2303 office restroom	sink		n/a
315-042	boys room by Room 2304 left	sink		<2
315-043	boys room by Room 2304 middle	sink		<2
315-044	boys room by Room 2304 right	sink		<2
315-045	hallway by boys restroom by Room 2304	drinking fountain		<2

315-046	girls restroom by Room 2102 left	sink		4
315-047	girls restroom by Room 2102 middle	sink		<2
315-048	girls restroom by Room 2102 right	sink		<2
315-049	room 2102 corner	sink		<2
315-050	room 2202 east wall	sink		<2
315-051	Room 2202 southeast wall	sink		n/a
315-052	room 2202A	sink		<2
315-053	room 2203 custodial	utility sink		3
315-054	north 2202- east wall	sink		<2
315-055	room 2206	sink		<2
315-056	hallway by Room 3312	drinking fountain		<2
315-057	room 3306A	sink		<2
315-058	boys restroom by Room 3303 left	sink		<2
315-059	boys restroom by Room 3303 middle	sink		<2
315-060	boys restroom by Room 3303 right	sink		<2
315-061	hallway by Room 3303	drinking fountain		<2
315-062	girls restroom by Room 3104 left	sink		<2
315-063	girls restroom by Room 3104 middle	sink		<2
315-064	girls restroom by Room 3104 right	sink		<2
315-065	room 3104 - teacher workstation	sink		<2
315-066	room 3202 prep room	sink		<2
315-067	room 3202 - north center west	sink		n/a
315-068	room 3202 teacher workstation	sink		<2
315-069	staff restroom by Room 3205 left	sink		<2
315-070	staff restroom by Room 3205 right	sink		<2
315-071	room 3204 custodial	utility sink		<2
315-072	west gym entry by Room 0402	water cooler		<2
315-073	room 0402 restroom	sink		<2
315-074	room 0404 girls locker room left	sink		<2
315-075	room 0404 girls locker room right	sink		<2
315-076	room 0407 restroom	sink		<2
315-077	room 0406 left	water cooler		<2
315-078	room 0406 right	water cooler	Pace? Part of double unit.	<2
315-079	room 0408 left	sink		<2
315-080	room 0408 right	sink		<2
315-081	hallway by Room 0407 left	water cooler		<2
315-082	hallway by Room 0407 right	water cooler		<2
315-083	Room 0409 maintenance	utility sink		<2
315-084	Room 0410 boys restroom left	sink		<2
315-085	Room 0410 boys restroom right	sink		<2
315-086	Room 0405 boys locker room left	sink		<2
315-087	Room 0405 boys locker room right	sink		<2
315-088	Room 0403 restroom	sink		<2
315-089	Room 0303	sink		<2

**Saint Paul Public Schools
Water Sample Results
Hazel Park
Building Number: 325**

Sample Date: August 28th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample #	Location	Fixture Type	Comments	Sample Results 2020
325-001	Room 2322	sink		<2
325-002	Room 2321	sink	Flush ID:Pb-204	<2
325-003	Boy's Restroom- across from rm 2321- north	sink		4
325-004	Boy's Restroom- across from rm 2321- south	sink		<2
325-005	Boy's Restroom- across from rm 2321- s.w	sink		<2
325-006	Boy's Restroom- across from rm 2321- w	sink		<2
325-007	Boy's Restroom- across from rm 2321-n.west	sink		<2
325-008	Girl's Restroom-across from rm 2317-south	sink		<2
325-009	Girl's Restroom-across from rm 2317-north	sink		<2
325-010	Girl's Restroom-across from rm 2317-s.w	sink	NO SAMPLE- NO COLD WATER	<2
325-011	Girl's Restroom-across from rm 2317-n.w	sink		<2
325-012	Room 2320- left	sink	Flush ID: pb-205 PACE	
325-013	Room 2320- right	sink	Flush ID: pb-206	
325-014	Room 2319	sink	NO SAMPLE-NO WATER	
325-015	Drinking fountain across from rm 2319	fountain	PACE	<2
325-016	Room 2318- left		NO SAMPLE-NO WATER FIXTURE	
325-017	Room 2318- right	sink	Flush ID: pb-207 PACE	
325-018	Room 2317- west	sink	NO SAMPLE- NO WATER	

325-019	Room 2317- east	sink	NO SAMPLE- NO WATER	
325-020	Room 2317- s.e	sink		<2
325-021	Room 2315- west	sink		<2
325-022	Room 2315- east	sink		<2
325-023	Room 2315- s.e	sink		<2
325-024	Room 2314- left	sink	NO SAMPLE- NO COLD WATER	6
325-025	Room 2314- right	sink	NO SAMPLE- NO COLD WATER	<2
325-026	Room 2313- west	sink	NO SAMPLE- NO WATER	n/a
325-027	Room 2313- east	sink		<2
325-028	Room 2313- east(central)	sink		n/a
325-029	Room 2313- east(south)	sink		<2
325-030	Room 2313- s.e	sink		n/a
325-031	Room 2313- south	sink		n/a
325-032	Room 2313- s.w	sink		<2
325-033	Room 2308A	sink		7
325-034	Room 2311- n.w	sink		<2
325-035	Room 2311- n.e	sink		<2
325-036	Room 2311- east	sink		n/a
325-037	Room 2311- east(south)	sink		<2
325-038	Room 2311- s.e	sink		15
325-039	Room 2311- south	sink		<2
325-040	Room 2311- west	sink		<2
325-041	Room 2309- n.w	sink		<2
325-042	Room 2309- n.e	sink	NO SAMPLE- NO WATER	n/a
325-043	Room 2309- s.e	sink		n/a
325-044	Room 2304/2306 Restroom	sink		<2
325-045	Room 2307	sink		<2
325-046	Room 2305	sink	NO SAMPLE- NO WATER	n/a
325-047	Boy's Restroom across from rm 2305- south	sink		n/a
325-048	Boy's Restroom across from rm 2305- north	sink		<2
325-049	Room 2303	sink		<2
325-050	Girl's Restroom across from rm 2301- s.w	sink		3
325-051	Girl's Restroom across from rm 2301- n.w	sink		<2
325-052	Girl's Restroom across from rm 2301- south	sink		<2
325-053	Girl's Restroom across from rm 2301- north	sink		<2
325-054	Girl's Restroom across from rm 2301- n.e	sink		n/a
325-055	Custodial Closet 2300A	slop		<2
325-056	Drinking Fountain across from rm 2303	fountain	NO SAMPLE- NOT WORKING	<2
325-057	Drinking Fountain across from rm 2307	cooler	PACE	<2
325-058	Room 1321	sink	NO SAMPLE- NO WATER	<2
325-059	Boy's Restroom across from rm 1321- west	sink		<2
325-060	Boy's Restroom across from rm 1321- east	sink		11
325-061	Drinking Fountain across from rm 1319	fountain	PACE	<2
325-062	Room 1319/1319A	sink		9
325-063	Girl's Restroom across from 1319/1319A- south	sink		<2
325-064	Girl's Restroom across from 1319/1319A- north	sink		<2
325-065	Girl's Restroom across from 1319/1319A- s.w	sink		30
325-066	Girls's Restroom across from 1319/1319A- n.w	sink		<2
325-067	Room 1317/1317A	sink		<2
325-068	Room 1316- left	sink		<2
325-069	Room 1316- right	sink		<2
325-070	Room 1315	sink		<2
325-071	Room 1313	sink		<2
325-072	Room 1312A- left	sink		<2
325-073	Room 1312A- right	sink		<2
325-074	Room 1311	sink	NO SAMPLE- NO WATER	<2
325-075	Room 1310	sink		<2
325-076	Room 1310 Restroom	sink		<2
325-077	Room 1309 Restroom	sink		<2
325-078	Drinking Fountain across from rm 1307	fountain	PACE	4
325-079	Drinking Fountain across from rm 1307	cooler	PACE	<2
325-080	Room 1308	sink		<2
325-081	Room 1308 Restroom	sink		<2
325-082	Room 1307 Restroom	sink		<2
325-083	Room 1306- left	sink		n/a

325-084	Room 1306- right	sink	NO SAMPLE- NO WATER	<2
325-085	Room 1305 Restroom	sink		<2
325-086	Boy's Restroom across from rm 1305- west	sink	Flush ID: pb-208	<2
325-087	Boy's Restroom across from rm 1305- east	sink		<2
325-088	Drinking Fountain across from rm 1305	fountain	PACE	<2
325-089	Girl's Restroom across from rm 1301- west	sink		<2
325-090	Girl's Restroom across from rm 1301- east	sink		<2
325-091	Room 1302- s.w	sink	NO SAMPLE- NO COLD WATER	<2
325-092	Room 1302- west	sink		<2
325-093	Room 1302- n.w	sink		<2
325-094	Room 1302- s.e	sink		<2
325-095	Room 1302- east	sink		<2
325-096	Room 1302- n.e	sink		<2
325-097	Room 1402- workroom off media center	sink		<2
325-098	Room 1206- Maintenance	sink		<2
325-099	Room 1206- Maintenance	slop	NO SAMPLE- CHEMICALS	<2
325-100	Nurses Office	sink	PACE	<2
325-101	Nurses Office Restroom	sink	PACE	<2
325-102	Room 1201 Restroom	sink		n/a
325-103	Restroom outside Room 1202	sink		<2
325-104	Boy's Restroom- across from gym 1107- left	sink		<2
325-105	Boy's Restroom-across from gym 1107- right	sink		<2
325-106	Girl's restroom- across from gym 1107- left	sink		<2
325-107	Girl's restroom- across from gym 1107- right	sink	NO SAMPLE- NO COLD WATER	<2
325-108	Drinking Fountain between restrooms by 1107	cooler	PACE	<2
325-109	Boiler Room- sink off office	sink		n/a
325-110	Cafeteria- drinking fountain	cooler	PACE	<2
325-111	Kitchen- Hand Sink	sink	PACE	<2
325-112	Kitchen-left	sink	NO SAMPLE- TAPED OFF	n/a
325-113	Kitchen-middle	sink	PACE	<2
325-114	Kitchen-right	sink	PACE	<2
325-115	Rm 1109- Boy's Locker Room- drink fountain	fountain	NO SAMPLE- NO WATER	<2
325-116	Rm 1109- Boy's Locker Room- sink	sink		<2
325-117	Rm 1108- Boy's Locker Rm office	sink		<2
325-118	Rm 1106- Girl's Locker Rm Office	sink		<2
325-119	Rm 1105- Girl's Locker Rm	sink		<2
325-120	Rm 1105- Girl's Locker Rm- drink fountain	fountain	PACE	<2

**Saint Paul Public Schools
Water Sample Results
L'Etoile du Nord Lower
Building Number: 542**

Sample Date: July 28th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample #	Location	Fixture Type	Comments	Sample Results 2020
542-001	Kitchen 1104 West Wall - Left	Sink		<2
542-002	Kitchen 1104 West Wall - Right	Sink		<2
542-003	Kitchen 1104	Hand Sink		2
542-004	Kitchen 1104	Bunn Machine		<2
542-005	Kitchen Restroom 1104B	Sink		6
542-006	Cafeteria Custodial Utility Sink	Utility Sink		<2
542-007	Staff Restroom Across From Gym	Sink		<2
542-008	Girls Restroom by Gym - Left	Sink		<2
542-009	Girls Restroom by Gym - Middle	Sink		<2
542-010	Girls Restroom by Gym - Right	Sink		<2
542-011	Boys Restroom by Gym - Left	Sink		<2
542-012	Boys Restroom by Gym - Middle	Sink		<2
542-013	Boys Restroom by Gym - Right	Sink		<2
542-014	Hallway by Room 1202	Drinking Fountain		<2
542-015	Custodial Room 1201	Utility Sink		<2
542-016	Room 1203	Sink		<2
542-017	Room 1203	Drinking Fountain		<2
542-018	Room 1204	Sink		<2
542-019	Room 1204	Drinking Fountain		<2
542-020	Room 1205	Sink		<2
542-021	Room 1205	Drinking Fountain		<2
542-022	Room 1205 Restroom	Sink		<2

542-023	Room 1206	Sink		<2
542-024	Room 1206 Restroom	Sink		<2
542-025	Custodial Room 1209	Utility Sink		<2
542-026	Boys Restroom by Room 1206 - Right	Sink		<2
542-027	Girlst Restroom by Room 1205 - Left	Sink		<2
542-028	Girlst Restroom by Room 1205 - Right	Sink		<2
542-029	Hallway by Room 1206 - Left	Drinking Fountain		<2
542-030	Hallway by Room 1206 - Right	Drinking Fountain		<2
542-031	Room 1301	Sink		<2
542-032	Room 1302	Sink		<2
542-033	Room 1303	Sink		<2
542-034	Room 1304	Sink		<2
542-035	Room 1305	Sink		<2
542-036	Room 1306	Sink		<2
542-037	Girls Restroom by Room 1013	Sink		<2
542-038	Boys Restroom by Room 1013	Sink		<2
542-039	Hallway by Room 1013	Water Cooler		<2
542-040	Main Office Restroom by 1008	Sink		<2
542-041	Nurse 1002	Sink		<2
542-042	Nurse Restroom 1003A	Sink		<2
542-043	Room 1101	Sink		<2
542-044	Room 1101 Restroom	Sink		<2
542-045	Room 1102	Sink		<2
542-046	Room 1102	Drinking Fountain	broken	n/a
542-047	Room 1102 Restroom	Sink		<2
542-048	Basement Restroom	Sink		<2
542-049	Basement Room 0110	Utility Sink		<2
542-050	Basement Room 0108	Sink		<2
542-051	Kitchen Sprayer	sink		<2
542-052	1203 Bathroom	sink		<2
542-053	1204 Restroom	sink		<2
542-054	Boys Restroom left	sink		<2
542-055	1011 Custodial	sink		<2
542-056	1101 fountain	Drinking Fountain		<2
542-057	Cafeteria Hydration Station	Drinking Fountain		<2

**Saint Paul Public Schools
Water Sample Results
L'Etoile du Nord Upper
Building Number: 413**

Sample Date: July 28th, 2020
Sampled by: Ally Peters, Brenda Kappel, Chelsea Moody, Tod Eckberg

Sample #	Location	Fixture Type	Comments	Sample Results 2020
413-001	Gym 1221 - WC	Water Cooler		2
413-002	Boys' Bathroom 1224 - SNK	Sink		4
413-003	Girls' Bathroom 1222 - SNK	Sink		<2
413-004	1223 Janitor's Closet - SNK	Sink		<2
413-005	1201B Dishroom - SNK	Sink		<2
413-006	1201B Dishroom - KS	Kitchen Sink	Sprayer	<2
413-007	Cafeteria 1201 - WC	Water Cooler		<2
413-008	1201 Kitchen (left) - KS	Kitchen Sink		3
413-009	1201 A Kitchen (right) - KS	Kitchen Sink		<2
413-010	1201 A Kitchen (handwashing) - SNK	Sink		2
413-011	1201 A Kitchen (bunn) - Bunn	Bunn	ould not test due to temperatu	-
413-012	1105 Break room - SNK	Sink		<2
413-013	0102 Mechanical - SNK	Sink		<2
413-014	1107C Bathroom - SNK	Sink		<2
413-015	Hallway 1100 - WC	Water Cooler		3
413-016	1109A Restroom - SNK	Sink		<2
413-017	1111 Nurse's Room - SNK	Sink		<2
413-018	1111A Nurse's Restroom - SNK	Sink		<2
413-019	1113 Custodial - SNK	Sink		<2
413-020	Room 2107 - SNK	Sink		<2
413-021	2103A Bathroom - SNK	Sink		7
413-022	Hallway 2100 - WC	Water Cooler		<2
413-023	2105A Restroom - SNK	Sink		<2
413-024	2101 - SNK	Sink		<2
413-025	Room 2202 - SNK	Sink		<2
413-026	Room 2202A - SNK	Sink		<2
413-027	2206 Girl's Restroom (left) - SNK	Sink		<2
413-028	2206 Girl's Restroom (center) - SNK	Sink		<2
413-029	2206 Girl's Restroom (right) - SNK	Sink		<2
413-030	2208 Custodial/Storage - SNK	Sink		<2

413-031	2210 Boy's Restroom (left) - SNK	Sink		<2
413-032	2210 Boy's Restroom (center) - SNK	Sink		<2
413-033	2210 Boy's Restroom (right) - SNK	Sink		2
413-034	Room 2212 - SNK	Sink		<2
413-035	Room 2215 - SNK	Sink		<2
413-036	Next to 2216 - WC	Water Cooler		<2
413-037	Room 2216 - SNK	Sink		<2
413-038	Room 2217 - SNK	Sink		<2
413-039	Room 2218 - SNK	Sink		<2
413-040	Hallway 3100 - WC	Water Cooler		<2
413-041	Room 3105 - SNK	Sink		2
413-042	Room 3101 - SNK	Sink		<2
413-043	Hallway 3200 by stairs (left) - WC	Water Cooler		<2
413-044	Hallway 3200 by stairs (right) - WC	Water Cooler		<2
413-045	3206 Girl's Restroom (left) - SNK	Sink		<2
413-046	3206 Girl's Restroom (left center) - SNK	Sink		<2
413-047	3206 Girl's Restroom (right center) - SNK	Sink		<2
413-048	3206 Girl's Restroom (right) - SNK	Sink		<2
413-049	3208 Custodial/Storage - SNK	Sink		<2
413-050	3210 Boy's Restroom (left) - SNK	Sink		6
413-051	3210 Boy's Restroom (left Center) - SNK	Sink		3
413-052	3210 Boy's Restroom (Right Center) - SNK	Sink		<2
413-053	3210 Boy's Restroom (Right) - SNK	Sink		5
413-054	Room 3215 - SNK	Sink		<2
413-055	Next to Room 3216 - WC	Water Cooler		<2
413-056	Room 3216 - SNK	Sink		<2
413-057	Room 3217 - SNK	Sink		<2
413-058	Room 3218 - SNK	Sink		<2

Saint Paul Public Schools
2020 Water Sample Results
Nokomis North Montessori
Building Number: 533

Sample Date: 7/22/2020
Sampled by: Tod, Chelsea, Ally, Brenda

Sample #	Location	Sample Results 2020	Flush Sample	Fixture Type
533-001	Hydration Station Cafeteria	below 2ppb		fountain
533-002	2202A 2nd Flr Girls Restroom Left	below 2ppb		sink
533-003	2202A 2nd Flr Girls Restroom Right	below 2ppb		sink
533-004	2202B 2nd Flr Boys Restroom Left	below 2ppb		sink
533-005	2202B 2nd Flr Boys Restroom Right	below 2ppb		sink
533-006	2203	below 2ppb		sink
533-007	2204	below 2ppb		sink
533-008	2205	below 2ppb		sink
533-009	2206	below 2ppb		sink
533-010	2nd floor outside 2207	below 2ppb		fountain
533-011	2206	below 2ppb		sink
533-012	2208	below 2ppb		sink
533-013	2208A 2nd Flr Staff Bathroom	below 2ppb		sink
533-014	2208B 2nd Flr Custodial Closet	below 2ppb		slop sink
533-015	1202A Girls Restroom-Left	below 2ppb		sink
533-016	1202A Girls Restroom-Right	below 2ppb		sink
533-017	1202B Boys Restroom-Left	below 2ppb		sink
533-018	1202B Boys Restroom-Right	below 2ppb		sink
533-019	1106 Custodial Closet	below 2ppb		slop sink
533-020	1203	below 2ppb		sink
533-021	1204	below 2ppb		sink
533-022	outside 1204	below 2ppb		fountain
533-023	1205	below 2ppb		sink
533-024	1206-Left	below 2ppb		sink
533-025	1206-Middle	below 2ppb		sink
533-026	1206-Right	below 2ppb		sink
533-027	1207	below 2ppb		sink
533-028	1208 1st Flr Staff bathroom	below 2ppb		sink
533-029	1301A Storage	below 2ppb		sink
533-030	outside 1303	below 2ppb		fountain
533-031	1303	below 2ppb		sink
533-032	1305A restroom	below 2ppb		sink
533-033	1305	below 2ppb		sink
533-034	1307	below 2ppb		sink
533-035	1307A Restroom	below 2ppb		sink
533-036	1402A Girls Restroom-Left	below 2ppb		sink
533-037	1402A Girls Restroom-Right	below 2ppb		sink

533-038	1402B Boys Restroom-Left	below 2ppb		sink
533-039	1402B Boys Restroom-Right	below 2ppb		sink
533-040	1402	below 2ppb		sink
533-041	1403	below 2ppb		sink
533-042	1404	below 2ppb		sink
533-043	1405	below 2ppb		sink
533-044	1406	below 2ppb		sink
533-045	Gym Left	below 2ppb		fountain
533-046	Gym Right	below 2ppb		fountain
533-047	Kitchen dish sprayer	below 2ppb		sprayer
533-048	Kitchen Utility Sink	below 2ppb		utility sink
533-049	Kitchen handwashing	below 2ppb		hand sink
533-050	1407	below 2ppb		sink
533-051	outside 1407	below 2ppb		fountain
533-052	1105 sink	below 2ppb		sink
533-053	nurse sink	below 2ppb		sink
533-054	nurse bathroom	below 2ppb		sink
533-055	office staff bathroom	below 2ppb		sink
533-056	staff lounge	below 2ppb		sink
533-057	Bunn Machine	5 ppb		bunn

**Saint Paul Public Schools
2020 Water Sample Results
Nokomis South
Building Number: 534**

**Sample Date: 7/22/2020
Sampled by: Tod, Chelsea, Ally**

Sample #	Location	fixture type	Sample Results 2020	15 seconds Flush Sample
534-001	Kitchen Sprayer	sprayer	<2 ppb	
534-002	Kitchen Handsink	sink	39 ppb	<2 ppb flush
534-003	Dish room Left	sink	<2 ppb	
534-004	Dish room Right	sink	<2 ppb	
534-005	Hydration Station Cafeteria	fountain	<2 ppb	
534-006	Storage rm in cafeteria 1402B	slop sink	<2 ppb	
534-007	drinking fountain-gym side	fountain	<2 ppb	
534-008	1305 bathroom	sink	<2 ppb	
534-009	1305	sink	<2 ppb	
534-010	1204	sink	<2 ppb	
534-011	1203	sink	<2 ppb	
534-012	outside 1203-Left	fountain	<2 ppb	
534-013	outside 1203-Right	fountain	<2 ppb	
534-014	1202	sink	<2 ppb	
534-015	front office staff bathroom	sink	<2 ppb	
534-016	Staff Lounge (off library)	sink	<2 ppb	
534-017	2204	sink	<2 ppb	
534-018	Boys Restroom 1st floor left (L to R)	sink	<2 ppb	
534-019	Boys Restroom 1st floor left middle	sink	<2 ppb	
534-020	boys Restroom 1st floor Right Middle	sink	<2 ppb	
534-021	Boys restroom 1st floor right	sink	<2 ppb	
534-022	Girls restroom 1st floor left (L to R)	sink	<2 ppb	
534-023	girls restroom 1st floor left middle	sink	<2 ppb	
534-024	girls restroom 1st floor right middle	sink	<2 ppb	
534-025	girls restroom 1st floor right	sink	<2 ppb	
534-026	2203	sink	<2 ppb	
534-027	2205	sink	<2 ppb	
534-028	outside 2205	fountain	<2 ppb	
534-029	2202	sink	<2 ppb	
534-030	2206	sink	<2 ppb	
534-031	2201	sink	4 ppb	
534-032	2207	sink	<2 ppb	
534-033	2101 Staff Lounge	sink	<2 ppb	
534-034	Staff Bathroom 2nd Floor (by lounge)	sink	<2 ppb	
534-035	outside 2nd Flr South Restrooms-Left	fountain	5 ppb	
534-036	outside 2nd Flr South Restrooms-Right	fountain	<2 ppb	barely works
534-037	2104 2nd Floor South Boys RR-Left (L to R)	sink	<2 ppb	
534-038	2104 2nd Floor South Boys RR-Left Middle	sink	<2 ppb	
534-039	2104 2nd Floor South Boys RR-Right Middle	sink	<2 ppb	
534-040	2104 2nd Floor South Boys RR-Right	sink	<2 ppb	
534-041	2203 2nd Floor South Girls RR-Left	sink	<2 ppb	
534-042	2203 2nd Floor South Girls RR-Left Middle	sink	<2 ppb	
534-043	2203 2nd Floor South Girls RR-Middle	sink	<2 ppb	
534-044	2203 2nd Floor South Girls RR-Right Middle	sink	<2 ppb	

534-045	2203 2nd Floor South Girls RR-Right	sink	<2 ppb	
534-046	1504	sink	<2 ppb	
534-047	1504	fountain	<2 ppb	
534-048	1504 restroom	sink	<2 ppb	
534-049	outside 1502	fountain	<2 ppb	
534-050	1502	sink	<2 ppb	
534-051	1502	fountain	<2 ppb	
534-052	1502 restroom	sink	<2 ppb	
534-053	2302 2nd Floor North Boys RR-Left	sink	<2 ppb	
534-054	2302 2nd Floor North Boys RR-Middle	sink	<2 ppb	
534-055	2302 2nd Floor North Boys RR-Right	sink	<2 ppb	
534-056	2301 2nd Floor North Girls RR-Left	sink	<2 ppb	
534-057	2301 2nd Floor North Girls RR-Middle	sink	<2 ppb	
534-058	2301 2nd Floor North Girls RR-Right	sink	<2 ppb	
534-059	Outside North 2nd Flr Restrooms-Left	fountain	<2 ppb	
534-060	Outside North 2nd Flr Restrooms-Right	fountain	<2 ppb	
534-061	2303 2nd Floor Custodial	slop sink	3 ppb	
534-062	2304	sink	<2 ppb	
534-063	2306	sink	<2 ppb	
534-064	2305	sink	<2 ppb	
534-065	Nurse Sink	sink	<2 ppb	
534-066	Nurse Restroom	sink	<2 ppb	
534-067	Kitchen Bunn Machine		turned off, unable to test	

Saint Paul Public Schools
2020 Water Sample Results
Parkway Middle
Building Number: 538

Sample Date: 8/28/2020
Sampled by: Tod, Chelsea, Ally

Sample #	Location	Fixture Type	2020 Results
538-001	Kitchen - SNK - NW	Sink	<2
538-002	Kitchen - SNK - NE	Sink	<2
538-003	Kitchen - Sprayer - NE	Sprayer	<2
538-004	Kitchen - SNK - NE - Far East	Sink	<2
538-005	Kitchen - SNK - East	Sink	<2
538-006	Cafeteria - WC - Right	Water Cooler	<2
538-007	Cafeteria - WC - Left	Water Cooler	<2
538-008	1300A DF	Drinking Fountain	<2
538-009	Dishwashing room - SNK	Drinking Fountain	<2
538-010	Dishwashing room - KSNK	Sink	<2
538-011	1307 - SNK - Right	Sink	<2
538-012	1307 - SNK - Middle	Sink	<2
538-013	1307 - SNK - Left	Sink	<2
538-014	1306 - SNK	Sink	7
538-015	1305 - SNK - Left	Sink	2
538-016	1305 - SNK - Middle Left	Sink	<2
538-017	1305 - SNK - Middle	Sink	<2
538-018	1305 - SNK - Middle Right	Sink	<2
538-019	1305 - SNK - Right	Sink	<2
538-020	0320 - SNK	Sink	n/a
538-021	1302 hallway WC - Left	Water Cooler	<2
538-022	1302 Hallway WC - Right	Water Cooler	n/a
538-023	1101 - SNK	Sink	3
538-024	1201/1202 DF	Drinking Fountain	7
538-025	1201 SNK	Sink	<2
538-026	1202 - SNK	Sink	<2
538-027	1205 - SNK	Sink	n/a
538-028	1204 - Nurse's SNK	Sink	<2
538-029	1204 - Nurse's DF	Drinking Fountain	<2
538-030	1212 Men's SNK	Sink	<2
538-031	1217 Women's SNK	Sink	<2
538-032	1215 Gym DF	Drinking Fountain	<2
538-033	1120 Women's Left	Sink	<2
538-034	1120 Women's Right	Sink	<2
538-035	1102 SNK	Sink	4
538-036	1100A WC Left	Water Cooler	<2
538-037	1100 WC Right	Water Cooler	<2
538-038	1116 - North SNK	Sink	<2
538-039	1116 - SNK South West	Sink	<2
538-040	1116 - SNK - West	Sink	<2
538-041	1100A - Left - SNK	Sink	<2
538-042	1100A - Middle Left - SNK	Sink	<2
538-043	1100A - Middle - SNK	Sink	<2

538-044	1100A - Middle Right - SNK	Sink	11
538-045	1100A - Right - SNK	Sink	<2
538-046	1109 SE - SNK	Sink	<2
538-047	1109 NW - SNK	Sink	<2
538-048	1109 NE - SNK	Sink	<2
538-049	1109 E - SNK	Sink	<2
538-050	3300 - WC - Left	Water Cooler	<2
538-051	3300 - WC - Right	Water Cooler	<2
538-052	3301 - Production - Snk	Sink	<2
538-053	2300 Hallway Left DF	Drinking Fountain	<2
538-054	2300 Hallway Right DF	Drinking Fountain	<2
538-055	2101 Snk - SE	Sink	<2
538-056	2101 Snk - SW	Sink	<2
538-057	2101 Snk - NW	Sink	<2
538-058	2101 Snk - N	Sink	
538-059	2106 - Snk	Sink	3
538-060	2100D - Snk - Left	Sink	<2
538-061	2100D - Snk - Left middle	Sink	<2
538-062	2100D - Snk - Middle	Sink	<2
538-063	2100D - Snk - Right Middle	Sink	<2
538-064	2100D - Snk - Right	Sink	<2
538-065	2105 - Snk	Sink	5
538-066	2109 - SE - Snk	Sink	<2
538-067	2109 SW - Snk	Sink	<2
538-068	2109 NW - Snk	Sink	<2
538-069	1105 - Snk	Sink	<2

Saint Paul Public Schools
Water Sample Results
Riverview Elementary
Building Number: 554

Sample Date: 10/13/2020
Sampled by: Tod, Chelsea, Max

Sample #	Location	Fixture Type	Sample Result 2020
554-001	Classroom 3201 - Far Left	Sink	<2ppb
554-002	Classroom 3201 - Left	Fountain	<2ppb
554-003	Classroom 3201 - Middle	Sink	<2ppb
554-004	Classroom 3201 - Right	Fountain	<2ppb
554-005	Classroom 3201 - Far Right	Sink	<2ppb
554-006	Classroom 3201 - Farthest Right	Cooler	<2ppb
554-007	3rd Flr West Men's Restroom - Left	Sink	<2ppb
554-008	3rd Flr West Men's Restroom - Middle	Sink	<2ppb
554-009	3rd Flr West Men's Restroom - Right	Sink	<2ppb
554-010	Hydration Station - Hall- Left	Hydra	<2ppb
554-011	Hydration Station - Hall -Right	Fountain	<2ppb
554-012	3rd Flr Women's Restroom -Left	Sink	<2ppb
554-013	3rd Flr Women's Restroom -Middle	Sink	<2ppb
554-014	3rd Flr Women's Restroom - Right	Sink	<2ppb
554-015	Room 3109 -Left	Sink	<2ppb
554-016	Room 3109 - Middle Left	Fountain	<2ppb
554-017	Room 3109 - Middle Right	Sink	<2ppb
554-018	Room 3109 - Right	Fountain	<2ppb
554-019	Gym 3114 - Left	Hydra	<2ppb
554-020	Gym 3114 - Right	Sink	3ppb
554-021	Unisex RR East Gym Entrance	Sink	<2ppb
554-022	Room 3111 - Left	Sink	<2ppb
554-023	Room 3111 - Middle Left	Fountain	<2ppb
554-024	Room 3111 - Middle Right	Sink	<2ppb
554-025	Room 3111 - Left	Fountain	<2ppb
554-026	3rd Flr East Women's RR - Left	Sink	<2ppb
554-027	3rd Flr East Women's RR - Middle	Sink	<2ppb
554-028	3rd Flr East Women's RR - Right	Sink	<2ppb
554-029	Hydration Station - Hall East - Left	Hyrda	<2ppb
554-030	Hydration Station - Hall East -Right	Hydra	<2ppb
554-031	3rd Flr East Men's RR - Left	Sink	<2ppb
554-032	3rd Flr East Men's RR - Middle	Sink	<2ppb
554-033	3rd Flr East Men's RR - Right	Sink	7ppb
554-034	Room 2205 Faculty Lounge	Sink	<2ppb
554-035	Room 2205 Faculty Lounge	Fountain	<2ppb
554-036	Room 2205 Faculty Lounge RR	Sink	<2ppb
554-037	Room 2205 Faculty Lounge	Cooler	Sink
554-038	2nd Flr West Men's Restroom - Left	Sink	Sink
554-039	2nd Flr West Men's Restroom - Middle	Sink	Sink
554-040	2nd Flr West Men's Restroom - Right	Sink	Sink

554-041	Hydration Station - Hall - Left	Hydra	Sink
554-042	Hall - Right	Hydra	Sink
554-043	2nd Flr West Women's Restroom- Left	Sink	Sink
554-044	2nd Flr West Women's Restroom- Middle	Sink	Sink
554-045	2nd Flr West Women's Restroom - Right	Sink	Sink
554-046	2nd Flr East Women's Restroom - Left	Sink	Sink
554-047	2nd Flr East Women's Restroom - Middle	Sink	Sink
554-048	2nd Flr East Women's Restroom - Right	Sink	Sink
554-049	Hydration Station - Hall - Left	Hydra	Sink
554-050	Hall - Right	Hydra	Sink
554-051	2nd Flr Men's Restroom - Left	Sink	Sink
554-052	2nd Flr Men's Restroom - Middle	Sink	N/A
554-053	2nd Flr Men's Restroom - Right	Sink	N/A
554-054	Room 1207	Sink	<2ppb
554-055	Room 1207	Fountain	Sink
554-056	Room 1207	Restroom	Sink
554-057	Room 1206	Sink	Sink
554-058	Room 1206	Fountain	Sink
554-059	Room 1206	Restroom	Sink
554-060	Unisex Restroom	Sink	Sink
554-061	Room 1204	Sink	Sink
554-062	Room 1204	Fountain	Sink
554-063	Room 1204	Restroom	Sink
554-064	Room 1202	Sink	Sink
554-065	Room 1202	Fountain	Sink
554-066	Room 1202	Restroom	7 ppb
554-067	Room 1201	Sink	<2ppb
554-068	Room 1201	Fountain	Sink
554-069	Room 1201	Restroom	Sink
554-070	Hall by Room 1205	Cooler	6ppb
554-071	Nurse Room 1001	Sink	<2ppb
554-072	Nurse Room 1001 Restroom	Sink	<2ppb
554-073	Hall by Cafeteria - Left	Cooler	off
554-074	Hall by Cafeteria - Right	Cooler	off
554-075	Dish Room 1106 - Left	Large Sink	<2ppb
554-076	Dish Room 1106- Middle sprayer	Large Sink	off
554-077	Dish Room 1106- Right hand sink	Hand Sink	<2ppb
554-078	Kitchen Rm 1108 West	Hand Sink	<2ppb
554-079	Kitchen Rm 1108 South Wall	Large Sink	<2ppb
554-080	Kitchen Rm 1108 Bunn	Bunn	off
554-081	Hydration Station - Cafeteria - Left	Hydra	<2ppb
554-082	Hydration Station - Cafeteria - Right	Hydra	3ppb
554-083	1st Flr Women's East Restroom - Left	Sink	Drinking Fountain
554-084	1st Flr Women's East Restroom - Middle	Sink	Drinking Fountain
554-085	1st Flr Women's East Restroom - Right	Sink	Drinking Fountain
554-086	Hallway	Cooler	Drinking Fountain
554-087	1st Flr Men's Restroom - Left	Sink	Drinking Fountain
554-088	1st Flr Men's Restroom - Middle	Sink	Drinking Fountain
554-089	1st Flr Men's Restroom - Right	Sink	Drinking Fountain
554-090	Room 1301	Sink	Drinking Fountain
554-091	Room 1301	Fountain	Drinking Fountain
554-092	Room 1301	Restroom	Drinking Fountain
554-093	Room 1302	Sink	Drinking Fountain
554-094	Room 1302	Fountain	8ppb
554-095	Room 1302	Restroom	N/A
554-096	Room 1304	Sink	Sink
554-097	Room 1304	Fountain	Sink
554-098	Room 1306	Sink	Sink
554-099	Room 1306	Fountain	Sink
554-100	Room 1308	Sink	Sink
554-101	Room 1308	Fountain	Sink
554-102	Boiler Room - Slop Stick	Hose Bib	10ppb
554-103	Room 1118 Maintenance closet	sink	<2ppb

Saint Paul Public Schools
Water Sample Results
The Heights
Building Number: 488

Sample Date: 7/28/2020
Sampled by: Tod, Chelsea, Ally, Brenda

Sample #	Location	Fixture Type	Comments	Sample Results 2020	flush
488-001	Restroom in Main Office	Sink		<2	
488-002	Kitchen in Admin Office	Sink		<2	

488-003	Nurse's Office	Sink		<2	
488-004	Restroom off Nurse's Office	Sink		<2	
488-005	Kindergarten Rm 2102	Sink		<2	
488-006	Kindergarten Rm 2102	Fountain		<2	
488-007	Restroom in Rm 2102	Sink		<2	
488-008	Kindergarten Rm 2104	Sink		<2	
488-009	Kindergarten Rm 2104	Fountain		<2	
488-010	Restroom in Rm 2104	Sink		<2	
488-011	Outside Rm 2109	Cooler		<2	
488-012	Room 2109	Sink		<2	
488-013	Outside Rm 2111	Fountain		<2	
488-014	Room 2111	Sink		<2	
488-015	Room 2113	Sink		<2	
488-016	Room 2115	Sink		<2	
488-017	Room 2114	Sink		<2	
488-018	Room 2114 Restroom	Sink		<2	
488-019	Room 1111	Sink		<2	
488-020	Room 1116	Sink		<2	
488-021	Room 1114	Sink		42	<2
488-022	Room 1109			<2	
488-023	Room 1108	Sink		2	
488-024	Cafe 1110	Fountain		<2	
488-025	Kitchen 1102 - Left	Large Sink		<2	
488-026	Kitchen 1102 - Right	Large Sink		<2	
488-027	Kitchen 1102 - Hand Sink	Sink		<2	
488-028	Kitchen 1102 - Bunn	Bunn		<2	
488-029	Hall by 1107 -	Fountain		<2	
488-030	Room 1107	Sink		<2	
488-031	Hall by 1102	Sink	pled sink on left- more than 1	<2	
488-032	Hall by 1105	Cooler		<2	
488-033	Room 1105	Sink		<2	
488-034	Storage 1101	Utility Sink		<2	
488-035	Room 4244	Sink		<2	
488-036	Room 4245	Sink		<2	
488-037	Room 4250 - Left	Sink	only water on right(038)	n/a	
488-038	Room 4250 - Right	Sink		12	
488-039	Room 4250	Fountain		n/a	
488-040	Boy's Restroom - Left	Sink		<2	
488-041	Boy's Restroom - Right	Sink		<2	
488-042	Hall by 4251 - Left	Fountain		<2	
488-043	Hall by 4251 - Right	Fountain	no water	n/a	
488-044	4251 Custodial	Utility Sink		<2	
488-045	Girl's Restroom - Left	Sink		<2	
488-046	Girl's Restroom - Right	Sink		<2	
488-047	Room 4252	Sink		5	
488-048	Room 4252	Fountain		<2	
488-049	Room 4257 Restroom	Sink		<2	
488-050	Custodial Room by 4257	Utility Sink		<2	
488-051	Hall by 4257	Cooler		<2	
488-052	Room 3244	Sink		<2	
488-053	Room 3243	Sink		<2	
488-054	Custodial 3249	Utility Sink		<2	
488-055	Hall by 3249	Cooler		<2	
488-056	Girl's Restroom - Left	Sink		3	
488-057	Girl's Restroom - Right	Sink		15	
488-058	Room 3251 Restroom	Sink		7	
488-059	Custodial by 3257	Utility Sink		<2	
488-060	Boy's Restroom - Left	Sink		<2	
488-061	Boy's Restroom - Right	Sink		<2	
488-062	Hall by 3257 - Left	Fountain		<2	
488-063	Hall by 3257 - Right	Fountain		<2	
488-064	Room 2244	Sink		<2	
488-065	Room 2245 - Left	Sink		<2	
488-066	Room 2245 - Middle	Sink		<2	
488-067	Room 2245 - Right	Sink		46	<2
488-068	Room 2245 - Restroom	Sink		<2	
488-069	Custodial 2249	Utility Sink		<2	
488-070	Boy's Restroom - Left	Sink		<2	
488-071	Boy's Restroom - Right	Sink		<2	
488-072	Hall by 2249	Cooler	No cooler	<2	
488-073	Hall by 2255 - Left	Fountain		<2	
488-074	Hall by 2255 - Right	Fountain		<2	
488-075	Girl's Restroom - Left	Sink		<2	

488-076	Girl's Restroom - Right	Sink		<2	
488-077	Custodial by 2255	Utility Sink		<2	
488-078	Room 2255	Sink		<2	
488-079	Men's Restroom 1349	Sink		<2	
488-080	Outside Gym 1251	Cooler		<2	
488-081	Women's Shower Room by Music	Sink		<2	
488-082	Women's Restroom by Music	Sink		<2	
488-083	Music Room	Utility Sink		<2	
488-084	Boiler Room 1351	Utility Sink	2nd draw- same sink as(085)	<2	
488-085	Boiler Room - First Draw	Utility Sink		<2	