

**Saint Paul Public Schools
Water Sample Results
Farnsworth Lower
Building Number: 458**

**Sample Date: April 17, 2016
Sampled by: Parker Prose & Kegan Silonis**

Sample #	Location	Sample Results 2016	15 seconds Flush Sample	Fixture Type
458-001	Kitchen - NE corner - Left	12		Large Sink
458-001.5	Kitchen - Restroom	6		Sink
458-002	Kitchen - NE corner - Right	0		Large Sink
458-003	Kitchen	0		Hand Sink
458-004	Kitchen - Bunn Machine	0		Sink
458-005	Rm 108	0		Sink
458-006	Rm 108	5		Fountain
458-007	Rm 107	23	11	Sink
458-008	Rm 107	5		Fountain
458-009	Rm 106	0		Sink
458-010	Rm 106	6		Fountain
458-011	First Floor Hallway North	15		Cooler
458-012	Nurse's Office	5		Sink
458-013	Nurse's Office	4		Fountain
458-014	Restroom off Nurse's cot Room	20		Sink
458-015	Admin Office	10		Sink
458-016	First Floor Hallway South	22	20	Cooler
458-017	Room 105	16		Sink
458-018	Room 105	0		Fountain
458-019	Room 104	4		Sink
458-020	Room 104	6		Fountain
458-021	Room 103	7		Sink
458-022	Room 103	6		Fountain
458-023	Room 102	8		Sink
458-024	Room 102	8		Fountain
458-025	Room 101	0		Sink
458-026	Room 101	33	11	Fountain
458-027	First Floor Janitor's Closet	10		Utility Sink
458-028	Rm 206 - Left	0		Sink
458-029	Rm 206 - Right	6		Sink
458-030	IMC Workroom	20	8	Sink
458-031	Outside Media Center - North			Cooler
458-032	Outside Media Center - South	18		Cooler
458-033	Second floor Janitor's Closet	14		Utility Sink
458-033.5	Second floor Janitor's Closet	0		Utility Sink
458-034	Science Rm 201 - Left	19		Sink
458-035	Science Rm 201 - Left Middle	16		Sink
458-036	Science Rm 201 - Right Middle	4		Sink
458-037	Science Rm 201 - right	7		Sink
458-038	Second floor girl's restroom - L	4		Sink
458-039	Second floor girl's restroom - LM	0		Sink
458-040	Second floor girl's restroom - Midd	8		Sink
458-040.5	Second floor girl's restroom -Midd	19		Sink
458-041	Second floor girl's restroom - RM	0		Sink
458-042	Second floor girl's restroom - Right	0		Sink
458-043	Second floor boy's restroom - Left	0		Sink
458-044	Second floor boy's restroom - Middle	5		Sink
458-045	Second floor boy's restroom - Right	0		Sink
458-046	Staff Room	0		Sink
458-046.5	Staff Restroom	0		Sink
458-047	Room 313	0		Sink
458-048	Room 310	0		Sink
458-049	Outside Rm 308	0		Cooler
458-050	Outside Rm 306	0		Cooler
458-051	Third Floor Janitor's Closet	3		Utility Sink
458-052	Third Floor Girl's Restroom - Left	10		Sink
458-053	Third Floor Girl's Restroom - LM	0		Sink
458-054	Third Floor Girl's Restroom - Middle	0		Sink
458-055	Third Floor Girl's Restroom - RM	2		Sink
458-056	Third Floor Girl's Restroom - Right	0		Sink
458-057	Third Floor Boy's Restroom - Left	0		Sink
458-058	Third Floor Boy's Restroom - Middle	0		Sink
458-059	Third Floor Boy's Restroom - Right	6		Sink
458-060	Custodial Office Utility Sink	0		Utility Sink
458-061	Custodial Office Restroom	0		Sink
458-062	Custodial Office - First Draw	0		Utility Sink
458-063	Outside Room 1301B Hallway	0		Fountain

**Saint Paul Public Schools
Water Sample Results
Frost Lake
Building Number: 464**

**Sample Date: 4/17/2016
Sampled by: Natalie Eskew & Kobe Patch**

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
464-001	Kitchen - Left	<2ppb		Large Sink
464-002	Kitchen - Right	<2ppb		Large Sink

464-003	Kitchen Hand Sink	<2ppb		Hand Sink
464-004	Kitchen Bunn Machine	PACE		Bunn
464-005	Kitchen Janitor's Closet - 1526A	Skipped		Utility Sink
464-006	Rec Cntr Men's Restroom 1505	<2ppb		Sink
464-007	Rec Cntr. Between Restrooms	3ppb		Fountain
464-008	Rec Cntr. H. C. Accessable restroom 1503	Skipped		Sink
464-009	Rec Cntr. Janitor's Closet by 1503	<2ppb		Utility Sink
464-010	Rec Cntr. Women's Restroom 1501	<2ppb		Sink
464-011	Rec Cntr. Kitchen 1502	<2ppb		Sink
464-012	Room 1315	<2ppb		Sink
464-013	Room 1315	<2ppb		Fountain
464-014	Room 1257	<2ppb		Sink
464-015	Room 1257	5ppb		Fountain
464-016	Room 1313	4ppb		Sink
464-017	Room 1313	<2ppb		Fountain
464-018	Room 1311	<2ppb		Sink
464-019	Room 1311	<2ppb		Fountain
464-020	Hallway by Room 1309	<2ppb		Fountain
464-021	Room 1309	<2ppb		Sink
464-022	Room 1309	<2ppb		Fountain
464-023	Room 1307	<2ppb		Sink
464-024	Room 1307	<2ppb		Fountain
464-025	Room 1305	<2ppb		Sink
464-026	Room 1305	<2ppb		Fountain
464-027	Room 1303	<2ppb		Sink
464-028	Room 1303	<2ppb		Fountain
464-029	Room 1303 Restroom	<2ppb		Sink
464-030	Nurse's Restroom	2ppb		Sink
464-031	Nurse's Office	<2ppb		Sink
464-032	Nurse's Office	NA		Fountain
464-033	Main Office Restroom off hallway	3ppb		Sink
464-033.5	Main Office Restroom	NA		Sink
464-034	Main Office Conference Room 1003	<2ppb		Sink
464-034.5	Main Office Conference Room 1003	NA		Sink
464-035	Main Office Conference Room 1003	<2ppb		Fountain
464-035.5	Main Office Conference Room 1003	NA		Fountain
464-036	Main Office 1001	<2ppb		Sink
464-037	Main Office 1001	NA		Fountain
464-038	Staff Lounge 1002	<2ppb		Sink
464-039	Staff Lounge 1002 Restroom	<2ppb		Sink
464-040	Room 1101	<2ppb		Sink
464-041	Room 1101	<2ppb		Fountain
464-042	Room 1103	<2ppb		Sink
464-043	Room 1103	<2ppb		Fountain
464-044	Room 1119	<2ppb		Sink
464-045	Room 1116	<2ppb		Sink
464-046	Room 1116	<2ppb		Fountain
464-047	Room 1121	<2ppb		Sink
464-048	Room 1121	NA		Fountain
464-049	Room 1123	<2ppb		Sink
464-050	Room 1123	NA		Fountain
464-051	Hall cooler by Room 1123	<2ppb		Cooler
464-052	Room 1203	<2ppb		Sink
464-053	Room 1203	<2ppb		Fountain
464-054	Room 1203 Restroom	<2ppb		Sink
464-055	Room 1205	<2ppb		Sink
464-056	Room 1205	<2ppb		Fountain
464-057	Room 1207	<2ppb		Sink
464-058	Room 1207	<2ppb		Fountain
464-059	Room 1209	5ppb		Sink
464-060	Room 1209	<2ppb		Fountain
464-061	Hallway by room 1209	<2ppb		Fountain
464-062	Room 1211	<2ppb		Sink
464-063	Room 1211	NA		Fountain
464-064	Room 1213	<2ppb		Sink
464-065	Room 1213	<2ppb		Fountain
464-066	Room 1251	<2ppb		Sink
464-067	Room 1251	NA		Fountain
464-068	Room 1215	<2ppb		Sink
464-069	Room 1215	<2ppb		Fountain
464-070	Room 1217	<2ppb		Sink
464-071	Room 1217	<2ppb		Fountain
464-072	IMC 1320	<2ppb		Sink
464-073	IMC 1320	NA		Fountain
464-074	Room 1221	<2ppb		Sink
464-075	Room 1221	<2ppb		Fountain
464-076	Room 1223	<2ppb		Sink
464-076.5	Rpp, 1223	NA		Sink
464-077	Room 1223	10ppb		Fountain
464-077.5	Room 1223	NA		Fountain
464-078	Women's restroom by custodial Office - Left	16ppb		Sink
464-078.5	Women's restroom by custodial Office - Left	NA		Sink
464-079	Women's restroom by custodial Office - Right	22ppb		Sink
464-079.5	Women's restroom by custodial Office - Right		<2ppb	Sink
464-080	Girl's restroom by custodial Office - Left	<2ppb		Sink
464-081	Girl's restroom by custodial Office - Right	2ppb		Sink
464-082	Boy's restroom by custodial Office - Left	<2ppb		Sink

464-083	Boy's restroom by custodial Office - Right	<2ppb		Sink
464-084	Men's restroom by custodial Office	7ppb		Sink
464-085	Room 1402	<2ppb		Sink
464-086	Restroom in 1402	<2ppb		Sink
464-087	H.C. Restroom 1404	<2ppb		Sink
464-088	Room 1403	<2ppb		Sink
464-089	Room 1405	<2ppb		Sink
464-090	Room 1407	<2ppb		Sink
464-091	Room 1411	<2ppb		Sink
464-092	Girl's restroom - Left	<2ppb		Sink
464-093	Girl's restroom - Middle	<2ppb		Sink
464-094	Girl's restroom - Right	<2ppb		Sink
464-094.5	Girl's restroom - Right			Sink
464-095	Hall Between Restrooms - Left	<2ppb		Cooler
464-096	Hall Between Restrooms - Right	<2ppb		Cooler
464-097	Boy's Restroom - Left	<2ppb		Sink
464-098	Boy's Restroom - Middle	<2ppb		Sink
464-099	Boy's Restroom - Right	<2ppb		Sink
464-100	Room 1413	<2ppb		Sink
464-101	Room 1415	<2ppb		Sink
464-102	Boiler Room	<2ppb		Sink
464-103	Boiler Room - First Draw	NA		Sink
464-104	Girl's Restroom Across from 1313 Left	<2ppb		Sink
464-105	Girl's Restroom Across from 1313 Middle	<2ppb		Sink
464-106	Girl's Restroom Across from 1313 Right	<2ppb		Sink
464-107	Boy's Restroom Across from 1311 North Left	<2ppb		Sink
464-108	Boy's Restroom Across from 1311 North Right	<2ppb		Sink
464-109	Boy's Restroom Across from 1311 East Left	<2ppb		Sink
464-110	Boy's Restroom Across from 1311 East Right	<2ppb		Sink
464-111	Girl's Restroom Across from 1130 Left	<2ppb		Sink
464-112	Girl's Restroom Across from 1130 Middle	<2ppb		Sink
464-113	Girl's Restroom Across from 1130 Right	<2ppb		Sink
464-114	Boy's Restroom Across from 1130 Left	<2ppb		Sink
464-115	Boy's Restroom Across from 1130 Middle	<2ppb		Sink
464-116	Boy's Restroom Across from 1130 Right	<2ppb		Sink
464-117	Girl's Restroom Across from 1213 Left	<2ppb		Sink
464-118	Girl's Restroom Across from 1213 Middle	<2ppb		Sink
464-119	Girl's Restroom Across from 1213 Right	<2ppb		Sink
464-120	Boy's Restroom Across from 1211 West Left	<2ppb		Sink
464-121	Boy's Restroom Across from 1211 West Right	<2ppb		Sink
464-122	Boy's Restroom Across from 1211 North Left	<2ppb		Sink
464-123	Boy's Restroom Across from 1211 North Right	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
Phalen Lake
Building Number: 541

Sample Date: April 17, 2016
Sampled by: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
541-001	Girl's Restroom 2012 - Left	>2		Sink
541-002	Girl's Restroom 2012 - Center	>2		Sink
541-003	Girl's Restroom 2012 - Right	>2		Sink
541-004	Boy's Restroom 2010 - Left	3		Sink
541-005	Boy's Restroom 2010 - Center	6		Sink
541-006	Boy's Restroom 2010 - Right	5		Sink
541-007	Room 2007	5		Sink
541-008	Hall Outside 2006 Left	4		Cooler
541-009	Restroom Off Room 2006	>2		Sink
541-010	Room 2003	>2		Sink
541-011	Room 2004	6		Sink
541-012	Room 2002	2		Sink
541-013	Room 2001	8		Sink
541-014	Nurse's Office	9		Sink
541-015	Restroom off Nurse's Office	26		Sink
541-016	Girl's Restrm Across from Nurse's Office - Left	3		Sink
541-017	Girl's Restrm Across from Nurse's Office - Center	>2		Sink
541-018	Girl's Restrm Across from Nurse's Office - Right	7		Sink
541-019	Boy's Restrm Across from Nurse's Office - Left	2		Sink
541-020	Boy's Restrm Across from Nurse's Office - Center	>2		Sink
541-021	Boy's Restrm Across from Nurse's Office - Right	>2		Sink
541-022	Teachers Lounge Arch #1014	>2		Sink
541-023	TeachersWorkroom Arch #001	>2		Sink
541-024	Admin Workroom 1002	7		Sink
541-025	Custodial Office Restroom	>2		Sink
541-026	Custodial Office Hand Sink	>2		Sink
541-027	Custodial Office Utility Sink	>2		Utility Sink
541-028	Girl's Restroom by Gym	16		Sink
541-029	Boys Restroom by Gym	11		Sink
541-030	Gym - East	>2		Fountain
541-031	Gym - West	>2		Fountain
541-032	Cafeteria - West	>2		Fountain
541-033	Cafeteria - East	4		Fountain
541-034	Dishwashing Hand Sink	4		Sink
541-035	Kitchen Large Sink	>2		Large Sink
541-036	Kitchen Hand Sink	3		Hand Sink

541-037	Kitchen Bunn Machine	XXX		Bunn
541-038	Faculty Dining	28		Sink
541-039	Hall west of Cafeteria - Left	>2		Cooler
541-040	Hall west of Cafeteria - Right	>2		Cooler
541-041	Girl's Restroom west of Cafeteria Left	>2		Sink
541-042	Girl's Restroom west of Cafeteria Center	>2		Sink
541-043	Girl's Restroom west of Cafeteria Right	>2		Sink
541-044	Hall by Above Boy's RR- Left	9		Cooler
541-045	Hall by above Boy's R - Right	7		Cooler
541-046	Boy's Restrm by Speech Therapy - L	3		Sink
541-047	Boy's Restrm by Speech Therapy - R	>2		Sink
541-048	Room 1401	11		Sink
541-049	Room 1401	XXX		Fountain
541-050	Room 1402	10		Sink
541-051	Room 1402	xxx		Fountain
541-052	Room Between 1410 & 1403	18		Sink
541-053	Room Between 1410 & 1403	xxx		Fountain
541-054	Room Between 1404 & 1409	9		Sink
541-055	Room between 1404 & 1409	xxx		Fountain
541-056	Room 1405	10		Sink
541-057	Room 1405	xxx		Fountain
541-058	Room Between 1411 & 1416	6		Sink
541-059	Room Between 1411 & 1416	xxx		Fountain
541-060	Room Between 1412 & 1415	>2		Sink
541-061	Room Between 1412 & 1415	xxx		Fountain
541-062	Room 1417	6		Sink
541-063	Room 1417	xxx		Fountain
541-064	Room 1418	17		Sink
541-065	Room 1418	xxx		Fountain
541-066	Girl's Restroom by Room 1303 Left	3		Sink
541-067	Girl's Restroom by Room 1303 Center	3		Sink
541-068	Girl's Restroom by Room 1303 Right	8		Sink
541-069	Room 1303	5		Sink
541-070	Room 1303	xxx		Fountain
541-071	Room 1304	6		Sink
541-072	Room 1304	xxx		Fountain
541-073	Room 1304 Restroom	3		Sink
541-074	Room 1301	13		Sink
541-075	Room 1301	xxx		Fountain
541-076	Restroom Off Room 1301	100+		Sink
541-077	Boys Restroom by Room 1223 Left	>2		Sink
541-078	Boys Restroom by Room 1223 Center	3		Sink
541-079	Boys Restroom by Room 1223 Right	>2		Sink
541-080	Room 1223	81		Sink
541-081	Room 1223	xxx		Fountain
541-082	Room 1222	13		Sink
541-083	Room 1222	xxx		Fountain
541-084	Room Between 1221 & 1218	10		Sink
541-085	Room Between 1221 & 1218	xxx		Fountain
541-086	Room Between 1220 & 1219	8		Sink
541-087	Room Between 1220 & 1219	xxx		Fountain
541-088	Room 1217	54		Sink
541-089	Room 1217	xxx		Fountain
541-090	Room 1216	18		Sink
541-091	Room 1216	xxx		Fountain
541-092	Office Off Library	6		Sink
541-093	Office Off Library	xxx		Fountain
541-094	Room 22	xxx		Sink
541-095	Room 22	xxx		Fountain
541-096	Room 1210	>2		Sink
541-097	Hall Cooler by 1210 - Left	>2		Cooler
541-098	Hall Cooler by 1210 - Right	5		Cooler
541-099	Girl's Restroom by 1210 - Left	2		Sink
541-100	Girl's Restroom by 1210 - right	>2		Sink
541-101	Boy's Restroom by 1210 - Left	>2		Sink
541-102	Boy's Restroom by 1210 - Right	>2		Sink
541-103	room 1203	>2		Sink
541-104	Room 1205	>2		Sink
541-105	Room 1205	>2		Fountain
541-106	Room 1205 Restroom	>2		Sink
541-107	Room 1209	>2		Sink
541-108	Room 1206 East - Left	3		Sink
541-109	Room 1206 East - Right	>2		Sink
541-110	Room 1206 West	>2		Sink
541-111	Room 1208	6		Sink
541-112	Room 1207 - Left	>2		Sink
541-113	Room 1207 - Middle	>2		Sink
541-114	Room 1207 - Right	>2		Sink
541-115	Mechanical Room TA14	>2		Sink
541-116	Run until cold to represent water in Service Connector	>2		Sink
541-46.5	Center sink between 46/47	3		Sink
541-015.5	Restroom off Nurse's Office		>2	Sink
541-038.5	Faculty Dining		>2	Sink
541-076.5	Restroom Off Room 1301		28	Sink
541-080.5	Room 1223		4	Sink
541-088.5	Room 1217		>2	Sink

Saint Paul Public Schools
 Water Sample Results
 The Heights
 Building Number: 488

Sample Date: April 17, 2016
 Sampled by: Nancy Fischer & Alissa Houghtaling

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
488-001	Restroom in Main Office	Below 2ppb		Sink
488-002	Kitchen in Admin Office	Below 2ppb		Sink
488-003	Nurse's Office	Below 2ppb		Sink
488-004	Restroom off Nurse's Office	5ppb		Sink
488-005	Kindergarten Rm 2102	Below 2ppb		Sink
488-006	Kindergarten Rm 2102	Below 2ppb		Fountain
488-007	Restroom in Rm 2102	Below 2ppb		Sink
488-008	Kindergarten Rm 2104	Below 2ppb		Sink
488-009	Kindergarten Rm 2104	3ppb		Fountain
488-010	Restroom in Rm 2104	Below 2ppb		Sink
488-011	Outside Rm 2109	Below 2ppb		Cooler
488-012	Room 2109	Below 2ppb		Sink
488-013	Outside Rm 2111	Below 2ppb		Fountain
488-014	Room 2111	Below 2ppb		Sink
488-015	Room 2113	Below 2ppb		Sink
488-016	Room 2115	8ppb		Sink
488-017	Room 2114	28 ppb	2ppb	Sink
488-018	Room 2114 Restroom	?		Sink
488-019	Room 1111	17ppb		Sink
488-020	Room 1116	4ppb		Sink
488-021	Room 1114	6ppb		Sink
488-022	Room 1109	Below 2ppb		
488-023	Room 1108	Below 2ppb		Sink
488-024	Cafe 1110	3ppb		Fountain
488-025	Kitchen 1102 - Left	3ppb		Large Sink
488-026	Kitchen 1102 - Right	2ppb		Large Sink
488-027	Kitchen 1102 - Hand Sink	Below 2ppb		Sink
488-028	Kitchen 1102 - Bunn	Below 2ppb		Bunn
488-029	Hall by 1107 -	Below 2ppb		Fountain
488-030	Room 1107	Below 2ppb		Sink
488-031	Hall by 1102	Below 2ppb		Sink
488-032	Hall by 1105	3ppb		Cooler
488-033	Room 1105	Below 2ppb		Sink
488-034	Storage 1101	Below 2ppb		Utility Sink
488-035	Room 4244	Below 2ppb		Sink
488-036	Room 4245	5ppb		Sink
488-037	Room 4250 - Left	?		Sink
488-038	Room 4250 - Right	Below 2ppb		Sink
488-039	Room 4250	2ppb		Fountain
488-040	Boy's Restroom - Left	Below 2ppb		Sink
488-041	Boy's Restroom - Right	Below 2ppb		Sink
488-042	Hall by 4251 - Left	3ppb		Fountain
488-043	Hall by 4251 - Right	?		Fountain
488-044	4251 Custodial	3ppb		Utility Sink
488-045	Girl's Restroom - Left	Below 2ppb		Sink
488-046	Girl's Restroom - Right	Below 2ppb		Sink
488-047	Room 4252	3ppb		Sink
488-048	Room 4252	Below 2ppb		Fountain
488-049	Room 4257 Restroom	Below 2ppb		Sink
488-050	Custodial Room by 4257	4ppb		Utility Sink
488-051	Hall by 4257	Below 2ppb		Cooler
488-052	Room 3244	Below 2ppb		Sink
488-053	Room 3243	Below 2ppb		Sink
488-054	Custodial 3249	Below 2ppb		Utility Sink
488-055	Hall by 3249	Below 2ppb		Cooler
488-056	Girl's Restroom - Left	Below 2ppb		Sink
488-057	Girl's Restroom - Right	14ppb		Sink
488-058	Room 3251 Restroom	5ppb		Sink
488-059	Custodial by 3257	Below 2ppb		Utility Sink
488-060	Boy's Restroom - Left	Below 2ppb		Sink
488-061	Boy's Restroom - Right	Below 2ppb		Sink
488-062	Hall by 3257 - Left	2ppb		Fountain
488-063	Hall by 3257 - Right	Below 2ppb		Fountain
488-064	Room 2244	Below 2ppb		Sink
488-065	Room 2245 - Left	Below 2ppb		Sink
488-066	Room 2245 - Middle	2ppb		Sink
488-067	Room 2245 - Right	Below 2ppb		Sink
488-068	Room 2245 - Restroom	6ppb		Sink
488-069	Custodial 2249	Below 2ppb		Utility Sink
488-070	Boy's Restroom - Left	Below 2ppb		Sink
488-071	Boy's Restroom - Right	Below 2ppb		Sink
488-072	Hall by 2249	?		Cooler
488-073	Hall by 2255 - Left	Below 2ppb		Fountain
488-074	Hall by 2255 - Right	Below 2ppb		Fountain
488-075	Girl's Restroom - Left	Below 2ppb		Sink
488-076	Girl's Restroom - Right	3ppb		Sink
488-077	Custodial by 2255	Below 2ppb		Utility Sink

488-078	Room 2255	4ppb		Sink
488-079	Men's Restroom 1349	Below 2ppb		Sink
488-080	Outside Gym 1251	2ppb		Cooler
488-081	Women's Shower Room by Music	Below 2ppb		Sink
488-082	Women's Restroom by Music	Below 2ppb		Sink
488-083	Music Room	Below 2ppb		Utility Sink
488-084	Boiler Room 1351	Below 2ppb		Utility Sink
488-085	Boiler Room - First Draw	Below 2ppb		Utility Sink

Saint Paul Public Schools
Water Sample Results
Harding Senior
Building Number: 215

Sample Date: 4/17/2016
Sampled By: Ted Sherman, Chandala Nagendrappa

Sample #	Location	Sample Result 2016	Flush Sample Results	Fixture Type
215-001	Dishwash Room South East Of Kitchen	3ppb		Sink
215-002	Kitchen Hand Sink (old)	below 2ppb		Sink
215-003	Kitchen Large Sink East by Cooler	3ppb		Sink
215-004	Kitchen Hand Sink (New)	below 2ppb		Sink
215-005	Kitchen Island Large Sink Left	below 2ppb		Sink
215-006	Kitchen Island Large Sink Right	below 2ppb		Sink
215-007	Kitchen Staff (Lounge) Office Room 1514			Sink
215-008	Kitchen Restroom	below 2ppb		Sink
215-009	Hallway North of Old Gym	below 2ppb		Fountain
215.009.5		below 2ppb		
215-010	Pool Mechanical Room	below 2ppb		Utility Sink
215-011	Custodial Room 7	below 2ppb		Utility Sink
215-012	Girl's Varsity Custodial Room	below 2ppb		Utility Sink
215-013	New Gym Cooler (L)	below 2ppb		Cooler
215-014	New Gym Cooler (R)	below 2ppb		Cooler
215-015	New Gym Mens RR (L)	below 2ppb		Sink
215-016	New Gym Mens RR (R)	below 2ppb		Sink
215-017	New Gym Womens RR (L)	below 2ppb		Sink
215-018	New Gym Womens RR (R)	below 2ppb		Sink
215-019	Girls Locker Room	below 2ppb		Fountain
215-020	Girls Locker Room	below 2ppb		Sink
215-021	Girls L.R. Coach's Office	below 2ppb		Sink
215-022	Pool Area North	below 2ppb		Fountain
215-023	Pool Area South	below 2ppb		Fountain
215.023.1		below 2ppb		
215-024	Women's Varsity Locker Room	6ppb		Cooler
215-025	Women's Varsity Locker Room (L)	above 100		Sink
215-025.5		9ppb		
215-026	Women's Varsity Locker Room (R)	below 2ppb		Sink
215-027	Women's Varsity LR Coach's Office			Sink
215-028	Women's Varsity LR Coach's Office	2ppb		Sink
215-029	Boy's Locker Room	above 100		Fountain
215.029.5		below 2ppb		
215-030	Boy's Locker Room Restroom Sink	below 2ppb		Sink
215-031	Boy's Locker Room Coach's Office	below 2ppb		Sink
215-032	Hall South of Old Gym			Fountain
215-033	Men's Varsity Locker Room	below 2ppb		Fountain
215.033.5		below 2ppb		
215-034	Men's Varsity Locker Room Restroom	below 2ppb		Sink
215-035	Men's Varsity LR Coach's Office	below 2ppb		Sink
215-036	Boy's Varsity Laundry	16ppb		Utility Sink
215-037	Custodial Room 9			Utility Sink
215-038	Custodial Room by Main Office			Utility Sink
215-039	Custodial Room 4			Utility Sink
215-040	Wrestling Room	below 2ppb		Fountain
215-041	School Pop Store East of Cafeteria	7ppb		Sink
215-042	Handicap Restroom by Room 1152	7ppb		Sink
215-043	Main Office Unisex Rest Room by 1127	below 2ppb		Sink
215-044	Main Office Cooler	below 2ppb		Cooler
215-045	Main Office Staff Lounge			Sink
215-046	Main Office Unisex Rest Room by 1118	below 2ppb		Sink
215-047	Main Office Copy Room 1116	below 2ppb		Sink
215-048	Main Office Principal's Conference Room			Sink
215-049	Men's RR East of Main Office (L)	below 2ppb		Sink
215-050	Men's RR East of Main Office (LM)	below 2ppb		Sink
215-051	Men's RR East of Main Office (RM)	below 2ppb		Sink
215-052	Men's RR East of Main Office (R)	below 2ppb		Sink
215-053	Hall Cooler East of Main Office (L)	below 2ppb		Cooler
215-054	Hall Cooler East of Main Office (R)	below 2ppb		Cooler
215-055	Women's RR East of Main Office (L)	below 2ppb		Sink
215-056	Women's RR East of Main Office (LM)	28ppb		Sink
56.5		below 2ppb		
215-057	Women's RR East of Main Office (RM)	below 2ppb		Sink
215-058	Women's RR East of Main Office (R)	below 2ppb		Sink
215-059	Office 1411	below 2ppb		Sink
215-060	Room 1412	below 2ppb		Sink
215-061	Faculty Lounge Restroom	below 2ppb		Sink
215-062	In Hallway by Room 1421	below 2ppb		Fountain
215.062.5		below 2ppb		
215-063	Men's RR by Room 1421 (L)	below 2ppb		Sink

215-064	Men's RR by Room 1421 (R)	below 2ppb		Sink
215-065	Hallway by Room 1422	below 2ppb		Fountain
215-065.5		below 2ppb		
215-066	Women's RR by Room 1422 (L)	below 2ppb		Sink
215-067	Women's RR by Room 1422 (R)	below 2ppb		Sink
215-068	Office 1426	below 2ppb		Sink
215-069	South Hallway by Room 1425 Left	below 2ppb		Fountain
215-070	South Hallway by Room 1425 Right	2ppb		Fountain
215-070.5	New Staff Room by 1425	below 2ppb		Sink
215-071	Teacher's Office Room 1451			Bottled
215-072	By Room 1454			Fountain
215-073	Women's RR by Room 1454 (L)	below 2ppb		Sink
215-074	Women's RR by Room 1454 (R)	below 2ppb		Sink
215-075	By Room 1455	below 2ppb		Fountain
75.5				
215-076	Men's RR by Room 1455 (L)			Sink
215-077	Men's RR by Room 1455 (R)	below 2ppb		Sink
215-078	Room 1462 (Journalism)	below 2ppb		Sink
215-079	Room 1468 Math Office			Sink
215-080	Hallway North of Room 1468	below 2ppb		Fountain
80.5		below 2ppb		
215-081	Women's Restroom North of Room 1468 Left	below 2ppb		Sink
215-082	Women's Restroom North of Room 1468 Right	below 2ppb		Sink
215-083	Staff Restroom North of Room 1468	below 2ppb		Sink
215-084	Hall South of IMC (Cooler)			Cooler
215-085	Hall South of IMC (Fountain)			Fountain
215-086	Room 1325 Typing	below 2ppb		Sink
215-087	Room 1324	below 2ppb		Sink
215-088	Hallway South of Room 1333	below 2ppb		Fountain
88.5		below 2ppb		
215-089	Men's RR South of Room 1333 Left	below 2ppb		Sink
215-090	Men's RR South of Room 1333 Middle	below 2ppb		Sink
215-091	Men's RR South of Room 1333 Right			Sink
215-092	Room 1323	below 2ppb		Sink
215-093	Room 1322	below 2ppb		Sink
215-094	Room 1320	below 2ppb		Sink
215-095	Room 1312	below 2ppb		Sink
215-096	Room 1310 Left	below 2ppb		Sink
215-097	Room 1310 Right	below 2ppb		Sink
215-098	Room 1311 North Wall Left	below 2ppb		Sink
215-099	Room 1311 North Wall Middle	below 2ppb		Sink
215-100	Room 1311 North Wall Right	below 2ppb		Sink
215-101	Room 1311 East Wall Left	below 2ppb		Sink
215-102	Room 1311 East Wall Middle	below 2ppb		Sink
215-103	Room 1311 East Wall Right	below 2ppb		Sink
215-104	Room 1313 Left	below 2ppb		Sink
215-105	Room 1313 Middle	below 2ppb		Sink
215-106	Room 1313 Right	below 2ppb		Sink
215-106.5	Room 1313 Dark Room	below 2ppb		Sink
215-107	Room 1330 Storage	below 2ppb		Sink
215-108	Room 1330 Office	below 2ppb		Sink
215-109	Room 1330 Teacher's Station	below 2ppb		Sink
215-110	Room 1330 West Wall Left	below 2ppb		Sink
215-111	Room 1330 West Wall Middle	below 2ppb		Sink
215-112	Room 1330 West Wall Right	below 2ppb		Sink
215-113	Room 1331A Storage Utility Sink	below 2ppb		Utility Sink
215-114	Room 1331 Teacher's Station	below 2ppb		Sink
215-115	Room 1331 East Wall Left	below 2ppb		Sink
215-116	Room 1331 East Wall Middle - m	below 2ppb		Sink
215-116	Room 1331 East Wall Middle	below 2ppb		Sink
215-117	Room 1331 East Wall Right	below 2ppb		Sink
215-117	Room 1331 East Wall Right	below 2ppb		Sink
215-118	Room 1332 Storage	below 2ppb		Sink
215-118.5		3ppb		
215-119	Room 1332 Office	below 2ppb		Sink
215-120	Room 1332 Teacher's Station	below 2ppb		Sink
215-121	Room 1332 East Wall Left	below 2ppb		Sink
215-122	Room 1332 East Wall Middle	below 2ppb		Sink
215-123	Room 1332 East Wall Right	below 2ppb		Sink
215-124	Room 1333 Office	above 100	26ppb	Sink
215-125	Room 1334 Physics	below 2ppb		Sink
215-125.5	Room 1334B	below 2ppb		Sink
215-126	Room 1335 (Teacher's Lab Only)	below 2ppb		Sink
215-127	Audio Visual in IMC 1380A	below 2ppb		Sink
215-128	IMC Storage 1380B	below 2ppb		Sink
215-129	Room 1336 (Teacher's Lab Only)	below 2ppb		Sink
215-130	Room 1336C	3ppb		Sink
215-131	Room 1337 (Teacher's Lab Only)	3ppb		Sink
215-131.5	Room 1339			Sink
215-132	Room 1338 (Teacher's Lab Only)	below 2ppb		Sink
215-133	Room 1338C	below 2ppb		Sink
215-134	Room 1374 Restroom	below 2ppb		Sink
215-135	NJROTC Room 1371	below 2ppb		Sink
215-136	NE Hall by Faculty RR (S)	below 2ppb		Fountain
215-137	Men's Faculty RR (L)	below 2ppb		Sink
215-138	Men's Faculty RR (M)	below 2ppb		Sink
215-139	Men's Faculty RR (R)	below 2ppb		Sink

215-140	NE Hall by Faculty RR (N)	below 2ppb		Fountain
215-141	Women's Faculty RR (L)	below 2ppb		Sink
215-142	Women's Faculty RR (M)	below 2ppb		Sink
215-143	Women's Faculty RR (R)	below 2ppb		Sink
215-144	Room 1370 (Home Econ) West Wall Left	6ppb		Sink
215-145	Room 1370 (Home Econ) West Wall Middle Left	10ppb		Sink
215-146	Room 1370 (Home Econ) West Wall Middle Right	6ppb		Sink
215-147	Room 1370 (Home Econ) West Wall Right	14ppb		Sink
215-148	Room 1370 (Home Econ) North	below 2ppb		Sink
215-149	Room 1370 (Home Econ) East	below 2ppb		Sink
215-150	Room 1340 Office	below 2ppb		Sink
215-151	Room 1341	below 2ppb		Sink
215-152	Room 1341 Restroom	below 2ppb		Sink
215-153	H. S. S. Room 1351 Restroom	below 2ppb		Sink
215-154	H. S. S. Room 1352 Restroom	below 2ppb		Sink
215-155	H. S. S. Room 1354	9ppb		Sink
215-156	H. S. S. Room 1364	below 2ppb		Sink
215-157	H. S. S. Restroom by 1364	below 2ppb		Sink
215-158	H. S. S. Exam Room 3	below 2ppb		Sink
215-159	H. S. S. Exam Room 2	below 2ppb		Sink
215-160	H. S. S. Exam Room 1	below 2ppb		Sink
215-161	H. S. S. Confrence Room	5ppb		Sink
215-162	Between Restrooms South of Band Room (R)	below 2ppb		Cooler
215-163	Men's Restroom South of Band Room - Left	below 2ppb		Sink
215-164	Men's Restroom South of Band Room - Right	below 2ppb		Sink
215-165	Men's Restroom South of Band Room	4ppb		Sink
215-166	Between Restrooms South of Band Room (L)	below 2ppb		Fountain
215-167	Woman's Restroom South of Band Room - Left	below 2ppb		Sink
215-168	Woman's Restroom South of Band Room - Right	below 2ppb		Sink
215-169	West Building NE Hall	below 2ppb		Fountain
215-170	Band Area	below 2ppb		Fountain
215-171	Room 1217B Office Area	below 2ppb		Sink
215-172	Room 1220A	below 2ppb		Sink
215-173	West Building NW Hall (S)	below 2ppb		Fountain
215-174	West Building NW Hall (N)	below 2ppb		Fountain
215-175	Auditorium West on Stage	below 2ppb		Fountain
215-176	Auditorium Utility Sink	below 2ppb		Sink
215-177	Auditorium RR West	below 2ppb		Sink
215-178	Auditorium West Dressing Room	below 2ppb		Sink
215-179	Auditorium East on Stage	below 2ppb		Fountain
215-180	Auditorium RR East	below 2ppb		Sink
215-181	Auditorium East Dressing Room	below 2ppb		Sink
215-182	Automotive Shop	below 2ppb		Fountain
215-183	Automotive Large Sink (L)	below 2ppb		Sink
215-184	Automotive Large Sink (R)	below 2ppb		Sink
215-185	Room 1243	below 2ppb		Utility Sink
215-186	Automotive Slop Sink	below 2ppb		Utility Sink
215-187	Shop Office	below 2ppb		Sink
215-188	Room 1241 Graphic Arts SS	below 2ppb		Large Sink
215-189	Room 1241 Graphic Arts Print Washer	below 2ppb		Sink
215-190	Room 1240 Wood Shop	below 2ppb		Sink
215-191	NW Main Corridor South of Shop Area	below 2ppb		Fountain
215-192	Custodial Restroom	below 2ppb		Sink
215-193	Custodial Office	below 2ppb		Utility Sink
215-194	Custodial Office	below 2ppb		Cooler
215-195	Custodial Basement Slop Sink	below 2ppb		Utility Sink
215-196	First Draw - Slop Sink in Basement	below 2ppb		Sink
215-197	Staff Lounge	below 2ppb		Sink
215-198	Main Entrance Work Room	below 2ppb		Sink
215-199	Custodial Sink by Workroom	2ppb		Utility Sink
215-200	Meeting Room A	below 2ppb		Sink
215-201	Meeting Room B	6ppb		Sink
215-202	Women's Restroom (L)	3ppb		Sink
215-203	Women's Restroom (R)	2ppm		Sink
215-204	Cooler Between Restrooms	below 2ppb		Fountain
215-205	Men's Restroom (L)	below 2ppb		Sink
215-206	Men's Restroom (R)	below 2ppb		Sink
215-207	ECFE Commons Area	2ppm		Cooler
215-208	ECFE Commons Area			Sink
215-209	ECFE Storage Room			Utility Sink
215-210	ECFE Preschool Room			Sink
215-211	ECFE Preschool Restroom East			Sink
215-212	ECFE Preschool Restroom North			Sink
215-213	ECFE Toddler/Infant Room			Sink
215-214	ECFE Toddler/Infant Restroom East			Sink
215-215	ECFE Toddler/Infant Restroom South			Sink
215-216	ECFE Parant Room			Sink
215-217	Daycare Commons Area			Cooler
215-218	Daycare Kitchen Hand Sink			Sink
215-219	Daycare Kitchen Large Sink Left			Sink
215-220	Daycare Kitchen Large Sink Right			Sink
215-221	Daycare Restroom Left			Sink
215-222	Daycare Restroom Middle			Sink
215-223	Daycare Restroom Right			Sink
215-224	Daycare Restroom South			Sink
215-225	Daycare Toddler Room Hand Sink			Sink
215-226	Daycare Toddler Room Stainless Steel Sink			Sink

215-227	Daycare Infant Room 1 East			Sink
215-228	Daycare Infant Room 1 West			Sink
215-229	Daycare Infant Room 2 Stainless Steel Sink			Sink
215-230	Daycare Infant Room 2 Wall Hand Sink			Sink
215-231	Daycare Infant Room 2 Countertop Hand Sink			Sink
215-232	Daycare Infant Room 3 Stainless Steel Sink			Sink
215-233	Daycare Infant Room 3 Hand Sink on Wall			Sink
215-234	Daycare Infant Room 3 Countertop Hand Sink			Sink

Saint Paul Public Schools
Water Sample Results
Bruce Vento
Building Number: 449

Sample Date: 4/24/16
Sampled By: Mary Ferrian & Chad Whyhlen

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
449-001	Nurse's Room 1002 - SNK	9		Sink
449-002	Nurse's Restroom 1004A - SNK	3		Sink
449-003	1006A Restroom - SNK	>2		Sink
449-004	1008 Workroom - SNK	6		Sink
449-005	1101A Girl's Restroom Left - SNK	26	>2	Sink
449-006	1101A Girl's Restroom Right - SNK	>2		Sink
449-007	1101B Boy's Restroom left - SNK	3		Sink
449-008	1101B Boy's Restroom Right - SNK	>2		Sink
449-009	Room 1102 - SNK	84	5	Sink
449-010	Room 1102 - DF	>2		Drinking Fountain
449-011	Room 1103 - SNK	>2		Sink
449-012	Room 1104 - SNK	>2		Sink
449-013	Room 1106 - SNK	64	4	Sink
449-014	Room 1106 - DF	>2		Drinking Fountain
449-009.25	Room 1102 - SNK	67		Sink
449-015	Room 1108 - SNK	23		Sink
449-014.25	Room 1106 - DF	>2		Drinking Fountain
449-013.25	Room 1106 - SNK	61		Sink
449-012.25	Room 1104 - SNK	9		Sink
449-011.25	Room 1103 - SNK	>2		Sink
449-010.25	Room 1102 - DF	4		Drinking Fountain
449-016	Room 1108-DF	21	19	Drinking Fountain
449-017	Room 1112 - SNK	100+	11	Sink
449-018	Room 1110- SNK	71	>2	Sink
449-019	Room 1110 - DF	>2		Drinking Fountain
449-020	Room 1113 - SNK	17		Sink
449-021	Room 1113 - DF	>2		Drinking Fountain
449-022	Room 1114 - SNK	>2		Sink
449-023	Room 114 - DF	>2		Drinking Fountain
449-024	Room 1115 - SNK	9		Sink
449-025	Room 1115 - DF	3		Drinking Fountain
449-026	1109A Girl's Restroom left - SNK	>2		Sink
449-027	1109A Girl's Restroom right - SNK	10		Sink
449-028	1109B Boy's restroom left - SNK	>2		Sink
449-029	1109B Boy's restroo right - SNK	>2		Sink
449-030	1201A Girl's Restroom left - SNK	7		Sink
449-031	1201A Girl's Restroom right - SNK	34	8	Sink
449-032	1201B Boy's Restroom left - SNK	>2		Sink
449-033	1201B Boy's Restroom right - SNK	>2		Sink
449-034	Room 1202 - SNK	6		Sink
449-035	Room 1202-DF	9		Drinking Fountain
449-036	Room 1203 - SNK	17		Sink
449-037	Room 1203-DF	>2		Drinking Fountain
449-038	Room 1204 - SNK	14		Sink
449-039	Room 1204 - DF	6		Drinking Fountain
449-040	Room 1206 - SNK	42	>2	Sink
449-041	Room 1206 - DF	>2		Drinking Fountain
449-042	Room 1208 - SNK	24	>2	Sink
449-043	Room 1210 - SNK	17		Sink
449-044	Room 1212 - SNK	36	>2	Sink
449-045	Room 1212-DF	11		Drinking Fountain
449-046	Room 1213 - SNK	>2		Sink
449-047	Room 1214 - SNK	39	>2	Sink
449-048	Room 1214 - DF	18		Drinking Fountain
449-049	Room 1215 - SNK	100+	9	Sink
449-050	Room 1215 - DF	8		Drinking Fountain
449-051	1209A Girl's Restroom left - SNK	5		Sink
449-052	1209A Girl's Restroom right - SNK	>2		Sink
449-053	1209B Boy's Restroom left - SNK	>2		Sink
449-054	1209B Boy's Restroom right - SNK	xxx		Sink
449-055	Cafeteria - WC	>2		Water Cooler
449-056	Kitchen 1313 - KS	>2		Kitchen Sink
449-057	1312 South Wall - KS	>2		Kitchen Sink
449-058	1312 handwashing North wall - SNK	>2		Sink
449-059	1312 Kitchen North left - KS	>2		Kitchen Sink
449-060	1312 Kitchen North Right - KS	>2		Kitchen Sink
449-061	1312 Kitchen Bunn	xxx		Bunn
449-062	1319A - SNK	>2		Sink
449-063	1319 B - SNK	>2		Sink

449-064	1309B left - SNK	>2		Sink
449-065	1319B - right - SNK	>2		Sink
449-066	Room 1308 - SNK	>2		Sink
449-067	Room 1308 - DF	>2		Drinking Fountain
449-068	Room 1306 - SNK	20	24	Sink
449-069	Room 1306 - DF	6		Drinking Fountain
449-070	Next to Roo 1209 - DF	4		Drinking Fountain
449-071	Room 1310 - SNK	15		Sink
449-072	Room 1253 - left - SNK	>2		Sink
449-073	Room 1253 - Right - SNK	>2		Sink
449-074	Room 1607 - SNK	>2		Sink
449-075	Gym east - DF	>2		Drinking Fountain
449-076	Gym west - DF	18		Drinking Fountain
449-077	1501A Women's Restroom - SNK	13		Sink
449-078	1501B Men's Restroom - SNK	100+	16	Sink
449-079	Room 1502 - SNK	>2		Sink
449-080	Room 1502 - DF	>2		Drinking Fountain
449-081	Room 1504 - SNK	100+	<2	Sink
449-082	1504 restroom - SNK	>2		Sink
449-083	Room 1505 - SNK	>2		Sink
449-084	Room 1505 - DF	>2		Drinking Fountain
449-085	1505A restroom - SNK	>2		Sink
449-086	Room 1507 - SNK	9		Sink
449-087	Room 1507 - DF	>2		Drinking Fountain
449-088	1507A restroom - SNK	>2		Sink
449-089	1502A restroom - SNK	>2		Sink
449-090	Room 1510 - SNK	>2		Sink
449-091	Room 1510 - DF	>2		Drinking Fountain
449-092	Room 1514 - SNK	4		Sink
449-093	Room 1515 - SNK	>2		Sink
449-094	Room 1515 - DF	15		Drinking Fountain
449-095	Room 1516 - SNK	22	38	Sink
449-096	Room 1516 - DF	36	18	Drinking Fountain
449-097	Room 1517 - SNK	32	<2	Sink
449-098	1509A Boy's Restroom left - SNK	61	<2	Sink
449-099	1509A Boy's Restroom right - SNK	10		Sink
449-100	1509B Girl's Restroom left - SNK	62	11	Sink
449-101	1509 B Girl's Restroom right - SNK	46	5	Sink
449-102	1401A Girl's Restroom left - SNK	3		Sink
449-103	1401A Girl's Restroom right - SNK	>2		Sink
449-104	1401B Boy's Restroom left - SNK	3		Sink
449-105	1401B Boy's Restroom right - SNK	>2		Sink
449-106	Room 1402 - SNK	23	<2	Sink
449-107	Room 1402 - DF	>2		Drinking Fountain
449-108	Room 1403 - SNK	15		Sink
449-109	Room 1403 - DF	xxx		Drinking Fountain
449-110	Room 1404 - SNK	14		Sink
449-111	Room 1404 - DF	>2		Drinking Fountain
449-112	Room 1405 - SNK	16		Sink
449-113	Room 1405 - DF	xxx		Drinking Fountain
449-114	Room 1417 - SNK	6		Sink
449-115	Room 1417 - DF	2		Drinking Fountain
449-116	Room 1418 - SNK	19		Sink
449-117	Room 1418 - DF	>2		Drinking Fountain
449-118	Room 1419 - SNK	>2		Sink
449-119	Room 1419 - DF	6		Drinking Fountain
449-120	Room 1420 - SNK	6		Sink
449-121	1410B Boy's Restroom left - SNK	12		Sink
449-122	1410B Boy's Restroom right - SNK	>2		Sink
449-123	1410A Girl's Restroom left - SNK	>2		Sink
449-124	1410A Girl's Restroom right - SNK	>2		Sink
449-125	next to 1410 - DF	9		Drinking Fountain
449-126	1410 custodial - SNK	10		Sink
449-127	1209 custodial - SNK	11		Sink
449-128	Room 1408 - SNK	17		Sink
449-129	Room 1408 - DF	>2		Drinking Fountain
449-130	Fountain outside of 1509 - DF	25	21	Drinking Fountain
449-131	Room 1509 - SNK	>2		Sink
449-132	Fountain outside of 1109 - DF	62	55	Drinking Fountain
449-133	Room 1109 - SNK	>2		Sink

Saint Paul Public Schools
Water Sample Results
L'Etoile du Nord Lower
Building Number: 542

Sample Date: April 24, 2016
Sampled by: Natalie Eskew & Kobe Patch

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
542-001	Kitchen 1104 West Wall - Left	<2ppb		Sink
542-002	Kitchen 1104 West Wall - Right	<2ppb		Sink
542-003	Kitchen 1104	<2ppb		Hand Sink
542-004	Kitchen 1104	PACE		Bunn Machine
542-005	Kitchen Restroom 1104B	11 ppb		Sink
542-006	Cafeteria Custodial Utility Sink	<2ppb		Utility Sink
542-007	Staff Restroom Across From Gym	4ppb		Sink

542-008	Girls Restroom by Gym - Left	<2ppb		Sink
542-009	Girls Restroom by Gym - Middle	<2ppb		Sink
542-010	Girls Restroom by Gym - Right	<2ppb		Sink
542-011	Boys Restroom by Gym - Left	<2ppb		Sink
542-012	Boys Restroom by Gym - Middle	<2ppb		Sink
542-013	Boys Restroom by Gym - Right	<2ppb		Sink
542-014	Hallway by Room 1202	<2ppb		Drinking Fountain
542-015	Custodial Room 1201	<2ppb		Utility Sink
542-016	Room 1203	<2ppb		Sink
542-017	Room 1203	<2ppb		Drinking Fountain
542-018	Room 1204	<2ppb		Sink
542-019	Room 1204	<2ppb		Drinking Fountain
542-020	Room 1205	<2ppb		Sink
542-021	Room 1205	<2ppb		Drinking Fountain
542-022	Room 1205 Restroom	<2ppb		Sink
542-023	Room 1206	<2ppb		Sink
542-024	Room 1206 Restroom	<2ppb		Sink
542-025	Custodial Room 1209	<2ppb		Utility Sink
542-026	Boys Restroom by Room 1206 - Right	<2ppb		Sink
542-027	Girls Restroom by Room 1205 - Left	<2ppb		Sink
542-028	Girls Restroom by Room 1205 - Right	<2ppb		Sink
542-029	Hallway by Room 1206 - Left	<2ppb		Drinking Fountain
542-030	Hallway by Room 1206 - Right	<2ppb		Drinking Fountain
542-031	Room 1301	<2ppb		Sink
542-032	Room 1302	<2ppb		Sink
542-033	Room 1303	<2ppb		Sink
542-034	Room 1304	<2ppb		Sink
542-035	Room 1305	<2ppb		Sink
542-036	Room 1306	4ppb		Sink
542-037	Girls Restroom by Room 1013	<2ppb		Sink
542-038	Boys Restroom by Room 1013	9ppb		Sink
542-039	Hallway by Room 1013	<2ppb		Water Cooler
542-040	Main Office Restroom by 1008	<2ppb		Sink
542-041	Nurse 1002	2ppb		Sink
542-042	Nurse Restroom 1003A	<2ppb		Sink
542-043	Room 1101	<2ppb		Sink
542-044	Room 1101 Restroom	<2ppb		Sink
542-045	Room 1102	<2ppb		Sink
542-046	Room 1102	<2ppb		Drinking Fountain
542-047	Room 1102 Restroom	<2ppb		Sink
542-048	Basement Restroom	<2ppb		Sink
542-049	Basement Room 0110	<2ppb		Utility Sink
542-050	Basement Room 0108	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
L'Etoile du Nord Upper
Building Number: 413

Sample Date: April 24, 2016
Sampled by: Mary Ferrian & Chad Whyhlen

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
413-001	Gym 1221 - WC	2		Water Cooler
413-002	Boys' Bathroom 1224 - SNK	4		Sink
413-003	Girls' Bathroom 1222 - SNK	<2		Sink
413-004	1223 Janitor's Closet - SNK	<2		Sink
413-005	1201B Dishroom - SNK	<2		Sink
413-006	1201B Dishroom - KS	<2		Kitchen Sink
413-007	Cafeteria 1201 - WC	<2		Water Cooler
413-008	1201 Kitchen (left) - KS	3		Kitchen Sink
413-009	1201 A Kitchen (right) - KS	<2		Kitchen Sink
413-010	1201 A Kitchen (handwashing) - SNK	2		Sink
413-011	1201 A Kitchen (bunn) - Bunn	-		Bunn
413-012	1105 Break room - SNK	4		Sink
413-013	0102 Mechanical - SNK	<2		Sink
413-014	1107C Bathroom - SNK	<2		Sink
413-015	Hallway 1100 - WC	3		Water Cooler
413-016	1109A Restroom - SNK	<2		Sink
413-017	1111 Nurse's Room - SNK	<2		Sink
413-018	1111A Nurse's Restroom - SNK	<2		Sink
413-019	1113 Custodial - SNK	<2		Sink
413-020	Room 2107 - SNK	<2		Sink
413-021	2103A Bathroom - SNK	8		Sink
413-022	Hallway 2100 - WC	<2		Water Cooler
413-023	2105A Restroom - SNK	<2		Sink
413-024	2101 - SNK	<2		Sink
413-025	Room 2202 - SNK	<2		Sink
413-026	Room 2202A - SNK	<2		Sink
413-027	2206 Girl's Restroom (left) - SNK	<2		Sink
413-028	2206 Girl's Restroom (center) - SNK	<2		Sink
413-029	2206 Girl's Restroom (right) - SNK	<2		Sink
413-030	2208 Custodial/Storage - SNK	<2		Sink
413-031	2210 Boy's Restroom (left) - SNK	<2		Sink
413-032	2210 Boy's Restroom (center) - SNK	<2		Sink
413-033	2210 Boy's Restroom (right) - SNK	2		Sink
413-034	Room 2212 - SNK	<2		Sink

413-035	Room 2215 - SNK	<2		Sink
413-036	Next to 2216 - WC	<2		Water Cooler
413-037	Room 2216 - SNK	<2		Sink
413-038	Room 2217 - SNK	<2		Sink
413-039	Room 2218 - SNK	<2		Sink
413-040	Hallway 3100 - WC	<2		Water Cooler
413-041	Room 3105 - SNK	2		Sink
413-042	Room 3101 - SNK	<2		Sink
413-043	Hallway 3200 by stairs (left) - WC	<2		Water Cooler
413-044	Hallway 3200 by stairs (right) - WC	<2		Water Cooler
413-045	3206 Girl's Restroom (left) - SNK	<2		Sink
413-046	3206 Girl's Restroom (left center) - SNK	<2		Sink
413-047	3206 Girl's Restroom (right center) - SNK	4		Sink
413-048	3206 Girl's Restroom (right) - SNK	<2		Sink
413-049	3208 Custodial/Storage - SNK	<2		Sink
413-050	3210 Boy's Restroom (left) - SNK	6		Sink
413-051	3210 Boy's Restroom (left Center) - SNK	3		Sink
413-052	3210 Boy's Restroom (Right Center) - SNK	3		Sink
413-053	3210 Boy's Restroom (Right) - SNK	5		Sink
413-054	Room 3215 - SNK	<2		Sink
413-055	Next to Room 3216 - WC	3		Water Cooler
413-056	Room 3216 - SNK	<2		Sink
413-057	Room 3217 - SNK	<2		Sink
413-058	Room 3218 - SNK	<2		Sink

Saint Paul Public Schools
Water Sample Results
Hazel Park Middle School
Building Number: 325

Sample Date: April 24, 2016
Sampled by: Nancy Fischer & Alissa Houghtaling

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
325-001	Room 2322	5ppb		sink
325-002	Room 2321	22ppb	11ppb	sink
325-003	Boy's Restroom- across from rm 2321- north	5ppb		sink
325-004	Boy's Restroom- across from rm 2321- south	13ppb		sink
325-005	Boy's Restroom- across from rm 2321- s.w	below 2		sink
325-006	Boy's Restroom- across from rm 2321- w	below 2		sink
325-007	Boy's Restroom- across from rm 2321-n.west	below 2		sink
325-008	Girl's Restroom-across from rm 2317-south	below 2		sink
325-009	Girl's Restroom-across from rm 2317-north	4ppb		sink
325-010	Girl's Restroom-across from rm 2317-s.w			sink
325-011	Girl's Restroom-across from rm 2317-n.w	2-ppb		sink
325-012	Room 2320- left	30ppb	52ppb	sink
325-013	Room 2320- right	30ppb	8ppb	sink
325-014	Room 2319			sink
325-015	Drinking fountain across from rm 2319	below 2		fountain
325-016	Room 2318- left			
325-017	Room 2318- right	above 100	20ppb	sink
325-018	Room 2317- west			sink
325-019	Room 2317- east			sink
325-020	Room 2317- s.e	below 2		sink
325-021	Room 2315- west	8ppb		sink
325-022	Room 2315- east	below 2		sink
325-023	Room 2315- s.e	below 2		sink
325-024	Room 2314- left			sink
325-025	Room 2314- right			sink
325-026	Room 2313- west			sink
325-027	Room 2313- east	5ppb		sink
325-028	Room 2313- east(central)	below 2		sink
325-029	Room 2313- east(south)	below 2		sink
325-030	Room 2313- s.e	8ppb		sink
325-031	Room 2313- south	below 2		sink
325-032	Room 2313- s.w	below 2		sink
325-033	Room 2308A	below 2		sink
325-034	Room 2311- n.w	2ppb		sink
325-035	Room 2311- n.e	6ppb		sink
325-036	Room 2311- east	below 2		sink
325-037	Room 2311- east(south)	below 2		sink
325-038	Room 2311- s.e	below 2		sink
325-039	Room 2311- south	5ppb		sink
325-040	Room 2311- west	below 2		sink
325-041	Room 2309- n.w	below 2		sink
325-042	Room 2309- n.e			sink
325-043	Room 2309- s.e	below 2		sink
325-044	Room 2304/2306 Restroom	5ppb		sink
325-045	Room 2307	below 2		sink
325-046	Room 2305			sink
325-047	Boy's Restroom across from rm 2305- south	19ppb		sink
325-048	Boy's Restroom across from rm 2305- north	below 2		sink
325-049	Room 2303	17ppb		sink
325-050	Girl's Restroom across from rm 2301- s.w	below 2		sink
325-051	Girl's Restroom across from rm 2301- n.w	below 2		sink
325-052	Girl's Restroom across from rm 2301- south	below 2		sink
325-053	Girl's Restroom across from rm 2301- north	below 2		sink
325-054	Girl's Restroom across from rm 2301- n.e	6ppb		sink

325-055	Custodial Closet 2300A	below 2		slop
325-056	Drinking Fountain across from rm 2303			fountain
325-057	Drinking Fountain across from rm 2307	5ppb		cooler
325-058	Room 1321			sink
325-059	Boy's Restroom across from rm 1321- west	18ppb		sink
325-060	Boy's Restroom across from rm 1321- east	10ppb		sink
325-061	Drinking Fountain across from rm 1319	below 2		fountain
325-062	Room 1319/1319A	3ppb		sink
325-063	Girl's Restroom across from 1319/1319A- south	below 2		sink
325-064	Girl's Restroom across from 1319/1319A- north	below 2		sink
325-065	Girl's Restroom across from 1319/1319A- s.w	below 2		sink
325-066	Girls's Restroom across from 1319/1319A- n.w	6ppb		sink
325-067	Room 1317/1317A	below 2		sink
325-068	Room 1316- left	below 2		sink
325-069	Room 1316- right	16ppb		sink
325-070	Room 1315	2ppb		sink
325-071	Room 1313	below 2		sink
325-072	Room 1312A- left	3ppb		sink
325-073	Room 1312A- right	below 2		sink
325-074	Room 1311			sink
325-075	Room 1310	below 2		sink
325-076	Room 1310 Restroom	below 2		sink
325-077	Room 1309 Restroom	below 2		sink
325-078	Drinking Fountain across from rm 1307	below 2		fountain
325-079	Drinking Fountain across from rm 1307	9ppb		cooler
325-080	Room 1308	below 2		sink
325-081	Room 1308 Restroom	below 2		sink
325-082	Room 1307 Restroom	below 2		sink
325-083	Room 1306- left	below 2		sink
325-084	Room 1306- right			sink
325-085	Room 1305 Restroom	7ppb		sink
325-086	Boy's Restroom across from rm 1305- west	29ppb	16ppb	sink
325-087	Boy's Restroom across from rm 1305- east	4ppb		sink
325-088	Drinking Fountain across from rm 1305	2ppb		fountain
325-089	Girl's Restroom across from rm 1301- west	below 2		sink
325-090	Girl's Restroom across from rm 1301- east	below 2		sink
325-091	Room 1302- s.w			sink
325-092	Room 1302- west	below 2		sink
325-093	Room 1302- n.w	below 2		sink
325-094	Room 1302- s.e	below 2		sink
325-095	Room 1302- east	below 2		sink
325-096	Room 1302- n.e	11ppb		sink
325-097	Room 1402- workroom off media center	9ppb		sink
325-098	Room 1206- Maintenance	below 2		sink
325-099	Room 1206- Maintenance			slop
325-100	Nurses Office	below 2		sink
325-101	Nurses Office Restroom	below 2		sink
325-102	Room 1201 Restroom	6ppb		sink
325-103	Restroom outside Room 1202	8ppb		sink
325-104	Boy's Restroom- across from gym 1107- left	below 2		sink
325-105	Boy's Restroom-across from gym 1107- right	11ppb		sink
325-106	Girl's restroom- across from gym 1107- left	2ppb		sink
325-107	Girl's restroom- across from gym 1107- right			sink
325-108	Drinking Fountain between restrooms by 1107	below 2		cooler
325-109	Boiler Room- sink off office	below 2		sink
325-110	Cafeteria- drinking fountain	6ppb		cooler
325-111	Kitchen- Hand Sink	below 2		sink
325-112	Kitchen-left			sink
325-113	Kitchen-middle	6ppb		sink
325-114	Kitchen-right	15ppb		sink
325-115	Rm 1109- Boy's Locker Room- drink fountain			fountain
325-116	Rm 1109- Boy's Locker Room- sink	10ppb		sink
325-117	Rm 1108- Boy's Locker Rm office	below 2		sink
325-118	Rm 1106- Girl's Locker Rm Office	below 2		sink
325-119	Rm 1105- Girl's Locker Rm	below 2		sink
325-120	Rm 1105- Girl's Locker Rm- drink fountain	below 2		fountain

Saint Paul Public Schools
Water Sample Results
Farnsworth Upper
Building Number: 315

Sample Date: April 24, 2016
Sampled By: Parker Prose, Kobe Patch, Keegan, & Natalie Eskew

Sample Number	Location	Sample result 2016 (ppb)	15 Seconds Flush Sample (ppb)	SampleType
315-001	Kitchen 1104 large- left	>2		sink
315-002	Kitchen 1104 large- right	>2		sink
315-003	kitchen 1104	>2		bunn
315-004	kitchen 1104	>2		hand sink
315-005	kitchen 1106 restroom	>2		sink
315-006	cafeteria 1102 left	>2		water cooler
315-007	cafeteria 1102 right	>2		water cooler
315-008	room 1006 restroom	>2		sink
315-009	hallway by room 1304	>2		drinking fountain
315-010	staff restroom by Room 1001	>2		sink

315-011	staff lounge Room 1205	>2		sink
315-012	room 1203	>2		sinnk
315-013	custodial closet by Room 1006	>2		utility sink
315-014	boys restroom by Room 1304- left	>2		sink
315-015	boys restroom by Room 1304- middle	>2		sink
315-016	boys restroom by Room 1304- right	4		sink
315-017	girls restroom by Room 1304- left	<2		sink
315-018	girls restroom by Room 1304- middle	>2		sink
315-019	girls restroom by Room 1304- right	>2		sink
315-020	Nurse Room 1303	>2		sink
315-021	Nurse Room 1303 restroom	5		sink
315-022	room 1311	<2		sink
315-023	hallway by Room 1314	<2		drinking fountain
315-024	room 1314 restroom	<2		sink
315-025	room 1403 left	<2		sink
315-026	room 1403 right	3		sink
315-027	girls restroom by Room 1405 left	<2		sink
315-028	girls restroom by Room 1405 right	<2		sink
315-029	Room 1405	2		sink
315-030	Room 1407	<2		sink
315-031	hallway by Room 1405 left	<2		water cooler
315-032	hallway by Room 1405 right	<2		water cooler
315-033	boys restroom by Room 1405 left	<2		sink
315-034	boys restroom by Room 1405 right	<2		sink
315-035	Room 1406 maintenance	<2		utility sink
315-036	room 1409 left	<2		sink
315-037	room 1409 right	<2		sinnk
315-038	room 1402	<2		sink
315-039	hallway by Room 2312	<2		drinking fountain
315-040	room 2312 restroom	<2		sink
315-041	room 2303 office restroom	<2		sink
315-042	boys room by Room 2304 left	<2		sink
315-043	boys room by Room 2304 middle	<2		sink
315-044	boys room by Room 2304 right	<2		sink
315-045	hallway by boys restroom by Room 2304	<2		drinking fountain
315-046	girls restroom by Room 2102 left	<2		sink
315-047	girls restroom by Room 2102 middle	<2		sink
315-048	girls restroom by Room 2102 right	<2		sink
315-049	room 2102 corner	51	<2	sink
315-050	room 2202 east wall	<2		sink
315-051	Room 2202 southeast wall	26	<2	sink
315-052	room 2202A	7		sink
315-053	room 2203 custodial	4		utility sink
315-054	north 2202- east wall	<2		sink
315-055	room 2206	4		sink
315-056	hallway by Room 3312	3		drinking fountain
315-057	room 3306A	<2		sink
315-058	boys restroom by Room 3303 left	<2		sink
315-059	boys restroom by Room 3303 middle	4		sink
315-060	boys restroom by Room 3303 right	<2		sink
315-061	hallway by Room 3303	7		drinking fountain
315-062	girls restroom by Room 3104 left	11		sink
315-063	girls restroom by Room 3104 middle	<2		sink
315-064	girls restroom by Room 3104 right	<2		sink
315-065	room 3104 - teacher workstation	14		sink
315-066	room 3202 prep room	3		sink
315-067	room 3202 - north center west	11		sink
315-068	room 3202 teacher workstation	<2		sink
315-069	staff restroom by Room 3205 left	8		sink
315-070	staff restroom by Room 3205 right	<2		sink
315-071	room 3204 custodial	3		utility sink
315-072	west gym entry by Room 0402	4		water cooler
315-073	room 0402 restroom	<2		sink
315-074	room 0404 girls locker room left	4		sink
315-075	room 0404 girls locker room right	4		sink
315-076	room 0407 restroom	3		sink
315-077	room 0406 left	5		water cooler
315-078	room 0406 right	<2		water cooler
315-079	room 0408 left	4		sink
315-080	room 0408 right	<2		sink
315-081	hallway by Room 0407 left	3		water cooler
315-082	hallway by Room 0407 right	<2		water cooler
315-083	Room 0409 maintenance	<2		utility sink
315-084	Room 0410 boys restroom left	<2		sink
315-085	Room 0410 boys restroom right	<2		sink
315-086	Room 0405 boys locker room left	<2		sink
315-087	Room 0405 boys locker room right	<2		sink
315-088	Room 0403 restroom	<2		sink
315-089	Room 0303	<2		sink

Saint Paul Public Schools
Water Sample Results
John A Johnson
Building Number: 060

Sample Date: 4/24/2016
Sampled by: Ted and Heidi

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
060-001	Fourth Floor Boy's RR West - Left	<2		
060-002	Fourth Floor Boy's RR West - Left Middle	<2		
060-003	Fourth Floor Boy's RR West - Middle	<2		
060-004	Fourth Floor Boy's RR West - Right Middle	<2		
060-005	Fourth Floor Boy's RR West - Right	<2		
060-006	Hall by 4201	<2		
060-007	Staff Room 4206	<2		
060-008	Staff Room 4206 - Restroom	<2		
060-009	Room 4207 - Left	<2		
060-010	Room 4207 - Right	<2		
060-011	Fourth Floor Girl's Restroom North East - Left	<2		
060-012	Fourth Floor Girl's Restroom North East - Left Middle	<2		
060-013	Fourth Floor Girl's Restroom North East - Middle	<2		
060-014	Fourth Floor Girl's Restroom North East - Right Middle	<2		
060-015	Fourth Floor Girl's Restroom North East - Right	<2		
060-016	Hall by 4305	<2		
060-017	Fourth Floor Girl's Restroom South East - Left	<2		
060-018	Fourth Floor Girl's Restroom South East - Left Middle	<2		
060-019	Fourth Floor Girl's Restroom South East - Right Middle	<2		
060-020	Fourth Floor Girl's Restroom South East - Right	<2		
060-021	Fourth Floor Boy's Restroom South East - Left	<2		
060-022	Fourth Floor Boy's Restroom South East - Left Middle	<2		
060-023	Fourth Floor Boy's Restroom South East - Right Middle	<2		
060-024	Fourth Floor Boy's Restroom South East - Right	<2		
060-025	IMC Office	<2		
060-026	Third Floor Boy's RR East - Left	<2		
060-027	Third Floor Boy's RR East - Left Middle	<2		
060-028	Third Floor Boy's RR East - Middle	<2		
060-029	Third Floor Boy's RR East - Right Middle	<2		
060-030	Third Floor Boy's RR East - Right	<2		
060-031	Hall by 3201	<2		
060-032	Room 3201 South	<2		
060-033	Room 3201 North	<2		
060-034	Room 3201 Restroom	<2		
060-035	Room 3203 North	<2		
060-036	Room 3201 South	<2		
060-037	Room 3201 Restroom	<2		
060-038	Workroom 3202B	<2		
060-039	Room 3202B Restroom	<2		
060-040	Workroom 3204	-		
060-041	Third Floor Girl's RR NE - Left	<2		
060-042	Third Floor Girl's RR NE - Left Middle	<2		
060-043	Third Floor Girl's RR NE - Middle	<2		
060-044	Third Floor Girl's RR NE - Right Middle	<2		
060-045	Third Floor Girl's RR NE - Right	<2		
060-046	Hall by 3305	-		
060-047	Third Floor Girl's RR SE - Left	<2		
060-048	Third Floor Girl's RR SE - Left Middle	<2		
060-049	Third Floor Girl's RR SE - Right Middle	<2		
060-050	Third Floor Girl's RR SE - Right	<2		
060-051	Third Floor Boy's RR SE - Left	<2		
060-052	Third Floor Boy's RR SE - Middle	<2		
060-053	Third Floor Boy's RR SE - Right	<2		
060-054	Commons Area 3400	<2		
060-055	Third Floor Staff Restrom by 3412	<2		
060-056	Room 2313	<2		
060-057	Room 2315 - Left	<2		
060-058	Room 2315 - Right	<2		
060-059	Room 2315 Restroom	<2		
060-060	Room 2317 - Left	<2		
060-061	Room 2317 - Right	<2		
060-062	Room 2317 Restroom	<2		
060-063	Room 2319	<2		
060-064	Room 2321	<2		
060-065	Room 2324	<2		
060-066	Room 2323	<2		
060-067	Romm 2323 Restroom	<2		
060-068	Room 2322	<2		
060-069	Room 2322 Restroom	<2		
060-070	Room 2108	<2		
060-071	Second Floor Women's RR - Left	<2		
060-072	Second Floor Women's RR - Left Middle	<2		
060-073	Second Floor Women's RR - Middle	<2		
060-074	Second Floor Women's RR - Right Middle	<2		
060-075	Second Floor Women's RR - Right	<2		
060-076	Second Floor Men's RR - Left	<2		
060-077	Second Floor Men's RR - Middle	<2		
060-078	Second Floor Men's RR - Right	<2		
060-079	Room 2104	<2		
060-080	Hall by 2314	-		
060-081	Main Office Area 2002F	<2		
060-082	Main Office Restroom	<2		
060-083	Room 2005	<2		
060-084	Nurse's Area East	<2		
060-085	Nurse's Area West	<2		

060-086	Nurse's Restroom	<2		
060-087	Nurse's Cot Room 2003E	<2		
060-088	Nurse's Cot Room 2003F	<2		
060-089	First Floor Hall By Cafeteria - Left	<2		
060-090	First Floor Hall By Cafeteria - Right	<2		
060-091	First Floor Boy's RR - Left	<2		
060-092	First Floor Boy's RR - Middle	<2		
060-093	First Floor Boy's RR - Right	<2		
060-094	First Floor Girl's RR - Left	<2		
060-095	First Floor Girl's RR - Middle	<2		
060-096	First Floor Girl's RR - Right	<2		
060-097	Staff Lounge 1107	<2		
060-098	Cafeteria Women's RR	<2		
060-099	Cafeteria Men's RR	<2		
060-100	Kitchen 1105C	<2		
060-101	Kitchen 1105J - Left	<2		
060-102	Kitchen 1105J - Right	<2		
060-103	Kitchen 1105I - Hand Sink	<2		
060-104	Kitchen 1105I - Hand Sink	<2		
060-105	Kitchen 1105I	<2		
060-106	Kitchen 1105I - Bunn	-		
060-107	Restroom 1133	<2		
060-108	First Draw	<2		

Saint Paul Public Schools
Water Sample Results
Nokomis Montessori
Building Number: 533

Sample Date: 4/24/2016
Sampled by: Ted and Heidi

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
533-001	Outside Elevator	Below 2 PPB		Cooler
533-002	Room 217	Below 2 PPB		Sink
533-003	Room 215	5 PPB		Sink
533-004	Room 213	Below 2 PPB		Sink
533-005	Second Floor Janitor's Closet	3 PPB		Utility Sink
533-006	Second Floor Staff Restroom	Below 2 PPB		Sink
533-007	Room 212	Below 2 PPB		Sink
533-008	Second Floor Hall by Room 212	Below 2 PPB		Cooler
533-009	Room 214	Below 2 PPB		Sink
533-010	Room 216	Below 2 PPB		Sink
533-011	Room 117	Below 2 PPB		Sink
533-012	Room 114	Below 2 PPB		Sink
533-013	Hall Cooler by Room 114	Below 2 PPB		Cooler
533-014	Room 115	Below 2 PPB		Sink
533-015	Room 112 - Left	Below 2 PPB		Utility Sink
533-016	Room 112 - Right	Below 2 PPB		Utility Sink
533-017	Room 113	Below 2 PPB		Sink
533-018	First Floor Staff Restroom by Room 113	Below 2 PPB		Sink
533-019	First floor Janitor's Closet by Room 113	Below 2 PPB		Utility Sink
533-020	Outside Rm 111	Below 2 PPB		Cooler
533-021	Outside Rm 111	Below 2 PPB		
533-022	Room 109	Below 2 PPB		Sink
533-023	Restroom off Rm 108	4		Sink
533-024	Room 108	4		Sink
533-025	Room 107 Restroom	Below 2 PPB		Hand Sink
533-026	Room 107	Below 2 PPB		Sink
533-027	Room 107	Below 2 PPB		Fountain
533-028	Room 105	Below 2 PPB		Sink
533-029	Room 104	Below 2 PPB		Sink
533-030	Room 104	Below 2 PPB		Fountain
533-031	Room 103	No sample		Sink
533-032	Room 103	Below 2 PPB		Fountain
533-033	Room 102	Below 2 PPB		Sink
533-034	Room 102	No Sample		Fountain
533-035	Room 101	Below 2 PPB		Sink
533-036	Room 101	Below 2 PPB		Fountain
533-037	Room 100	Below 2 PPB		Sink
533-038	Room 100	Below 2 PPB		Fountain
533-039	Hallway Outside Rm 100 - Left	Below 2 PPB		Fountain
533-040	Hallway Outside Rm 100 - Right	Below 2 PPB		Fountain
533-041	Restroom Off Nurse's Office	Below 2 PPB		Sink
533-042	Nurse's Office	No sample		Sink
533-043	Restroom Main Office Copy Room	Below 2 PPB		Sink
533-044	Staff Lounge	Below 2 PPB		Sink
533-045	Gym - N end of E wall	Below 2 PPB		Cooler
533-046	Gym - S end of E wall	Below 2 PPB		Cooler
533-047	Kitchen - N wall - Left	Below 2 PPB		Large Sink
533-048	Kitchen - N wall - Right	Below 2 PPB		Large Sink
533-049	Kitchen - Handwashing	Below 2 PPB		Hand Sink
533-050	Building Storage by Gym	Below 2 PPB		Utility Sink
533-051	Building Storage by Gym - First Draw	Below 2 PPB		Utility Sink

Saint Paul Public Schools

Sample Date: April 24, 2016

**Water Sample Results
Parkway Middle
Building Number: 538**

Sampled by: Parker Prose and Kegan

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
533-001	Kitchen - SNK - NW	<2		Sink
533-002	Kitchen - SNK - NE	<2		Sink
533-003	Kitchen - Sprayer - NE	<2		Sprayer
533-004	Kitchen - SNK - NE - Far East	2		Sink
533-005	Kitchen - SNK - East	3		Sink
533-006	Cafeteria - WC - Right	<2		Water Cooler
533-007	Cafeteria - WC - Left	<2		Water Cooler
533-008	1300A DF	<2		Drinking Fountain
533-009	Dishwashing room - SNK	<2		Drinking Fountain
533-010	Dishwashing room - KSNK	<2		Sink
533-011	1307 - SNK - Right	<2		Sink
533-012	1307 - SNK - Middle	<2		Sink
533-013	1307 - SNK - Left	<2		Sink
533-014	1306 - SNK	<2		Sink
533-015	1305 - SNK - Left	<2		Sink
533-016	1305 - SNK - Middle Left	<2		Sink
533-017	1305 - SNK - Middle	<2		Sink
533-018	1305 - SNK - Middle Right	<2		Sink
533-019	1305 - SNK - Right	<2		Sink
533-020	0320 - SNK	<2		Sink
533-021	1302 hallway WC - Left	<2		Water Cooler
533-022	1302 Hallway WC - Right	<2		Water Cooler
533-023	1101 - SNK	2		Sink
533-024	1201/1202 DF	3		Drinking Fountain
533-025	1201 SNK	<2		Sink
533-026	1202 - SNK	<2		Sink
533-027	1205 - SNK	<2		Sink
533-028	1204 - Nurse's SNK	<2		Sink
533-029	1204 - Nurse's DF	2		Drinking Fountain
533-030	1212 Men's SNK	<2		Sink
533-031	1217 Women's SNK	<2		Sink
533-032	1215 Gym DF	<2		Drinking Fountain
533-033	1120 Women's Left	<2		Sink
533-034	1120 Women's Right	<2		Sink
533-035	1102 SNK	2		Sink
533-036	1100A WC Left	<2		Water Cooler
533-037	1100 WC Right	<2		Water Cooler
533-038	1116 - North SNK	<2		Sink
533-039	1116 - SNK South West	<2		Sink
533-040	1116 - SNK - West	<2		Sink
533-041	1100A - Left -SNK	<2		Sink
533-042	1100A - Middle Left - SNK	<2		Sink
533-043	1100A - Middle -SNK	<2		Sink
533-044	1100A - Middle Right - SNK	<2		Sink
533-045	1100A - Right - SNK	<2		Sink
533-046	1109 SE - SNK	<2		Sink
533-047	1109 NW - SNK	<2		Sink
533-048	1109 NE - SNK	<2		Sink
533-049	1109 E - SNK	<2		Sink
533-050	3300 - WC - Left	<2		Water Cooler
533-051	3300 - WC - Right	<2		Water Cooler
533-052	3301 - Production - Snk	<2		Sink
533-053	2300 Hallway Left DF	<2		Drinking Fountain
533-054	2300 Hallway Right DF	<2		Drinking Fountain
533-055	2101 Snk - SE	<2		Sink
533-056	2101 Snk - SW	<2		Sink
533-057	2101 Snk - NW	<2		Sink
533-058	2101 Snk - N	<2		Sink
533-059	2106 - Snk	<2		Sink
533-060	2100D - Snk - Left	<2		Sink
533-061	2100D - Snk - Left middle	<2		Sink
533-062	2100D - Snk - Middle	<2		Sink
533-063	2100D - Snk - Right Middle	3		Sink
533-064	2100D - Snk - Right	<2		Sink
533-065	2105 - Snk	<2		Sink
533-066	2109 - SE - Snk	<2		Sink
533-067	2109 SW - Snk	<2		Sink
533-068	2109 NW - Snk	<2		Sink
533-069	1105 - Snk	<2		Sink

**Saint Paul Public Schools
Water Sample Results
AGAPE
Building Number: 719**

Sample Date: May 1st, 2016
Sampled by: Nancy Fischer & Alissa Houghtaling

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
719-001	Room 1055- Receiving	below 2		slop
719-002	Room 1053- Kitchen- hand sink	below 2		hand sink

719-003	Room 1053- Kitchen- left	below 2		sink
719-004	Room 1053- Kitchen-middle	below 2		sink
719-005	Room 1053- Kitchen-right	below 2		sink
719-006	Room 1052- Custodian			slop
719-007	Room 1051-W. Restroom-left	below 2		sink
719-008	Room 1051-W. Restroom-right	3ppb		sink
719-009	Room 1050- M. Restroom-left	below 2		sink
719-010	Room 1050- M. Restroom-right	below 2		sink
719-011	1048- Cafeteria	4ppb		cooler
719-012	1048-Cafeteria	below 2		cooler
719-013	Room 1045- Science Lab	24ppb	below 2	sink
719-014	Room 1045- Science Lab	36ppb	below 2	sink
719-015	Room 1045- Science Lab	below 2		sink
719-016	Room 1045- Science Lab	below 2		sink
719-017	Room 1045- Science Lab	below 2		sink
719-018	Room 1045- Science Lab			sink
719-019	Room 1045- Science Lab	below 2		sink
719-020	Room 1046- Nurse	below 2		sink
719-021	Room 1047- Nurse Restroom	below 2		sink
719-022	Room 1044- Mechanical	below 2		slop
719-023	Room 1039-W. Restroom-left	below 2		sink
719-024	Room 1039-W. Restroom-right	below 2		sink
719-025	Drinking Foun.-by rm 1038-left	below 2		cooler
719-026	Drinking Foun.-by rm 1038-right	below 2		cooler
719-027	Room 1037- Staff Restroom	12ppb		sink
719-028	Room 1036- Laundry	below 2		sink
719-029	Room 1035 -C. Care Kitchen-left	below 2		sink
719-030	Room1035 -C. Care Kitchen-right	below 2		sink
719-031	Room 1035 -C. Care Kitchen-hand	below 2		hand sink
719-032	Room 1030- left	below 2		sink
719-033	Room 1030- right	below 2		sink
719-034	Room 1034- Restroom-left	below 2		sink
719-035	Room 1034- Restroom-right	below 2		sink
719-036	Room 1031- left	below 2		sink
719-037	Room 1031- right	below 2		sink
719-038	Room 1032- left	below 2		sink
719-039	Room 1032- right	below 2		sink
719-040	Drinking Fountain by 1032-left	3ppb		cooler
719-041	Drinking Fountain by 1032-right	3ppb		cooler
719-042	Room 1033- left	below 2		sink
719-043	Room 1033- right	below 2		sink
719-044	Room 1028- left	20ppb		sink
719-045	Room 1028- right	below 2		sink
719-046	Room 1027- left	below 2		sink
719-047	Room 1027- right	below 2		sink
719-048	Room 1020-Health Start-left	below 2		sink
719-049	Room 1020-Health Start-right	below 2		sink
719-050	Room 1021- Exam	below 2		sink
719-051	Room 1022	below 2		sink
719-052	Staff Restroom by 1016-left	below 2		sink
719-053	Staff Restroom by 1016-right	below 2		sink
719-054	Room 1016- Custodial	below 2		slop
719-055	Room 1015- W. Restroom-left	below 2		sink
719-056	Room 1015- W. Restroom-right	below 2		sink
719-057	Drinking Fountain across 1014	below 2		cooler
719-058	Room 1014- Home Ec-left	below 2		sink
719-059	Room 1014- Home Ec-right	below 2		sink
719-060	Room 1013	below 2		sink
719-061	Room 1007- Break Room	7ppb		sink

Saint Paul Public Schools
Water Sample Results
Como Park Elementary
Building Number: 431

Sample Date:5/01/2016
Sampled By: Chandala, Ted Sherman & Heidi

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
431-001	Kitchen Large Sink	6ppb		Large Sink
431-002	Kitchen Hand Sink	Below 2ppb		Sink
431-003	BUNN	Below 2ppb		Sink
431-004	Faculty Lounge	Below 2ppb		Sink
431-005	Faculty Mens Restroom	Below 2ppb		Sink
431-006	Faculty Womens Restroom	Below 2ppb		Sink
431-007	Boys Restroom	Below 2ppb		Sink
431-008	Girls Restroom - Left	8ppb		Sink
431-009	Girls Restroom - Right	14ppb		Sink
431-010	Hall by Above Girls Restroom	Below 2ppb		Fountain
431-011	Special Dinning Room 1318	15ppb		Sink
431-012	Janitor's Closet by Main Office	Below 2ppb		Utility Sink
431-013	Bath Off Cot Room 1134	Below 2ppb		Sink
431-014	Nurses Office - East room 1135	4ppb		Sink
431-015	Nurses Office - West room 1134	3ppb		Sink
431-016	Cot Room 1132	Below 2ppb		Sink
431-017	Restroom Off Cot Room 1132	5ppb		Sink
431-018	Projection Room NW 1103			Sink

431-019	Science Room 1102 - Left	4ppb		Sink
431-020	Science Room 1102- Right	18ppb		Sink
431-021	Utility off 1111	Below 2ppb		Sink
431-022	Restroom Off 1111 Hand Sink	Below 2ppb		Sink
431-023	Room 1111	Below 2ppb		Sink
431-024	Girls Restroom	Below 2ppb		Sink
431-025	Boys Restroom	41ppb	Below 2ppb	Sink
431-026	Room 1112 East	48ppb	Below 2ppb	Sink
431-027	Room 1113 West	5ppb		Sink
431-028	Restroom between 1112 and 1113	Below 2ppb		Sink
431-029	Room 1115 West	28ppb	Below 2ppb	Sink
431-030	Room 1114 East	Below 2ppb		Sink
431-031	Restroom Off Rm 1115	8ppb		Sink
431-032	Speech Room 1130	Below 2ppb		Sink
431-033	Room off Speech 1128	9ppb		Sink
431-034	Restrm Off Phys. Therapy 1123	Below 2ppb		Sink
431-035	Occupational Therapy 1123	3ppb		Sink
431-036	Room 1116 West	12ppb		Sink
431-037	Room 1117 East	47ppb	Below 2ppb	Sink
431-038	Restroom Off 1117 East	Below 2ppb		Sink
431-039	Room 1118	Below 2ppb		Sink
431-040	Restroom Off Rm. 1119			Sink
431-041	Room 1119	13ppb		Sink
431-042	Room 1120	11ppb		Sink
431-043	Room 1121	6ppb		Sink
431-044	Restroom Off 1120	Below 2ppb		Sink
431-045	Room 1201	Below 2ppb		Sink
431-046	Room 1202	Below 2ppb		Sink
431-047	Room 1203	4ppb		Sink
431-048	Speech 1138	10ppb		Sink
431-049	Foods Classroom West 1321	3ppb		Sink
431-050	Foods Classroom South 1321	Below 2ppb		Sink
431-051	Room 1204	4ppb		Sink
431-052	Hall by Pool	Below 2ppb		Fountain
431-053	Janitor's Closet by Pool 1205	3ppb		Utility Sink
431-054	Restroom Off Pool Office	12ppb		Sink
431-055	Girls Locker Room by Pool - Left	3ppb		Sink
431-056	Girls Locker Room by Pool - Right	7ppb		Sink
431-057	Laundry Room 1212	17ppb		Sink
431-058	Boys Locker Room by Pool - Left	2ppb		Sink
431-059	Boys Locker Room by Pool - Right	4ppb		Sink
431-060	Room 1310	2ppb		Sink
431-061	Room 1313	Below 2ppb		Sink
431-062	Room 1309	Below 2ppb		Sink
431-063	Room 1308	Below 2ppb		Sink
431-064	Room 1315	Below 2ppb		Sink
431-065	Room 1307	41ppb	Below 2ppb	Sink
431-066	Secon Floor Admin Workroom 2004	26ppb	Below 2ppb	Sink
431-067	Room 2101	5ppb		Sink
431-068	Room 2101	Below 2ppb		Fountain
431-069	Janitor's Closet by Room 2000B	Below 2ppb		Utility Sink
431-070	Room 2104	19ppb		Sink
431-071	Room 2104	5ppb		Fountain
431-072	Room 2108	5ppb		Sink
431-073	Room 2108			Fountain
431-074	Workroom Across From 2204			Sink
431-075	Rm 2202	42ppb	Below 2ppb	Sink
431-076	Rm 2202	15ppb		Fountain
431-077	Rm 212			Sink
431-078	Rm 212			Fountain
431-079	Faculty Room 2204	37ppb	Below 2ppb	Sink
431-080	Girls Restroom by Elevator	8ppb		Sink
431-081	Hall by Restrooms & Elevator	3ppb		Sink
431-082	Mens Restroom by Elevator	22ppb	Below 2ppb	Sink
431-083	Janitor's Closet by Room 2212	29ppb	Below 2ppb	Utility Sink
431-084	Room 2209 - North	22ppb	Below 2ppb	Sink
431-085	Room 2209 - North	8ppb		Fountain
431-086	Boys Restroom Arch #2210 - Left	8ppb		Sink
431-087	Boys Restroom Arch #2210 - Right	14ppb		Sink
431-088	Girls Restroom Arch #2220 - Left	26ppb	Below 2ppb	Sink
431-089	Girls Restroom Arch #2220 - Right	24ppb	Below 2ppb	Sink
431-090	Room 2309	24ppb	Below 2ppb	Sink
431-091	Room 2309	23ppb	Below 2ppb	Fountain
431-092	Room 2308	17ppb		Sink
431-093	Room 2308	18ppb		Fountain
431-094	Workroom Off Library Arch #2319	11ppb		Sink
431-095	Boys Restroom by Rm 220 - Left	14ppb		Sink
431-096	Boys Restroom by Rm 220 - Right	9ppb		Sink
431-097	Hall Outside Boys Restroom Left	Below 2ppb		Cooler
431-097.1	Hall Outside Boys Restroom Right	Below 2ppb		Cooler
431-098	Girls Restroom by Rm 201 - Left	14ppb		Sink
431-099	Girls Restroom by Rm 201 - Right	8ppb		Sink
431-100	Room 2304	26ppb	Below 2ppb	Sink
431-101	Restroom Across From 2607 - Left	19ppb		Sink
431-102	Restroom Across From 2607 - Right	Below 2ppb		Sink
431-103	Room 2607 Restroom - Left	2ppb		Sink
431-104	Room 2607 Restroom - Right	6ppb		Sink

431-105	Outside Room 2607 - Left	Below 2ppb		Cooler
431-106	Outside Room 2607 - Right	3ppb		Cooler
431-107	Restroom in Room 245			Sink
431-108	Outside Room 242 - Left			Fountain
431-109	Outside Room 242 - Right			Fountain
431-110	Office Copy Room 2701	2ppb		Sink
431-111	Office Restroom 2701	6ppb		Sink
431-112	Room 2506	Below 2ppb		Sink
431-113	Hall by Room 238-Left	3ppb		Cooler
431-114	Hall By Room 238 - Right			Fountain
431-115	Girls Restroom By Rm 238 - Left	5ppb		Sink
431-116	Girls Restroom By Rm 238 - Center			Sink
431-117	Girl's Restroom by Room 338 - Right			Sink
431-118	Room 238			Sink
431-119	Room 2604 - Left	2ppb		Sink
431-120	Room 2604 - Right	2ppb		Sink
431-121	Hall by Room 2604 - Left	Below 2ppb		Cooler
431-122	Hall by Room 2604 - Right			Fountain
431-123	Boys Restroom By Rm 226 - Left	Below 2ppb		Sink
431-124	Boys Restroom By Rm 226-Center	Below 2ppb		Sink
431-125	Boys Restroom By Rm 226-Right	Below 2ppb		Sink
431-126	Custodial Closet by Above Boys Restroom	6ppb		Sink
431-127	Room 2302	Below 2ppb		Sink
431-128	Room 2302	Below 2ppb		Drinking Fountain
431-129	Basement Utility Sink	Below 2ppb		Sink

Saint Paul Public Schools
Water Sample Results
Chelsea Heights Elementary
Building Number: 425

Sample Date: May 1st, 2016
Sampled By: Parker Prose

Sample #	Location	Sample Results 2016	15 Sconds Flush Sample	Fixture Type
425-001	kitchen hand sink	4		SNK
425-002	bunn coffee	<2		Bunn
425-003	main sink left	<2		KS
425-004	main sink right	<2		KS
425-005	kitchen bathroom sink	10		SNK
425-006	1305 bathroom	<2		SNK
425-007	1305 sink	<2		SNK
425-008	1306 sink	<2		SNK
425-009	1306 bathroom sink	<2		SNK
425-010	1306 dinking fountain	<2		DF
425-011	1304 sink	<2		SNK
425-012	1303 sink	2		SNK
425-013	boys bathroom left outside 1307	<2		SNK
425-014	boys bathroom right outside 1307	<2		SNK
425-015	1309A	<2		SNK
425-016	hallway DF	<2		DF
425-017	outside 1311 Girls Left Snk	<2		SNK
425-018	outside 1311 Girls Middle Snk	6		SNK
425-019	Outside 1311 Girls Right Snk	2		SNK
425-020	1302 Sink	3		SNK
425-021	1301 Sink	<2		SNK
425-022	1200 Boys Sink	5		SNK
425-023	1205 Boys sink Left	<2		SNK
425-024	1205 Boys Sink Right	<2		SNK
425-025	Nurse bathroom sink	<2		SNK
425-026	WC in hallway	<2		WC
425-027	Office Restroom Sink	<2		SNK
425-028	1202 Sink	5		SNK
425-029	1201 Sink Left	<2		SNK
425-030	1201 Sink Right	<2		SNK
425-031	staff lounge	<2		SNK
425-032	1101 Girls Left	3		SNK
425-033	1101 Girls Right	<2		SNK
425-034	1101 sink	6		SNK
425-035	1101 DF	<2		DF
425-036	1102 Sink	<2		SNK
425-037	1103 Right	<2		SNK
425-038	1103 Left	<2		SNK
425-039	1108 Boys Sink	31	288-7ppb	SNK
425-040	1108 Girls Left	<2		SNK
425-041	1108 Girls Right	<2		SNK
425-042	gym drinking fountain inbetween boys and girls bathroom	<2		DF
425-043	gym drinking fountain	<2		DF
425-044	boys bathroom by gym	7		SNK
425-045	DF outside 1121	<2		Df
425-046	1121 Girls Bathroom by Gym Left	<2		SNK
425-047	1121 Girls bathroom by gym Right	6		SNK
425-048	1117 girls bathroom	<2		SNK

425-049	1117 boys bathroom	<2		SNK
425-050	media center water cooler	<2		WC
425-051	2112 sink	6		SNK
425-052	2112 DF	<2		DF
425-053	2111 DF	<2		DF
425-054	2111 Sink	<2		SNK
425-055	2110 df	<2		DF
425-056	2110 sink	<2		SNK
425-057	2107 sink	<2		SNK
425-058	2103 sink	<2		SNK
425-059	2103 df	<2		DF
425-060	2102 sink	<2		SNK
425-061	2102 df	5		SNK
425-062	2101 sink	<2		SNK
425-063	2114 slop sink	<2		Slop Sink
425-064	bathroom across 2203 girls Left			SNK
425-065	Girls Bathroom across 2203 right			SNK
425-066	DF across 2203 left			DF
425-067	DF across 2203 Right			DF
425-068	2202 sink			SNK
425-069	2201 boys bathroom right			SNK
425-070	2201 boys bathroom left			SNK
425-071	0.206			SNK
425-072	0.212			SNK
425-073	basement DF			DF
425-074	0202 bottom			Slop Sink
425-075	0202 top			Slop Sink

Saint Paul Public Schools
Water Sample Results
Hamline Elementary
Building Number: 482

Sample Date: May 1st, 2016
Sampled by: Parker Prose

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
482-001	1123 NE corner	<2		SNK
482-002	1123 NE corner	<2		KS
482-003	1123 NE Corner Bunn	<2		Coffee
482-004	1123A	<2		SNK
482-005	1123A	<2		Sprayer Snk
482-006	1123A - Left	<2		KS
482-007	1123A - Right	<2		KS
482-008	1131	<2		SNK
482-009	1012B	3		SNK
482-010	1012	3		SNK
482-011	1004	<2		SNK
482-012	1108	<2		WC
482-013	1108 - Left	2		SNK
482-014	1108 - Middle	<2		SNK
482-015	1108 - Right	<2		SNK
482-016	1112 - Left	<2		SNK
482-017	1112 - Middle	<2		SNK
482-018	1112 - Right	<2		SNK
482-019	1213	9		SNK
482-020	1217 Bathroom	14		SNK
482-021	1217 Classroom	6		SNK
482-022	1216 Bathroom	2		SNK
482-023	1216 Classroom	8		SNK
482-024	1214	10		SNK
482-025	1214	64	#173 - 7ppm	DF
482-026	1200 hallway	<2		WC
482-027	1209 Left	<2		SNK
482-028	1209 Right	<2		SNK
482-029	1207 Left	<2		SNK
482-030	1207 Right	<2		SNK
482-031	1205	<2		SNK
482-032	1205	<2		DF
482-033	1206	<2		SNK
482-034	1206	<2		DF
482-035	1204	<2		Snk
482-036	1204	5		DF
482-037	1203	4		SNK
482-038	1203	19		DF
482-039	1202	5		SNK
482-040	1202	<2		DF
482-041	1201	<2		SNK
482-042	1201	<2		DF
482-043	1221	<2		Slop Sink
482-044	1101	<2		SNK
482-045	1101B	<2		SNK
482-046	1103	<2		SNK
482-047	1103	<2		DF
482-048	1105	<2		SNK
482-049	1107	<2		SNK

482-050	1109	<2		SNK
482-051	1302	<2		Slop Sink
482-052	Gym Left	6		DF
482-053	Gym Right	4		DF
482-054	1510	<2		Snk
482-055	1513 Left	5		SNK
482-056	1513 Right	2		SNK
482-057	1509	2		WC
482-058	1509 Left	2		SNK
482-059	1509 Right	2		SNK
482-060	1504	<2		SNK
482-061	1401	<2		SNK
482-062	1403	<2		SNK
482-063	1405	<2		SNK
482-064	1400 Hallway	<2		WC
482-065	1406 Left	<2		SNK
482-066	1406 Right	<2		SNK
482-067	1408 Left	<2		SNK
482-068	1408 Right	<2		SNK
482-069	1420A	<2		SNK
482-070	1420	<2		SNK
482-071	2202	<2		SNK
482-072	2202	<2		DF
482-073	2201	<2		SNK
482-074	2201	<2		DF
482-075	2204	3		SNK
482-076	2204	5		DF
482-077	2203	4		SNK
482-078	2203	<2		DF
482-079	2205	<2		SNK
482-080	2205	<2		DF
482-081	2206	<2		SNK
482-082	2206	<2		DF
482-083	2207 Left	<2		SNK
482-084	2207 Right	<2		SNK
482-085	2209 Left	<2		SNK
482-086	2209 Right	4		SNK
482-087	2200 Hallway	<2		WC
482-088	2207/2209 hallway	3		WC
482-089	2217	2		SNK
482-090	2217	<2		DF
482-091	2218	4		SNK
482-092	2218	<2		DF
482-093	2219	3		SNK
482-094	2219	7		DF
482-095	2220	3		SNK
482-096	2220	4		DF
482-097	2221	12		SNK
482-098	2221	7		DF
482-099	2222	<2		SNK
482-100	2222	6		DF

Saint Paul Public Schools
Water Sample Results
Gordon Parks
Building Number: 710

Sample Date: May 1st, 2016
Sampled by: Nancy Fischer & Alissa Houghtaling

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
710-001	Room 1212- Mechanical	below 2		slop
710-002	Room 1208- Student Store	3ppb		hand sink
710-003	Room 1208- Student Store	below 2		sink
710-004	Women's Restroom- across from Guidance	below 2		sink
710-005	Women's Restroom- across from Guidance	5ppb		sink
710-006	Women's Restroom- across from Guidance	2ppb		sink
710-007	Women's Restroom- across from Guidance	below 2		sink
710-008	Women's Restroom- across from Guidance	below 2		sink
710-009	Men's Restroom- across from Guidance	below 2		sink
710-010	Men's Restroom- across from Guidance	below 2		sink
710-011	Men's Restroom- across from Guidance	below 2		sink
710-012	Men's Restroom- across from Guidance	below 2		sink
710-013	Men's Restroom- across from Guidance	below 2		sink
710-014	Drinking Fountain-left by Guidance	below 2		cooler
710-015	Drinking Fountain-right by Guidance	below 2		cooler
710-016	Gym(1302)- Drinking Fountain- left	below 2		cooler
710-017	Gym(1302)- Drinking Fountain- right	4ppb		cooler
710-018	Room 1126-office	below 2		sink
710-019	Room 1122-nurses office	below 2		sink
710-020	Restroom next to room 1122	below 2		sink
710-021	Nurses office commons- next to room1118	below 2		sink
710-022	Room 1118- nurses office	below 2		sink
710-023	Room 1136- Custodian	below 2		slop
710-024	Drinking Fountain- left- next to elevator	3ppb		cooler
710-025	Drinking Fountain- right- next to elevator	below 2		cooler

710-026	Men's Staff Restroom- by elevator	below 2		sink
710-027	Women's Restroom- across from rm 1107	below 2		sink
710-028	Room 1110-office	below 2		sink
710-029	Staff Lounge area outside Rm 1110	below 2		sink
710-030	Room 1104 -workroom	below 2		sink
710-031	Room 1103	2ppb		sink
710-032	Room 1101- Career Lab	below 2		sink
710-033	Women's Restroom- 2nd floor- left	below 2		sink
710-034	Women's Restroom- 2nd floor- right	below 2		sink
710-035	Men's Restroom- 2nd floor- left	below 2		sink
710-036	Men's Restroom- 2nd floor- right	below 2		sink
710-037	Drinking Fountain-2nd floor- left	below 2		cooler
710-038	Drinking Fountain-2nd floor- right	below 2		cooler
710-039	Unisex Restroom-2nd floor	below 2		sink
710-040	Room 2011- science classroom	below 2		sink
710-041	Room 2011- science classroom	below 2		sink
710-042	Room 2011- science classroom	5ppb		sink
710-043	Room 2011- science classroom	below 2		sink
710-044	Room 2013- storage off rm 2011	below 2		sink

Saint Paul Public Schools
Water Sample Results
Hubbs
Building Number: 470

Sample Date: May 1st, 2016
Sampled by: Nancy Fischer & Alissa Houghtaling

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
470-001	Room 1110- Custodial	below 2		sink
470-002	Room 1110- Custodial	below 2		slop
470-003	Room 1210- Childcare	3ppb		cooler
470-004	Room 1210- Childcare	below 2		sink
470-005	Room 1210A- Restroom- left	below 2		sink
470-006	Room 1210A- Restroom- middle	below 2		sink
470-007	Room 1210A- Restroom- right	below 2		sink
470-008	Room 1213	4ppb		cooler
470-009	Room 1213	4ppb		sink
470-010	Room 1214- left	below 2		sink
470-011	Room 1214- right	below 2		sink
470-012	Room 1214 Restroom- left	below 2		sink
470-013	Room 1214 Restroom- right	below 2		sink
470-014	Room 1215	below 2		sink
470-015	Room 1216- kitchen- left	below 2		sink
470-016	Room 1216- kitchen- right	below 2		sink
470-017	Room 1216- kitchen- hand sink	below 2		sink
470-018	Room 1203- staff	below 2		sink
470-019	Room 1203B- restroom	below 2		sink
470-020	Room 1203A- restroom	below 2		sink
470-021	Room 1315- Nurses	below 2		sink
470-022	Drinking Fountain- left by 1430B	below 2		cooler
470-023	Drinking Fountain- right by 1430B	below 2		cooler
470-024	Room 1430C- Men's Restroom	below 2		sink
470-025	Room 1430C- Men's Restroom	5ppb		sink
470-026	Room 1430C- Men's Restroom	below 2		sink
470-027	Room 1430C- Men's Restroom	below 2		sink
470-028	Room 1430A- Women's Restroom	below 2		sink
470-029	Room 1430A- Women's Restroom	5ppb		sink
470-030	Room 1430A- Women's Restroom	below 2		sink
470-031	Room 1430A- Women's Restroom	below 2		sink
470-032	Room 1407	5ppb		sink
470-033	Room 1202B- Maintance	4ppb		slop
470-034	Room 1202A- W. Restroom-left	below 2		sink
470-035	Room 1202A- W. Restroom-middle	3ppb		sink
470-036	Room 1202A- W. Restroom-right	below 2		sink
470-037	Room 1202C-M. Restroom-left	below 2		sink
470-038	Room 1202C-M. Restroom-middle	below 2		sink
470-039	Room 1202C-M. Restroom-right	below 2		sink
470-040	Drinking Fountain-left-by1202C	below 2		cooler
470-041	Drinking Fountain-right-by 1202C	below 2		cooler

Saint Paul Public Schools
Water Sample Results
Jackson Prep
Building Number: 500

Sample Date: May 1st, 2016
Sampled by: Mary Ferrian, Chad Whaylen, Natalie Eskew & Kobe Patch

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture type
500-001	Kitchen Dish N. left - SNK	>2		Sink
500-002	Kitchen Dish N Right - SNK	>2		Sink
500-003	Kitchen North Wall - SNK	>2		Sink
500-004	Kitchen Bunn	xxx		Bunn
500-005	Kitchen South Wall - SNK	>2		Sink
500-006	Kitchen North Wall - SNK	>2		Sink

500-007	Maintenance 1213A - SNK	>2		Slop
500-008	Gym 1207 North - DF	>2		Drinking Fountain
500-009	Gym 1207 - DF	>2		Drinking Fountain
500-010	Room 1210 - SNK	>2		Sink
500-011	Room 1210 - DF	>2		Drinking Fountain
500-012	Room 1210 Restroom - SNK	>2		Sink
500-013	Room 1208 - SNK	>2		Sink
500-014	Room 1208 - DF	>2		Drinking Fountain
500-015	Room 1208 Restroom - SNK	3		Sink
500-016	Handicap restroom by Room 1208 - SNK	6		Sink
500-017	Room 1206 - SNK	>2		Sink
500-018	Room 1206 - DF	>2		Drinking Fountain
500-019	Room 1206 Restroom - SNK	>2		Sink
500-020	Room 1204 - SNK	>2		Sink
500-021	Room 1204 - DF	>2		Drinking Fountain
500-022	Room 1204 restroom - SNK	>2		Sink
500-023	Boy's Restroom by 1103 left - SNK	>2		Sink
500-024	Boy's restroom by 1103 right - SNK	>2		Sink
500-025	Women's restroom by main office left - SNK	>2		Sink
500-026	Women's restroom by main office right - SNK	>2		Sink
500-027	Principle's restroom - SNK	>2		Sink
500-028	Maintenance 1111 lower - SNK	>2		Sink
500-029	Maintenance 1111 upper - SNK	>2		Sink
500-030	Room 1112 - SNK	>2		Sink
500-031	Hallway by room 1112 - WC	>2		Water Cooler
500-032	Room 1114 - SNK	>2		Sink
500-033	Room 1116 - SNK	26		Sink
500-034	Room 1116 - DF	10		Drinking Fountain
500-035	Room 2101 Lounge - SNK	>2		Sink
500-036	Girl's restroom by Room 2105 left - SNK	>2		Sink
500-037	Girl's restroom by Room 2105 right - SNK	>2		Sink
500-038	Handicap restroom by room 2105 - SNK	>2		Sink
500-039	Maintenance 2110 lower - SNK	>2		Slop
500-040	Room 2112A - SNK	>2		Sink
500-041	Hallway by Room 2112 - WC	>2		Water Cooler
500-042	Boy's restroom by Room 2114 left - SNK	>2		Sink
500-043	Boy's restroom by room 2114 right - SNK	>2		Sink
500-044	Room 2116 - SNK	>2		Sink
500-045	Room 2116 - DF	>2		Drinking Fountain
500-046	Room 2113 - SNK	18		Sink
500-047	Room 2113 - DF	>2		Drinking Fountain
500-048	Girl's Restroom by 3101 left - SNK	>2		Sink
500-049	Girl's restroom by 3101 right - SNK	4		Sink
500-050	Maintenance 3108 left - SNK	>2		Sink
500-051	Maintenance 3108 right - SNK	>2		Sink
500-052	Room 3105 restroom - SNK	>2		Sink
500-053	Hallway by Room 3110 - WC	>2		Water Cooler
500-054	Room 3112 - SNK	>2		Sink
500-055	Boy's Restroom by 3112 left - SNK	>2		Sink
500-056	Boy's Restroom by 3112 right - SNK	>2		Sink
500-057	Room 3114 - SNK	12		Sink
500-058	Room 3114 - DF	14		Drinking Fountain
500-033.5	Room 1116 - SNK		2	Sink

Saint Paul Public Schools
Water Sample Results
Maxfield Elementary
Building Number: 524

Sample Date: May 1, 2016
Sampled by: Natalie Eskew & Kobe Patch

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
524-001	Kitchen Southeast	<2ppb		Sink
524-002	Kitchen	4ppb		Hand Sink
524-003	Kitchen	NA		BUNN
524-004	Kitchen Northeast Right	<2ppb		Sink
524-005	Kitchen Northeast Left	<2ppb		Sink
524-006	Kitchen Office Restroom	8ppb		Sink
524-007	Hallway by Cafeteria	<2ppb		Fountain
524-008	Ladies by Cafeteria	<2ppb		Sink
524-009	Boys by Cafeteria	<2ppb		Sink
524-010	Main Office Restroom	<2ppb		Sink
524-011	Main Office Room 1005	<2ppb		Sink
524-012	Nurse Room 1112	<2ppb		Sink
524-013	Nurse Restroom	<2ppb		Sink
524-014	Boiler Room	<2ppb		Utility Sink
524-015	Hallway by Room 1111 Left	<2ppb		Fountain
524-016	Hallway by Room 1111 Right	<2ppb		Fountain
524-017	Room 1102	<2ppb		Sink
524-018	Room 1103	<2ppb		Sink
524-019	Room 1111	<2ppb		Sink
524-020	Room 1104	<2ppb		Sink
524-021	Room 1105	<2ppb		Sink
524-022	Maintenance Room 1108	4ppb		Utility Sink
524-023	Hallway by Room 1106 - Left	<2ppb		Fountain

524-024	Hallway by Room 1106 - Right	<2ppb		Fountain
524-025	Room 1106	9ppb		Sink
524-026	Maintenance Room 1210 Restroom	<2ppb		Sink
524-027	Room 1306	<2ppb		Sink
524-028	Room 1305	<2ppb		Sink
524-029	Room 1303	26ppb		Sink
524-029R	Room 1303 RETEST		7ppb	Sink
524-030	Room 1302	66ppb		Sink
524-030R	Room 1302 RETEST		3ppb	Sink
524-031	Womens Restroom by Gymnasium	<2ppb		Sink
524-032	Mens Restroom by Gymnasium	43ppb		Sink
524-032R	Mens Restroom by Gymnasium RETEST		8ppb	Sink
524-033	Maintenance by Gymnasium	<2ppb		Utility Sink
524-034	Gymnasium West	<2ppb		Fountain
524-035	Gymnasium East	<2ppb		Fountain
524-036	Room 1403	12ppb		Sink
524-037	Room 1406	<2ppb		Sink
524-038	Room 1409	26ppb		Fountain
524-038R	Room 1409 Retest		5ppb	Fountain
524-039	Room 1410	37ppb		Sink
524-039R	Room 1410 RETEST		<2ppb	Sink
524-040	Room 1410	9ppb		Fountain
524-041	Room 1413	8ppb		Sink
524-042	Hallway by Room 1512 Left	<2ppb		Fountain
524-043	Hallway by Room 1512 Right	<2ppb		Fountain
524-044	Hallway by Room 1512	<2ppb		Sink
524-045	Maintenance Room 1511C	<2ppb		Utility Sink
524-046	Room 1603	<2ppb		Sink
524-047	Room 1603	<2ppb		Fountain
524-048	Room 1603 Restroom	<2ppb		Sink
524-049	Room 1602	3ppb		Sink
524-050	Room 1602	<2ppb		Fountain
524-051	Room 1602 Restroom	<2ppb		Sink
524-052	Room 1509	17ppb		Sink
524-053	Room 1503	9ppb		Sink
524-054	Room 1504 Northwest	<2ppb		Sink
524-055	Room 1504 Southwest	<2ppb		Sink
524-056	Room 1504 East Wall	33ppb		Sink
524-056R	Room 1504 East Wall RETEST		<2ppb	Sink
524-057	Room 1502	<2ppb		Sink
524-058	Room 2101	<2ppb		Sink
524-059	Room 2102	<2ppb		Sink
524-060	Room 2103	<2ppb		Sink
524-061	Room 2104	<2ppb		Sink
524-062	Room 2105	<2ppb		Sink
524-063	Maintenance Room 2108	<2ppb		Utility Sink
524-064	Hallway by Room 2015 Left	<2ppb		Fountain
524-065	Room 2106	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
Washington Tech
Building Number: 240

Sample Date: 5/1/2016
Sampled By: Chandala, Ted Sherman, Jake

Sample Number	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
240-001	Women's Varsity Locker Room	Below 2ppb		Cooler
240-002	Women's Varsity L.R. Office Restroom	Below 2ppb		Sink
240-003	Women's Varsity Locker Room Left	Below 2ppb		Sink
240-004	Women's Varsity Locker Room Right	Below 2ppb		Sink
240-005	Women's Phy Ed Locker Room	Below 2ppb		Cooler
240-006	Women's Phy Ed Locker Room Left	Below 2ppb		Sink
240-007	Women's Phy Ed Locker Room Right	Below 2ppb		Sink
240-008	Main Gym Cooler Left	Below 2ppb		Cooler
240-009	Main Gym Cooler Right	Below 2ppb		Cooler
240-010	Men's Phy Ed Coaches Restroom	Below 2ppb		Sink
240-011	Men's Phy Ed Locker Room Cooler	Below 2ppb		Cooler
240-012	Men's Phy Ed Locker Room Left	Below 2ppb		Sink
240-013	Men's Phy Ed Locker Room Right	Below 2ppb		Sink
240-014	Men's Varsity Locker Room	Below 2ppb		Cooler
240-015	Men's Varsity Locker Room Left			Sink
240-016	Men's Varsity Locker Room Right	Below 2ppb		Sink
240-017	Auxiliary Gym Cooler Left	Below 2ppb		Cooler
240-018	Auxiliary Gym Cooler Right	Below 2ppb		Cooler
240-019	Pool Hallway	Below 2ppb		Cooler
240-020	Men's Pool Locker Room Left	Below 2ppb		Sink
240-021	Men's Pool Locker Room Right	Below 2ppb		Sink
240-022	Pool Area	Below 2ppb		Cooler
240-023	Women's Pool Locker Room Left	Below 2ppb		Sink
240-024	Women's Pool Locker Room Right	Below 2ppb		Sink
240-025	Main Office 1605	Below 2ppb		Sink
240-026	Main Office Restroom	Below 2ppb		Sink
240-027	Main Office Workroom 1604	Below 2ppb		Sink
240-028	Main Office 1607	Below 2ppb		Sink
240-029	Principal's Conference Room 1610	Below 2ppb		Sink

240-030	MCRC 1623	Below 2ppb		Sink
240-031	IRC Workroom	Below 2ppb		Sink
240-032	Food Lab Laundry 1721	Below 2ppb		Utility Sink
240-033	Food Lab 1720 North	Below 2ppb		Sink
240-034	Food Lab 1720 N. E.	Below 2ppb		Sink
240-035	Food Lab 1720 S. E.	Below 2ppb		Sink
240-036	Food Lab 1720 South Left	Below 2ppb		Sink
240-037	Food Lab 1720 South Middle	Below 2ppb		Sink
240-038	Food Lab 1720 South Right	Below 2ppb		Sink
240-039	Food Lab 1720 S. W.	Below 2ppb		Sink
240-040	Food Lab 1720 N. W.	Below 2ppb		Sink
240-041	Classroom 1710	Below 2ppb		Sink
240-042	Preschool Lab 1740 Restroom	Below 2ppb		Sink
240-043	Preschool Lab 1740 Left	Below 2ppb		Sink
240-044	Preschool Lab 1740 Right	Below 2ppb		Sink
240-045	Hallway North of 1301 Left	Below 2ppb		Cooler
240-046	Hallway North of 1301 Right	Below 2ppb		Cooler
240-047	North of 1301 Wemen's Restroom Left	Below 2ppb		Sink
240-048	North of 1301 Wemen's Restroom Right	Below 2ppb		Sink
240-049	North of 1301 Men's Restroom Left	Below 2ppb		Sink
240-050	North of 1301 Men's Restroom Right			Sink
240-051	Classroom 1301	Below 2ppb		Sink
240-052	Hallway South of 1270 Left	Below 2ppb		Cooler
240-053	Hallway South of 1270 Right	Below 2ppb		Cooler
240-054	South of 1270 Wemen's Restroom Left	64ppb	Below 2ppb	Sink
240-055	South of 1270 Wemen's Restroom Right	Below 2ppb		Sink
240-056	South of 1270 Men's Restroom	Below 2ppb		Sink
240-057	Classroom 1201 West Wall	Below 2ppb		Sink
240-058	Classroom 1201 Teacher's Station	Below 2ppb		Sink
240-059	Classroom 1170 East	Below 2ppb		Sink
240-060	Classroom 1170 Island North			Sink
240-061	Classroom 1170 Island South			
240-062	Classroom 1170 Island Teacher's Station	Below 2ppb		
240-063	Classroom 1170 Prep Room 1172	Below 2ppb		Sink
240-064	Hallway South of 1170 Left	Below 2ppb		Cooler
240-065	Hallway South of 1170 Right	Below 2ppb		Cooler
240-066	South of 1170 Women's Restroom Left	Below 2ppb		Sink
240-067	South of 1170 Women's Restroom Right	Below 2ppb		Sink
240-068	South of 1170 Men's Restroom Left	Below 2ppb		Sink
240-069	South of 1170 Men's Restroom Right	Below 2ppb		Sink
240-070	Concession Stand 2032	Below 2ppb		Sink
240-070.1		Below 2ppb		Hand Sink
240-071	Laundry Room 2033	Below 2ppb		Utility Sink
240-072	Hallway by Conditioning Room	Below 2ppb		Cooler
240-073	Conditioning Room 2050	Below 2ppb		Cooler
240-074	Hallway by Mechanical Room 2020 Left	Below 2ppb		Cooler
240-075	Hallway by Mechanical Room 2020 Right	Below 2ppb		Cooler
240-076	By Mechanical Room 2020 Men's RR Left	Below 2ppb		Sink
240-077	By Mechanical Room 2020 Men's RR Middle	Below 2ppb		Sink
240-078	By Mechanical Room 2020 Men's RR Right	Below 2ppb		Sink
240-079	By Mechanical 2020 Women's RR Left	Below 2ppb		Sink
240-080	By Mechanical 2020 Women's RR Middle Left	Below 2ppb		Sink
240-081	By Mechanical 2020 Women's RR Middle Right	Below 2ppb		Sink
240-082	By Mechanical 2020 Women's RR Right	Below 2ppb		Sink
240-083	Wemen's Restroom by Office 2613	Below 2ppb		Sink
240-084	Men's Restroom by Office 2613	Below 2ppb		Sink
240-085	Staff Workroom 2616	Below 2ppb		Sink
240-086	Unisex Restroom South of 2629	Below 2ppb		Sink
240-087	Unisex Restroom North of 2635	Below 2ppb		Sink
240-088	Cot Room 2675 Restroom	Below 2ppb		Sink
240-089	Cot Room 2672 Restroom	Below 2ppb		Sink
240-090	Room 2671 Nurse's Office Entry	Below 2ppb		Sink
240-091	Nurse Area Lab 2667 North Sink	Below 2ppb		Sink
240-092	Nurse Area Lab 2667 South Sink	Below 2ppb		Sink
240-093	Nurse Area Exam Room A 2658	Below 2ppb		Sink
240-094	Nurse Area Exam Room B 2659	Below 2ppb		Sink
240-095	Nurse Area Exam Room C 2660	Below 2ppb		Sink
240-096	Nurse's Area Men's Restroom	Below 2ppb		Sink
240-097	Nurse's Area Women's Restroom	Below 2ppb		Sink
240-098	Classroom 2720			Cooler
240-099	Classroom 2720 Storage Laundry Tub			Utility Sink
240-100	3-D Lab Classroom 2730 West Left	Below 2ppb		Sink
240-101	3-D Lab Classroom 2730 West Middle	Below 2ppb		Sink
240-102	3-D Lab Classroom 2730 West Right	Below 2ppb		Sink
240-103	3-D Lab Classroom 2730 North Left	Below 2ppb		Sink
240-104	3-D Lab Classroom 2730 North Middle	Below 2ppb		Sink
240-105	3-D Lab Classroom 2730 North Right	Below 2ppb		Sink
240-106	3-D Lab Classroom 2730 Wet Area 2731	Below 2ppb		Utility Sink
240-107	Hallway By 2750	Below 2ppb		Cooler
240-108	Classroom 2750 Left to Right 1	Below 2ppb		Sink
240-109	Classroom 2750 Left to Right 2	Below 2ppb		Sink
240-110	Classroom 2750 Left to Right 3	Below 2ppb		Sink
240-111	Classroom 2750 Left to Right 4	Below 2ppb		Sink
240-112	Classroom 2750 Left to Right 5	Below 2ppb		Sink
240-113	Classroom 2750 Left to Right 6	Below 2ppb		Sink
240-114	Choir Room 2760	Below 2ppb		Cooler
240-115	Dressing Room A RR 2818A	Below 2ppb		Sink

240-116	Dressing Room B RR 2819A	Below 2ppb		Sink
240-117	Girl's Restroom 2379 Left	Below 2ppb		Sink
240-118	Girl's Restroom 2379 Right	Below 2ppb		Sink
240-119	Boy's Restroom 2378 Left	Below 2ppb		Sink
240-120	Boy's Restroom 2378 Right	Below 2ppb		Sink
240-121	Hallway by Faculty Office by 2370 Left	Below 2ppb		Cooler
240-122	Hallway by Faculty Office by 2370 Right	Below 2ppb		Cooler
240-123	Hallway by Communications Closet 2476 L	Below 2ppb		Cooler
240-124	Hallway by Communications Closet 2476 R	Below 2ppb		Cooler
240-125	Boy's Restroom 2479 Left	Below 2ppb		Sink
240-126	Boy's Restroom 2479 Middle	Below 2ppb		Sink
240-127	Boy's Restroom 2479 Right	Below 2ppb		Sink
240-128	Girl's Restroom 2478 Left	Below 2ppb		Sink
240-129	Girl's Restroom 2478 Middle	Below 2ppb		Sink
240-130	Girl's Restroom 2478 Right	Below 2ppb		Sink
240-131	Faculty Office Restroom 2471			Sink
240-132	Room 2503 Laundry			Sink
240-133	Infant Room 2510 Left	Below 2ppb		Sink
240-134	Infant Room 2510 Right	Below 2ppb		Sink
240-135	Infant Room 2520 Left	Below 2ppb		Sink
240-136	Infant Room 2530 Right	Below 2ppb		Sink
240-137	Infant Room 2530 Left	Below 2ppb		Sink
240-138	Infant Room 2520 Right			Sink
240-139	Daycare Kitchen Hand Sink	Below 2ppb		Sink
240-140	Daycare Kitchen Large Sink Left	Below 2ppb		Large Sink
240-141	Daycare Kitchen Large Sink Right	Below 2ppb		Large Sink
240-142	Laundry 2503	Below 2ppb		Sink
240-143	Toddler Room 2550 Right			Sink
240-144	Toddler Room 2550 Left	Below 2ppb		Sink
240-145	Toddler Room 2550 Restroom Left	Below 2ppb		Sink
240-146	Toddler Room 2550 Restroom Right	Below 2ppb		Sink
240-147	Toddler Room 2560 Right	Below 2ppb		Sink
240-148	Toddler Room 2560 Left	Below 2ppb		Sink
240-149	Daycare area Restroom	Below 2ppb		Sink
240-150	Daycare Hallway Drinking Cooler	Below 2ppb		Cooler
240-151	Classroom 2360 Laundry	Below 2ppb		Utility Sink
240-152	Classroom 2360 Kitchen	Below 2ppb		
240-153	Classroom 2360 Restroom	Below 2ppb		
240-154	Faculty Office Restroom 2270	Below 2ppb		Sink
240-155	Hallway by 2270 Left	Below 2ppb		Cooler
240-156	Hallway by 2270 Right	Below 2ppb		Cooler
240-157	Classroom 2230	Below 2ppb		Sink
240-158	Classroom 2220 (Teacher's station only)	2ppb		Sink
240-159	Preparation Room 2222	Below 2ppb		Sink
240-160	Classroom 2210 (Teacher's station only)	Below 2ppb		Sink
240-161	Boy's Restroom 2278 Left	Below 2ppb		Sink
240-162	Boy's Restroom 2278 Right	Below 2ppb		Sink
240-163	Girl's Restroom 2278 Left	Below 2ppb		Sink
240-164	Girl's Restroom 2278 Right	Below 2ppb		Sink
240-165	Faculty Office Restroom 2170	Below 2ppb		Sink
240-166	Hallway by 2170 Left	Below 2ppb		Cooler
240-167	Hallway by 2170 Right	Below 2ppb		Cooler
240-168	Classroom 2150 (Teacher's Station Only)	Below 2ppb		Sink
240-169	Preparation Area 2141	Below 2ppb		Sink
240-170	Classroom 2140	Below 2ppb		Sink
240-171	Classroom 2130			Sink
240-172	Boy's Restroom 2178 Left	Below 2ppb		Sink
240-173	Boy's Restroom 2178 Right	Below 2ppb		Sink
240-174	Girl's Restroom 2179 Left	Below 2ppb		Sink
240-175	Girl's Restroom 2179 Right	Below 2ppb		Sink
240-176	Girl's Restroom [3179] - Left	Below 2ppb		Sink
240-177	Girl's Restroom [3179] - Right	Below 2ppb		Sink
240-178	Boy's Restroom [3178] - Left	Below 2ppb		Sink
240-179	Boy's Restroom [3178] - Right	Below 2ppb		Sink
240-180	Hallway by Faculty Office 3170 - Left	Below 2ppb		Cooler
240-181	Hallway by Faculty Office 3170 - Right	Below 2ppb		Cooler
240-182	Faculty Office 3170 Restroom	Below 2ppb		Sink
240-183	Girls Restroom [3279] - Left	Below 2ppb		Sink
240-184	Girls Restroom [3279] - Right	Below 2ppb		Sink
240-185	Boy's Restroom [3278] - Left	Below 2ppb		Sink
240-186	Boy's Restroom [3278] - Right	Below 2ppb		Sink
240-187	Hallway by Faculty Office 3270 - Left	Below 2ppb		Cooler
240-188	Hallway by Faculty Office 3270 - Right	Below 2ppb		Cooler
240-189	Faculty Office 3270 Restroom	Below 2ppb		Sink
240-190	Girl's Restroom [3379] - Left	Below 2ppb		Sink
240-191	Girl's Restroom [3379] - Right	Below 2ppb		Sink
240-192	Boy's Restroom [3378] - Left	Below 2ppb		Sink
240-193	Girl's Restroom [3379] - Right	Below 2ppb		Sink
240-194	Hallway by L.A.F. [3370] - Left	Below 2ppb		Cooler
240-195	Hallway by L.A.F. [3370] - Right	Below 2ppb		Cooler
240-196	L.A.F. Room [3370] Restroom [3372]	Below 2ppb		Sink
240-197	Girl's Restroom [3479] - Left	Below 2ppb		Sink
240-198	Girl's Restroom [3479] - Right	Below 2ppb		Sink
240-199	Boy's Restroom [3478] - Left	Below 2ppb		Sink
240-200	Boy's Restroom [3478] - Right	Below 2ppb		Sink
240-201	Hallway by Faculty Office 3470 - Left	Below 2ppb		Cooler
240-202	Hallway by Faculty Office 3470 - Right	Below 2ppb		Cooler

240-203	Faculty Office 3470 Restroom	Below 2ppb		Sink
240-204	Girl's Restroom [4179] - Left	Below 2ppb		Sink
240-205	Girl's Restroom [4179] - Right	Below 2ppb		Sink
240-206	Boy's Restroom [4178] - Left	Below 2ppb		Sink
240-207	Boy's Restroom [4178] - Right	Below 2ppb		Sink
240-208	Hallway by Faculty Office 4170 - Left	Below 2ppb		Cooler
240-209	Hallway by Faculty Office 4170 - Right	Below 2ppb		Cooler
240-210	Faculty Office 4170 Restroom	Below 2ppb		Sink
240-211	Classroom 4160 Teacher's Station			Sink
240-212	Classroom 4160 Wall - Left	Below 2ppb		Sink
240-213	Hallway by Faculty Office 4170 - Right	Below 2ppb		Sink
240-214	Science Lab 4208 Prep Area [4207]	Below 2ppb		Sink
240-215	Science Lab 4208 Teacher's Station	Below 2ppb		Sink
240-216	Classroom 4210 Teacher's Station	Below 2ppb		Sink
240-217	Classroom 4210 Wall - Left	Below 2ppb		Sink
240-218	Classroom 4210 Wall - Right	Below 2ppb		Sink
240-219	Girl's Restroom [4279] - Left	Below 2ppb		Sink
240-220	Girl's Restroom [4279] - Right	Below 2ppb		Sink
240-221	Boy's Restroom [4278] - Left	Below 2ppb		Sink
240-222	Boy's Restroom [4278] - Right	Below 2ppb		Sink
240-223	Hallway by Faculty Office 4270 - Left			Cooler
240-224	Hallway by Faculty Office 4270 - Right	Below 2ppb		Cooler
240-225	Faculty Office 4273 Restroom	Below 2ppb		Sink
240-226	Faculty Lounge [4308]	Below 2ppb		Sink
240-227	Girl's Restroom [4379] - Left	Below 2ppb		Sink
240-228	Girl's Restroom [4379] - Right	Below 2ppb		Sink
240-229	Boy's Restroom [4279] - Left	Below 2ppb		Sink
240-230	Boy's Restroom [4279] - Right	Below 2ppb		Sink
240-231	Hallway by Faculty Office 4370 - Left	Below 2ppb		Cooler
240-232	Hallway by Faculty Office 4370 - Right	Below 2ppb		Cooler
240-233	Faculty Office 4370 Restroom	Below 2ppb		Sink
240-234	Classroom 4360 Teacher's Station	Below 2ppb		Sink
240-235	Classroom 4360 Wall - Left	Below 2ppb		Sink
240-236	Classroom 4360 Wall - Right	Below 2ppb		Sink
240-237	Science Lab 4408 Teacher's Station	Below 2ppb		Sink
240-238	Science Lab 4408 Prep Area [4407]	Below 2ppb		Sink
240-239	Classroom 4410 Teacher's Station	Below 2ppb		Sink
240-240	Classroom 4410 Wall - Left	Below 2ppb		Sink
240-241	Classroom 4410 Wall - Right	Below 2ppb		Sink
240-242	Girl's Restroom [4478] - Left	Below 2ppb		Sink
240-243	Girl's Restroom [4478] - Right	Below 2ppb		Sink
240-244	Boy's Restroom [4479] - Left	Below 2ppb		Sink
240-245	Boy's Restroom [4479] - Right	Below 2ppb		Sink
240-246	Hallway by Faculty Office 4470 - Left	Below 2ppb		Cooler
240-247	Hallway by Faculty Office 4470 - Right	Below 2ppb		Cooler
240-248	Faculty Office 4470 Restroom	Below 2ppb		Sink
240-249	Custodial Lounge 2864	Below 2ppb		Sink
240-250	Custodial Hall Cooler	Below 2ppb		Cooler
240-251	Custodial Men's Restroom 2863	Below 2ppb		Sink
240-252	Custodial Women's Restroom 2862	Below 2ppb		Sink
240-253	Kitchen Sink East	Below 2ppb		Sink
240-254	Kitchen Hand Sink Interior Wall East	Below 2ppb		Sink
240-255	Kitchen Hand Sink Interior Wall West	Below 2ppb		Sink
240-256	Kitchen Bunn Sink	Below 2ppb		Sink
240-257	Kitchen Bunn Machine	Below 2ppb		Bunn Machine
240-258	Kitchen Hand Sink Interior Wall South	Below 2ppb		Sink
240-259	Kitchen Island Sink	Below 2ppb		Sink
240-260	Kitchen Hook	Below 2ppb		Sink
240-261	Kitchen Dishwash Room East Wall Left	Below 2ppb		Large Sink
240-262	Kitchen Dishwash Room East Wall Right	Below 2ppb		Large Sink
240-263	Kitchen Dishwash Room West Wall	Below 2ppb		Large Sink

Saint Paul Public Schools
Water Sample Results
Wellstone Elementary
Building Number: 352

Sample Date: May 1st, 2016
Sampled by: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
352-001	3020 Maintenance - SNK	6		Slop
352-002	3018 Boy's Left - SNK	>2		Sink
352-003	3018 Boy's center - SNK	>2		Sink
352-004	3018 Boy's right - SNK	>2		Sink
352-005	3008 Girl's left - SNK	>2		Sink
352-006	3008 Girl's Center - SNK	>2		Sink
352-007	3008 Girl's right - SNK	>2		Sink
352-008	Cooridor 3003 South - DF	6		Drinking Fountain
352-009	Room 3051 - SNK	>2		Sink
352-010	Cooridor 3003 North - DF	>2		Drinking Fountain
352-011	3057 Maintenance - SNK	>2		Slop
352-012	3202 Maintenance - SNK	>2		Slop
352-013	Room 3113 - SNK	>2		Sink
352-014	Girl's restroom 3204 left - SNK	>2		Sink
352-015	Girl's restroom 3204 center - SNK	>2		Sink
352-016	Girls restroom 3204 right - SNK	>2		Sink

352-017	Staff restroom 3206 - SNK	>2		Sink
352-018	Boy's restroom 3208 left - SNK	>2		Sink
352-019	Boy's restroom 3208 center - SNK	>2		Sink
352-020	Boy's restroom 3208 right - SNK	>2		Sink
352-021	Cooridor 3200 - DF	>2		Drinking Fountain
352-022	Room 3220 north - SNK	>2		Sink
352-023	Room 3220 west - SNK	3		Sink
352-024	Room 3218 - SNK	71		Sink
352-025	Room 3215 south - SNK	>2		Sink
352-026	Room 3215 east - SNK	8		Sink
352-027	Room 2028 south wall - SNK	13		Sink
352-028	Room 2028 island - SNK	>2		Sink
352-029	Room 2030 - SNK	5		Sink
352-030	2031 Maintenance - SNK	>2		Slop
352-031	Cooridor 2003 - DF	3		Drinking Fountain
352-032	2019 Boy's Restroom left - SNK	>2		Sink
352-033	2019 Boy's Restroom center - SNK	>2		Sink
352-034	2019 Boy's Restroom right - SNK	>2		Sink
352-035	2008 Girl's Restroom left - SNK	>2		Sink
352-036	2008 Girl's Restroom left center - SNK	>2		Sink
352-037	2008 Girl's Restroom right center - SNK	>2		Sink
352-037.5	2008 Girl's Restroom right - SNK	>2		Sink
352-038	Room 2005 - SNK	>2		Sink
352-039	Room 2050 - SNK	>2		Sink
352-040	Room 2050A Restroom - SNK	>2		Sink
352-041	Room 2052A Restroom - SNK	>2		Sink
352-042	Room 2058 - SNK	>2		Sink
352-043	2063 Restroom - SNK	>2		Sink
352-044	2063 - SNK	>2		Sink
352-045	2057 Maintenance - SNK	11		Slop
352-046	Next to 2134 - SNK	>2		Sink
352-047	2107 north - SNK	>2		Sink
352-048	2107 south - SNK	>2		Sink
352-049	Women's Restroom 2118 left - SNK	>2		Sink
352-050	Women's Restroom 2118 left center - SNK	>2		Sink
352-051	Women's Restroom 2118 right center - SNK	>2		Sink
352-052	Women's Restroom 2118 right - SNK	>2		Sink
352-053	Men's Restrom 2117 left - SNK	>2		Sink
352-054	Men's Restroom 2117 left center - SNK	>2		Sink
352-055	Men's Restroom 2117 right center - SNK	>2		Sink
352-056	Men's Restroom 2117 right - SNK	>2		Sink
352-057	2115 Lobby left - WC	>2		Water Cooler
352-058	2115 lobby - Right - WC	>2		Water Cooler
352-059	2115B Cooridor - DF	2		Drinking Fountain
352-060	Room 2203 - SNK	>2		Sink
352-061	Room 2204 Staff Restroom left - SNK	>2		Sink
352-062	Room 2204 Staff Restroom right - SNK	>2		Sink
352-063	Cooridor 2201 - DF	>2		Drinking Fountain
352-064	2212 Maintenance - SNK	>2		Slop
352-065	Room 2215 - SNK	>2		Sink
352-066	Room 2217 - SNK	>2		Sink
352-067	Room 2218 Restroom - SNK	8		Sink
352-068	Room 2220 - SNK	>2		Sink
352-069	Room 1018 Restroom - SNK	>2		Sink
352-070	1016 Maintenance - SNK	2		Slop
352-071	1012 Nurse's Restroom - SNK	>2		Sink
352-072	1012 Nurse's Office - SNK	>2		Sink
352-073	1105 Maintenance - SNK	2		Slop
352-074	Room 1110 - SNK	>2		Sink
352-075	Boy's Locker Room 1115 - DF	8		Drinking Fountain
352-076	Next to Boy's Locker Room - WC	>2		Water Cooler
352-077	Men's Restroom 1122 left - SNK	4		Sink
352-078	Men's Restroom 1122 center - SNK	4		Sink
352-079	Men's Restroom 1122 right - SNK	>2		Sink
352-080	1123 Maintenance - SNK	>2		Sink
352-081	Cooridor 1164 - WC	5		Water Cooler
352-082	Room 1130 Art - SNK	>2		Sink
352-083	Girl's Locker Room 1151 left - SNK	>2		Sink
352-084	Girl's Locker Room 1151 left center - SNK	>2		Sink
352-085	Girl's Locker Room 1151 center - SNK	>2		Sink
352-086	Girl's Locker Room 1151 right center - SNK	>2		Sink
352-087	Girl's Locker Room 1151 right - SNK	>2		Sink
352-088	1162 Mechanical - SNK	>2		Slop
352-089	1129 Mechanical - SNK	>2		Slop
352-090	Gym 1065 - DF	>2		Drinking Fountain
352-091	Room 1064 - SNK	>2		Sink
352-092	Room 1062 - SNK	>2		Sink
352-093	1059 Maintenance - SNK	>2		Slop
352-094	Men's Restroom 1057 left - SNK	>2		Sink
352-095	Men's Restroom 1057 right - SNK	>2		Sink
352-096	Women's Restroom 1056 left - SNK	>2		Sink
352-097	Women's Restroom 1056 right - SNK	>2		Sink
352-098	Room 1113 - SNK	>2		Sink
352-099	Girl's Restroom 1204 left - SNK	>2		Sink
352-100	Girl's Restroom 1204 right - SNK	>2		Sink
352-101	Staff Restroom 1206 - SNK	>2		Sink
352-102	Boy's Restroom 1208 left - SNK	>2		Sink

352-103	Boy's Restroom 1208 center - SNK	6		Sink
352-104	Boy's Restroom 1208 right - SNK	>2		Sink
352-105	Outside 1211 - DF	>2		Drinking Fountain
352-106	Cooridor 1219 - WC	20		Water Cooler
352-107	Staff Lounge 1034 - SNK	>2		Sink
352-108	Room 1028 - SNK	>2		Sink
352-109	Office 123 - SNK	13		Sink
352-110	Men's Restroom 115 - SNK	15		Sink
352-111	Women's Restroom 113 - SNK	81		Sink
352-112	Between 115 and 113 - WC	18		Water Cooler
352-113	Restroom 134 - right - SNK	22		Sink
352-114	Restroom 133 - left - SNK	7		Sink
352-115	Room 131 Lounge - SNK	7		Sink
352-116	Janitor 112 - SNK	>2		Slop
352-117	0046 east next to dishwasher - SPRY	2		Kitchen Sink
352-118	0046 west next to sink - SPRY	5		Kitchen Sink
352-119	0046 west next to sprayer - SNK	>2		Kitchen Sink
352-120	0046 North SNK	xxx		Sink
352-121	0048 Locker - SNK	>2		Sink
352-122	0046 Hand Sink south - SNK	>2		Kitchen Sink
352-123	0046 Spray Sink far west wall - SNK	>2		Kitchen Sink
352-124	Next to 0006 slop sink - SNK	>2		Sink
352-125	Bunn	xxx		Bunn
352-126	Cafeteria - WC	>2		Water Cooler
352-024.5	Room 3218 - SNK		6	Sink
352-106.5	Cooridor 1219 - WC		>2	Water Cooler
352-111.5	Women's Restroom 113 - SNK		>2	Sink
352-113.5	Restroom 134 - right - SNK		9	Sink

Saint Paul Public Schools
Water Sample Results
crossroads
Building Number: 465

Date: 5/15/2016
Sampled By: Parker Prose & Jens Erickson

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
465-001	Kitchen - West Wall	<2		ksnk
465-002	Kitchen - West wall	5		snk
465-003	Kitchen - West wall sprayer	8		sprayer
465-004	Bunn - Kitchen			bunn
465-005	Kitchen East wall	<2		snk
465-006	Kitchen North Wall Sprayer	<2		sprayer
465-007	Dishwashing North Wall West	<2		ksnk
465-008	Dishwashing North Wall East	<2		snk
465-009	Dishwashing North Wall Sprayer	21	<2	sprayer
465-010	Dishwashing South Wall Sprayer	20		sprayer
465-011	1003 West WC	3		wc
465-012	1526	<2		snk
465-013	1530	7		snk
465-014	1529	22	<2	snk
465-015	1003 East Short WC	<2		wc
465-016	1003 East Tall WC	43	<2	wc
465-017	1604	4		snk
465-018	1605	<2		snk
465-019	1600	30	<2	snk
465-020	1602	6		snk
465-021	1606	<2		snk
465-022	1612	<2		snk
465-023	1614	<2		snk
465-024	1617	24	<2	snk
465-025	1616	<2		snk
465-026	1618	15		snk
465-027	1620	<2		snk
465-028	1622	<2		snk
465-029	1624	<2		snk
465-030	1623	15		snk
465-031	1628	<2		snk
465-032	1627	<2		snk
465-033	1630	<2		snk
465-034	1120 - nurse	<2		snk
465-035	1125	<2		snk
465-036	1106	<2		snk
465-037	1112	8		snk
465-038	1111	<2		snk
465-039	1114	<2		snk
465-040	1011 left	<2		snk
465-041	1011 right	<2		snk
465-042	1012 left	20		snk
465-043	1012 right	<2		snk
465-044	1503	<2		snk
465-045	1500 east tall WC	<2		wc
465-046	1500 south short WC	5		wc
465-047	1500 west wc	<2		snk
465-048	1402	26	5	df
465-049	1402	<2		snk
465-050	1404	<2		df

465-051	1404	<2		snk
465-052	1406	32	<2	df
465-053	1406	<2		snk
465-054	1422	<2		snk
465-055	1407 left	<2		snk
465-056	1407 center	<2		snk
465-057	1407 right	<2		snk
465-058	1408	14		snk
465-059	1408	<2		df
465-060	1410	<2		snk
465-061	1410	<2		df
465-062	1412	<2		snk
465-063	1412	<2		df
465-064	1416 south	<2		snk
465-065	1416 north	<2		snk
465-066	1312	<2		snk
465-067	1310	7		snk
465-068	1310	20		df
465-069	1308	<2		snk
465-070	1311 left	10		snk
465-071	1311 center	2		snk
465-072	1311 right	7		snk
465-073	1306	<2		snk
465-074	1306	<2		df
465-075	1304	3		snk
465-076	1302	<2		snk
465-077	1302	21	<2	df
465-078	1320 east	<2		snk
465-079	1320 west	<2		snk
465-080	1202	3		snk
465-081	1202	23	13	df
465-082	1206	<2		snk
465-083	1206	4		df
465-084	1203	9		snk
465-085	1207	16		snk
465-086	1204	<2		snk
465-087	1204	15		df
465-088	1205	<2		snk
465-089	1208	<2		snk
465-090	1208	<2		df
465-091	1209	<2		snk
465-092	1210	<2		snk
465-093	1210	<2		df
465-094	1211	13		snk
465-095	1214	<2		snk
465-096	1214	6		df
465-097	1215	7		snk
465-098	1218	<2		snk
465-099	1218	<2		df
465-100	1219	<2		snk
465-101	1216	<2		snk
465-102	1216	<2		df
465-103	1217	<2		snk
465-104	1212	<2		snk
465-105	1212	<2		df
465-106	1213	<2		snk
465-107	2003	<2		snk
465-108	4214	<2		snk
465-109	2404	<2		snk
465-110	2406	<2		snk
465-111	2406	<2		df
465-112	2408	<2		snk
465-113	2408	26	<2	df
465-114	4119 left	<2		snk
465-115	4119 center	<2		snk
465-116	4119 right	<2		snk
465-117	2410	<2		snk
465-118	2410	<2		df
465-119	2412	<2		snk
465-120	2412	6		snk
465-121	2416 south	<2		snk
465-122	2416 north	<2		snk
465-123	2302	<2		snk
465-124	2302	<2		df
465-125	2312	10		snk
465-126	2312	<2		df
465-127	2310	<2		snk
465-128	2310	<2		df
465-129	x120 L	<2		snk
465-130	x120 C	<2		snk
465-131	x120 R	<2		snk
465-132	2308	<2		snk
465-133	2306	<2		snk
465-134	2306	<2		df
465-135	2304	<32		snk
465-136	2318	<2		snk

**Saint Paul Public Schools
Water Sample Results
Four Seasons Elementary
Building Number: 460**

**Sample Date: May 15, 2016
Sampled by:
Nancy Fischer
Alissa Houghtaling**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	SampleType
460-001	1104- Kindergarten	below 2		sink
460-002	1104- Kindergarten	below 2		fountain
460-003	1104A- Kindergarten Restroom	below 2		sink
460-004	1103- Kindergarten	4ppb		sink
460-005	1103- Kindergarten	below 2		fountain
460-006	1103A- Kindergarten Restroom	below 2		sink
460-007	1102- Kindergarten	below 2		sink
460-008	1102- Kindergarten	3ppb		fountain
460-009	1102A- Kindergarten Restroom	below 2		sink
460-010	1101- Cafeteria	below 2		cooler
460-011	Hallway outside 1201- Gym	below 2		cooler
460-012	1205- Boy's Restroom	below 2		sink
460-013	1203- Girl's Restroom	below 2		sink
460-014	1107- Kitchen	below 2		hand
460-015	1107- Kitchen left	below 2		large sink
460-016	1107- Kitchen right	below 2		large sink
460-017	1107- Kitchen Bunn	8ppb		bunn
460-018	1209A- Restroom	below 2		sink
460-019	1210- Custodial	below 2		slop
460-020	1212- Mechanical	below 2		sink
460-021	1501- Pre- Kindergarten	below 2		sink
460-022	1501- Pre- Kindergarten	below 2		fountain
460-023	1005- Girl's Restroom left	below 2		sink
460-024	1005- Girl's Restroom right	below 2		sink
460-025	Hallway across from 1004	below 2		cooler
460-026	1006A- Nurses Restroom	below 2		sink
460-027	1006B- Nurses Office	below 2		sink
460-028	1007- Workroom	28ppb	3ppb	sink
460-029	1003- Maintenance	below 2		slop
460-030	1001- Restroom left	below 2		sink
460-031	1001- Restroom middle	below 2		sink
460-032	1001- Restroom right	below 2		sink
460-033	1301- Teacher's Lounge	below 2		sink
460-034	1302- Staff Restroom	below 2		sink
460-035	1303- Staff Restroom	below 2		sink
460-036	1304- Art	6ppb		sink
460-037	1304- Art	below 2		fountain
460-038	1304- Art	below 2		sink
460-039	1304- Art	below 2		sink
460-040	1304A	12ppb		sink
460-041	1214A	below 2		sink
460-042	1402A- Custodial	above 100	below 2	sink
460-043	Hallway across from 1504	5ppb		sink
460-044	1601- Boy's Restroom	below 2		sink
460-045	1602- Girl's Restroom	below 2		sink
460-046	Hallway outside 1601/1602 left	below 2		cooler
460-047	Hallway outside 1601/1602 right	below 2		cooler
460-048	1603- Maintenance	below 2		slop
460-049	2402- Girl's Restroom left	below 2		sink
460-050	2402- Girl's Restroom right	below 2		sink
460-051	2401- Boy's restroom left	below 2		sink
460-052	2401- Boy's Restroom right	below 2		sink
460-053	Hallway outside 2401	below 2		cooler
460-054	Hallway across from 2301	below 2		sink
460-055	Hallway across from 2301	below 2		fountain
460-056	Hallway across from 2503	below 2		sink
460-057	Hallway across from 2503	5ppb		fountain
460-058	2001- Boy's Restroom left	below 2		sink
460-059	2001- Boy's Restroom middle	below 2		sink
460-060	2001- Boy's Restroom right	3ppb		sink
460-061	Hallway outside 2001	below 2		sink
460-062	Hallway outside 2001	below 2		fountain
460-063	2002- Maintenance	-		slop
460-064	Hallway outside 2003	below 2		sink
460-065	Hallway outside 2003	below 2		fountain
460-066	2003- Girl's Restroom left	below 2		sink
460-067	2003- Girl's Restroom right	below 2		sink

**Saint Paul Public Schools
Water Sample Results
Galtier Elementary
Building Number: 467**

**Sample Date: 5/15/16
Sampled By: Mary Ferrian and Chad Whylen**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
467-001	1206 Boy's Restroom - SNK	less than 2		SNK
467-002	1204 Girl's Restroom - SNK	6		SNK

467-003	Room 1207 - SNK	16		SNK
467-004	Hallway Outside Room 1201 left - WC	less than 2		WC
467-005	Hallway Outside Room 1201 right - WC	less than 2		WC
467-006	1209A Custodial - SNK	less than 2		Slop
467-007	1209B Restroom - SNK	less than 2		SNK
467-008	1163 Kitchen Hand Sink - SNK	less than 2		SNK
467-009	1163 Bunn	-		Bunn
467-010	1163 Kitchen Sprayer - KS	less than 2		KS
467-011	1163B Dish Sprayer - KS	less than 2		KS
467-012	Room 1201 left - SNK	less than 2		SNK
467-013	Room 1201 left middle - SNK	14		SNK
467-014	Room 1201 right middle - SNK	39		SNK
467-015	Room 1201 right - SNK	9		SNK
467-016	Hallway outside of Cafeteria 1162 left - WC	less than 2		WC
467-017	Hallway outside of Cafeteria 1162 right - WC	less than 2		WC
467-018	Boiler Room 1161 - SNK	9		SNK
467-019	Room 1155A Restroom - SNK	less than 2		SNK
467-020	Room 1155 - SNK	less than 2		SNK
467-021	Room 1154 - SNK	less than 2		SNK
467-022	1154B Restroom North- SNK	less than 2		SNK
467-023	1154A Restroom South- SNK	less than 2		SNK
467-024	Room 1153 - SNK	less than 2		SNK
467-025	Room 1153A Restroom - SNK	less than 2		SNK
467-026	Hallway Outside 1153 - WC	less than 2		WC
467-027	1149 Boy's Restroom left - SNK	37		SNK
467-028	1149 Boy's Restroom center - SNK	15		SNK
467-029	1149 Boy's Restroom Right - SNK	15		SNK
467-030	1148 Custodial - SNK	less than 2		Slop
467-031	1147 Girl's Restroom left - SNK	less than 2		SNK
467-032	1147 Girl's Restroom center - SNK	less than 2		SNK
467-033	1147 Girl's Restroom right - SNK	5		SNK
467-034	1146 Staff Lounge - SNK	less than 2		SNK
467-035	Room 1145 Island North - SNK	4		SNK
467-036	Room 1145 Island South - SNK	less than 2		SNK
467-037	Room 1145 West Wall left - SNK	6		SNK
467-038	Room 1145 West Wall right - SNK	5		SNK
467-039	Room 1142 - SNK	less than 2		SNK
467-040	Room 1142A Restroom - SNK	less than 2		SNK
467-041	Room 1141 - SNK	less than 2		SNK
467-042	Room 1141A Restroom - SNK	less than 2		SNK
467-043	1005 Nurse's Office - SNK	less than 2		SNK
467-044	Nurse's Restroom 1004 - SNK	less than 2		SNK
467-045	1010 Men's Restroom - SNK	less than 2		SNK
467-046	1012 Women's Restroom - SNK	less than 2		SNK
467-047	1011 Custodial - SNK	less than 2		Slop
467-048	Room 1013 - SNK	less than 2		SNK
467-049	Room 0102 - SNK	29		SNK
467-050	1003 Restroom - SNK	2		SNK
467-051	Room 0101 Small Storage Room - SNK	4		SNK
467-052	Room 0101 Restroom 1016 - SNK	27		SNK
467-053	Room 0101 - SNK	less than 2		SNK
467-054	2200 Exploration - SNK	less than 2		SNK
467-055	Room 2253C - SNK	less than 2		SNK
467-056	Room 2253A - SNK	less than 2		SNK
467-057	Hallway outside 2249 Boy's Restroom - WC	11		WC
467-058	Hallway outside 2247 Girl's Restroom - WC	less than 2		WC
467-059	2249 Boy's Restroom left - SNK	less than 2		SNK
467-060	2249 Boy's Restroom center - SNK	less than 2		SNK
467-061	2249 Boy's Restroom Right - SNK	3		SNK
467-062	2247 Girl's Restroom left - SNK	3		SNK
467-063	2247 Girl's Restroom center - SNK	less than 2		SNK
467-064	2247 Girl's Restroom right - SNK	3		SNK
467-065	Room 2245C - SNK	less than 2		SNK
467-066	Room 2245A - SNK	less than 2		SNK
467-014.5	Room 1201 right middle - SNK	-	less than 2	SNK
467-027.5	1149 Boy's Restroom left - SNK	-	7	SNK
467-49.5	Room 0102 - SNK	-	46	SNK
467-052.5	Room 0101 Restroom 1016 - SNK	-	6	SNK

Saint Paul Public Schools
Water Sample Results
LEAP
Building Number: 355

Sample Date: 5/15/16
Sampled by: Mary Ferrian and Chad Whyalen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
355-001	Room 3103 (North) - SNK	less than 2		SNK
355-002	Room 3103 A (South) - SNK	less than 2		SNK
355-003	Room 3106 Custodial Closet - SNK	less than 2		Slop
355-004	Hallway Outside 3103 - WC	2		WC
355-005	Room 3102B - SNK	less than 2		SNK
355-006	Room 3102 - SNK	less than 2		SNK
355-007	3101 Girl's Restroom left - SNK	less than 2		SNK

355-008	3101 Girl's Restroom center - SNK	less than 2		SNK
355-009	3101 Girl's Restroom right - SNK	11		SNK
355-010	Room 3206 - SNK	less than 2		SNK
355-011	3301 Boy's Restroom left - SNK	less than 2		SNK
355-012	3301 Boy's Restroom center - SNK	less than 2		SNK
355-013	3301 Boy's Restroom right - SNK	less than 2		SNK
355-014	Hallway Outside 3305 - WC	less than 2		WC
355-015	Custodial 3308 - SNK	less than 2		Slop
355-016	Room 2106 Lounge - SNK	5		SNK
355-017	Room 2106A Lounge Restroom - SNK	7		SNK
355-018	2108 Custodial - SNK	less than 2		Slop
355-019	Hallway Outside 2102 - WC	less than 2		WC
355-020	Room 2102A - SNK	less than 2		SNK
355-021	2101 Girl's Restroom left - SNK	less than 2		SNK
355-022	2101 Girl's Restroom center - SNK	less than 2		SNK
355-023	2101 Girl's Restroom right - SNK	less than 2		SNK
355-024	2101A Restroom - SNK	less than 2		SNK
355-025	2003E - SNK	less than 2		SNK
355-026	2003F Restroom - SNK	less than 2		SNK
355-027	2301 Boy's Restroom left - SNK	2		SNK
355-028	2301 Boy's Restroom Center - SNK	less than 2		SNK
355-029	2301 Boy's Restroom Right - SNK	4		SNK
355-030	Room 2302 Island - SNK	24		SNK
355-031	Room 2302 East Wall - SNK	-		SNK
355-032	Hallway Outside 2303 - WC	less than 2		WC
355-033	2306 Custodial - SNK	less than 2		Slop
355-034	Room 1109 - SNK	less than 2		SNK
355-035	Auditorium - DF	less than 2		DF
355-036	1113 Custodial - SNK	less than 2		Slop
355-037	Room 1107 - SNK	11		SNK
355-038	Hallway Outside 1106 - WB	less than 2		Water Bottle Filler
355-039	Room 1106 - SNK	11		SNK
355-040	Room 1105 - SNK	less than 2		SNK
355-041	1104 Girl's Restroom left - SNK	less than 2		SNK
355-042	1104 Girl's Restroom center - SNK	11		SNK
355-043	1104 Girl's Restroom right - SNK	less than 2		SNK
355-044	1103A Maintenance Restroom - SNK	less than 2		SNK
355-045	1102 Nurse's - SNK	less than 2		SNK
355-046	1102B Nurse's Restroom - SNK	less than 2		SNK
355-047	1205 Media Center left - WC	less than 2		WC
355-048	1205 Media Center right - WC	less than 2		WC
355-049	1206 Restroom - SNK	less than 2		SNK
355-050	1004A Restroom - SNK	less than 2		SNK
355-051	1301 Boy's Restroom left - SNK	less than 2		SNK
355-052	1301 Boy's Restroom center - SNK	less than 2		SNK
355-053	1301 Boy's Restroom right - SNK	less than 2		SNK
355-054	Room 1302 - SNK	less than 2		SNK
355-055	Hallway Outside of 1303 - WC	less than 2		WC
355-056	1305 Custodial - SNK	less than 2		Slop
355-057	Gym 1401 - WC	less than 2		WC
355-058	1403A Men's Locker Room left - SNK	less than 2		SNK
355-059	1403A Men's Locker Room right - SNK	less than 2		SNK
355-060	1401B Restroom - SNK	less than 2		SNK
355-061	1402A Girl's Locker Room left - SNK	less than 2		SNK
355-062	1402A Girl's Locker Room right - SNK	3		SNK
355-063	0202B Sprayer - SNK	less than 2		SNK
355-064	0202 Handwashing North - SNK	less than 2		SNK
355-065	0202A Restroom - SNK	less than 2		SNK
355-066	0202 Bunn - Bunn	-		Bunn
355-067	0202 East Wall Hand Sink - SNK	less than 2		SNK
355-068	0202 - KS	less than 2		KS
355-069	Cafeteria 1101 - SNK	less than 2		SNK
355-070	Cafeteria 1101 - WC	less than 2		WC
355-071	0209 Custodial - SNK	less than 2		Slop
355-072	0207 Boiler Room - SNK	less than 2		SNK
355-073	0205 Girl's Locker Room left - SNK	less than 2		SNK
355-074	0205 Girl's Locker Room right - SNK	less than 2		SNK
355-075	0206D Boy's Locker Room - SNK	15		SNK
355-030.5	Room 2302 Island - SNK	-	less than 2	SNK

Saint Paul Public Schools
Water Sample Results
Mississippi Creative Arts
Building Number: 527

Sample Date: May 15, 2016
Sampled By:
Nancy Fischer
Alissa Houghtaling

Sample Number	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
527-001	1105- Mech Rm Restroom	below 2		sink
527-002	1105- Mech Rm	3ppb		slop
527-003	1002- Work Room	below 2		sink
527-004	1004- Nurses Office	below 2		sink

527-005	1004- Nurses Office Restroom	below 2		sink
527-006	1111A- Media Office	below 2		sink
527-007	1112- Kitchen	below 2		hand
527-008	1112-Kitchen left			large sink
527-009	1112- Kitchen right	3ppb		large sink
527-010	1112- Kitchen Bunn	below 2		Bunn
527-011	Hallway Outside 1112	below 2		Fountain
527-012	1114- Maintenance	below 2		slop
527-013	Room 1304	below 2		sink
527-014	Room 1304	below 2		fountain
527-015	Room 1304A- Restroom	below 2		sink
527-016	1306- Boy's Restroom- left	below 2		sink
527-017	1306- Boy's Restroom- right	below 2		sink
527-018	1308- Girl's Restroom- left	below 2		sink
527-019	1308- Girl's Restroom- right	below 2		sink
527-020	Hallway outside 1306/1308	below 2		cooler
527-021	Room 1310	below 2		sink
527-022	Room 1310	below 2		fountain
527-023	Room 1310A- Restroom	below 2		sink
527-024	1312- Staff Restroom	below 2		sink
527-025	Room 1311	below 2		sink
527-026	Room 1311	below 2		fountain
527-027	Room 1313	below 2		sink
527-028	Room 1313	below 2		Fountain
527-029	Room 1314	below 2		sink
527-030	Room 1314	below 2		Fountain
527-031	Room 1314A- Restroom	below 2		sink
527-032	Room 1315	below 2		sink
527-033	Hallway outside 1315- left	below 2		cooler
527-034	Hallway outside 1315- right	below 2		cooler
527-035	1319- Girl's Restroom	below 2		sink
527-036	1317- Boy's Restroom	below 2		sink
527-037	Room 1316	below 2		sink
527-038	Room 1316A- Restroom	below 2		sink
527-039	Room 1318	below 2		sink
527-040	Room 1321	below 2		sink
527-041	Room 1320	below 2		sink
527-042	Room 1322	below 2		sink
527-043	Room 1323	below 2		sink
527-044	Room 1325	below 2		sink
527-045	1206- Maintenance			slop
527-046	1208- Boy's Restroom- left	below 2		sink
527-047	1208 Boy's Restroom- right	below 2		sink
527-048	Hallway across from 1206- left	below 2		cooler
527-049	Hallway across from 1206- right	below 2		cooler
527-050	1209A- Staff Restroom	below 2		sink
527-051	1209B-Staff Restroom	below 2		sink
527-052	Room 1212- left	below 2		sink
527-053	Room 1212- right	below 2		sink
527-054	1213- Staff Lounge	below 2		sink
527-055	Hallway outside 1214	below 2		cooler
527-056	Room 1215	below 2		sink
527-057	Room 1216	below 2		sink
527-058	Room 1219	below 2		sink
527-059	Room 1218	9ppb		sink
527-060	Room 1221	below 2		sink
527-061	Hallway outside 1222	below 2		cooler
527-062	1226- Restroom left	below 2		sink
527-063	1226- Restroom right	below 2		sink
527-064	1228- Maintenance	below 2		slop
527-065	Room 1225	below 2		sink
527-066	Room 1230	below 2		sink
527-067	2205- Maintenance	below 2		slop
527-068	2210- Staff Restroom	below 2		sink
527-069	Hallway outside 2211- left	below 2		cooler
527-070	Hallway outside 2211- right	below 2		cooler
527-071	Room 2212	below 2		sink
527-072	Room 2213	below 2		sink
527-073	Room 2214	2ppb		sink
527-074	Room 2215	2ppb		sink
527-075	Room 2216	below 2		sink
527-076	Room 2217	below 2		sink
527-077	Hallway outside 2216- left	below 2		cooler
527-078	Hallway outside 2216- right	below 2		cooler
527-079	Room 2218	below 2		sink
527-080	Room 2219	below 2		sink
527-081	Room 2220	13ppb		sink
527-082	Room 2221	below 2		sink
527-083	Hallway outside 2222	below 2		cooler
527-084	2226- Maintenance	below 2		slop
527-085	Room 2225	below 2		sink
527-086	Room 2228	below 2		sink

Building 434 (III on ANDalyze)

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
434-001	Workroom 2016	<2 ppb		Sink
434-002	Room 2007			Sink
434-003	Office 2005	<2 ppb		Sink
434-004	Womens' Room East of 2001	<2 ppb		Sink
434-005	Outside Room 2140	<2 ppb		Cooler
434-006	Mens' Room East of 2001	4 ppb		Sink
434-007	Conference Room 2007 Restroom	<2 ppb		Sink
434-008	Conference Room 2007 Sink	<2 ppb		Sink
434-009	Bath Off 2209	<2 ppb		Sink
434-010	Room 2209	<2 ppb		Sink
434-011	Room 2201	<2 ppb		Sink
434-012	Room 2203	<2 ppb		Sink
434-013	Room 2202	<2 ppb		Sink
434-014	Womens' Bath Across from 2145	<2 ppb		Sink
434-015	Mens' Bath Across from 2145	3 ppb		Sink
434-016	Between Baths Across 2145	<2 ppb		Cooler
434-017	Room 2145	<2 ppb		Sink
434-018	Outside Room 2220 - Left	<2 ppb		Cooler
434-019	Outside Room 2220 - Right			Cooler
19.1	Boy's Restroom - Left	<2 ppb		Sink
19.2	Boys' Restroom - Middle	<2 ppb		Sink
19.3	Boys' Restroom - Right	<2 ppb		Sink
19.4	Girls' Restroom - Left	<2 ppb		Sink
19.5	Girls' Restroom - Middle	<2 ppb		Sink
19.6	Girls' Restroom - Right	<2 ppb		Sink
434-020	Staff Lounge Room 2243	<2 ppb		Sink
434-021	Staff Lounge Room 2130 Womens' Restrom	<2 ppb		Sink
434-022	Staff Lounge Room 2130 Mens' Restroom	<2 ppb		Sink
434-023	Band Room 2237	<2 ppb		Sink
434-024	Room 2292	<2 ppb		Sink
434-025	Boys' Restroom 2211 - Left	<2 ppb		Sink
434-026	Boys' Restroom 2211 - Left Middle	12 ppb		Sink
434-027	Boys' Restroom 2211 - Right Middle	<2 ppb		Sink
434-028	Boys' Restroom 2211 - Right	<2 ppb		Sink
434-029	Girls' Restroom 2213 - Left	2 ppb		Sink
434-030	Girls' Restroom 2213 - Left Middle	<2 ppb		Sink
434-031	Girls' Restroom 2213 - Right Middle	<2 ppb		Sink
434-032	Girls' Restroom 2213 - Right	<2 ppb		Sink
434-033	Outside Room 2227 - Left	<2 ppb		Cooler
434-034	Outside Room 2227 - Right	<2 ppb		Cooler
434-035	Room 2227 - East	<2 ppb		Sink
434-036	Room 2227 - West	<2 ppb		Sink
434-037	Home Ec Room 2301	<2 ppb		Utility Sink
434-038	Home Ec Room West Wall	<2 ppb		Sink
434-039	Home Ec Room N Wall - Right	5 ppb		Sink
434-040	Home Ec Room N Wall - Left	3 ppb		Sink
434-041	Home Ec Room E Wall - North	2 ppb		Sink
434-042	Home Ec Room E Wall - South	<2 ppb		Sink
434-043	Room 2304 - South	<2 ppb		Utility Sink
434-044	Room 2304 - North	<2 ppb		Utility Sink
434-045	Room 2305 - Left	<2 ppb		Sink
434-046	Room 2305 - Right	<2 ppb		Sink
434-047	Across from Room 2306	<2 ppb		Cooler
434-048	Science Lab Room 2320 Teacher Station	<2 ppb		Sink
434-049	Science Lab Room 2320 Back Exit Counter	<2 ppb		Sink
434-050	Room 2225 E Wall	<2 ppb		Sink
434-051	Room 2225 N Wall	<2 ppb		Sink
434-052	Outside Room 2315 - Left	<2 ppb		Cooler
434-053	Outside Room 2315 - Right	<2 ppb		Cooler
53.1	Restroom - Left	<2 ppb		Sink
53.2	Restroom - Right	<2 ppb		Sink
53.3	Restroom - Left	<2 ppb		Sink
53.4	Restroom - Right	<2 ppb		Sink
434-054	Outside Room 2505	<2 ppb		Cooler
434-055	Room 2505	6 ppb		Sink
434-056	Room 2506	<2 ppb		Sink
434-057	Room 2507	3 ppb		Sink
434-058	Room 2508	4 ppb		Sink
434-059	Outside Room 2508	<2 ppb		Cooler
434-060	IMC Office 2151A	<2 ppb		Sink
434-061	Outside Room 2104	<2 ppb		Cooler
434-062	Room 2104	4 ppb		Cooler
434-063	Room 2104	4 ppb		Sink
434-064	Room 2102	2 ppb		Sink
434-065	Room 2101 - East	<2 ppb		Sink
434-066	Room 2101 - West	2 ppb		Sink
434-067	Outside Room 2101	<2 ppb		Cooler
434-068	Room 2105	<2 ppb		Utility Sink
434-069	Room 2105 - West	<2 ppb		Sink
434-070	Room 2106	<2 ppb		Sink
434-071	Outside Room 2106	3 ppb		Cooler
434-072	Room 2107	<2 ppb		Sink

434-073	Room 2108	4 ppb		Sink
434-074	By Electrical Closet Room 2109	2 ppb		Cooler
74.1	Boys' Restroom - Left	<2 ppb		Sink
74.2	Boys' Restroom - Right	<2 ppb		Sink
74.3	Girls' Restroom - Left	<2 ppb		Sink
74.4	Girls' Restroom - Right	<2 ppb		Sink
434-075	Service Kitchen - West	<2 ppb		Sink
434-076	Service Kitchen- East	<2 ppb		Sink
434-077	Service Kitchen	<2 ppb		Hand Sink
77.1	Boys' Restroom - Left	<2 ppb		Sink
77.2	Boys' Restroom - Right	<2 ppb		Sink
77.3	Girls' Restroom - Left	<2 ppb		Sink
77.4	Girls' Restroom - Right	<2 ppb		Sink
434-078	Outside to the Right of Room 2519	<2 ppb		Cooler
434-079	Outside to the Right of Room 2520	<2 ppb		Cooler
79.1	Boys' Restroom - Left	<2 ppb		Sink
79.2	Boys' Restroom - Right	<2 ppb		Sink
79.3	Girls' Restroom - Left	<2 ppb		Sink
79.4	Girls' Restroom - Right	<2 ppb		Sink
434-080	Room 2511	<2 ppb		Sink
434-081	Room 2512	<2 ppb		Sink
434-082	Outside Room 2515	<2 ppb		Cooler
434-083	Room 2513	2 ppb		Sink
434-084	Room 2514 South Wall - East	<2 ppb		Sink
434-085	Room 2514 South Wall - West	<2 ppb		Sink
434-086	Room 2515	<2 ppb		Sink
434-087	Room 2516	<2 ppb		Sink
434-088	Outside Room 2516			Cooler
434-089	Room 2517	4 ppb		Sink
434-090	Room 2518	<2 ppb		Sink
434-091	Outside Room 2523	<2 ppb		Cooler
434-092	Room 2523	5 ppb		Sink
434-093	Room 2524	<2 ppb		Sink
434-094	Room 2525	<2 ppb		Sink
434-095	Room 2526	<2 ppb		Sink
434-096	Outside Room 2614	<2 ppb		Sink
434-097	Room 2614	3 ppb		Sink
434-098	Room 2611 - East	<2 ppb		Sink
434-099	Room 2611 - West	<2 ppb		Sink
434-100	Room 2613	2 ppb		Sink
434-101	Outside Room 2704	<2 ppb		Cooler
434-102	Room 2704	6 ppb		Sink
434-103	Room 2705	<2 ppb		Sink
434-104	Room 2706	5 ppb		Sink
434-105	Room 2707 South Wall - East	6 ppb		Sink
434-106	Room 2702 South Wall - Middle	<2 ppb		Sink
434-107	Room 2707 South Wall - West			Sink
434-108	Outside Room 2707	<2 ppb		Cooler
434-109	Room 2714	<2 ppb		Sink
434-110	Bath Off Room 2714	<2 ppb		Sink
434-111	Room 2711	<2 ppb		Sink
111.1	Restroom Off 2711	<2 ppb		Sink
434-112	Room 2710	<2 ppb		Sink
434-113	Room 2709	3 ppb		Sink
434-114	Outside Room 2709	<2 ppb		Cooler
114.1	Room 2708	<2 ppb		Sink
434-115	Room 2701	<2 ppb		Sink
115.1	Boys' Restroom - Left	<2 ppb		Sink
115.2	Boys' Restroom - Right	<2 ppb		Sink
115.3	Girls' Restroom - Left	<2 ppb		Sink
115.4	Girls' Restroom - Right	<2 ppb		Sink
434-116	Gym 1118 by Entrance	<2 ppb		Cooler
434-117	Bath Off Room 1724	<2 ppb		Sink
434-118	Off Room 1722	<2 ppb		Sink
434-119	Outside Room 1715			Sink
434-120	Room 1715	2 ppb		Sink
434-121	Room 1714	<2 ppb		Sink
434-122	Room 1713	2 ppb		Sink
434-123	Room 1712	3 ppb		Sink
434-124	Hall Outside Room 1712	<2 ppb		Cooler
434-125	Serving Room 1712	<2 ppb		Large Sink
434-126	Serving Room 1712	<2 ppb		Hand Sink
434-127	Room 1510 Work Room	3 ppb		Cooler
434-128	Boys' Restroom - Left	<2 ppb		Sink
434-129	Boys' Restroom - Right	<2 ppb		Sink
434-130	Girls' Restroom - Left	<2 ppb		Sink
434-131	Girls' Restroom - Right	<2 ppb		Sink
434-132	Hall by Room 1701	<2 ppb		Cooler
434-133	Room 1716	<2 ppb		Sink
434-134	Room 1717	<2 ppb		Sink
434-135	Hall by Room 1717	<2 ppb		Cooler
434-136	Room 1718	<2 ppb		Sink
434-137	Room 1503	<2 ppb		Sink
434-138	Restroom Off Room 1503	<2 ppb		Hand Sink
434-139	Room 1105	3 ppb		Sink
434-140	Restroom Off Room 1105	<2 ppb		Hand Sink
434-141	Room 1106	<2 ppb		Sink

434-142	Hall by Room 1106	<2 ppb		Cooler
434-143	Room 1107	<2 ppb		Sink
434-144	Room 1108	4 ppb		Sink
434-145	Hall by Room 1109	<2 ppb		Cooler
434-146	Girls' Restroom - Left	<2 ppb		Sink
434-147	Girls' Restroom - Right	<2 ppb		Sink
434-148	Boys' Restroom - Left	<2 ppb		Sink
434-149	Boys' Restroom - Right	<2 ppb		Sink
434-150	Room 1112	<2 ppb		Sink
434-151	Kitchen 1114A	<2 ppb		Large Sink
434-152	Kitchen - West	<2 ppb		Hand Sink
434-153	Kitchen - East	<2 ppb		Hand Sink
434-154	Hall by Room 1104	<2 ppb		Cooler
434-155	Room 1104	<2 ppb		Sink
434-156	Room 1103	2 ppb		Sink
434-157	Hall by Room 1103	<2 ppb		Cooler
434-158	Room 1102	2 ppb		Sink
434-159	Room 1101	2 ppb		Sink
434-160	Restroom Off Room 1101	<2 ppb		Hand Sink
434-161	Room 1228	<2 ppb		Sink
434-162	Near 1223 Womens' Restroom - Left	<2 ppb		Sink
434-163	Near 1223 Womens' Restroom - Right	<2 ppb		Sink
434-164	Near Room 1223	<2 ppb		Cooler
434-165	Near 1223 Mens' Restroom - Left	<2 ppb		Sink
434-166	Near 1223 Mens' Restroom - Right	3 ppb		Sink
434-167	Room 1217	<2 ppb		Sink
434-168	Restroom Off Room 1217	<2 ppb		Sink
434-169	Restroom Off Room 1217	<2 ppb		Hand Sink
434-170	Room 1214	<2 ppb		Sink
434-171	Room 1210	<2 ppb		Sink
434-172	Restroom Off Room 1210	<2 ppb		Sink
434-173	Restroom Off Room 1210	<2 ppb		Hand Sink
434-174	ECFE Hall Cooler	<2 ppb		Cooler
434-175	Room 1206	<2 ppb		Sink
434-176	Restroom Off Room 1206	<2 ppb		Sink
434-177	Restroom Off Room 1206	<2 ppb		Hand Sink
434-178	Room 1205	<2 ppb		Sink
434-179	Room 1204	<2 ppb		Sink
434-180	Restroom Between Room 1204 & 1203	<2 ppb		Sink
434-181	Room 1203	<2 ppb		Sink
434-182	Room 1230	<2 ppb		Sink
434-183	Hall by Custodial Office	2 ppb		Cooler
434-184	Restroom by Staff Room 1246 - Left	4 ppb		Sink
434-185	Restroom by Staff Room 1246 - Right	4 ppb		Sink
434-186	Room 1246 Staff Lounge	2 ppb		Sink
434-187	Room 1246 Restroom - Left	4 ppb		Sink
434-188	Room 1246 Restroom - Left	2 ppb		Sink
434-189	Room 1319	5 ppb		Sink
434-190	Restroom Off Room 1319	3 ppb		Sink
434-191	Restroom Off Room 1319	5 ppb		Hand Sink
434-192	Room 1322	4 ppb		Sink
434-193	Nurse Restroom	3 ppb		Sink
434-194	Nurse Room 1313	3 ppb		Hand Sink
434-195	Nurse Room 1314	<2 ppb		Hand Sink
434-196	Nurse Entrance 1316	3 ppb		Sink
434-197	Nurse Entrance 1318	<2 ppb		Sink
434-198	Room 1323	<2 ppb		Sink
434-199	Restroom Off Room 1323	<2 ppb		Sink
434-200	Restroom Off Room 1323	<2 ppb		Hand Sink
434-201	Room 1326	5 ppb		Sink
434-202	Room 1306 Kitchen	<2 ppb		Large Sink
434-203	Room 1306 Kitchen	<2 ppb		Hand Sink
434-204	Room 1344	5 ppb		Hand Sink
434-205	Room 1344 B	7 ppb		Large Sink
434-206	Room 1331	<2 ppb		Sink
434-207	Restroom Off 1331	<2 ppb		Sink
434-208	Restroom Off 1331	<2 ppb		Hand Sink
434-209	Room 1334	<2 ppb		Sink
434-210	Room 1336	<2 ppb		Sink
434-211	Room 1337	<2 ppb		Sink
434-212	Room 1338	<2 ppb		Sink
434-213	Room 1339	<2 ppb		Sink
434-214	Room 1340	<2 ppb		Sink
434-215	Room 1341	3 ppb		Sink
434-216	Room 1342	3 ppb		Sink
434-217	Room 1343	<2 ppb		Sink
434-218	Principal Office 1402	<2 ppb		Sink
434-219	NE Entry Mens' Restroom - Left	<2 ppb		Sink
434-220	NE Entry Mens' Restroom - Right	<2 ppb		Sink
434-221	Hallway Cooler	<2 ppb		Cooler
434-222	NE Entry Womens' Restroom - Left	<2 ppb		Sink
434-223	NE Entry Womens' Restroom - Right	<2 ppb		Sink
434-224	Gym Room 1401	<2 ppb		Sink
434-225	Girls' Locker Room 1404 - Left	<2 ppb		Sink
434-226	Girls' Locker Room 1404 - Middle	<2 ppb		Sink
434-227	Girls' Locker Room 1404 - Right	<2 ppb		Sink
434-228	Boys' Locker Room 1407 - Left	<2 ppb		Sink

434-229	Boys' Locker Room 1407 - Middle	<2 ppb		Sink
434-230	Boys' Locker Room 1407 - Right	<2 ppb		Sink
434-231	Mechanical 1411	<2 ppb		Hose Bib
434-232	Hall by Room 1526	<2 ppb		Cooler
434-233	Room 1526	2 ppb		Sink
434-234	Room 1525	2 ppb		Sink
434-235	Room 1524	<2 ppb		Sink
434-236	Room 1523	3 ppb		Sink
434-237	Hall by Room 1523	<2 ppb		Cooler
434-238	Near 1520 Girls' Restroom - Left	<2 ppb		Sink
434-239	Near 1520 Girls' Restroom - Right	<2 ppb		Sink
434-240	Near 1520 Boys' Restroom - Left	<2 ppb		Sink
434-241	Near 1520 Boys' Restroom - Right	<2 ppb		Sink
434-242	Hall by Room 1520	<2 ppb		Cooler
434-243	Room 1518	<2 ppb		Sink
434-244	Room 1517	<2 ppb		Sink
434-245	Hall by Room 1517	<2 ppb		Cooler
434-246	Room 1514	6 ppb		Sink
246.1	Room 1516	<2 ppb		Sink
434-247	Room 1513	<2 ppb		Sink
247.1	Room 1515	<2 ppb		Sink
434-248	Hall by Room 1513	<2 ppb		Cooler
434-249	Room 1512	<2 ppb		Sink
434-250	Room 1511	3 ppb		Sink
434-251	Hall by Room 1519	<2 ppb		Cooler
434-252	Near 1519 Boys' Restroom - Left	<2 ppb		Sink
434-253	Near 1519 Boys' Restroom - Right	<2 ppb		Sink
434-254	Near 1519 Girls' Restroom - Left	<2 ppb		Sink
434-255	Near 1519 Girls' Restroom - Right	<2 ppb		Sink
434-256	Hall by Room 1508	<2 ppb		Cooler
434-257	Room 1508	<2 ppb		Sink
434-258	Room 1507	<2 ppb		Sink
434-259	Hall by Room 1507	<2 ppb		Cooler
434-260	Room 1506	<2 ppb		Sink
434-261	Room 1243 Kitchen Staff Lounge	<2 ppb		Large Sink
434-262	Womens' Restroom - Left	22 ppb		Sink
434-263	Womens' Restroom - Left Middle	3 ppb		Sink
434-264	Womens' Restroom - Right Middle	3 ppb		Sink
434-265	Womens' Restroom - Right	4 ppb		Sink
434-266	Mens' Restroom - Left			Sink
434-267	Mens' Restroom - Left Middle	<2 ppb		Sink
434-268	Men's Restroom - Middle	<2 ppb		Sink
434-269	Mens' Restroom - Right Middle	<2 ppb		Sink
434-270	Mens' Restroom - Right	<2 ppb		Sink
434-271	Dishwashing Room - Left	<2 ppb		Sink
434-272	Dishwashing Room - Right	<2 ppb		Sink
434-273	Dishwashing Room - Small Sink	<2 ppb		Sink
434-274	Kitchen Hand Sink	<2 ppb		Hand Sink
434-275	Kitchen Island Sink	<2 ppb		Sink
434-276	Kitchen Bunn Machine	<2 ppb		Bunn
434-277	Kitchen Kettle Room South Wall - Left	45 ppb		Sink
434-278	Kitchen Kettle Room South Wall - Right	<2 ppb		Sink
434-279	Custodial Office Cooler			Cooler
434-280	Custodial Office Area			Utility Sink

Saint Paul Public Schools
Water Sample Results
St. Paul Music Academy
Building Number: 536

Sample Date: May 15, 2016
Sampled By: Natalie Eskew & Kobe Patch

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
536-001	Kitchen - North Wall Single Left	<2ppb		Sink
536-002	Kitchen - Bunn	NA		Bunn
536-003	Kitchen - North Wall Double Right	<2ppb		Sink
536-004	Kitchen - Hand Sink	7ppb		Hand Sink
536-005	Kitchen - Island Prep	<2ppb		Sink
536-006	Kitchen Restroom	<2ppb		Sink
536-007	Kitchen Door 5 Entry - Pipe Faucet	<2ppb		Utility Faucet
536-008	Room 1212 Custodial	<2ppb		Utility Sink
536-009	Room 1211	<2ppb		Sink
536-010	Room 1211	<2ppb		Drinking Fountain
536-011	Room 1210	<2ppb		Sink
536-012	Room 1210	<2ppb		Drinking Fountain
536-013	Room 1217 Boiler Room	<2ppb		Utility Sink
536-014	Room 1209	<2ppb		Sink
536-015	Room 1209	<2ppb		Drinking Fountain
536-016	Room 1205 - Left	<2ppb		Sink
536-017	Room 1205 - Right	<2ppb		Sink
536-018	Room 1204	<2ppb		Sink
536-019	Room 1204	<2ppb		Drinking Fountain
536-020	Room 1202	5ppb		Sink
536-021	Room 1202	<2ppb		Drinking Fountain
536-022	Room 1201	<2ppb		Sink
536-023	Room 1201	<2ppb		Drinking Fountain

536-024	Hallway by Girls by Gymnasium	<2ppb		Drinking Fountain
536-025	Girls by Gymnasium - Left	<2ppb		Sink
536-026	Girls by Gymnasium - Center	<2ppb		Sink
536-027	Girls by Gymnasium - Right	<2ppb		Sink
536-028	Boys by Gymnasium - Left	<2ppb		Sink
536-029	Boys by Gymnasium - Center	<2ppb		Sink
536-030	Boys by Gymnasium - Right	<2ppb		Sink
536-031	Hallway by Boys by Gymnasium	<2ppb		Drinking Fountain
536-032	Room 1105	<2ppb		Sink
536-033	Room 1105	<2ppb		Drinking Fountain
536-034	Room 1105 Restroom	<2ppb		Sink
536-035	Room 1104	<2ppb		Sink
536-036	Room 1104	5ppb		Drinking Fountain
536-037	Room 1104 Restroom	<2ppb		Sink
536-038	Room 1103	<2ppb		Sink
536-039	Room 1103	<2ppb		Drinking Fountain
536-040	Room 1103 Restroom	<2ppb		Sink
536-041	Cafeteria	<2ppb		Water Cooler
536-042	Cafeteria	<2ppb		Bottle Filler
536-043	Girls by Room 1313 Left	<2ppb		Sink
536-044	Girls by Room 1313 Right	<2ppb		Sink
536-045	Hallway by Room 1307	<2ppb		Drinking Fountain
536-046	Room 1319 Custodial	<2ppb		Utility Sink
536-047	Room 1306 Restroom	<2ppb		Sink
536-048	Staff Restroom by Room 1306	<2ppb		Sink
536-049	Hallway by Room 1305	<2ppb		Sink
536-050	Room 1305 Restroom	<2ppb		Sink
536-051	Hallway by Room 1305	<2ppb		Drinking Fountain
536-052	Boys by Room 1305 Left	<2ppb		Sink
536-053	Boys by Room 1305 Center	<2ppb		Sink
536-054	Boys by Room 1305 Right	<2ppb		Sink
536-055	Room 1301	<2ppb		Sink
536-056	Room 1301 Restroom	<2ppb		Sink
536-057	Room 2204	<2ppb		Sink
536-058	Room 2202	<2ppb		Sink
536-059	Room 2202	<2ppb		Drinking Fountain
536-060	Room 2201	<2ppb		Sink
536-061	Room 2201	<2ppb		Drinking Fountain
536-062	Room 2211	<2ppb		Sink
536-063	Room 2208	<2ppb		Sink
536-064	Room 2208	<2ppb		Drinking Fountain
536-065	Room 2209	<2ppb		Sink
536-066	Room 2209	<2ppb		Drinking Fountain
536-067	Room 2217 Custodial	<2ppb		Utility Sink
536-068	Hallway by Room 2217	<2ppb		Drinking Fountain
536-069	Boys by Room 2217 Left	<2ppb		Sink
536-070	Boys by Room 2217 Right	<2ppb		Sink
536-071	Girls by Room 2214 Left	<2ppb		Sink
536-072	Girls by Room 2214 Center	<2ppb		Sink
536-073	Girls by Room 2214 Right	<2ppb		Sink
536-074	Hallway by Room 2214	<2ppb		Drinking Fountain
536-075	Room 2010 Nurse	<2ppb		Sink
536-076	Room 2013 Nurse Restroom	<2ppb		Sink
536-077	Main Office Womens Restroom	<2ppb		Sink
536-078	Main Office Mens Restroom	<2ppb		Sink
536-079	Room 2005 in Main Office	<2ppb		Sink
536-080	Room 2002	<2ppb		Sink
536-081	Room 2102 SW Corner	2ppb		Sink
536-082	Room 2201 NW Corner	<2ppb		Sink
536-083	Room 2102 SE Corner	<2ppb		Sink
536-084	Room 2104	<2ppb		Sink
536-085	Room 2105	<2ppb		Sink
536-086	Room 2105	<2ppb		Drinking Fountain
536-087	Room 2107 Left	11ppb		Sink
536-088	Room 2107 Right	<2ppb		Sink
536-089	Room 2106	<2ppb		Sink
536-090	Room 2106	<2ppb		Drinking Fountain
536-091	Girls by Room 2312 Left	<2ppb		Sink
536-092	Girls by Room 2312 Center	<2ppb		Sink
536-093	Girls by Room 2312 Right	<2ppb		Sink
536-094	Hallway by Room 2306	<2ppb		Drinking Fountain
536-095	Staff Restroom by Room 2306	<2ppb		Sink
536-096	Hallway by Room 2305	<2ppb		Sink
536-097	Hallway by Room 2305	<2ppb		Drinking Fountain
536-098	Boys by Room 2301 Left	<2ppb		Sink
536-099	Boys by Room 2301 Center	<2ppb		Sink
536-100	Boys by Room 2301 Right	<2ppb		Sink
536-101	Room 2318 Custodial	<2ppb		Utility Sink

Saint Paul Public Schools
Water Sample Results
Student Placement Center
Building Number: 022

Sample Date: May 1st, 2016
Sampled by: Parker Prose & Jens Erickson

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
----------	----------	--------------------	-------------------------	--------------

022-001	staff men	12		snk
022-002	staff women	11		snk
022-003	204	13		snk
022-004	219a	<2		snk
022-005	225 water bottle filler	<2		WBF
022-006	225 short	<2		df
022-007	225 Tall	<2		df
022-008	301	<2		snk
022-009	104	<2		snk
022-010	112	12		snk
022-011	111 tall	<2		df
022-012	111 short	<2		df
022-013	116	<2		snk
022-014	115 left	27	<2	snk
022-015	115 right	<2		snk
022-016	114 left	<2		snk
022-017	114 right	<2		snk
022-018	120	<2		snk
022-019	121	<2		snk

Saint Paul Public Schools
Water Sample Results
Wheelock Elementary
Building Number: 581

15-May-16
Natalie Eskew & Kobe Patch

Sample #	Location	Sample Results 2016	15 seconds Flush Sample	Fixture Type
581-001	Kitchen Room 1103	5ppb		Sink
581-002	Room 1105 Custodial Office	>100ppb		Utility Sink
581-002R	Room 1105 Custodial Office RETEST		<2ppb	Utility Sink
581-003	Room 1107 Boiler Room	<2ppb		Utility Sink
581-004	Room 1006B Main Office Restroom	<2ppb		Sink
581-005	Room 1006 in Main Office	<2ppb		Sink
581-006	Room 1005 Nurse	3ppb		Sink
581-007	Room 1004 in Main Office	<2ppb		Sink
581-008	Room 1004 in Main Office	<2ppb		Drinking Fountain
581-009	Girls by Room 1204 Left	<2ppb		Sink
581-010	Girls by Room 1204 Right	<2ppb		Sink
581-011	Boys by Room 1203 Left	<2ppb		Sink
581-012	Boys by Room 1203 Right	<2ppb		Sink
581-013	Room 1204	<2ppb		Sink
581-014	Room 1203	<2ppb		Sink
581-015	Room 1203	<2ppb		Drinking Fountain
581-016	Room 1205	<2ppb		Sink
581-017	Room 1206	<2ppb		Sink
581-018	Room 1301	<2ppb		Sink
581-019	Room 1301 Boys 1301A	<2ppb		Sink
581-020	Room 1301 Girls 1301B	6ppb		Sink
581-021	Room 1302	<2ppb		Sink
581-022	Room 1302	<2ppb		Drinking Fountain
581-023	Room 1302 Boys 1302A	3ppb		Sink
581-024	Room 1302 Girls 1302B	5ppb		Sink
581-025	Room 1303	<2ppb		Sink
581-026	Room 1303	<2ppb		Drinking Fountain
581-027	Room 1303 Boys 1303A	<2ppb		Sink
581-028	Room 1303 Girls 1303B	<2ppb		Sink
581-029	Room 1304 North Wall	<2ppb		Sink
581-030	Room 1304 Center	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
Como Park Senior
Building Number: 212

Sample Date: 5/22/16
Sampled By: Jake Baxter, Ted Sherman, & Chandala Nagendrappa

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
212-001	Staff Lounge 2301	<2ppb		Sink
212-002	Womens' Restroom	<2		Sink
212-003	Mens' Restroom	4ppb		Sink
212-004	Hall Outside Library	<2		Cooler
212-005	Room 2433	<2		Cooler
212-006	Room 2430	<2		Sink
212-007	Room 2431	4ppb		Sink
212-008	Room 2428	4		Sink
212-009	Near Room 2428	<2		Cooler
212-010	Room 2429	7		Sink
212-011	Room 2426	<2		Sink
212-012	Room 2427	17		Sink
212-013	Room 2424	3		Sink
212-014	Hall by Room 2424	3		Cooler
212-015	Room 2425	<2		Sink
212-016	Room 2422	19		Sink
212-017	Hall by Room 2420	3		Cooler

212-018	Room 2420	4		Sink
212-019	Room 2418	3		Sink
212-019.1	Womens' Restroom - Left	16		Sink
212-019.2	Womens' Restroom - Middle	3		Sink
212-019.3	Womens' Restroom - Right	3		Sink
212-019.4	Mens' Restroom - Left	22		Sink
212-019.5	Mens' Restroom - Middle	7		Sink
212-019.6	Mens' Restroom - Right	5		Sink
212-020	Room 1424	4		Sink
212-021	Hall by Room 1424	<2		Cooler
212-022	Room 1422	5		Sink
212-023	Room 1423	Removed		Sink
212-024	Room 1420	18		Sink
212-025	Room 1418 - Left	Removed		Utility
212-026	Room 1418 - Right	5		Utility
212-026.1	Womens' Restroom - Left	49		Sink
212-026.2	Womens' Restroom - Middle	4		Sink
212-026.3	Womens' Restroom - Right	7		Sink
212-026.4	Mens' Restroom - Left	5		Sink
212-026.5	Mens' Restroom - Middle	NW		Sink
212-026.6	Mens' Restroom - Right	3		Sink
212-027	Hall by Room 1420	<2		Cooler
212-028	Staff Lounge 1301	<2		Sink
212-029	Restroom East	<2		Sink
212-030	Restroom West	4		Sink
212-031	Room 1415A	8		Sink
212-032	Room 1410 South	<2		Sink
212-033	Room 1410 North	<2		Sink
212-034	Hall by Room 1415	<2		Cooler
212-035	Room 1408 South	3		Sink
212-036	Room 1408 North	<2		Sink
212-037	Room 1407	7		Sink
212-038	Room 1406	<2		Sink
212-038.1	Room 1406 Teacher Station	<2		Sink
212-039	Room 1405	2		Sink
212-039.1	Room 1405 Teacher Station	<2		Sink
212-040	Cafeteria Hydration Station	<2		Hydra
212-041	Kitchen Large Sink South - Right	<2		Large Sink
212-042	Kitchen Large Sink South - Left	<2		Large Sink
212-043	Kitchen Large Sink North Wall	<2		Large Sink
212-044	Kitchen Hand Sink North Wall	No sample		Hand Sink
212-045	Kitchen Hand Sink South Wall	3		Hand Sink
212-046	Dishwashing Hand Sink	2		Hand Sink
212-047	Serving Office Kitchen Hand Sink	No Sample		Hand Sink
212-047.25		4		
212-047.50		<2		
212-047.75		<2		
212-048	Room 1214 NW	2		Sink
212-049	Room 1214 NW	No Sample		Fountain
212-050	Room 1214 NE	<2		Fountain
212-051	Room 1214 NE	<2		Sink
212-052	Room 1214 South Wall	<2		Fountain
212-053	Room 1214 Restroom	<2		Sink
212-054	Room 1212	2		Utility
212-055	Hall by Room 1404	<2		Cooler
212-056	Room 1404 West	<2		Sink
212-057	Room 1404 East	<2		Sink
212-058	Room 1403 West	<2		Sink
212-059	Room 1403 East	<2		Sink
212-059.1	Mens' Restroom - Left	<2		Sink
212-059.2	Mens' Restroom - Middle	<2		Sink
212-059.3	Mens' Restroom - Right	<2		Sink
212-059.4	Womens' Restroom - Left	2		Sink
212-059.5	Womens' Restroom - Middle	3		Sink
212-059.6	Womens' Restroom - Right	No Sample		Sink
212-059.7	Room 1404A	<2		Sink
212-060	Room 1402A	<2		Sink
212-061	Room 1403A	<2		Sink
212-062	Room 1216 Enter Left and Clockwise	<2		Sink
212-063	Room 1216 2nd from Left	<2		Sink
212-064	Room 1216 3rd from Left	<2		Sink
212-065	Room 1216 4th from Left	<2		Sink
212-066	Room 1216 5th from Left	<2		Sink
212-067	Room 1216 6th from Left	<2		Fountain
212-068	Room 1216A	2		Sink
212-069	Room 1220 North	<2		Sink
212-070	Room 1220 South	6		Sink
212-071	Hall Cooler by Room 1222	<2		Cooler
212-072	Room 1222	<2		Sink
212-073	Hook up to Wash Machine	No sample		Sink
212-074	Room 1224 Left	<2		Sink
212-075	Room 1224 Right	<2		Sink
212-076	Room 1224A	No Sample		Sink
212-077	Room 1223	<2		Sink
212-078	Room 1221A	<2		Sink
212-078.1	Room 1221 Teacher Station	<2		Sink
212-078.2	Room 1219 Teacher Station	<2		Sink

212-078.3	Room 1217 Teacher Station	<2		Sink
212-079	Room 1213A	3		Sink
212-080	Hall Cooler by Room 1212	<2		Cooler
212-080.1	Womens' Restroom - Left	3		Sink
212-080.2	Womens' Restroom - Left Middle	3		Sink
212-080.3	Womens' Restroom - Middle	6		Sink
212-080.4	Womens' Restroom - Right Middle	11		Sink
212-080.5	Womens' Restroom - Right	7		Sink
212-080.6	Mens' Restroom - Left	18		Sink
212-080.7	Mens' Restroom - Middle	24		Sink
212-080.8	Mens' Restroom - Right	No Sample		Sink
212-081	Music Room 1205 Cooler	<2		Cooler
212-082	Hydration Station by Room 1205	<2		Hydra
212-082.1	Womens' Restroom - Left	10		Sink
212-082.2	Womens' Restroom - Middle	4		Sink
212-082.3	Womens' Restroom - Right	8		Sink
212-082.4	Mens' Restroom - Left	35		Sink
212-082.5	Mens' Restroom - Middle	3		Sink
212-082.6	Mens' Restroom - Right	5		Sink
212-083	Room 1202	4		Sink
212-084	Room 1201 Woodshop	<2		Fountain
212-085	Room 1201 Woodshop	<2		Sink
212-086	Field House - Left	<2		Fountain
212-087	Field House - Right	<2		Fountain
212-088	Room 1116 West	4		Sink
212-089	Room 1116 East	51		Sink
212-090	Room 1120 Girls' Locker Room	2		Fountain
212-091	Room 1120 Girls' Locker Room - Left	11		Sink
212-092	Room 1120 Girls' Locker Room - Right	4		Sink
212-093	Old Gym West	No Sample		
212-094	Girls' Locker Room Office Restroom	60		Sink
212-095	Room 1117 Boys' Locker Room	No Sample		Fountain
212-096	Room 1117 Boys' Locker Room - Left	6		Sink
212-097	Room 1117 Boy's Locker Room - Right	4		Sink
212-098	Room 1121 Old Gym Cooler - East	<2		Cooler
212-099	Boys' Locker Room Office Restroom	24		Sink
212-100	Room 1112 Womens' Locker Room - Left	<2		Sink
212-101	Room 1112 Womens' Locker Room - Right	5		Sink
212-102	Room 1112 Womens' Locker Room Ftn	<2		Cooler
212-103	Room 1112 Womens' Locker Restroom	5		Sink
212-104	Room 1112 Women's Locker N - Left	2		Sink
212-105	Room 1112 Womens' Locker N - Right	10		Sink
212-106	Room 1111 - Swimming Pool S	<2		Sink
212-107	Room 1111 - Swimming Pool N	2		Sink
212-108	Room 1110 Mens' Locker Room - Left	<2		Sink
212-109	Room 1110 Mens' Locker Room - Right	3		Sink
212-110	Room 1110 Mens' Locker Room Ftn	No Sample		Cooler
212-111	Room 1110B	3		Sink
212-112	Room 1110A	69		Sink
212-113	Boys' Locker Room S - Left	<2		Sink
212-114	Boys' Locker Room S - Right	<2		Sink
212-115	Room 1104 Utility Sink	4		Utility sink
212-116	Room 1002 Main Office Workroom	2		Sink
212-117	Main Office Restroom East	3		Sink
212-118	Guidance Hall	2		Fountain
212-119	Main Office Restroom West	8		Sink
212-120	Room 1019	2		Sink
212-121	Room 1018	<2		Sink
212-122		5		
212-123	Room 1025	4		Sink
212-124	Room 1021 Restroom	4		Sink
212-125	Room 1021 Office	2		Sink
212-126	Custodial Womens' Restroom by Boiler	8		Sink
212-127	Custodial Mens' Restroom by Boiler	7		Sink
212-128	Removed	No Sample		
212-129	Custodial Office	<2		Sink
212-130	Custodial Office Floor Drain	<2		Sink

Saint Paul Public Schools
Water Sample Results
Groveland Park
Building Number: 476

Sample Date: 5/22/16
Sampled by: Natalie Eskew & Kobe Patch

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
476-001	Cafeteria Room 1101	<2ppb		Hand Sink
476-002	Room 1105	<2ppb		Sink
476-003	Room 1105 Restroom	<2ppb		Sink
476-004	Hallway by Room 1105	<2ppb		Drinking Fountain
476-005	Boys Restroom by Room 1105 Left	<2ppb		Sink
476-006	Boys Restroom by Room 1105 Right	<2ppb		Sink
476-007	Room 1113	<2ppb		Sink
476-008	Room 1113 Restroom	<2ppb		Sink
476-009	Staff Restroom by Room 1119	<2ppb		Sink
476-010	Room 1123	<2ppb		Sink

476-011	Kitchen 1120 North	<2ppb		Hand Sink
476-012	Kitchen 1120 Island Prep	<2ppb		Sink
476-013	Kitchen 1120 South	<2ppb		Hand Sink
476-014	Kitchen 1120 South Prep	<2ppb		Sink
476-015	Kitchen 1120 South Red Faucet	NA		Hot Faucet
476-016	Hallway by Room 1200	<2ppb		Drinking Fountain
476-017	Girls Restroom by Room 1200 Left	<2ppb		Sink
476-018	Girls Restroom by Room 1200 Right	<2ppb		Sink
476-019	Room 1135	<2ppb		Drinking Fountain
476-020	Room 1135	<2ppb		Sink
476-021	Room 1135 Restroom	<2ppb		Sink
476-022	Room 2020 Nurse	<2ppb		Sink
476-023	Room 2020 Nurse Restroom	<2ppb		Sink
476-024	Room 2015 Staff Lounge	<2ppb		Sink
476-025	Main Office Restroom by 2015 Lounge	<2ppb		Sink
476-026	Girls Restroom by Room 2137 Left	<2ppb		Sink
476-027	Girls Restroom by Room 2137 Center	<2ppb		Sink
476-028	Girls Restroom by Room 2137 Right	<2ppb		Sink
476-029	Hallway by Room 2137	<2ppb		Drinking Fountain
476-030	Custodial Room 2120 Upper	<2ppb		Utility Sink
476-031	Custodial Room 2120 Lower	5ppb		Utility Sink
476-032	Boys Restroom by Room 2113 Left	<2ppb		Sink
476-033	Boys Restroom by Room 2113 Right	<2ppb		Sink
476-034	Hallway by Room 2113	<2ppb		Drinking Fountain
476-035	Room 2104	<2ppb		Sink
476-036	Girls Restroom by Room 3137 Left	3ppb		Sink
476-037	Girls Restroom by Room 3137 Center	<2ppb		Sink
476-038	Girls Restroom by Room 3137 Right	<2ppb		Sink
476-039	Hallway by Room 3137	<2ppb		Drinking Fountain
476-040	Room 3136 Lounge South	<2ppb		Sink
476-041	Room 3136 Lounge Restroom	<2ppb		Sink
476-042	Room 3136 Lounge North	<2ppb		Sink
476-043	Restroom by Room 3121	<2ppb		Sink
476-044	Room 3120	<2ppb		Sink
476-045	Custodial Room 3316 Upper	<2ppb		Utility Sink
476-046	Custodial Room 3316 Lower	<2ppb		Utility Sink
476-047	Boys Restroom by Room 3113 Left	5ppb		Sink
476-048	Boys Restroom by Room 3113 Right	<2ppb		Sink
476-049	Hallway by Room 3113	<2ppb		Drinking Fountain
476-050	Room 3104	6ppb		Sink
476-051	Mens Restroom by Gym 1320	<2ppb		Sink
476-052	Hallway by Gym 1320	<2ppb		Drinking Fountain
476-053	Womens Restroom by Gym 1320	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
J.J. Hill Montessori
Building Number: 495

Sample Date: 5/22/16
Sampled by: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
495-001	1104 Mechanical - SNK	51		Sink
495-002	1103D Kitchen Restroom - SNK	18		Sink
495-003	1103 Kitchen Hand Sink	41		Sink
495-004	1103E Sprayer - SNK	<2		Sink
495-005	1103 Sprayer - SNK	<2		Sink
495-006	1103 - SNK	<2		Sink
495-007	1103 - Bunn	-		Bunn
495-008	1103B Maintenance - SNK	30		Slop
495-009	Restroom 1111 Girl's left - SNK	<2		Sink
495-010	Restroom 1111 Girl's right - SNK	<2		Sink
495-011	Restroom 1109A left - SNK	4		Sink
495-012	Restroom 1109A right - SNK	<2		Sink
495-013	Outside Gym 1109 - DF	<2		Fountain
495-014	Bathroom outside Gym 1109 - SNK	<2		Sink
495-015	Room 1014 - SNK	45		Sink
495-016	Nurse's - SNK	<2		Sink
495-017	Nurse's Restroom 1015 - SNK	<2		Sink
495-018	Room 1008 - SNK	<2		Sink
495-019	Lounge 1009 - SNK	<2		Sink
495-020	Restroom 1006 - SNK	7		Sink
495-021	Restroom 1007 left - SNK	8		Sink
495-022	Restroom 1007 right - SNK	13		Sink
495-023	Room 1008 - WC	<2		Cooler
495-024	Atrium left - DF	3		Fountain
495-025	Atrium right - DF	<2		Fountain
495-026	Room 1401 - SNK	5		Sink
495-027	Room 1401A Restroom - SNK	6		Sink
495-028	Room 1402 - SNK	6		Sink
495-029	Room 1402A Restroom - SNK	5		Sink
495-030	Room 1403 - SNK	46		Sink
495-031	Room 1403A Restroom - SNK	56		Sink
495-032	Room 1404 - SNK	4		Sink
495-033	Room 1404A Restroom - SNK	22		Sink
495-034	Room 1308 - SNK	<2		Sink
495-035	Room 1407 - SNK	<2		Sink

495-036	Room 1309 left - SNK	<2		Sink
495-037	Room 1309 middle - SNK	16		Sink
495-038	Room 1309 right - SNK	6		Sink
495-039	Room 2215 - SNK	13		Sink
495-040	Room 2209 - SNK	6		Sink
495-041	Room 2209A Maintenance - SNK	13		Slop
495-042	Outside 2209 - DF	5		Fountain
495-043	2210/2211 Restroom left - SNK	<2		Sink
495-044	2210/2211 Restroom right - SNK	<2		Sink
495-045	Room 2201 - SNK	<2		Sink
495-046	Room 2207 - SNK	11		Sink
495-047	Outside 2207 - DF	<2		Fountain
495-048	2206/2205 Restroom left - SNK	<2		Sink
495-049	2206/2205 Restroom right - SNK	<2		Sink
495-050	Room 2204 - SNK	19		Sink
495-051	Media Center Rom 1304 - SNK	4		Sink
495-052	Room 1213 - SNK	<2		Sink
495-053	1212/1211 Restroom left - SNK	<2		Sink
495-054	1212/1211 Restroom right - SNK	<2		Sink
495-055	1210 - SNK	<2		Sink
495-056	1210A Maintenance - SNK	<2		Sink
495-057	Outside 1210 - DF	<2		Fountain
495-058	Room 1209 - SNK	<2		Sink
495-059	Room 1208 - SNK	<2		Sink
495-060	Room 1207 - SNK	<2		Sink
495-061	Outside 1207 - DF	8		Fountain
495-062	1206/1205 Restroom left - SNK	<2		Sink
495-063	1206/1205 Restroom right - SNK	<2		Sink
495-064	Room 1202 - SNK	9		Sink
495-065	Room 1204 - SNK	<2		Sink
495-066	Room 1215 - SNK	33		Sink
495-001.5	1104 Mechanical - SNK		60	Sink
495-003.5	1103 Kitchen Hand - SNK	<2		Sink
495.008.5	1103B Maintenance - SNK	<2		Sink
495-015.5	Room 1014 - SNK	<2		Sink
495-030.5	Room 1403 - SNK	<2		Sink
495-031.5	Room 1403A Restroom - SNK	<2		Sink
495-033.5	Room 1404A Restroom - SNK	<2		Sink
495-066.5	Room 1215 - SNK	<2		Sink

Saint Paul Public Schools
Water Sample Results
Linwood Monroe lower
Building Number: 509

Sample Date: 5/22/2016
Sampled By: Chandala Nagendrappa
Jake Baxter

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
509-001	Kitchen Large Sink Left	22	2	Sink
509-002	Kitchen Large Sink Right	<2		Sink
509-003	Kitchen Dishwashing sink	<2		Sink
509-004	Kitchen hand sink	4		Sink
509-005	Cooler by room 1202	<2		Cooler
509-006	Cooler in front of Cafeteria 1303	<2		Cooler
509-007	Restroom by hallway stairs First floor	17		Sink
509-008	Boys RR by Hallway Left	<2		Sink
509-009	Boys RR by Hallway Right	<2		Sink
509-010	Boys RR by Hallway Middle	<2		Sink
509-011	Girls RR by Hallway Left	<2		Sink
509-012	Girls RR by Hallway Left Middle	<2		Sink
509-013	Girls RR by Hallway Right Middle	18		Sink
509-014	Girls RR by Hallway Right	<2		Sink
509-015	Staff Workroom 1006	16		Sink
509-016	Staff Restroom 1006	9		Sink
509-017	Staff Lounge room 1107	17		Sink
509-018	Staff Lounge room Restroom 1107	11		Sink
509-019	Room 1108 Classroom	<2		Sink
509-020	Room 1202 RR sink	6		Sink
509-021	Room 1204 Sink classroom	27	2	Sink
509-022	Cooler by room 1216	<2		Cooler
509-023	Room 1216 RR sink	<2		Sink
509-024	Room 2204 Sink	17		Sink
509-025	Room 2204A RR sink	<2		Sink
509-026	Hallway cooler by room 2202	<2		Cooler
509-027	Room 2202 RR sink	12		Sink
509-028	Hallway cooler by room 2202	<2		Cooler
509-029	Room 2102	<2		Sink
509-030	RR in front of 2104	<2		Sink
509-031	Room 2104 sink	31	2	Sink
509-032	Boys RR second floor Right	26	2	Sink
509-033	Boys RR second floor Middle	<2		Sink
509-034	Boys RR second floor Left	15		Sink
509-035	Girls RR by room 2106 Left	<2		Sink
509-036	Girls RR by room 2106 Left Middle	<2		Sink
509-037	Girls RR by room 2106 Right Middle	20	2	Sink
509-038	Girls RR by room 2106 Right	<2		Sink

509-039	Classroom 2107	<2		Sink
509-040	No Sample			
509-041	Hallway cooler by 3204	<2		Cooler
509-042	Room 3204 RR sink	<2		Sink
509-043	Hallway cooler by room 3102	<2		Cooler
509-044	Room 3102	11		Sink
509-045	RR in front of 3102	3		Sink
509-046	Boys RR third Floor Left	<2		Sink
509-047	Boys RR third Floor Middle	17		Sink
509-048	Boys RR third Floor Right	<2		Sink
509-049	Room 3104	<2		Sink
509-050	Girls RR third floor Left	<2		Sink
509-051	Girls RR third floor Left Middle	8		Sink
509-052	Girls RR third floor Right Middle	23	2	Sink
509-053	Girls RR third floor Right	<2		Sink
509-054	Classroom 3107	11		Sink
509-055	Basement room 0101	<2		Sink
509-056	Basement Mechanical room 0101A	7		Sink
509-057	Basement Bolier room 0101B	<2		Sink

Saint Paul Public Schools
Water Sample Results
Murray Middle School
Building Number: 342

Sample Date: 5/22/16
Sampled by: Parker Prose & Kegan Silonis

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
342-001	kitchen office	<2		snk
342-002	kitchen west wall	<2		snk
342-003	kitchen south wall	<2		snk
342-004	kitchen south wall	<2		ksnk
342-005	kitchen south wall sprayer	3		ksnk
342-006	kitchen - bunn	<2		bunn
342-007	cafeteria WC short	<2		WC
342-008	Cafeteria WC tall	<2		WC
342-009	1107 storage	30	503/8ppm	snk
342-010	1109	<2		df
342-011	1109	<2		wc
342-012	1101 north	4		df
342-013	girls bathroom locker room	<2		df
342-014	girls locker room	<2		snk
342-015	girls locker room	18		df
342-016	boys locker room	82	510/18ppm	df
342-017	1002 staff work room	<2		snk
342-018	office women's bathroom	2		snk
342-019	office men's bathroom	<2		snk
342-020	1204 custodial closet	<2		snk
342-021	boys bathroom left by 1202	5		snk
342-022	boys bathroom right by 1202	<2		snk
342-023	1202 womens bathroom left	<2		snk
342-024	1202 womens bathroom right	<2		snk
342-025	wc by 1204	<2		WC
342-026	1209	5		snk
342-027	staff restroom by 1218 Left	<2		snk
342-028	Staff restroom by 1218 Right	<2		snk
342-029	WC by 1218	<2		WC
342-030	Medica center work room	54	531/10ppm	snk
342-031	medica center lounge	39	532/13ppm	snk
342-032	utility sink	3		snk
342-033	boys by 2205 left	<2		snk
342-034	boys by 2205 right	<2		snk
342-035	girls by 2205 left	<2		snk
342-036	girls by 2205 right	<2		snk
342-037	2211 bathroom straight	<2		snk
342-038	2211 bathroom left	<2		snk
342-039	2214 wc	<2		WC
342-040	2112 boys left	3		snk
342-041	2112 boys right	8		snk
342-042	2110 teacher's sink	<2		snk
342-043	2103 teacher	<2		snk
342-044	2103a east	2		snk
342-045	2103a north	10		snk
342-046	2103 back sink	21	545/3ppm	snk
342-047	2104 back	10		snk
342-048	2104 front	3		snk
342-049	2102 front	16		snk
342-050	2109 back left	<2		snk
342-051	2109 back right	8		snk
342-052	2109 front	18		snk
342-053	2108 SE	<2		snk
342-054	2108 SW	<2		snk
342-055	2108 NW	<2		snk
342-056	2108 N	2		snk
342-057	2108 NE	19		snk
342-058	2106	<2		DF
342-059	2106 girls L	10		snk

342-060	2106 Girls Right	<2		snk
342-061	2105A	17		snk
342-062	2105A Bathroom	3		snk
342-063	2105	5		snk
342-064	0203 Right	<2		snk
342-065	0203 Left	<2		snk
342-066	0405 Tall	<2		WC
342-067	0405 Short	<2		WC
342-068	0405 Hallway Girls Left	<2		snk
342-069	0405 Hallway Grils right	<2		snk
342-070	0405 Hallway Girls Left	<2		snk
342-071	0405 Hallway Girls Right	<2		snk
342-072	0403 Utility	<2		Utility Sink

Saint Paul Public Schools
Water Sample Results
Obama Elementary
Building Number: 578

Sample Date: 5/22/16
Sampled by: Mary Ferrian & Chad Whyalen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
578-001	3203A Maintenance SNK	<2		Slop
578-002	Hallway outside 3203 - WC	<2		Cooler
578-003	Room 3205 - SNK	19		Sink
578-004	Restroom 3206 Boy's (left) - SNK	6		Sink
578-005	Restroom 3206 Boy's (center) - SNK	<2		Sink
578-006	Restroom 3206 Boy's (right) - SNK	<2		Sink
578-007	Room 3209 n- SNK	<2		Sink
578-008	Room 3210 - SNK	<2		Sink
578-009	Restroom 3212 Girl's (left) - SNK	<2		Sink
578-010	Restroom 3212 Girl's (center) - SNK	<2		Sink
578-011	Restroom 3212 Girl's (right) - SNK	<2		Sink
578-012	Outside 3213 - WC	<2		Cooler
578-013	Restroom 3217 - SNK	<2		Sink
578-014	Restroom 2212 Girl's (left) - SNK	<2		Sink
578-015	Restroom 2212 Girl's (center) - SNK	<2		Sink
578-016	Restroom 2212 Girl's (right) - SNK	<2		Sink
578-017	Restroom 2206 Boy's (left) - SNK	<2		Sink
578-018	Restroom 2206 Boy's (center) - SNK	<2		Sink
578-019	Restroom 2206 Boy's (right) - SNK	<2		Sink
578-020	Room 2205 - SNK	<2		Sink
578-021	Hallway Outside 2203 - WC	13		Cooler
578-022	Room 2203A Maintenance - SNK	<2		Slop
578-023	Gym 1201 - WC	<2		Cooler
578-024	Room 1207 (left) - SNK	<2		Sink
578-025	Room 1207 (right) - SNK	15		Sink
578-026	Room 1207A Maintenance - SNK	<2		Sink
578-027	Hallway outside 1207 - WC	<2		Cooler
578-028	Restroom 1208 Boy's (left) - SNK	<2		Sink
578-029	Restroom 1208 Boy's (center) - SNK	<2		Sink
578-030	Restroom 1208 (right) - SNK	<2		Sink
578-031	Room 1209 - SNK	<2		Sink
578-032	Restroom 1218 Girl's (left)	<2		Sink
578-033	Restroom 1218 Girl's (center)	<2		Sink
578-034	Restroom 1218 Girl's (right)	<2		Sink
578-035	Room 1219 Southwest wall - SNK	<2		Sink
578-036	Room 1219 West Island (North) - SNK	-		Sink
578-037	Room 1219 West Island (South) - SNK	-		Sink
578-038	Room 1219 on Room Partition - SNK	<2		Sink
578-039	Room 1219 East Island (North) - SNK	<2		Sink
578-040	Room 1219 East Island (South) - SNK	<2		Sink
578-041	Hallway Outside 1219 - WC	<2		Cooler
578-042	Staff Lounge 1103A - SNK	9		Sink
578-043	1105 Kitchen Restroom - SNK	<2		Sink
578-044	1105 Kitchen North Wall - KS	<2		Sink
578-045	1104 Kitchen West Wall - SNK	14		Sink
578-046	1104B Dishroom - SNK	<2		Sink
578-047	1104B Dishroom (left) - KS	<2		Sink
578-048	1104B Dishroom (Right) - KS	4		Sink
578-049	1104 Kitchen - Bunn	-		Bunn
578-050	1015 Nurse's - SNK	<2		Sink
578-051	1011 Nuse Restroom - SNK	24		Sink
578-052	1012 Nurse Restroom - SNK	<2		Sink
578-053	Hallway of offices - SNK	<2		Sink
578-054	1019 Restroom - SNK	<2		Sink
578-055	1020 Restroom - SNK	<2		Sink
578-056	Restroom 1108 Girl's (left) - SNK	<2		Sink
578-057	Restroom 1108 Girl's (Center) - SNK	7		Sink
578-058	Restroom 1108 Girl's (right) - SNK	<2		Sink
578-059	Restroom 1109 Boy's (left) - SNK	19		Sink
578-060	Restroom 1109 Boy's (Center) - SNK	<2		Sink
578-061	Restroom 1109 Boy's (Right) - SNK	<2		Sink
578-062	Fountain Outside 1108A - DF	<2		Fountain
578-063	1108A Maintenance - SNK	<2		Slop
578-064	Room 1113 in Media Center - SNK	9		Sink

578-065	Room 1120 West side of Island (North) - SNK	4		Sink
578-066	Room 1120 West side of Island (South) - SNK	<2		Sink
578-067	Room 1120 East Wall - SNK	52		Sink
578-068	Room 1120 East side of Island (North) - SNK	57		Sink
578-069	Room 1120 East side of Island (South) - SNK	100+		Sink
578-070	Room 1119 - SNK	55		Sink
578-071	Room 1118 - SNK	64		Sink
578-072	Room 1114 - SNK	<2		Sink
578-073	Room 1114 - DF	<2		Fountain
578-074	Room 116 West Wall - SNK	<2		Sink
578-075	Room 116 West Island (North) - SNK	-		Sink
578-076	Room 116 West Island (South) - SNK	-		Sink
578-077	Room 116 East Island (North) - SNK	-		Sink
578-078	Room 116 East Island (South) - SNK	-		Sink
578-079	Room 115B Restroom - SNK	<2		Sink
578-080	Room 1301 - SNK	<2		Sink
578-081	Restroom 1319 Girl's (left) - SNK	<2		Sink
578-082	Restroom 1319 Girl's (Center) - SNK	<2		Sink
578-083	Restroom 1319 Girl's (Right) - SNK	<2		Sink
578-084	Room 1302 - SNK	<2		Sink
578-085	Room 1303 - SNK	4		Sink
578-086	Next to 0301 - WC	9		Cooler
578-087	Room 1306 - SNK	30		Sink
578-088	Room 1307 - SNK	<2		Sink
578-089	Room 1308 - SNK	<2		Sink
578-090	Room 1316 Maintenance - SNK	8		Slop
578-091	Room 1309 - WC	6		Cooler
578-092	Room 1309B Restroom - SNK	<2		Sink
578-093	Next to 1316 - WC	<2		Cooler
578-094	Restroom 1315 Boy's (left) - SNK	3		Sink
578-095	Restroom 1315 Boy's (center) - SNK	4		Sink
578-096	Restroom 1315 Boy's (right) - SNK	<2		Sink
578-097	Room 1310 - SNK	48		Sink
578-098	Room 1311 - SNK	<2		Sink
578-099	Restroom 2315 Boy's (left) - SNK	<2		Sink
578-100	Restroom 2315 Boy's (Left middle) - SNK	<2		Sink
578-101	Restroom 2315 Boy's (Right middle) - SNK	<2		Sink
578-102	Restroom 2315 (Right) - SNK	<2		Sink
578-103	2315A Maintenance - SNK	24		Slop
578-104	Room 2311 - SNK	<2		Sink
578-105	Outside 2310 - WC	<2		Cooler
578-106	Room 2310B Restroom - SNK	<2		Sink
578-107	Outside 2307 - WC	22		Cooler
578-108	Room 2307 - SNK	-		Sink
578-109	Room 2304 Restroom - SNK	<2		Sink
578-110	Restroom 2316 Girl's (left) - SNK	<2		Sink
578-111	Restroom 2316 Girl's (center) - SNK	<2		Sink
578-112	Restroom 2316 (right) - SNK	<2		Sink
578-113	Restroom 3315 Girl's (left) - SNK	<2		Sink
578-114	Restroom 3315 Girl's (center) - SNK	<2		Sink
578-115	Restroom 3315 Girl's (right) - SNK	<2		Sink
578-116	Across From 3304 - WC	32		Cooler
578-117	Room 3304 - SNK	<2		Sink
578-118	Outside 3307 - WC	<2		Cooler
578-119	Room 3308 - SNK	<2		Sink
578-120	Restroom 3314 Boy's (left) - SNK	6		Sink
578-121	Restroom 3314 Boy's (left middle) - SNK	<2		Sink
578-122	Restroom 3314 (Right middle) - SNK	<2		Sink
578-123	Restroom 3314 (right) - SNK	<2		Sink
578-124	3314B Maintenance - SNK	<2		Slop
578-125	0301 Maintenance - SNK	<2		Sink
578-126	Room 0216 - SNK	<2		Sink
578-127	Room 0214 - SNK	<2		Sink
578-128	Room 0218 - SNK	<2		Sink
578-129	Room 0213 - SNK	<2		Sink
578-130	Room 0212 - SNK	7		Sink
578-131	Restroom 0207 - SNK	86		Sink
578-132	Room 0204 - SNK	5		Sink
578-133	Room 0203 SNK	<2		Slop
578-051.5	1011 Nuse Restroom - SNK		<2	Sink
578-067.5	Room 1120 East Wall - SNK		<2	Sink
578-068.5	Room 1120 East side of Island (North) - SNK		<2	Sink
578-069.5	Room 1120 East side of Island (South) - SNK		<2	Sink
578-070.5	Room 1119 - SNK		<2	Sink
578-071.5	Room 1118 - SNK		<2	Sink
578-087.5	Room 1306 - SNK		<2	Sink
578-097.5	Room 1310 - SNK		<2	Sink
578-103.5	2315A Maintenance - SNK		100+	Sink
578-107.5	Outside 2307 - WC		<2	Cooler
578-116.5	Across From 3304 - WC		<2	Cooler
578-131.5	Restroom 0207 - SNK		<2	Sink

Saint Paul Public Schools
Water Sample Results
Ramsey Middle
Building Number: 345

Sample Date: 5/22/16
Sampled by: Natalie Eskew, Kobe Patch

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
345-001	K3 Entrance Maintenance	<2ppb		Utility Sink
345-002	Kitchen Restroom 1303A	<2ppb		Sink
345-003	Kitchen Room 1303 South	<2ppb		Hand Sink
345-004	Kitchen Room 1303	NA		Bunn
345-005	Kitchen Room 1303 North Left	<2ppb		Sink
345-006	Kitchen Room 1303 North Right	3ppb		Sink
345-007	Kitchen Room 1303 North	<2ppb		Hand Sink
345-008	Room 1302 Cafeteria	<2ppb		Water Cooler
345-009	Room 1302 Cafeteria	<2ppb		Bottle Filler
345-010	Room 1306 Gym South	4ppb		Drinking Fountain
345-011	Boys Locker Room 1307	<2ppb		Drinking Fountain
345-012	Boys Locker Room Office Restroom 1308A	<2ppb		Sink
345-013	Boys Locker Room 1307C Left	<2ppb		Sink
345-014	Boys Locker Room 1307C Center	<2ppb		Sink
345-015	Boys Locker Room 1307C Right	30ppb		Sink
345-015R	Boys Locker Room 1307C Right RETEST		<2ppb	Sink
345-016	Girls Locker Room 1309	<2ppb		Drinking Fountain
345-017	Girls Locker Room 1309 Left	12ppb		Sink
345-018	Girls Locker Room 1309 Right	3ppb		Sink
345-019	Girls Locker Room Office Restroom 1310A	16ppb		Sink
345-020	Hallway by Cafeteria	<2ppb		Drinking Fountain
345-021	Boys Restroom 1313 Left	2ppb		Sink
345-022	Boys Restroom 1313 Right	<2ppb		Sink
345-023	Custodial Room 1312 Left	9ppb		Utility Sink
345-024	Custodial Room 1312 Right	<2ppb		Utility Sink
345-025	Girls Restroom 1311	<2ppb		Sink
345-026	Media Center Office 1215	<2ppb		Sink
345-027	Room 1209	<2ppb		Sink
345-028	Hallway by Room 1205	<2ppb		Drinking Fountain
345-029	Mens Restroom 1201	<2ppb		Sink
345-030	Womens Restroom 1202	<2ppb		Sink
345-031	Custodial Room 1104 Left	<2ppb		Utility Sink
345-032	Custodial Room 1104 Right	<2ppb		Utility Sink
345-033	Mens Restroom by Room 1004 Left	<2ppb		Sink
345-034	Mens Restroom by Room 1004 Center	<2ppb		Sink
345-035	Mens Restroom by Room 1004 Right	<2ppb		Sink
345-036	Hallway by Room 1102	<2ppb		Drinking Fountain
345-037	Room 1007	<2ppb		Sink
345-038	Main Office Restroom 1010A	2ppb		Sink
345-039	Nurse Restroom 1014B	34ppb		Sink
345-039R	Nurse Restroom 1014B RETEST		<2ppb	Sink
345-040	Nurse Room 1015	6ppb		Sink
345-041	Hallway by Room 1014	<2ppb		Drinking Fountain
345-042	Womens Restroom by Room 1014 Left	<2ppb		Sink
345-043	Womens Restroom by Room 1014 Center	<2ppb		Sink
345-044	Womens Restroom by Room 1014 Right	<2ppb		Sink
345-045	Room 0204 Left	<2ppb		Sink
345-046	Room 0204 Center	<2ppb		Sink
345-047	Room 0204 Right	<2ppb		Sink
345-048	Mechanical Room 0103 Left	<2ppb		Utility Sink
345-049	Mechanical Room 0103 Center	<2ppb		Utility Sink
345-050	Mechanical Room 0103 Right	<2ppb		Utility Sink
345-051	Custodial Room by Room 0105	3ppb		Utility Sink
345-052	Room 0105 Left	<2ppb		Sink
345-053	Room 0105 Center	<2ppb		Sink
345-054	Room 0105 Right	<2ppb		Sink
345-055	Staff Restroom by Room 0109	<2ppb		Sink
345-056	Mens Restroom by Room 2105 Left	<2ppb		Sink
345-057	Mens Restroom by Room 2105 Center	<2ppb		Sink
345-058	Mens Restroom by Room 2105 Right	<2ppb		Sink
345-059	Custodial Room 2103A Left	8ppb		Utility Sink
345-060	Custodial Room 2103A Right	<2ppb		Utility Sink
345-061	Hallway by Room 2103	<2ppb		Drinking Fountain
345-062	Room 2107 Staff Lounge	<2ppb		Sink
345-063	Room 2017 Restroom	4ppb		Sink
345-064	Room 2110	<2ppb		Sink
345-065	Womens Restroom by Room 2114 Left	<2ppb		Sink
345-066	Womens Restroom by Room 2114 Center	<2ppb		Sink
345-067	Womens Restroom by Room 2114 Right	<2ppb		Sink
345-068	Hallway by Room 2114	<2ppb		Drinking Fountain
345-069	Room 2119	<2ppb		Sink
345-070	Custodial Room 2301	<2ppb		Utility Sink
345-071	Room 2305	<2ppb		Sink
345-072	Custodial Room 3106B	<2ppb		Utility Sink
345-073	Mens Restroom by Room 3103 Right	<2ppb		Sink
345-074	Room 3101	<2ppb		Sink
345-075	Hallway by Room 3103	<2ppb		Drinking Fountain
345-076	Room 3107 Teachers Station	<2ppb		Sink
345-077	Room 3108 Storage	<2ppb		Sink
345-078	Room 3110 Teachers Station	<2ppb		Sink
345-079	Room 3112 Restroom	<2ppb		Sink
345-080	Womens Restroom by Room 3114 Left	<2ppb		Sink
345-081	Womens Restroom by Room 3114 Center	3ppb		Sink

345-082	Womens Restroom by Room 3114 Right	<2ppb		Sink
345-083	Hallway by Room 3114	<2ppb		Drinking Fountain
345-084	Room 3114	<2ppb		Sink
345-085	Room 3114 Storage	<2ppb		Sink

Saint Paul Public Schools
Water Sample Results
St. Anthony Park Elementary
Building Number: 557

Sample Date: 5/22/16
Sampled by: Parker Prose and Kegan Silonis

Sample #	Location	Sample Results 2016	Flush Sample	Fixture Type
557-001	Kitchen (SE) Sprayer	12		KSNK
557-002	Kitchen (SE) KSNK	22		KSNK
557-003	Kitchen (Middle) SNK	<2		SNK
557-004	Kitchen (West) Sprayer	<2		KSNK
557-005	Kitchen Slop Sink	<2		SNK
557-006	Kitchen Bathroom SNK	<2		SNK
557-007	Bunn Machine	<2		BUNN
557-008	1100A Tall	<2		WC
557-009	1100A Short	<2		WC
557-010	1109 S WC	<2		WC
557-011	1109 N WC	<2		WC
557-012	1112 SNK	<2		SNK
557-013	Boy's @ 1107	<2		SNK
557-014	1116 Girl's	<2		SNK
557-015	1301 SNK	4		SNK
557-016	1314 L	<2		SNK
557-017	1314 R	<2		SNK
557-018	1313 SNK	<2		SNK
557-019	1313 DF	3		DF
557-020	1307 SNK	<2		SNK
557-021	1307 DF	<2		DF
557-022	1312 SNK	<2		SNK
557-023	1312 DF	<2		DF
557-024	1308 SNK	<2		SNK
557-025	1308 DF	<2		DF
557-026	1300 L	<2		WC
557-027	1300 R	<2		WC
557-028	1310 L - Girl's	<2		SNK
557-029	1310 R - Girl's	<2		SNK
557-030	1309 L - Boy's	<2		SNK
557-031	1309 R - Boy's	<2		SNK
557-032	1213 Bathroom	<2		SNK
557-033	1213 SNK	<2		SNK
557-034	1213 - DF	<2		DF
557-035	1212 - Bathroom	2		SNK
557-036	1212 - DF	<2		DF
557-037	1212 SNK	<2		SNK
557-038	1214 SNK	<2		SNK
557-039	1214 DF	<2		DF
557-040	1211 SNK	<2		SNK
557-041	1211 DF	<2		DF
557-042	1215 SNK	<2		SNK
557-043	1215 DF	<2		DF
557-044	1210 SNK	<2		SNK
557-045	1210 DF	5		DF
557-046	1406 Staff Lounge	<2		SNK
557-047	1404 SNK	<2		SNK
557-048	1403 SNK	<2		SNK
557-049	1405 SNK	<2		SNK
557-050	1216 SNK	4		SNK
557-051	1216 DF	<2		DF
557-052	1121 SNK	4		SNK
557-053	1202 SNK	<2		SNK
557-054	1202 SNK	<2		SNK
557-055	1202/1203 WC Tall	<2		WC
557-056	1202/1203 WC Short	<2		WC
557-057	1203 SNK	<2		SNK
557-058	1203 SNK	<2		SNK
557-059	1201 Slop Sink	<2		SNK
557-060	1123 Work Room SNK	<2		SNK
557-061	1003 Conf	<2		SNK
557-062	Nurse Sink	<2		SNK
557-063	2209 SNK	<2		SNK
557-064	2210 SNK	<2		SNK
557-065	2200 (N) Left Tall WC	<2		WC
557-066	2200 (N) Right Short WC	<2		WC
557-067	2212 SNK	<2		SNK
557-068	2212 Bathroom SNK	5		SNK
557-069	2202 Left	4		SNK
557-070	2202 Right	<2		SNK
557-071	2203 Left	<2		SNK
557-072	2203 Right	<2		SNK
557-073	2204 SNK	<2		SNK

557-074	2204 DF	<2		SNK
557-075	2205 SNK	<2		SNK
557-076	2205 DF	<2		DF
557-077	2206 SNK	<2		SNK
557-078	2206 DF	<2		DF
557-079	2208 SNK - WALL	<2		SNK
557-080	2208 SNK - COUNTER	3		SNK
557-081	2200 South WC	<2		WC

**Saint Paul Public Schools
Water Sample Results
Adams Spanish Immersion
Building Number: 410**

**Sample Date: June 5, 2016
Sampled by:
Nancy Fischer
Alissa Houghtaling**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
410-001	3110 Corridor - left	below 2ppb		cooler
410-002	3110 Corridor - right	below 2ppb		cooler
410-003	3112 Boy's Restroom- left	2ppb		sink
410-004	3112 Boy's Restroom- right	below 2ppb		sink
410-005	3104A Restroom	below 2ppb		sink
410-006	3107 Custodial Closet	below 2ppb		slop
410-007	3104- left	3ppb		sink
410-008	3104- right	5ppb		sink
410-009	3105 Girl's Restroom- left	3ppb		sink
410-010	3105 Girl's Restroom- right	below 2ppb		sink
410-011	3102	below 2ppb		sink
410-012	2110A Boy's Restroom- left	below 2ppb		sink
410-013	2110A Boy's Restroom- right	below 2ppb		sink
410-014	2111	below 2ppb		sink
410-015	2210 Corridor- left	below 2ppb		cooler
410-016	2210 Corridor- right	14ppb		cooler
410-017	2100B Restroom	below 2ppb		sink
410-018	2102	below 2ppb		sink
410-019	2101 Girl's Restroom- left	below 2ppb		sink
410-020	2101 Girl's Restroom- middle	below 2ppb		sink
410-021	2101 Girl's Restroom- right	below 2ppb		sink
410-022	2100 Corridor	below 2ppb		fountain
410-023	2201A Restroom	below 2ppb		sink
410-024	2201 Staff Lounge	below 2ppb		sink
410-025	2204	6ppb		sink
410-026	2203	below 2ppb		sink
410-027	2202	12ppb		sink
410-028	2205	5ppb		sink
410-029	2206	3ppb		sink
410-030	2213			sink
410-031	2207	6ppb		sink
410-032	2208 Maintenance	below 2ppb		slop
410-033	1009 Main Office	below 2ppb		sink
410-034	1007 Nurses Restroom	below 2ppb		sink
410-035	1008 Restroom	6ppb		sink
410-036	1101 Girl's Restroom- left	4ppb		sink
410-037	1101 Girl's Restroom- right	below 2ppb		sink
410-038	1100 Corridor across from 1106	below 2ppb		fountain
410-039	1102 Restroom	below 2ppb		sink
410-040	1103	below 2ppb		sink
410-041	1011 Restroom between 1111&1104	below 2ppb		sink
410-042	1104 Kindergarten	below 2ppb		sink
410-043	1104A Kindergarten Restroom	below 2ppb		sink
410-044	1106 Kindergarten	below 2ppb		sink
410-045	1106A Kindergarten Restroom	below 2ppb		sink
410-046	1111 Kindergarten	below 2ppb		sink
410-047	1115 Kindergarten	below 2ppb		sink
410-048	1115B Kindergarten Restroom	4ppb		sink
410-049	1114 Kindergarten	4ppb		sink
410-050	1114B Kindergarten Restroom	below 2ppb		sink
410-051	1108 Kindergarten	below 2ppb		sink
410-052	1108B Kindergarten Restroom	below 2ppb		sink
410-053	1110 Corridor across from 1108-left	below 2ppb		cooler
410-054	1110 Corridor across from 1108-right	below 2ppb		cooler
410-055	1113 Boy's Restroom- left	below 2ppb		sink
410-056	1113 Boy's Restroom- right	below 2ppb		sink
410-057	1110A Maintenance	below 2ppb		slop
410-058	1204	29ppb	7ppb	sink
410-059	1203	11ppb		sink
410-060	1202	20ppb		sink
410-061	1207	14ppb		sink
410-062	1206	5ppb		sink
410-063	1205	below 2ppb		sink
410-064	Corridor outside Kitchen 1404	below 2ppb		slop
410-065	1407 Kitchen Restroom	below 2ppb		sink
410-066	1404 Kitchen- by Restroom	below 2ppb		hand sink
410-067	1404 Kitchen- left	below 2ppb		hand sink
410-068	1404 Kitchen- right	below 2ppb		hand sink
410-069	1404 Kitchen- left	below 2ppb		large sink

410-070	1404 Kitchen- right	4ppb		large sink
410-071	1402 Cafeteria/Gym- left	below 2ppb		cooler
410-072	1402 Cafeteria/Gym- right	below 2ppb		cooler
410-073	1402 Cafeteria/Gym	12ppb		sink
410-074	0101 Mechanical	below 2ppb		utility sink

Saint Paul Public Schools
Water Sample Results
Central Senior
Building Number: 210

Sample Date: 6/5/16
Sampled by: Jake Baxter, Ted Sherman, & Chandala Nagendrappa

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
210-001	Room 4103	5		Sink
210-002	Hall Outside Room 4103	<2		Fountain
210-003	Hall Outside Room 4107	4		Fountain
210-004	IMC southwest Office 4211	11		Sink
210-005	IMC East Office Restroom 4210A	<2		Sink
210-006	Hall Outside Room 4407	No Sample		Fountain
210-007	Hall Outside Room 4404	<2		Fountain
210-008	Rm 3207 - Men's Restroom	<2		Sink
210-009	Room 3208 - Women's Restroom	<2		Sink
210-010	Rm 3205 - Kitchen Sink	<2		Sink
210-011	Hallway by Room 3101	7		Fountain
210-012	Room 3101	<2		Sink
210-013	Hall Across From 3104	2		Fountain
210-014	Hall Across From 3107	3		Fountain
210-015	Mechanical Room 3411 F [4167]	7		Hose Bib
210-016	Hall Outside Room 3407	12		Fountain
210-017	Hall Outside Room 3404	4		Fountain
210-018	Hall Outside Room 3401	5		Fountain
210-019	Classroom 3420	16		Sink
210-020	Chemical Storage Room 2309	6		Sink
210-021	Room 2307 Front Peninsula North	<2		Sink
210-022	Room 2307 Front Peninsula South	<2		Sink
210-023	Room 2306 Front Peninsula North	10		Sink
210-024	Room 2306 Front Peninsula North	<2		Sink
210-025	Room 2305	<2		Sink
210-026	Room 2311 Front Peninsula North	<2		Sink
210-027	Room 2311 Front Peninsula South	<2		Sink
210-028	Room 2312 Front Peninsula	<2		Sink
210-029	Room 2312 North Wall	15		Sink
210-030	Room 2312 Back Wall	11		Sink
210-031	Hall outside Rm 2312	No sample		Fountain
210-032	Room 2304 Front Peninsula	5		Sink
210-033	Room 2304 Peninsula on South Wall	12		Sink
210-034	Room 2403 Peninsula	<2		Sink
210-035	Room 2403 South Wall	<2		Sink
210-036	Room 2404 Front Peninsula	5		Sink
210-037	Room 2404 Front Peninsula - Lower Sink	<2		Sink
210-038	Room 2404 Back	<2		Sink
210-039	Outside Room 2404	21		Fountain
210-040	Room 2405 Front Peninsula	3		Sink
210-041	Room 2405 Front Peninsula - Lower Sink	<2		Sink
210-042	Room 2405 Back	6		Sink
210-043	Room 2406 Front Peninsula	<2		Sink
210-044	Room 2406 West Wall	<2		Sink
210-045	Room 2407	4		Sink
210-046	Room 2408 Southeast	<2		Sink
210-047	Room 2408 Southwest	5		Sink
210-048	Room 2408 Teacher's Station	<2		Sink
210-049	Room 2408 Teacher's Station - Lower Sink	<2		Sink
210-050	Hall Outside Auditorium - Left	<2		Fountain
210-051	Hall Outside Auditorium - Right	2		Fountain
210-052	Kitchen Restroom	<2		Sink
210-053	Kitchen Handsink West Wall	<2		Sink
210-054	Kitchen West Island Sink	<2		Large Sink
210-055	Kitchen South Wall Large Sink	<2		Large Sink
210-056	Kitchen Bunn Machine	<2		Bunn
210-057	Kitchen Hand Sink North Wall	3		Sink
210-058	Kitchen Large Sink East Wall	<2		Large Sink
210-059	Cafeteria	<2		Cooler
210-060	Outside Cafeteria - Left	4		Fountain
210-061	Outside Cafeteria - Right	<2		Fountain
210-062	Main Office Room 2001A	<2		Sink
210-063	Main Office Room 2027 Work Room	13		Sink
210-064	Main Office Women's Restroom Arch #3230	10		Sink
210-065	Main Office Hallway Arch #3225	2		Cooler
210-066	Main Office Men's Restroom Arch #3229	<2		Sink
210-067	Storage Room 2402	No sample		Sink
210-068	Room 2107	3		Sink
210-069	Bath By 2107 Arch #3093	7		Sink
210-070	Room 356 - Lab	5		Sink
210-071	Bath By Room 357	8		Sink
210-072	Outside Room 357	No sample		Fountain

210-073	Room 2114A	12		Sink
210-074	Room 2115	<2		Sink
210-075	Room 2116	<2		Sink
210-076	Room 2501	<2		Fountain
210-077	Room 2507	11		Sink
210-078	Room 2507	<2		Fountain
210-079	Auditorium Dressing Room South	9		Sink
210-080	Auditorium Dressing Room North	16		Sink
210-080.1	Restroom Stage	3		Sink
210-080.2	Wood Shop Room 1314	3		Sink
210-081	Room 1311	2		Sink
210-082	Room 1308 South Wall Left	4		Sink
210-083	Room 1308 South Wall second from left	<2		Sink
210-084	Room 1308 South Wall third from left	<2		Sink
210-085	Room 1308 South Wall Right	11		Sink
210-086	Hall Outside Room 1316	4		Fountain
210-087	Room 1317 - Left	No sample		Sink
210-088	Room 1317 - Right	4		Sink
210-089	Room 1303	7		Large Sink
210-090	Room 1304 North Wall L to R	5		Sink
210-091	1304 North Wall L to R	4		Sink
210-092	1304 North Wall L to R	6		Sink
210-093	1304 North Wall L to R	7		Sink
210-094	Room 1318	3		Sink
210-095	Room 1406	4		Sink
210-096	Room 1401	4		Sink
210-097	1407 'Arch #2167	<2		Sink
210-098	Room 1409	8		Sink
210-099	Room East Wall	No sample		Sink
210-100	Home Ec Room 1414 East Wall	6		Sink
210-101	Home Ec Room 1414 East Wall	5		Sink
210-102	Home Ec Room 1414 North Wall/East	3		Sink
210-103	Home Ec Room 1414 North Wall/West	3		Sink
210-104	Home Ec Room 1414 West Wall	No sample		Sink
210-105	Room 1415 East	No sample		Sink
210-106	Room 1415 West	<2		Utility Sink
210-107	Hallway By Room 1416	<2		Fountain
210-107.1	Womens Restroom Left	3		Sink
210-107.2	Womens Restroom Right	<2		Sink
210-107.3	Mens Restroom Left	<2		Sink
210-107.4	Mens Restroom Right	<2		Sink
210-108	Girls Handicap 1502	<2		Sink
210-109	Girls LR South 1502	3		Sink
210-109.1	Girls Locker Room North	4		Sink
210-110	Girl's Locker Room Coach's Restroom 1502	16		Sink
210-111	Girl's Locker Room 1502	<2		Fountain
210-112	Boy's's Locker Room Coach's Restroom 1503	8		Sink
210-113	Boy's Locker Room 1503	No sample		Fountain
210-113.1	Boy's Locker Room Hand	<2		Sink
210-113.2	Boy's Locker Room North	5		Sink
210-113.3	Boy's Locker Room South	12		Sink
210-114	Aux Gym 1505 North	<2		Fountain
210-115	Aux Gym 1505 South	8		Fountain
210-116	Room 1507 South restroom	15		Sink
210-117	Room 1508 North Restroom	5		Sink
210-118	Room 1511	<2		Utility Sink
210-119	Rm 1510 - Lockers	<2		Fountain
210-120	Rm 1510 - Lockers	<2		Sink
210-120.1	Womens Restroom 1510 Left	<2		Sink
210-120.2	Womens Restroom 1510 Middle Left	<2		Sink
210-120.3	Womens Restroom 1510 Right Middle	<2		Sink
210-120.4	Womens Restroom 1510 Right	<2		Sink
210-121	Rm 1509 - Lockers	<2		Fountain
210-121.1	Room 1509 Left Sink	<2		Sink
210-121.2	Room 1509 Left MiddleSink	<2		Sink
210-121.3	Room 1509 Middle Sink	<2		Sink
210-121.4	Room 1509 Right Middle Sink	<2		Sink
210-121.5	Room 1509 Right Sink	<2		Sink
210-122	Room 1509A	5		Utility Sink
210-123	Room 1117 Weight Room	<2		Fountain
210-124	Room 1116 West	7		Sink
210-125	Room 1116 East	8		Sink
210-126	Room 1115 West	8		Sink
210-127	Room 1115 East	5		Sink
210-128	Room 1114 Dance Studio	12		Fountain
210-129	Hall Outside Room 1215	5		Fountain
210-130	Room 1106	3		Sink
210-131	Room 1202 Teacher's Station - Left	<2		Sink
210-132	Room 1202 Teacher's Station - Right	No sample		Sink
210-133	Room 1202 by Eye Wash	<2		Sink
210-134	Room 1203 Teacher's Station - Left	<2		Sink
210-135	Room 1203 Teacher's Station - Right	<2		Sink
210-136	Room 1203 by Eye Wash	<2		Sink
210-137	Daycare Restroom North Upper Sink	No sample		Sink
210-138	Daycare Restroom North Lower Sink	No sample		Sink
210-139	By Boy's Rm - Right by elevator on 2nd floor	<2		Fountain
210-140	By Girls Rm - Left by elevator on 2nd floor	<2		Fountain

210-141	Hallway by Room 0202	<2		Fountain
210-142	Lower Level Room 0401 - Left	5		Sink
210-143	Lower Level Room 0401 - Right	13		Sink
210-143.1	Womens Restroom	5		Sink
210-143.2	Mens Restroom	6		Sink
210-144	Lower Level Room 0404A - Dark Room	No sample		Sink
210-145	Hallway Outside Rm 0404	2		Fountain
210-146	Room 112	3		Utility Sink
210-147	Lower Level Boiler Room SS	22	6	Utility Sink
210-148	Hallway Across From Room 0406A	23	5	Fountain
210-149	Boiler Room Utility Sink - let run 10 minutes	9		Utility Sink

Saint Paul Public Schools
Water Sample Results
Creative Arts
Building Number: 070

Sample Date: 6/5/16
Sampled by: Jake Baxter, Ted Sherman, & Chandala Nagendrappa

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
070-001	Room 8106	<2		Sink
070-002	Room 8107	7		Sink
070-003	Room 8109	7		Sink
070-004	Left Bathroom sink -Left	<2		Sink
070-005	Left Bathroom Sink - Right	<2		Sink
070-006	Fountain between Bathrooms - Left	<2		Drinking Fountain
070-006.1	Fountain between Bathrooms - Right	<2		Drinking Fountain
070-007	Right Bathroom Sink - Left	<2		Sink
070-008	Right Bathroom Sink - Right	<2		Sink
070-009	Room 8110	<2		Sink
070-010	Room 8112	<2		Sink
070-010.1	Room 8112	<2		Sink
070-011	Room 7106	10		Sink
070-012	Room 7107	<2		Sink
070-013	Room 7109	4		Sink
070-014	Left Bathroon Sink - Left	<2		Sink
070-015	Left Bathroon Sink - Right	<2		Sink
070-016	Left Fountain Between Bathrooms	<2		Drinking Fountain
070-016.1	Right Fountain Between Bathrooms	<2		Drinking Fountain
070-017	Right Bathroom Sink - Left	<2		Sink
070-018	Right Bathroom Sink - Right	<2		Sink
070-019	Room 7110	<2		Sink
070-020	Room 7112	<2		Sink
070-020.1	Room 7112	<2		Sink
070-021	Room 6106	<2		Sink
070-022	Room 6107	<2		Sink
070-023	Room 6109	<2		Sink
070-024	Left Bathroom sink - Left	<2		Sink
070-025	Left Bathroom sink - Right	2		Sink
070-026	Left Fountain Between Bathrooms	<2		Drinking Fountain
070-026.1	Right Fountain Between Bathrooms	<2		Drinking Fountain
070-027	Right Bathroom Sink - Left	2		Sink
070-028	Right Bathroom Sink - Right	<2		Sink
070-029	Room 6110	<2		Sink
070-030	Room 6112	<2		Sink
070-030.1	Gender Restroom	<2		Sink
070-031	Boys Bathroom Left	<2		Sink
070-032	Boys Bathroom Right	<2		Sink
070-033	Left Fountain	<2		Sink
070-034	Right Fountain	<2		Sink
070-035	Girls Bathroom Left	<2		Sink
070-036	Girls Bathroom Right	<2		Sink
070-037	Room 4105	NW		Sink
070-038	Room 4106	<2		Sink
070-039	Room 4107	<2		Sink
070-040	Room 4108	<2		Sink
070-041	Cooler Left by 4108	4		Sink
070-042	Cooler Right by 4108	6		Sink
070-043	Boys Bathroom Left Sink	3		Sink
070-044	Boys Bathroom Right Sink	<2		Sink
070-045	Girls Bathroom	3		Sink
070-046	Gender Restroom	<2		Sink
070-047	Café Boys Bathroom Left	7		Sink
070-048	Café Boys Bathroom Right	<2		Sink
070-049	Café Hydration Station Cooler - Left	<2		Hydration Station
070-050	Café Hydration Station Cooler - Right	<2		Hydration Station
070-051	Café Girls Bathroom Left	<2		Sink
070-052	Café Girls Bathroom Middle	<2		Sink
070-053	Café Girls Bathroom Right	<2		Sink
070-054	Kitchen Hand Sink	<2		Sink
070-055	Large Sink Kitchen	<2		Sink
070-056	Kitchen Bunn Machine	<2		Sink
070-057	Kitchen Island Sink	<2		Sink
070-058	Kitchen Handsink East	<2		Sink
070-059	Kitchen Bathroon sink	<2		Sink
070-060	Dishroom Hand Sink	<2		Sink

070-061	Dishroom Large Sink Left	<2		Sink
070-062	Dishroom Large Sink Right	<2		Sink
070-063	Boys Bathroom Left Sink	<2		Sink
070-064	Boys Bathroom Right Sink	<2		Sink
070-065	Girls Bathroom Left Sink	<2		Sink
070-066	Girls Bathroom Middle Sink	<2		Sink
070-067	Girls Bathroom Right Sink	<2		Sink
070-068	Left Cooler By stairs	<2		Drinking Fountain
070-069	Right Cooler By stairs	<2		Drinking Fountain
070-070	Dance Studio Cooler Left	<2		Drinking Fountain
070-071	Dance Studio Hydration Station Right	<2		Hydration Station
070-072	Gender Restroom	<2		Sink
070-073	Room 1208 Left	12		Sink
070-074	Room 1208 Right	32	9	Sink
070-075	Room 1202 West (Right Wall)	3		Sink
070-076	Room 1202 North	<2		Sink
070-077	Gender Restroom 1203D	15		Sink
070-078	1205A Left Sink	12		Sink
070-079	1205A Bubbler Right	12		Sink
070-080	Room 1203 - Utility Sink	No Sample		Sink
070-081	Room 1203 - Sink	No Sample		Sink
070-082	Girls Bathroom by 1207	14		Sink
070-083	Room 1207 - Sink	10		Sink
070-084	Room 1102B, Bathroom Sink	6		Sink
070-085	Room 1102 B Hand Sink	20		Sink
070-086	Lobby Girls Bathroom - Far Left	8		Sink
070-087	Lobby Girls Bathroom - Mid Left	11		Sink
070-088	Lobby Girls Bathroom - Mid Right	<2		Sink
070-089	Lobby Girls Bathroom - Far Right	11		Sink
070-090	Lobby Chiller Left	8		Drinking Fountain
070-091	Lobby Chiller Right	4		Drinking Fountain
070-092	Boys Lobby Bathroom - Left	6		Sink
070-093	Boys Lobby Bathroom - Left Middle	<2		Sink
070-094	Boys Lobby Bathroom - Right Middle	7		Sink
070-095	Boys Lobby Bathroom - Right	<2		Sink
070-096	Womens Restroom Left	7		Sink
070-097	Womens Restroom right	5		Sink
070-098	Chiller Left, Between restrooms	12		Drinking Fountain
070-099	Chiller Right, Between restrooms	8		Drinking Fountain
070-100	Mens Restroom Left	14		Sink
070-101	Mens Restroom Right	7		Sink
070-102	Room 0208	6		Sink
070-103	Room 0118	9		Sink
070-104	Room 0119	<2		Sink
070-105	Hallway Hand Sink - Left	6		Sink
070-106	Hallway Hand Sink - Right	13		Sink
070-107	Room 0116	<2		Sink
070-108	Room 0114	11		Sink
070-109	Room 0113	<2		Sink
070-110	Room 0112	<2		Sink
070-111	Room 0107	<2		Sink
070-112	Chiller Hallway - Left	4		Drinking Fountain
070-113	Chiller Hallway - Right	3		Drinking Fountain
070-114	Girls Restroom	<2		Sink
070-115	Kitchen Hand Sink	<2		Sink
070-116	Kitchen Large Sink	<2		Sink

Saint Paul Public Schools
Water Sample Results
Expo Harriet Bishop
Building Number: 435

Sample Date: June 5, 2016
Sampled by: Natalie Eskew, Kobe Patch, and Stephanie Pinkalla

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
435-001	Kitchen - North	<2ppb		Hand Sink
435-002	Kitchen - West Wall North	<2ppb		Sink
435-003	Kitchen West Wall South	<2ppb		Sink
435-004	Kitchen - Dishroom	<2ppb		Hand Sink
435-005	Hallway by Room 0117 - Left	<2ppb		Water Cooler
435-006	Hallway by Room 0117 - Right	<2ppb		Water Cooler
435-007	Hallway by Room 0117 - Bottle Filler	<2ppb		Bottle Filler
435-008	Boys Restroom by Kitchen - Left	<2ppb		Sink
435-009	Boys Restroom by Kitchen - Center	<2ppb		Sink
435-010	Boys Restroom by Kitchen - Right	<2ppb		Sink
435-011	Girls Restroom by Kitchen - Left	<2ppb		Sink
435-012	Girls Restroom by Kitchen - Center	<2ppb		Sink
435-013	Girls Restroom by Kitchen - Right	<2ppb		Sink
435-014	Maintenance Room 0117	<2ppb		Utility Sink
435-015	Mechanical Room 0116 Boiler Room	<2ppb		Utility Sink
435-016	Mechanical Room 0114	<2ppb		Utility Sink
435-017	Hallway by Room 0108	<2ppb		Drinking Fountain
435-018	Staff Restroom by Room 0207A Left	<2 ppb		Sink
435-019	Staff Restroom by Room 0207A Right	<2 ppb		Sink
435-020	Room 0107	3ppb		Sink
435-021	Room 0107 Restroom	<2ppb		Sink

435-022	Room 0106	4ppb		Sink
435-023	Room 0105	<2ppb		Sink
435-024	Room 0105 Restroom	<2ppb		Sink
435-025	Room 0104	<2ppb		Sink
435-026	Room 0102	<2ppb		Sink
435-027	Room 0121 Left	<2ppb		Sink
435-028	Room 0121 Center	<2ppb		Sink
435-029	Room 0121 Right	<2ppb		Sink
435-030	Gymnasium	<2ppb		Drinking Fountain
435-031	Room 112A	<2ppb		Sink
435-032	Girls Restroom by Room 1109 Left	22ppb		Sink
435-032R	Girls Restroom by Room 1109 Left REATEST		5ppb	Sink
435-033	Girls Restroom by Room 1109 Left Center	8ppb		Sink
435-034	Girls Restroom by Room 1109 Center	<2ppb		Sink
435-035	Girls Restroom by Room 1109 Right Center	<2ppb		Sink
435-036	Girls Restroom by Room 1109 Right	<2ppb		Sink
435-037	Hallway by Room 1203	<2ppb		Drinking Fountain
435-038	Room 1104 Restroom Left	<2ppb		Sink
435-039	Room 1104 Restroom Right	<2ppb		Sink
435-040	Room 1103 Restroom Left	4ppb		Sink
435-041	Room 1103 Restroom Right	<2ppb		Sink
435-042	Staff Men Restroom by Room 1103	<2ppb		Sink
435-043	Nurse Room 1101 Restroom	92ppb		Sink
435-043R	Nurse Room 1101 Restroom RETEST		<2ppb	Sink
435-044	Boys Restroom by Room 1102 Left	<2ppb		Sink
435-045	Boys Restroom by Room 1102 Left Center	<2ppb		Sink
435-046	Boys Restroom by Room 1102 Right Center	<2ppb		Sink
435-047	Boys Restroom by Room 1102 Right	<2ppb		Sink
435-048	Room 1005	<2ppb		Sink
435-049	Staff Women Restroom Left	<2ppb		Sink
435-050	Staff Women Restroom Right	<2ppb		Sink
435-051	Hallway by Main Office 1001 Left	<2ppb		Drinking Fountain
435-052	Hallway by Main Office 1001 Right	<2ppb		Drinking Fountain
435-053	Maintenance Room 1205B	<2ppb		Utility Sink
435-054	Media Center Office Room 2113	<2ppb		Sink
435-055	Girls Restroom by Room 2110 Left	<2ppb		Sink
435-056	Girls Restroom by Room 2110 Left Center	<2ppb		Sink
435-057	Girls Restroom by Room 2110 Center	<2ppb		Sink
435-058	Girls Restroom by Room 2110 Right Center	<2ppb		Sink
435-059	Girls Restroom by Room 2110 Right	<2ppb		Sink
435-060	Hallway by Room 2110	<2ppb		Drinking Fountain
435-061	Boys Restroom by Room 2103 Left	<2ppb		Sink
435-062	Boys Restroom by Room 2103 Left Center	<2ppb		Sink
435-063	Boys Restroom by Room 2103 Center	<2ppb		Sink
435-064	Boys Restroom by Room 2103 Right Center	<2ppb		Sink
435-065	Boys Restroom by Room 2103 Right	4ppb		Sink
435-066	Room 2102	4ppb		Sink
435-067	Hallway by Room 2209	<2ppb		Drinking Fountain
435-068	Room 2206 Staff Lounge	<2ppb		Sink
435-069	Room 2117B	3ppb		Sink
435-070	Room 2117C	<2ppb		Sink
435-071	Room 2117D	<2ppb		Sink
435-072	Room 2117A	3ppb		Sink
435-073	Room 2116 Southeast	<2ppb		Sink
435-074	Room 2116 Southwest	<2ppb		Sink
435-075	Maintenance Room 2205	<2ppb		Utility Sink

**Saint Paul Public Schools
Water Sample Results
Highland Park Elementary
Building Number: 491**

**Sample Date: June 5, 2016
Sampled by:
Nancy Fischer
Alissa Houghtaling**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
491-001	0407 Mechanical	below 2ppb		sink
491-002	0405 Restroom	below 2ppb		sink
491-003	0405 Restroom	8ppb		slop/shower
491-004	0404 Kitchen Storage	8ppb		Bunn
491-005	0403 Kitchen	below 2ppb		large sink
491-006	1202 Maintenance			slop
491-007	1204 Kindergarten	below 2ppb		sink
491-008	1204B Kindergarten Restroom	below 2ppb		sink
491-009	1204 Kindergarten	below 2ppb		cooler
491-010	1205 Kindergarten	below 2ppb		sink
491-011	1205 Kindergarten	below 2ppb		cooler
491-012	1205B Kindergarten Restroom	below 2ppb		sink
491-013	1200A Corridor- left	below 2ppb		cooler
491-014	1200A Corridor- right	below 2ppb		cooler
491-015	1207 Kitchen	below 2ppb		sink
491-016	1211 Girl's Restroom- left	below 2ppb		bradley
491-017	1211 Girl's Restroom- middle	below 2ppb		bradley
491-018	1211 Girl's Restroom- right	below 2ppb		bradley
491-019	1212A Maintenance	below 2ppb		slop
491-020	1212 Boy's Restroom- left	below 2ppb		bradley
491-021	1212 Boy's Restroom- right	3ppb		bradley

491-022	1213	below 2ppb		sink
491-023	1200B Corridor across from 1220	below 2ppb		cooler
491-024	1219	below 2ppb		sink
491-025	1214	below 2ppb		sink
491-026	1200B Corridor by 1214	below 2ppb		cooler
491-027	1218	below 2ppb		sink
491-028	1215	3ppb		sink
491-029	1200B Corridor by 1215	below 2ppb		cooler
491-030	1216	below 2ppb		sink
491-031	1217	below 2ppb		sink
491-032	1301 Restroom	9ppb		sink
491-033	Corridor outside 1301 Restroom	below 2ppb		cooler
491-034	1302 Maintenance			slop
491-035	1304 Media Center Office	below 2ppb		sink
491-036	2105	below 2ppb		sink
491-037	2106	below 2ppb		sink
491-038	1006 Corridor by 2106	below 2ppb		cooler
491-039	2104	below 2ppb		sink
491-040	2107	below 2ppb		sink
491-041	1006 Corridor by 2107	below 2ppb		cooler
491-042	2103	below 2ppb		sink
491-043	2108	below 2ppb		sink
491-044	2109 Boy's Restroom	below 2ppb		sink
491-045	2109 Boy's Restroom- left	below 2ppb		bradley
491-046	2109 Boy's Restroom- middle	below 2ppb		bradley
491-047	2109 Boy's Restroom- right	below 2ppb		bradley
491-048	2110 Maintenance			slop
491-049	1006 Corridor by 2110	below 2ppb		cooler
491-050	2102 Staff Restroom	26ppb	below 2ppb	sink
491-051	2101 Staff Lounge	below 2ppb		sink
491-052	2003 Nurse/Health	below 2ppb		sink
491-053	2003A Nurse Restroom	below 2ppb		sink
491-054	2002A Principal Office Restroom	4 ppb		sink
491-055		2005 below 2ppb		sink
491-056	2112 Restroom	below 2ppb		sink
491-057	2112 Restroom- left	3ppb		bradley
491-058	2112 Restroom- middle	below 2ppb		bradley
491-059	2112 Restroom- right	below 2ppb		bradley

Saint Paul Public Schools
Water Sample Results
Horace Mann
Building Number: 518

Sample Date: June 5, 2016
Sampled by: Natalie Eskew, Kobe Patch, and Stephanie Pinkalla

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
518-001	Boys Restroom by Room 1203 Left	<2ppb		Sink
518-002	Boys Restroom by Room 1203 Right	<2ppb		Sink
518-003	Girls Restroom by Room 1209	<2ppb		Sink
518-004	Hallway by Room 1203	<2ppb		Water Cooler
518-005	Room 1202	<2ppb		Sink
518-006	Room 1203 Restroom	<2ppb		Sink
518-007	Room 1205	<2ppb		Drinking Fountain
518-008	Room 1205	<2ppb		Sink
518-009	Room 1204	<2ppb		Sink
518-010	Room 1204 Restroom	<2ppb		Sink
518-011	Room 1204	<2ppb		Drinking Fountain
518-012	Maintenance Room 1201A	<2ppb		Utility Sink
518-013	Boys Restroom by Room 2103 Left	<2ppb		Sink
518-014	Boys Restroom by Room 2103 Right	<2ppb		Sink
10	Hallway by Room 2103	<2ppb		Drinking Fountain
518-016	Room 2103	<2ppb		Sink
518-017	Room 2104	<2ppb		Sink
518-018	Room 2105	<2ppb		Sink
518-019	Maintenance Room 2106 Upper	<2ppb		Utility Sink
518-020	Maintenance Room 2106 Lower	<2ppb		Utility Sink
518-021	Girls Restroom by Room 2106 Left	<2ppb		Drinking Fountain
518-022	Girls Restroom by Room 2106 Right	<2ppb		Sink
518-023	Mainenance Room 2201A	<2ppb		Utility Sink
518-024	Room 2203 Restroom	<2ppb		Sink
518-025	Girls Restroom by Room 2203 Left	<2ppb		Sink
518-026	Girls Restroom by Room 2203 Right	<2ppb		Sink
518-027	Hallway by Room 2203	<2ppb		Water Cooler
518-028	Boys Restroom by Room 2211 Left	<2ppb		Sink
518-029	Boys Restroom by Room 2211 Right	<2ppb		Sink
518-030	Room 2207 Left	<2ppb		Sink
518-031	Room 2207 Center	<2ppb		Sink
518-032	Room 2207 Right	<2ppb		Sink
518-033	Room 0210	<2ppb		Sink
518-034	Hallway by Room 0210	<2ppb		Water Cooler
518-035	Mechanical Room 0208 Boiler Room	<2ppb		Hand Sink
518-036	Mechanical Room 0208 Boiler Room	<2ppb		Utility Sink
518-037	Restroom by Room 0206	<2ppb		Sink
518-038	Nurse Restroom 1004	<2ppb		Sink
518-039	Nurse Room 1005	<2ppb		Sink

518-040	Hallway by Room 1101	<2ppb		Drinking Fountain
518-041	Room 1101	<2ppb		Sink
518-042	Room 1102	<2ppb		Sink
518-043	Boys Restroom by Room 1102 Left	<2ppb		Sink
518-044	Boys Restroom by Room 1102 Right	<2ppb		Sink
518-045	Girls Restroom by Room 1102 Left	<2ppb		Sink
518-046	Girls Restroom by Room 1102 Right	<2ppb		Sink
518-047	Room 1103	<2ppb		Sink
518-048	Maintenance Room 1302	<2ppb		Utility Sink
518-049	Restroom by Room 1303	<2ppb		Sink
518-050	Room 1305	<2ppb		Sink
518-051	Hallway by Room 1307	<2ppb		Drinking Fountain
518-052	Room 1401 Lounge	<2ppb		Sink
518-053	Gymnasium 1404	<2ppb		Drinking Fountain
518-054	Kitchen 1408	4ppb		Hand Sink
518-055	Kitchen 1408	<2ppb		Sink
518-056	Kitchen 1408B Restroom	<2ppb		Sink
518-057	Maintenance 1405A	<2ppb		Utility Sink
518-058	Kitchen Bunn	<2ppb		Bunn Machine

Saint Paul Public Schools
Water Sample Results
Journeys
Building Number: 050

Sample Date: June 5th, 2016
Sampled By: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
050-001	Dishroom handsink - SNK	<2		Sink
050-002	Dishroom sprayer - SPR	<2		Sprayer
050-003	Kitchen 1117 Hand Sink - SNK	<2		Sink
050-004	Kitchen Sprayer - SPR	6		Sprayer
050-005	Kitchen Sink Left - SNK	<2		Sink
050-006	Room 1115 - SNK	<2		Sink
050-007	Room 1118 - SNK	<2		Sink
050-008	Room 1116 Restroom - SNK	<2		Sink
050-009	First Floor Hallway - WC	100+		Water Cooler
050-009	First Floor Hallway - WC (flush)		<2	Water Cooler
050-010	First Floor Boy's Bathroom (left) - SNK	<2		Sink
050-011	First Floor Boy's Bathroom (middle) - SNK	<2		Sink
050-012	First Floor Boy's Bathroom (right) - SNK	<2		Sink
050-013	Room 1114 Nurse's Restroom - SNK	94		Sink
050-014	Room 1114 Nurse's Office - SNK	<2		Sink
050-14.5	Room 1114 Nurse's Restroom - SNK (flush)		<2	Sink
050-015	First Floor Girl's Restroom (left) - SNK	<2		Sink
050-016	First Floor Girl's Restroom (middle) - SNK	<2		Sink
050-017	First Floor Girl's Restroom (right) - SNK	<2		Sink
050-018	Room 1110 - SNK	53		Sink
050-019	Room 1108 - SNK	<2		Slop Sink
050-018.5	Room 1110 - SNK (flush)		<2	Sink
050-020	Room 1104A Staff Lounge Kitchen - SNK	14		Sink
050-021	Room 1104A Staff Lounge Restroom - SNK	<2		Sink
050-022	Staff Restroom next to 1107 - SNK	3		Sink
050-023	Hallway Next to Room 1107 - WC	<2		Water Cooler
050-024	Hallway outside 2101 - WC	<2		Water Cooler
050-025	Room 2101 North - SNK	<2		Sink
050-026	Room 2101 East - SNK	<2		Sink
050-027	Room 2101 South - SNK	<2		Sink
050-028	Restroom Outside 2101 - SNK	52		Sink
050-029	Room 2102 - SNK	<2		Sink
050-028.5	Restroom Outside 2101 - SNK (flush)		15	Sink
050-030	Room 2105 - SNK	<2		Sink
050-031	Room 2104 - SNK	<2		Sink
050-032	Room 2107 - SNK	<2		Sink
050-033	2nd Floor Girl's Restroom (left) - SNK	<2		Sink
050-034	2nd Floor Girl's Restroom (left middle) - SNK	<2		Sink
050-035	2nd Floor Girl's Restroom (right middle) - SNK	<2		Sink
050-036	2nd Floor Girl's Restroom (right) - SNK	<2		Sink
050-037	Basement Custodial Office - SNK	<2		Sink
050-038	Room 2110 Custodial - SNK	<2		Slop Sink
050-039	2nd Floor Boy's Restroom (left) - SNK	<2		Sink
050-040	2nd Floor Boy's Restroom (middle) - SNK	<2		Sink
050-041	2nd Floor Boy's Restroom (right) - SNK	<2		Sink
050-042	Hallway Outside 2110 - WC	<2		Water Cooler
050-043	Room 2115 - SNK	<2		Sink
050-044	Room 2114 - SNK	<2		Sink
050-045	Room 3101 - SNK	<2		Sink
050-046	Restroom next to 3101 - SNK	<2		Sink
050-047	Hallway outside 3101 - WC	<2		Water Cooler
050-048	3rd floor Girl's bathroom (left) - SNK	<2		Sink
050-049	3rd Floor Girl's Bathroom (left middle) - SNK	<2		Sink

050-050	3rd Floor Girl's Bathroom (right middle) - SNK	100+		Sink
050-051	3rd Floor Girl's Bathroom (right) - SNK	<2		Sink
050-050.5	3rd Floor Girl's Bathroom (right middle) - SNK (flush)		<2	Sink
050-052	3rd Floor Boy's Bathroom (left) - SNK	<2		Sink
050-053	3rd Floor Boy's Bathroom (middle) - SNK	<2		Sink
050-054	3rd Floor Boy's Bathroom (right) - SNK	<2		Sink
050-055	Mechanical Room 3110 - SNK	<2		Slop Sink
050-056	Hallway outside 3110 - WC	<2		Water Cooler
050-057	Room 303 Gym Closet - SNK	<2		Sink
050-058	Kitchen Bunn - BUNN	<2		Bunn

Saint Paul Public Schools
Water Sample Results
Linwood Upper
Building Number: 528

Sample Date: 6/5/2016
Sampled By: Parker Prose & Kegan Silonis

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
528-001	cafeteria: middle WC	<2		WC
528-002	Cafeteria: East WC	<2		WC
528-003	Cafeteria East WBF	<2		WBF
528-004	West Sprayer - Kitchen	<2		Sprayer
528-005	North main Kitchen Sink - KSNK	5		KSNK
528-006	108 DF	<2		DF
528-007	1203 SNK	<2		SNK
528-008	1203 bathroom snk	<2		Snk
528-009	1207 snk	<2		Snk
528-010	108 df	8		DF
528-011	1204 Snk	<2		SNK
528-012	1216 hallway abthroom Right	<2		SNK
528-013	1216 hallway bathroom left	<2		Snk
528-014	1216 hallway WC	<2		WC
528-015	1216 hallway bathroom middle	2		Snk
528-016	1216 office Sink	20		Snk
528-017	1207 Restroom Sink	5		Snk
528-018	1217 custodial Sink	20		Snk
528-019	1208 Sink	<2		Snk
528-020	1213 Men's Sink	<2		Snk
528-021	1216 Restroom Sink	<2		Snk
528-022	1213 Women's Sink	60	<2	Snk
528-023	1209 Hallway DF	<2		DF
528-024	1217 Custodial Utility Sink	8		Snk
528-025	1109 Hallway WC	<2		WC
528-026	Kitchen - Bunn	4		Bunn
528-027	1102 boy's bathroom Left	3		Snk
528-028	1102 boys bathroom middle	12		Snk
528-029	1102 boys bathroom right	<2		Snk
528-030	1009 Sink	<2		Snk
528-031	1503 hallway WC	6		Wc
528-032	1009 Sink	<2		Snk
528-033	1503 boys sink	<2		Snk
528-034	1503 girls Sink	<2		Snk
528-035	1508 West Sink	<2		Snk
528-036	1504 East Right Sink	<2		Snk
528-037	1504 East Left Sink	<2		Snk
528-038	1507 Sink	<2		Snk
528-039	1507 restroom Wink	<2		Snk
528-040	East Nurse Sink	<2		Snk
528-041	West Nurse Sink	<2		Snk
528-042	Nurse Restroom Sink	16		Snk
528-043	1402 Girls Bathroom Left	<2		Snk
528-044	1402 Girls bathroom Middle	6		Snk
528-045	1402 Girls Bathroom Right	<2		Snk
528-046	1100-1400 hallway WC	<2		WC
528-047	1408 hallway WC	3		WC
528-048	3400 hallway wc	<2		WC
528-049	3406 West Sink	<2		Snk
528-050	3406 east Sink	<2		Snk
528-051	3405 Laundry Sink	9		Snk
528-052	3403 Sink	<2		Snk
528-053	3301 Girls Left	<2		Snk
528-054	3301 Girls middle	13		Snk
528-055	3301 girls right	5		Snk
528-056	3303 hallway WC	<2		WC
528-057	3102 boys left	<2		Snk
528-058	3102 boys middle	<2		Snk
528-059	3102 boys right	<2		Snk
528-060	3103 utility sink	<2		Snk
528-061	3109 hallway wink	<2		Snk
528-062	2405 hallway WC	8		WC
528-063	2405 hallway restroom	4		Snk
528-064	2403 girls left	11		Snk
528-065	2403 girls middle	<2		Snk
528-066	2403 girls right	<2		Snk

528-067	2304 sink	<2		Snk
528-068	2306 hallway WC	15		WC
528-069	2102 boys left	<2		Snk
528-070	2102 boys middle	<2		Snk
528-071	2102 boys right	<2		Snk
528-072	2103 utility sink	10		Snk
528-073	lower level girls left	<2		Snk
528-074	lower level girls right	11		Snk
528-075	lower level mens left	<2		Snk
528-076	lower level mens right	<2		Snk

Saint Paul Public Schools
Water Sample Results
Randolph Heights
Building Number: 545

Sample Date: June 6th, 2016
Sampled By: Parker Prose & Kegan Silonis

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
545-001	Bunn	<2		Bunn
545-002	Kitchen - Sprayer	<2		Sprayer
545-003	Kitchen - Sink	<2		Snk
545-004	Kitchen - Kitchen Sink	6		KSnk
545-005	2312 sink	5		Snk
545-006	2220 hall boy's bathroom left	5		Snk
545-007	2220 hallway boy's bathroom middle	<2		Snk
545-008	2220 hallway boy's bathroom right	12		Snk
545-009	2313 sink	25	8	Snk
545-010	2004B hallway DF left	<2		DF
545-011	2004b hallway DF Right	17		DF
545-012	2004 bathroom sink	<2		Snk
545-013	2002 sink	<2		Snk
545-014	2220 girls bathroom left	<2		Snk
545-015	2220 girls bathroom middle	<2		Snk
545-016	2220 girls bathroom right	<2		Snk
545-017	2100 hallway north WC	<2		WC
545-018	2310 Hallway DF	<2		DF
545-019	2100 hallway south DF	<2		DF
545-020	2100 hallway restroom	<2		Snk
545-021	2005 sink	<2		Snk
545-022	2004 sink	<2		Snk
545-023	2006 sink	8		Snk
545-024	2002 sink	7		Snk
545-025	2405 left	<2		Snk
545-026	2405 middle	<2		Snk
545-027	2405 right	<2		Snk
545-028	2407 boys restroom hallway	<2		Snk
545-029	2407 hallway WC	<2		WC
545-030	2409 hallway girls restroom	<2		Snk
545-031	1400 hallway girls bathroom	<2		Snk
545-032	1400 hallways boys bathroom	<2		Snk
545-033	1203 gym entrance sink	<2		Snk
545-034	1203 gym entrance WC	<2		WC
545-035	gym WC	<2		WC
545-036	1409 hallway WC left	<2		WC
545-037	1409 hallway WC Right	17		WC
545-038	2410 staff sink	<2		Snk
545-039	utility sink in maintence near 2410	<2		Snk
545-040	cust office slop sink left	<2		Snk
545-041	cust office slop sink right	<2		Snk

Saint Paul Public Schools
Water Sample Results
Rivereast Homcroft
Building Number: 497

Sample Date: June 5, 2016
Sampled by: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
497-001	Room A141 Workroom - SNK	<2		Sink
497-002	Next to Door 13 - DF	<2		Drinking Fountain
497-003	Girl's Bathroom Across from A141 (left) - SNK	<2		Sink
497-004	Girl's Bathroom Across from A141 (right) - SNK	<2		Sink
497-005	Boy's Bathroom Across from A141 (left) - SNK	<2		Sink
497-006	Boy's Bathroom Across from A141 (right) - SNK	<2		Sink
497-007	1104 Maintenance - SNK	<2		Slop Sink
497-008	A142 Main Office - SNK	<2		Sink
497-009	A142 Main Office Restroom - SNK	<2		Sink
497-010	Room 1108 - SNK	<2		Sink
497-011	Room 1109 - SNK	<2		Sink
497-012	Hallway Outside 1110 - WC	<2		Water Cooler
497-013	Room 1110 - SNK	<2		Sink

497-014	Room 1111 - SNK	<2		Sink
497-015	Hallway Outside 1112 - DF	<2		Drinking Fountain
497-016	Room 1112 - SNK	<2		Sink
497-017	Room 1113 - SNK	<2		Sink
497-018	Room 1114 - SNK	<2		Sink
497-019	Outside Room 1114 - DF	5		Drinking Fountain
497-020	Room 1206 - SNK	33		Sink
497-020.5	Room 1206 - SNK (flush)		<2	Sink
497-021	Kitchen 1401 - SNK	13		Sink
497-022	Rec Center - WC	25		Water Cooler
497-022.5	Rec Center - WC (flush)		10	Water Cooler
497-023	Across from Nurse Women's Restroom (left) - SNK	10		Sink
497-024	Across from Nurse Women's Restroom (right) - SNK	76		Sink
497-025	Across from Nurse Men's Restroom (left) - SNK	37		Sink
497-026	Across from Nurse Men's Restroom (right) - SNK	29		Sink
497-024.5	Across from Nurse Women's Restroom (right) - SNK (flush)		<2	Sink
497-025.5	Across from Nurse Men's Restroom (left) - SNK (flush)		<2	Sink
497-026.5	Across from Nurse Men's Restroom (right) - SNK (flush)		<2	Sink
497-027	Room 1308 Custodial - SNK	<2		Slop Sink
497-028	Room 1312A Restroom - SNK	<2		Sink
497-029	Custodial Office Restroom - SNK	<2		Sink
497-030	Outside Custodial Office (left) - WC	<2		Water Cooler
497-031	Outside Custodial Office (right) - WC	<2		Water Cooler
497-032	2300 Cooridor (left) - WC	<2		Water Cooler
497-033	2300 Cooridor (right) - WC	<2		Water Cooler
497-034	2300 Boy's Bathroom (left) - SNK	<2		Sink
497-035	2300 Boy's Bathroom (right) - SNK	3		Sink
497-036	Room 2307 - SNK	<2		Sink
497-037	2300 Cooridor Unisex bathroom - SNK	<2		Sink
497-038	2300 Cooridor Custodial - SNK	24		Slop Sink
497-038.5	2300 Cooridor Custodial - SNK (flush)		<2	Sink
497-039	2300 Cooridor near girl's restroom - DF	<2		Drinking Fountain
497-040	2300 Cooridor Girl's Restroom (left) - SNK	<2		Sink
497-041	2300 Cooridor Girl's Restroom (middle) - SNK	6		Sink
497-042	2300 Cooridor Girl's Restroom (right) - SNK	<2		Sink
497-043	3300 Cooridor near Elevator (left) - WC	<2		Water Cooler
497-044	3300 Cooridor near Elevator (right) - WC	<2		Water Cooler
497-045	3300 Cooridor Boy's Bathroom (left) - SNK	<2		Sink
497-046	3300 Cooridor Boy's Bathroom (right) - SNK	<2		Sink
497-047	3300 Cooridor Unisex Bathroom - SNK	<2		Sink
497-048	3300 Cooridor Maintenance - SNK	10		Slop Sink
497-049	3300 Cooridor near Girl's Bathroom - DF	<2		Drinking Fountain
497-050	3300 Cooridor Girl's Restroom (left) - SNK	28		Sink
497-051	3300 Cooridor Girl's Restroom (middle) - SNK	3		Sink
497-052	3300 Cooridor Girl's Restroom (right) - SNK	<2		Sink
497-050.5	3300 Cooridor Girl's Restroom (left) - SNK (flush)	9		Sink

Saint Paul Public Schools
Water Sample Results
Battle Creek Elementary
Building Number: 422

Sample Date: June 12th, 2016
Sampled by: Mary Ferrian, Chad Whytlen, & Jake Baxter

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
422-003	Kitchen 1202 - SPR	34		Sprayer
422-003.5	Kitchen 1202 - SPR (flush)		<2	Sprayer
422-012	Room 1206 - SNK	24		Sink
422-012.5	Room 1206 - SNK (flush)		<2	Sink
422-017	Room 1213 - SNK	21		Sink
422-017.5	Room 1213 - SNK (flush)		<2	Sink
422-019	Room 1212 - SNK	30		Sink
422-020	Faculty Workroom 1215 Restroom - SNK	15		Sink
422-019.5	Room 1212 - SNK (flush)		<2	Sink
422-028	Room 1103 - SNK	61		Sink
422-028.5	Room 1103 - SNK (flush)		<2	Sink
422-038	Nurse's Office 1006 - SNK	60		Sink
422-038.5	Nurse's Office 1006 - SNK (flush)		<2	Sink
422-049	Outside Girl's Restroom 1327 (left) - WC	23		Water Cooler
422-058	Room 1332 - SNK	18		Sink
422-060	Room 1334 - DF	17		Drinking Fountain
422-070	Room 1326 - SNK	16		Sink
422-072	Room 1323 - SNK	30		Sink
422-072.5	Room 1323 - SNK (flush)		<2	Sink
422-076	Room 1321 - SNK	22		Sink
422-090	Room 1316 - SNK	19		Sink
422-094	Room 1314 Bathroom - SNK	18		Sink
422-097	Room 1312 Restroom - SNK	77		Sink
422-098	Room 1312 - DF	21		Drinking Fountain
422-100	Room 1309 - SNK	22		Sink
422-102	Room 1310 Restroom - SNK	93		Sink
422-103	Room 1310 - SNK	25		Sink
422-098.5	Room 1312 - DF (flush)		<2	Drinking Fountain

422-100.5	Room 1309 - SNK (flush)		52	Sink
422-102.5	Room 1310 Restroom - SNK (flush)		<2	Sink
422-097.5	Room 1312 Restroom - SNK (flush)		2	Sink
422-103.5	Room 1310 - SNK		<2	Sink
422-111	Kitchen - Bunn	42		Bunn

Saint Paul Public Schools
Water Sample Results
Belvidere
Building Number: 551

Sample Date: 6/12/16
Sampled by: Mary Ferrian, Chad Whyhlen, & Jake Baxter

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
551-001	Kitchen 1301 (left) - KS	<2		Kitchen Sink
551-002	Kitchen 1301 (right) - KS	<2		Kitchen Sink
551-003	Kitchen Hand sink - SNK	<2		Sink
551-004	Kitchen Sprayer - SPR	-		Sprayer
551-005	Room 1206 Workroom - SNK	<2		Sink
551-006	Room 1206 Restroom - SNK	<2		Sink
551-007	Room 1205 Lounge - SNK	<2		Sink
551-008	Room 1203 - Slop	<2		Slop Sink
551-009	Gymnasium - WC	<2		Water Cooler
551-010	Room 1102 Restroom - SNK	<2		Sink
551-011	1100 Cooridor South (left) - WC	<2		Water Cooler
551-012	1100 Cooridor South (right) - WC	<2		Water Cooler
551-013	Boy's Restroom 1104 (left) - SNK	<2		Sink
551-014	Boy's Restroom 1104 (middle) - SNK	<2		Sink
551-015	Boy's Restroom 1104 (right) - SNK	<2		Sink
551-016	Room 1103 - SNK	<2		Sink
551-017	Room 1105 - SNK	<2		Sink
551-018	Room 1107 - SNK	<2		Sink
551-019	Room 1109 - SNK	<2		Sink
551-020	Girl's Restroom 1108 (left) - SNK	<2		Sink
551-021	Girl's Restroom 1108 (middle) - SNK	<2		Sink
551-022	Girl's Restroom 1108 (right) - SNK	<2		Sink
551-023	Room 1111 - SNK	<2		Sink
551-024	Room 1111 Restroom - SNK	<2		Sink
551-025	1100 Cooridor North (left) - WC	<2		Water Cooler
551-026	1100 Cooridor North (right) - WC	<2		Water Cooler
551-027	Room 1113 Restroom - SNK	<2		Sink
551-028	Room 1113 - SNK	<2		Sink
551-029	Room 1113 - DF	<2		Drinking Fountain
551-030	Maintenance 1110 - SNK	4		Sink
551-031	Maintenance 1110 - Slop	<2		Slop Sink
551-032	Boiler Room (Basement) 102 - SNK	<2		Sink
551-033	Boiler Room (Basement) 102 - Slop	<2		Slop Sink
551-034	Room 1402 - SNK	9		Sink
551-035	Room 1402 - DF	<2		Drinking Fountain
551-036	Room 1402 Restroom - SNK	<2		Sink
551-037	Room 1401 - SNK	<2		Sink
551-038	Room 1401 - DF	<2		Drinking Fountain
551-039	Room 1401 Restroom - SNK	<2		Sink
551-040	Room 1307 Media Center - SNK	<2		Sink
551-041	Boy's Restroom 1309 - SNK	<2		Sink
551-042	Outside 1309/1308 - WC	<2		Water Cooler
551-043	Girl's Restroom 1308 - SNK	<2		Sink
551-044	Room 2103 - SNK	<2		Sink
551-045	Cooridor 2100 (South) (left) - WC	<2		Water Cooler
551-046	Cooridor 2100 (South) (right) - WC	<2		Water Cooler
551-047	Room 2105 - SNK	<2		Sink
551-048	Boy's Restroom 2104 (left) - SNK	4		Sink
551-049	Boy's Restroom 2104 (middle) - SNK	<2		Sink
551-050	Boy's Restroom 2104 (right) - SNK	<2		Sink
551-051	Room 2107 - SNK	<2		Sink
551-052	Room 2108 - SNK	<2		Sink
551-053	Room 2109 - SNK	<2		Sink
551-054	Room 2110 Restroom - SNK	<2		Sink
551-055	Room 2111 - SNK	4		Sink
551-056	Girl's Restroom 2114 (left) - SNK	<2		Sink
551-057	Girl's Restroom 2114 (middle) - SNK	<2		Sink
551-058	Girl's Restroom 2114 (right) - SNK	<2		Sink
551-059	Cooridor 2100 North (left) - WC	<2		Water Cooler
551-060	Cooridor 2100 North (right) - WC	<2		Water Cooler
551-061	Room 2113 - SNK	<2		Sink
551-062	Room 2115 - SNK	<2		Sink
551-063	Room 2116 Slop	-		Slop Sink
551-064	Room 2116 - SNK	-		Slop Sink

Saint Paul Public Schools
Water Sample Results
Cherokee Heights
Building Number: 428

Sample Date: June 12th, 2016
Sampled by: Parker Prose & Kegan Silonis

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
428-001	Kitchen Hand sink	<2		Sink
428-002	N Dish Sink Sprayer	<2		Sprayer
428-003	N Dish Sink	<2		Sink
428-004	South Sink	<2		Sink
428-005	Bunn	<2		Bunn
428-006	Gym West WC	<2		Water Cooler
428-007	Gym East WC	<2		Water Cooler
428-008	1106 Hallway DF Left	<2		Drinking Fountain
428-009	1106 Hallway DF Right	<2		Drinking Fountain
428-010	Pool DF	<2		Drinking Fountain
428-011	Boy Locker Room Sink Left	<2		Sink
428-012	Boy Locker Room Sink Right	<2		Sink
428-013	Boy's Locker Room DF	<2		Drinking Fountain
428-014	Girl's Locker Room Left	<2		Sink
428-015	Girl's Locker Room Right	<2		Sink
428-016	Girl's Locker Room DF	<2		Drinking Fountain
428-017	1103 Utility Sink	<2		Sink
428-018	1103 Sink	<2		Sink
428-019	1103 Bathroom Sink	<2		Sink
428-020	3101A Boys Left	<2		Sink
428-021	3101A Boys Left Middle	<2		Sink
428-022	3101A Boys Right Middle	<2		Sink
428-023	3101A Boys Right	<2		Sink
428-024	3101A Girls Left	<2		Sink
428-025	3101A Girls Left Middle	<2		Sink
428-026	3101A Girls Right Middle	<2		Sink
428-027	3101A Girls Right	4		Sink
428-028	3103 Sink Left	<2		Sink
428-029	3103 Sink Right	<2		Sink
428-030	3100 Sink	<2		Sink
428-031	3105 Sink	<2		Sink
428-032	3101A Hallway DF R	<2		Drinking Fountain
428-033	3101A Hallway DF L	<2		Drinking Fountain
428-034	3203 Hallway DF Right	<2		Drinking Fountain
428-035	3203 Hallway DF Left	<2		Drinking Fountain
428-036	Bathroom Near 1104	<2		Sink
428-037	3000 Staff Men Left	<2		Sink
428-038	3000 Staff Men Right	<2		Sink
428-039	3206 Sink	<2		Sink
428-040	2nd Floor Boys by Elevator Left	<2		Sink
428-041	2nd Floor Boy's Bathroom by Elevator Middle Left	<2		Sink
428-042	2nd Floor Boys Bathroom by Elevator Middle Right	<2		Sink
428-043	2nd Floor Boy's Bathroom by Elevator Right	<2		Sink
428-044	Girl's Bathroom by Elevator 2nd Floor Left	<2		Sink
428-045	Girl's Bathroom by Elevator 2nd Floor Middle Left	<2		Sink
428-046	Girl's Bathroom by Elevator 2nd Floor Middle Right	<2		Sink
428-047	Girl's Bathroom by Elevator 2nd Floor Right	<2		Sink
428-048	2204 DF Left	<2		Drinking Fountain
428-049	2204 DF Right	<2		Drinking Fountain
428-050	2nd Floor Staff Girl's Left	<2		Sink
428-051	2nd Floor Staff Girl's Right	<2		Sink
428-052	2203 Sink	<2		Sink
428-053	2202 Nurse's Sink	<2		Sink
428-054	2208 SK	<2		Sink
428-055	2207 Sink	<2		Sink
428-056	2211 Hallway DF	<2		Drinking Fountain
428-057	2007 Storage Sink	<2		Sink
428-058	2101A Hallway DF	<2		Drinking Fountain
428-059	2103 Sink	<2		Sink
428-060	2104 Sink	4		Sink
428-061	2105 Sink	<2		Sink
428-062	2106 Sink	3		Sink
428-063	2107 Sink	3		Sink
428-064	2108 Sink	<2		Sink
428-065	1101 Utility Sink	<2		Sink
428-066	4203A Utility Sink	<2		Sink
428-067	4204 Hallway DF	<2		Drinking Fountain
428-068	2110 Sink	<2		Sink
428-069	2109 Sink	<2		Sink
428-070	1207 Left Sink	<2		Sink
428-071	1207 Right Sink	<2		Sink
428-072	1205 Hallway DF	<2		Drinking Fountain
428-073	C109A Men's Left	<2		Sink
428-074	C109A Men's Right	<2		Sink
428-075	C109B Women's Left	<2		Sink
428-076	C109B Women's Right	<2		Sink
428-077	C109 Sink	<2		Sink
428-078	C108 Sink	<2		Sink
428-079	C106 Hallway WC Right	<2		Water Cooler
428-080	C106 Hallway WC Left	<2		Water Cooler
428-081	1113 Sink	<2		Sink
428-082	1208 Hallway WC	<2		Water Cooler
428-083	1208 Hallway WC Lower	<2		Water Cooler
428-084	All Gender Left	<2		Sink
428-085	All Gender Right	<2		Sink

428-086	C201 Sink	<2		Sink
428-087	C200 WC Left	<2		Water Cooler
428-088	C200 WC Right	<2		Water Cooler
428-089	C202A Sink	<2		Sink
428-090	C203 Slop Sink	<2		Slop Sink

Saint Paul Public Schools
Water Sample Results
American Indian Magnet
Building Number: 579

Sample Date: June 12, 2016
Sampled by: Natalie Eskew, Kobe Patch

Sample #	Location	Sample Results 2016	15 Secinds Flush Sample	Fixture Type
579-001	Kitchen South	<2ppb		Hand Sink
579-002	Kitchen Custodial South	<2ppb		Utility Sink
579-003	Kitchen North	<2ppb		Hand Sink
579-004	Kitchen North West Wall	<2ppb		Sink
579-005	Kitchen North Wall Left	<2ppb		Sink
579-006	Kitchen Restroom	<2ppb		Sink
579-007	Kitchen Bunn	<2ppb		Bunn
579-008	Hallway by Room 1305	<2ppb		Water Cooler
579-009	Hallway by Room 1305	<2ppb		Bottle Filler
579-010	Room 1304	<2ppb		Sink
579-011	Room 1303	<2ppb		Sink
579-012	Room 1303 Restroom	3ppb		Sink
579-013	Room 1302	<2ppb		Sink
579-014	Room 1302 Restroom	<2ppb		Sink
579-015	Room 1301	<2ppb		Sink
579-016	Room 1210	3ppb		Sink
579-017	Girls Restroom by Room 1209 Left	<2ppb		Sink
579-018	Girls Restroom by Room 1209 Right	<2ppb		Sink
579-019	Room 1209	<2ppb		Sink
579-020	Custodial Room 1212	<2ppb		Utility Sink
579-021	Boys Restroom by Room 1209 Left	<2ppb		Sink
579-022	Boys Restroom by Room 1209 Right	<2ppb		Sink
579-023	Handicap Restroom by Room 1209	<2ppb		Sink
579-024	Hallway by Room 1209	<2ppb		Drinking Fountain
579-025	Room 1208	3ppb		Sink
579-026	Room 1216	<2ppb		Sink
579-027	Room 1202 Lounge	<2ppb		Sink
579-028	Boiler Room 1201	<2ppb		Utility Sink
579-029	Hallway by Room 1101	<2ppb		Water Cooler
579-030	Giels Restroom by Room 1101 Left	<2ppb		Sink
579-031	Giels Restroom by Room 1101 Right	<2ppb		Sink
579-032	Boys Restroom by Room 1101 Left	<2ppb		Sink
579-033	Boys Restroom by Room 1101 Right	<2ppb		Sink
579-034	Gymnasium 1104	<2ppb		Drinking Fountain
579-035	Boys Locker Room Left	<2ppb		Sink
579-036	Boys Locker Room Right	<2ppb		Sink
579-037	Room 1107C Custodial	<2ppb		Utility Sink
579-038	Girls Locker Room Left	4ppb		Sink
579-039	Girls Locker Room Right	<2ppb		Sink
579-040	Room 1108C Custodial	<2ppb		Utility Sink
579-041	Nurse	<2ppb		Sink
579-042	Nurse Restroom	<2ppb		Sink
579-043	Main Office Women Restroom	<2ppb		Sink
579-044	Main Office Men Restroom	<2ppb		Sink
579-045	Main Office Room 1009 Lounge	<2ppb		Sink
579-046	Main Office Room 1013 Principal	<2ppb		Sink
579-047	Room 2306	<2ppb		Sink
579-048	Room 2304	<2ppb		Sink
579-049	Room 2302	<2ppb		Sink
579-050	Staff Restroom by Room 2302 Left	<2ppb		Sink
579-051	Staff Restroom by Room 2302 Right	<2ppb		Sink
579-052	Hallway by Room 2301	<2ppb		Drinking Fountain
579-053	Room 2301	<2ppb		Sink
579-054	Room 2207	<2ppb		Sink
579-055	Room 2206	<2ppb		Sink
579-056	Girls Restroom by Room 2206 Left	<2ppb		Sink
579-057	Girls Restroom by Room 2206 Right	<2ppb		Sink
579-058	Custodial Room 2209	<2ppb		Utility Sink
579-059	Room 2206 Restroom	<2ppb		Sink
579-060	Room 2203	<2ppb		Sink
579-061	Room 2203 Restroom	<2ppb		Sink
579-062	Hallway by Room 2201	<2ppb		Drinking Fountain
579-063	Boys Restroom by Room 2201 Left	<2ppb		Sink
579-064	Boys Restroom by Room 2201 Right	<2ppb		Sink
579-065	Room 2201	<2ppb		Sink
579-066	Room 2201 Restroom	<2ppb		Sink
579-067	Room 3306	<2ppb		Sink
579-068	Room 3304	<2ppb		Sink
579-069	Staff Restroom by Room 3302	<2ppb		Sink
579-070	Hallway by Room 3302	<2ppb		Drinking Fountain
579-071	Room 3302	<2ppb		Sink
579-072	Room 3301	<2ppb		Sink

579-073	Room 3207	<2ppb		Sink
579-074	Room 3206	<2ppb		Sink
579-075	Boys Restroom by Room 3206 Left	<2ppb		Sink
579-076	Boys Restroom by Room 3206 Right	<2ppb		Sink
579-077	Custodial Room 3209	<2ppb		Utility Sink
579-078	Room 3205	<2ppb		Sink
579-079	Room 3204	<2ppb		Sink
579-080	Room 3203	<2ppb		Sink
579-081	Hallway by Room 3201	<2ppb		Drinking Fountain
579-082	Girls Restroom by Room 3201 Left	<2ppb		Sink
579-083	Girls Restroom by Room 3201 Right	<2ppb		Sink
579-084	Room 3201	<2ppb		Sink
579-085	Room 4306	<2ppb		Sink
579-086	Room 4305	<2ppb		Sink
579-087	Staff Restroom by Room 4308 Left	<2ppb		Sink
579-088	Staff Restroom by Room 4308 Right	<2ppb		Sink
579-089	Room 4302	<2ppb		Sink
579-090	Hallway by Room 4301	<2ppb		Drinking Fountain
579-091	Room 4301	<2ppb		Sink
579-092	Room 4207	<2ppb		Sink
579-093	Room 4206	<2ppb		Sink
579-094	Girls Restroom by Room 4205 Left			Sink
579-095	Girls Restroom by Room 4205 Right			Sink
579-096	Custodial Room 4209			Utility Sink
579-097	Room 4205			Sink
579-098	Room 4204			Sink
579-099	Room 4203			Sink
579-100	Boys Restroom by Room 4201 Left			Sink
579-101	Boys Restroom by Room 4201 Right			Sink
579-102	Hallway by Room 4201			Drinking Fountain
579-103	Room 4201 Left			Sink
579-104	Room 4201 Center			Sink
579-105	Room 4201 Right			Sink

Saint Paul Public Schools
Water Sample Results
Eastern Heights
Building Number: 452

Sample Date: June 12th, 2016
Sampled by: Parker Prose & Kegan Silonis

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	SampleType
452-001	Gym DF	<2		Drinking Fountain
452-002	North Kitchen Hand Sink	<2		Sink
452-003	Kitchen Bathroom Sink	<2		Sink
452-004	East Kitchen Hand Sink	<2		Sink
452-005	1108B Utility Sink	<2		Sink
452-006	South Kitchen Dish Sink	5		Sink
452-007	1207 Hallway DF	3		Drinking Fountain
452-008	1202 Sink	8		Sink
452-009	BUNN	7		BUNN
452-010	1101 Hallway DF	<2		Drinking Fountain
452-011	Boy's Near 1205	7		Sink
452-012	Girl's Near 1205	<2		Sink
452-013	1303 Sink	<2		Sink
452-014	1209 Sink	15		Sink
452-015	1203 Bathroom Sink	<2		Sink
452-016	1305 sink	<2		Sink
452-017	1305 Hallway DF	<2		Drinking Fountain
452-018	1205 Utility Sink	<2		Sink
452-019	1301 Sink	<2		Sink
452-020	1311 Sink	<2		Sink
452-021	1309 Sink	<2		Sink
452-022	1304 Sink	<2		Sink
452-023	1307 Sink	<2		Sink
452-024	1315 Utility Sink	<2		Sink
452-025	1302 Sink	<2		Sink
452-026	1304 Hallway DF	<2		Drinking Fountain
452-027	Boy's Right by 1313	<2		Sink
452-028	Boy's Left by 1313	<2		Sink
452-029	DF Near 1313	<2		Drinking Fountain
452-030	Girl's Right by 1313	<2		Sink
452-031	Girl's Left by 1313	<2		Sink
452-032	Boy's Left Near 2101	<2		Sink
452-033	Boy's Right Near 2101	<2		Sink
452-034	2315A Utility Sink	<2		Sink
452-035	2102 Sink	<2		Sink
452-036	2304 Sink	<2		Sink
452-037	1010 Restroom Right Sink	<2		Sink
452-038	1010 Restroom Left Sink	<2		Sink
452-039	2307 Sink	<2		Sink
452-040	Nurse's Sink	<2		Sink
452-041	2309 Sink	<2		Sink
452-042	2313 Sink	<2		Sink
452-043	Girl's Right near 2101	<2		Sink
452-044	Girl's left near 2101	<2		Sink

452-045	2301 Sink	<2		Sink
452-046	2305 Sink	<2		Sink
452-047	2303 Sink	<2		Sink
452-048	Nurse's Bathroom Sink	<2		Sink
452-049	2206 Sink	<2		Sink
452-050	2102 Hallway - DF	<2		Drinking Fountain
452-051	2204 Sink	<2		Sink
452-052	2207 Sink	<2		Sink
452-053	2311 Sink	<2		Sink
452-054	2304 Hallway DF	<2		Drinking Fountain
452-055	2306 Sink	<2		Sink
452-056	2202 Sink	<2		Sink
452-057	2207 Hallway DF	<2		Drinking Fountain
452-058	2207 Boy's	<2		Sink
452-059	2207 Girl's	<2		Sink
452-060	2302 Sink	<2		Sink
452-061	3106 Hallway DF	<2		Drinking Fountain
452-062	2108b Utility Sink	<2		Sink
452-063	3108 Restroom	<2		Sink
452-064	3rd Floor Main Room Sink	<2		Sink
452-065	Basement Restroom	<2		Sink
452-066	2nd Floor Teacher's Break Room	<2		Sink

Saint Paul Public Schools
Water Sample Results
Humboldt Senior
Building Number: 225

Sample Date: 6/12/2016
Sampled by: Chandala, Racquel, Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
225-001	Room 1407C	<2		Sink
225-002	Boy's Varsity locker Room - Left	<2		Sink
225-003	Boy's Varsity locker Room - Middle	<2		Sink
225-004	Boy's Varsity locker Room - Right	4		Sink
225-005	Lockers Arch #1407 Left	7		Fountain
225-006	Lockers Arch #1407 Right	7		Fountain
225-007	Restroom Staff 1407D	5		Sink
225-008	Restroom Staff 1403D	6		Sink
225-009	Lockers Arch #1403 Left	5		Fountain
225-010	Lockers Arch #1403 Right	2		Fountain
225-011	Girl's Varsity locker Room - Left	<2		Sink
225-012	Girl's Varsity locker Room - Middle	<2		Sink
225-013	Girl's Varsity locker Room - Right	<2		Sink
225-014	Concessions Room	<2		Sink
225-015	1403C	Above 100		Sink
225-016	1407C	<2		Sink
225-017	1401A	<2		Sink
225-018	Cooler Right next to 1407	<2		Sink
225-019	1113 Right DF	<2		DF
225-020	Cooler Left next to 1407	<2		Cooler
225-021	Left DF outside 1113	<2		DF
225-022	Left Bathroom Sink outside 1408	<2		Sink
225-023	Next to 1407 RR sink	<2		Sink
225-024	Kitchen Prep Sink Right of eyewash	<2		Sink
225-025	Kitchen Deep sink LH	<2		Sink
225-026	Kitchen Deep Sink RH	<2		Sink
225-027	Kitchen Hans Sink Left of Eyewash	<2		Sink
225-028	Kitchen Hand sink Right of eyewash	<2		Sink
225-029	Kitchen Staff locker	3		Sink
225-030	Cafeteria DF Left	<2		DF
225-031	Cafeteria DF Right	<2		DF
225-032	Cafeteria DF by room 1102	<2		DF
225-033	Room 1102 Pool equipment	<2		Sink/Bib
225-034	1102 Basement pool equipment room	<2		Sink/Bib
225-035	Main Entrance Mens RR Left	<2		Sink
225-036	Main Entrance Mens RR Middle	<2		Sink
225-037	Main Entrance Mens RR Right	<2		Sink
225-038	Nurses Office Sink Room 1003	<2		Sink
225-039	Nurses Office RR Sink Room 1003	<2		Sink
225-040	Nurses Office Cot Sink Room 1003	<2		Sink
225-041	Room 1012 Sink	12		Sink
225-042	Rom 1010 RR sink	<2		Sink
225-043	Room 1013 Left sink	<2		Sink
225-044	Room 1013 Right Sink	15		Sink
225-045	Maintenance Room 1215	<2		Sink
225-046	Custodial Closet Next to 1216	4		Sink
225-047	Hallway DF in front of 1306	5		DF
225-048	Room 1212 Sink	8		Sink
225-049	Room 1212 DF	57		DF
225-050	Mens RR hallway Left	8		Sink
225-051	Mens RR hallway Middle	<2		Sink
225-052	Mens RR hallway Right	3		Sink
225-053	Room 1225 Left Sink	<2		Sink
225-054	Room 1225 Right Sink	7		Sink
225-055	Girls RR left Sink Hallway by room 1216	<2		Sink

225-056	Girls RR Middle Sink Hallway by room 1216	4		Sink
225-057	Girls RR Right Sink Hallway by room 1216	11		Sink
225-058	DF in front of 1214 Left Hall	<2		DF
225-059	DF in front of 1214 Right Hall	2		DF
225-060	Room 1127 Mens Dressing room Left	6		Sink
225-061	1127 Mens Dressing room Right Sink	8		Sink
225-062	1126 Womens dressing room Left Sink	<2		Sink
225-063	1127 Womens dressing room Right Sink	6		Sink
225-064	1014 Main Office Sink	<2		Sink
225-064.1	Room 1259 Left Sink	<2		Sink
225-065	1122 Sink	<2		Sink
225-065.1	Room 1259 Left Center Sink	<2		Sink
225-066	DF in front of room 1120	14		DF
225-066.1	Room 1259 Right Sink	<2		Sink
225-067	Room 1259 Right Sink	<2		Sink
225-068	Room 1259A Sink	<2		Sink
225-069	Room 1254 East Sink	<2		Sink
225-070	Room 1254 West Sink	<2		Sink
225-071	Room 1252 West Sink	<2		Sink
225-072	Room 1252 East Sink	<2		Sink
225-073	Room 1248 NW Sink	<2		Sink
225-074	Room 1248 Across from Sample 73	14		Sink
225-075	Room 1248 SW Sink	3		Sink
225-076	Room 1248 Across from Sample 75	2		Sink
225-077	Room 1248 North Central Sink	10		Sink
225-078	Room 1248 SE Sink	<2		Sink
225-079	Room 1248 Scross from sample 78	5		Sink
225-080	Room 1247 Sink	<2		Sink
225-081	Room 1248A Sink	7		Sink
225-082	Room 1246 North Right Sink	<2		Sink
225-083	Room 1246 Sprayer	<2		Sink
225-084	Room 1246 North Left Sink	4		Sink
225-085	Room 1246 Foot Pedal Sink	<2		Sink
225-086	Room 1246 SE Sink	4		Sink
225-087	Room 1245 SW Sink	<2		Sink
225-088	Room 1245 NE Sink	5		Sink
225-089	Room 1244 Restroom Sink	4		Sink
225-090	Room 1244 Sink	17		Sink
225-091	Room 1238B Sink	<2		Sink
225-092	Room 1238 Left Sink	20		Sink
225-093	Room 1238 Middle Sink	4		Sink
225-094	Room 1238 Sink	<2		Sink
225-095	Room 1103 Left Sink	33		Sink
225-096	Room 1103 Right Sink	10		Sink
225-097	Room 1103 DF	<2		DF
225-098	Hallway DF Next to Room 1120	<2		Sink
225-099	Room 1105 Sink Dishroom	<2		Sink
225-100	Room 1105 Dishroom sprayer	<2		Sink
225-101	Womens Locker Room Sink Right	<2		Sink
225-102	Womens LR Sink Left	<2		Sink
225-103	Room 1104 Womens LR DF	<2		DF
225-104	Womens RR in front of Cafeteria Left Sink	<2		Sink
225-105	Womens RR in front of Cafeteria Middle Sink	<2		Sink
225-106	Womens RR in front of Cafeteria Right Sink	<2		Sink
225-107	TE8 Mens Left Sink	<2		Sink
225-108	TE8 Mens Middle Sink	8		Sink
225-109	TE8 Mens Right Sink	<2		Sink
225-110	TE8 Womens Left Sink	<2		Sink
225-111	TE8 Womens Middle Sink	NA		Sink
225-112	TE8 Womens Right Sink	<2		Sink
225-113	Hallway outside TE8 Left DF	<2		DF
225-114	Room 2232 Sink	<2		Sink
225-115	Room 2234 Sink	3		Sink
225-116	Room 2243 Sink	<2		Sink
225-117	Room 2247B Sink	43		Sink
225-118	Room 2250 DF	<2		DF
225-119	Room 2259 Sink	6		Sink
225-120	Room 3211 Sink	23		Sink
225-121	Room 3208 Sink	89		Sink
225-122	Room 3215 Sink	18		Sink
225-123	Room 3216 Sink	<2		Sink
225-124	Room 3217 Sink	4		Sink
225-125	Room 3232 Demonstration Sink	<2		Sink
225-126	3rd Floor Hallway DF by 3218 Left	4		DF
225-127	3rd Floor Hallway DF by 3218 Right	3		DF
225-128	3rd floor Mens RR Sink Left	<2		Sink
225-129	3rd floor Mens RR Sink Middle	<2		Sink
225-130	3rd floor Mens RR Sink Right	<2		Sink
225-131	3rd floor Womens RR Sink Left	<2		Sink
225-132	3rd floor Womens RR Sink Middle	<2		Sink
225-133	3rd floor Womens RR Sink Right	<2		Sink
225-134	Room 3222 Sink	<2		Sink
225-135	Science Room 3234 Sink 1	<2		Sink
225-136	Science Room 3234 Sink 2	<2		Sink
225-137	Science Room 3234 Sink 3	<2		Sink
225-138	Science Room 3234 Sink 4	<2		Sink
225-139	Science Room 3234 Sink 5	<2		Sink

225-140	Science Room 3234 Sink 6	<2		Sink
225-141	Science Room 3234 Sink 7	<2		Sink
225-142	Room 3235 Sink	<2		Sink
225-143	Science Room 3236 Sink 1	<2		Sink
225-144	Science Room 3236 Sink 2	<2		Sink
225-145	Science Room 3236 Sink 3	<2		Sink
225-146	Science Room 3236 Sink 4	<2		Sink
225-147	Science Room 3236 Sink 5	8		Sink
225-148	Science Room 3236 Sink 6	<2		Sink
225-149	Science Room 3238 Sink 1	<2		Sink
225-150	Science Room 3238 Sink 2	4		Sink
225-151	Science Room 3238 Sink 3	<2		Sink
225-152	Science Room 3238 Sink 4	2		Sink
225-153	Science Room 3238 Sink 5	<2		Sink
225-154	Science Room 3238 Sink 6	<2		Sink
225-155	Science Room 3238 Sink 7	<2		Sink
225-156	Science Room 3238 Sink 8	<2		Sink
225-157	Science Room 3238 Sink 9	<2		Sink
225-158	Science Room 3238 Sink 10	<2		Sink
225-159	Room 1006B Sink	<2		Sink
225-160	Room 1004 Sink	<2		Sink
225-161	Room 1004 RR sink	<2		Sink
225-162	Room 1004 Sink	2		Sink
225-163	Room 1235 Sink Left	2		Sink
225-164	Room 1235 Sink Right	3		Sink
225-165	Room 1101 Pool DF Left	<2		DF
225-166	Room 1101 Pool DF Right	<2		DF

Saint Paul Public Schools
Water Sample Results
Nokomis South
Building Number: 534

Sample Date: 6/12/16
Sampled by: Mary Ferrian, Chad Whyhlen, & Jake Baxter

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
534-001	Cafeteria - WC	<2		Water Cooler
534-002	Kitchen Hand Sink - SNK	<2		Sink
534-003	Dish room Sprayer - SPR	5		Sprayer
534-004	Dish room (left) - SNK	2		Sink
534-005	Dish room (right) - SNK	2		Sink
534-006	Kitchen Bunn	<2		Bunn
534-007	Room 1305 - SNK	<2		Sink
534-008	Room 1305 Restroom - SNK	<2		Sink
534-009	Room 1306 Maintenance - SLOp	<2		Slop Sink
534-010	Boy's Restroom 1302 (left) - SNK	<2		Sink
534-011	Boy's Restroom 1302 (left middle) - SNK	<2		Sink
534-012	Boy's Restroom 1302 (right middle) - SNK	<2		Sink
534-013	Boy's Restroom 1302 (right) - SNK	<2		Sink
534-014	Girl's Restroom 1301 (left) - SNK	<2		Sink
534-015	Girl's Restroom 1301 (left middle) - SNK	<2		Sink
534-016	Girl's Restroom 1301 (right middle) - SNK	<2		Sink
534-017	Girl's Restroom 1301 (right) - SNK	<2		Sink
534-018	Room 1205 - Slop	<2		Slop Sink
534-019	1200 Cooridor (left) - WC (broken)			Water Cooler
534-020	1200 Cooridor (right) - WC	<2		Water Cooler
534-021	Room 1203 - SNK	<2		Sink
534-022	Room 1204 - SNK	<2		Sink
534-023	Room 1202 - SNK	<2		Sink
534-024	Room 1001A Restroom - SNK	18		Sink
534-025	Nurse's -SNK	<2		Sink
534-026	Nurse's Restroom - SNK	<2		Sink
534-027	Room 1007 - SNK	<2		Sink
534-028	Room 1201 - SNK	<2		Sink
534-029	Room 1104 Media Center - SNK	<2		Sink
534-030	Cooridor 1500 - DF	<2		Fountain
534-031	Room 1502 - SNK	<2		Sink
534-032	Room 1502 Restroom - SNK	<2		Sink
534-033	Room 1504 - SNK	<2		Sink
534-034	Room 1504 Restroom - SNK	18		Sink
534-035	Boy's Restroom 2104 (left) - SNK	<2		Sink
534-036	Boy's Restroom 2104 (left middle) - SNK	<2		Sink
534-037	Boy's Restroom 2104 (right middle) - SNK	<2		Sink
534-038	Boy's Restroom 2104 (right) - SNK	<2		Sink
534-039	2100 Cooridor (left) - DF	<2		Fountain
534-040	2100 Cooridor (right) - DF	2		Fountain
534-041	Girl's Restroom 2203 (left) - SNK	<2		Sink
534-042	Girl's Restroom 2203 (left middle) - SNK	<2		Sink
534-043	Girl's Restroom 2203 (middle) - SNK	10		Sink
534-044	Girl's Restroom 2203 (right middle) - SNK	<2		Sink
534-045	Girl's Restroom 2203 (right) - SNK	<2		Sink
534-046	Room 2102A Bathroom - SNK	5		Sink
534-047	Room 2100 - SNK	<2		Sink
534-048	Room 2207 - SNK	<2		Sink
534-049	Room 2201 Resource Room - SNK	<2		Sink
534-050	Room 2206 - SNK	<2		Sink

534-051	Room 2202 - SNK	<2		Sink
534-052	2200 Cooridor - DF	<2		Fountain
534-053	Room 2205 - SNK	<2		Sink
534-054	Room 2203 - SNK	<2		Sink
534-055	Room 2204 - SNK	<2		Sink
534-056	Girl's Restroom 2301 (left) - SNK	<2		Sink
534-057	Girl's Restroom 2301 (middle) - SNK	<2		Sink
534-058	Girl's Restroom 2301 (right) - SNK	<2		Sink
534-059	Boy's Restroom 2302 (left) - SNK	<2		Sink
534-060	Boy's Restroom 2302 (middle) - SNK	<2		Sink
534-061	Boy's Restroom 2302 (right) - SNK	<2		Sink
534-062	Cooridor 2300 (left) - WC	<2		Water Cooler
534-063	Cooridor 2300 (right) - WC	<2		Water Cooler
534-064	Room 2303 - Slop	<2		Slop Sink
534-065	Room 2304 - SNK	<2		Sink
534-066	Room 2306 - SNK	<2		Sink
534-067	Room 2305 - SNK	<2		Sink

Saint Paul Public Schools
Water Sample Results
Riverview Elementary
Building Number: 554

Sample Date: 6/12/2016
Sampled by: Ted Sherman, Chandala Nagendrappa,
Stephanie Pinkalla

Sample #	Location	Sample Result 2016	15 Seconds Flush Sample	Fixture Type
554-001	Classroom 3201 - Far Left	<2ppb		Sink
554-002	Classroom 3201 - Left	<2ppb		Fountain
554-003	Classroom 3201 - Middle	<2ppb		Sink
554-004	Classroom 3201 - Right	<2ppb		Fountain
554-005	Classroom 3201 - Far Right	<2ppb		Sink
554-006	Classroom 3201 - Farthest Right	<2ppb		Cooler
554-007	3rd Flr West Men's Restroom - Left	<2ppb		Sink
554-008	3rd Flr West Men's Restroom - Middle	<2ppb		Sink
554-009	3rd Flr West Men's Restroom - Right	<2ppb		Sink
554-010	Hydration Station - Hall- Left	<2ppb		Hydra
554-011	Hydration Station - Hall-Right	<2ppb		Fountain
554-012	3rd Flr Women's Restroom -Left	<2ppb		Sink
554-013	3rd Flr Women's Restroom -Middle	<2ppb		Sink
554-014	3rd Flr Women's Restroom - Right	<2ppb		Sink
554-015	Room 3109 -Left	<2ppb		Sink
554-016	Room 3109 - Middle Left	<2ppb		Fountain
554-017	Room 3109 - Middle Right	<2ppb		Sink
554-018	Room 3109 - Right	<2ppb		Fountain
554-019	Gym 3114 - Left	<2ppb		Hydra
554-020	Gym 3114 - Right	<2ppb		Sink
554-021	Unisex RR East Gym Entrance	<2ppb		Sink
554-022	Room 3111 - Left	<2ppb		Sink
554-023	Room 3111 - Middle Left	<2ppb		Fountain
554-024	Room 3111 - Middle Right	<2ppb		Sink
554-025	Room 3111 - Left	<2ppb		Fountain
554-026	3rd Flr East Women's RR - Left	<2ppb		Sink
554-027	3rd Flr East Women's RR - Middle	<2ppb		Sink
554-028	3rd Flr East Women's RR - Right	<2ppb		Sink
554-029	Hydration Station - Hall East - Left	<2ppb		Hydra
554-030	Hydration Station - Hall East -Right	<2ppb		Hydra
554-031	3rd Flr East Men's RR - Left	<2ppb		Sink
554-032	3rd Flr East Men's RR - Middle	<2ppb		Sink
554-033	3rd Flr East Men's RR - Right	<2ppb		Sink
554-034	Room 2205 Faculty Lounge	<2ppb		Sink
554-035	Room 2205 Faculty Lounge	<2ppb		Fountain
554-036	Room 2205 Faculty Lounge RR	<2ppb		Sink
554-037	Room 2205 Faculty Lounge	<2ppb		Cooler
554-038	2nd Flr West Men's Restroom - Left	<2ppb		Sink
554-039	2nd Flr West Men's Restroom - Middle	<2ppb		Sink
554-040	2nd Flr West Men's Restroom - Right	<2ppb		Sink
554-041	Hydration Station - Hall - Left	<2ppb		Hydra
554-042	Hall - Right	<2ppb		Hydra
554-043	2nd Flr West Women's Restroom- Left	<2ppb		Sink
554-044	2nd Flr West Women's Restroom- Middle	<2ppb		Sink
554-045	2nd Flr West Women's Restroom - Right	<2ppb		Sink
554-046	2nd Flr East Women's Restroom - Left	<2ppb		Sink
554-047	2nd Flr East Women's Restroom - Middle	<2ppb		Sink
554-048	2nd Flr East Women's Restroom - Right	<2ppb		Sink
554-049	Hydration Station - Hall - Left	<2ppb		Hydra
554-050	Hall - Right	<2ppb		Hydra
554-051	2nd Flr Men's Restroom - Left	<2ppb		Sink
554-052	2nd Flr Men's Restroom - Middle	<2ppb		Sink
554-053	2nd Flr Men's Restroom - Right	<2ppb		Sink
554-054	Room 1207	<2ppb		Sink
554-055	Room 1207	<2ppb		Fountain
554-056	Room 1207	<2ppb		Restroom
554-057	Room 1206	<2ppb		Sink
554-058	Room 1206	<2ppb		Fountain
554-059	Room 1206	<2ppb		Restroom
554-060	Unisex Restroom	<2ppb		Sink

554-061	Room 1204	<2ppb		Sink
554-062	Room 1204	<2ppb		Fountain
554-063	Room 1204	<2ppb		Restroom
554-064	Room 1202	<2ppb		Sink
554-065	Room 1202	<2ppb		Fountain
554-066	Room 1202	<2ppb		Restroom
554-067	Room 1201	<2ppb		Sink
554-068	Room 1201	<2ppb		Fountain
554-069	Room 1201	<2ppb		Restroom
554-070	Hall by Room 1205	<2ppb		Cooler
554-071	Nurse Room 1001	<2ppb		Sink
554-072	Nurse Room 1001 Restroom	<2ppb		Sink
554-073	Hall by Cafeteria - Left	<2ppb		Cooler
554-074	Hall by Cafeteria - Right	<2ppb		Cooler
554-075	Dish Room 1106 - Left	<2ppb		Large Sink
554-076	Dish Room 1106 - Middle	<2ppb		Large Sink
554-077	Dish Room 1106 - Right	<2ppb		Hand Sink
554-078	Kitchen Rm 1108 West	<2ppb		Hand Sink
554-079	Kitchen Rm 1108 South Wall	<2ppb		Large Sink
554-080	Kitchen Rm 1108 Bunn			Bunn
554-081	Hydration Station - Cafeteria - Left	<2ppb		Hydra
554-082	Hydration Station - Cafeteria - Right	<2ppb		Hydra
554-083	1st Flr Women's East Restroom - Left	<2ppb		Sink
554-084	1st Flr Women's East Restroom - Middle	<2ppb		Sink
554-085	1st Flr Women's East Restroom - Right	<2ppb		Sink
554-086	Hallway	<2ppb		Cooler
554-087	1st Flr Men's Restroom - Left	<2ppb		Sink
554-088	1st Flr Men's Restroom - Middle	<2ppb		Sink
554-089	1st Flr Men's Restroom - Right	<2ppb		Sink
554-090	Room 1301	<2ppb		Sink
554-091	Room 1301	<2ppb		Fountain
554-092	Room 1301	<2ppb		Restroom
554-093	Room 1302	<2ppb		Sink
554-094	Room 1302	5 ppb	NF	Fountain
554-095	Room 1302	<2ppb		Restroom
554-096	Room 1304	<2ppb		Sink
554-097	Room 1304	<2ppb		Fountain
554-098	Room 1306	<2ppb		Sink
554-099	Room 1306	<2ppb		Fountain
554-100	Room 1308	<2ppb		Sink
554-101	Room 1308	<2ppb		Fountain
554-102	Boiler Room - Slop Stick	<2ppb		Hose Bib

Saint Paul Public Schools
Water Sample Results
Battle Creek Junior High
Building Number: 310

Sample Date: July 10th, 2016
Sampled by: Mary Ferrian & Chad Whaylen

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
310-001	South Kitchen 2106 - KS	<2		Kitchen Sink
310-002	Kitchen 2105 Hand Sink - SNK	<2		Sink
310-003	Hand Sink West Wall 2106 - SNK	<2		Sink
310-004	2106 North (left) - KS	<2		Kitchen Sink
310-005	2106 North (right) - KS	<2		Kitchen Sink
310-006	North Hand Sink - SNK	<2		Sink
310-007	Dishroom - SPR	<2		Sprayer
310-008	Cafeteria East - WC	8		Water Cooler
310-009	Cafeteria West - WC	50		Water Cooler
310-009.5	Cafeteria West - WC (Flush)		<2	Water Cooler
310-010	2110 Mechanical	<2		Slop
310-011	Nutrition Services Restroom (next to 2110) - SNK	<2		Sink
310-012	2000 Cooridor West (left) - WC	8		Water Cooler
310-013	2000 Cooridor West (right) - WC	<2		Water Cooler
310-014	Room 2205 - SNK	13		Sink
310-015	Room 2206 - SNK	29		Sink
310-016	Girl's Restroom 2103 (left) - SNK	<2		Sink
310-017	Girl's Restroom 2103 (right) - SNK	<2		Sink
310-015.5	Room 2205 - SNK (flush)		<2	Sink
310-018	Boy's Restroom 2101 (left) - SNK	3		Sink
310-019	Boy's Restroom 2101 (right) - SNK	<2		Sink
310-020	Room 2611 - SNK	<2		Sink
310-021	Room 2614 - SNK	2		Sink
310-022	Room 2617 - SNK	3		Sink
310-023	2000 Cooridor East (left) - WC	<2		Water Cooler
310-024	2000 Cooridor East (right) - WC	<2		Water Cooler
310-025	2300 Cooridor East - WC	<2		Water Cooler
310-026	Room 2502 - SNK	<2		Sink
310-027	Room 2503 North Wall - SNK	4		Sink
310-028	Room 2503 East Wall - SNK	40		Sink
310-029	Room 2503A Restroom (left) - SNK	<2		Sink
310-030	Room 2503A Restroom (right) - SNK	<2		Sink
310-031	Room 2504 North Wall (east) - SNK	45		Sink
310-032	Room 2504 North Wall (west) - SNK	<2		Sink
310-028.5	Room 2503 East Wall - SNK (flush)		<2	Sink

310-031.5	Room 2504 North Wall (east) - SNK (flush)		4	Sink
310-033	Room 2504 West Wall (north) - SNK	6		Sink
310-034	Room 2504 West Wall (south) - SNK	18		Sink
310-035	Room 2504 South Wall - SNK	47		Sink
310-036	Room 933 Custodian - SNK	10		Slop
310-037	Girl's Restroom 2506 (left) - SNK	<2		Sink
310-035.5	Room 2504 South Wall - SNK (flush)		<2	Sink
310-038	Girl's Restroom 2506 (right) - SNK	<2		Sink
310-039	Outside Girl's Restroom 2506 - WC	<2		Water Cooler
310-040	Outside Boy's Restroom 2301 - WC	<2		Water Cooler
310-041	Boy's Restroom 2301 (left) - SNK	20		Sink
310-042	Boy's Restroom 2301 (right) - SNK	<2		Sink
310-041.5	Boy's Restroom 2301 (left) - SNK (flush)		<2	Sink
310-043	2300 Cooridor West - WC	<2		Water Cooler
310-044	1100 Cooridor West (left) - WC	<2		Water Cooler
310-045	1100 Cooridor West (right) - WC	<2		Water Cooler
310-046	Room 1203 West Wall - SNK	<2		Sink
310-047	Room 1203 North Wall (west) - SNK	<2		Sink
310-048	Room 1203 North Wall (east) - SNK	<2		Sink
310-049	Room 1203 South Wall - SNK	<2		Sink
310-050	Room 1203 Eastern Island - SNK	<2		Sink
310-051	Room 1202 Western Island - SNK	<2		Sink
310-052	Room 1202 North Wall - SNK	<2		Sink
310-053	Room 1202 East Wall (left) - SNK	<2		Sink
310-054	Room 1202 East Wall (right) - SNK	<2		Sink
310-055	Room 1201 North Wall (west) - SNK	6		Sink
310-056	Room 1201 North Wall (east) - SNK	<2		Sink
310-057	Room 1201 East Wall - SNK	2		Sink
310-058	Room 1201 South Wall - SNK	<2		Sink
310-059	Room 1103 (left) - SNK	<2		Sink
310-060	Room 1103 (right) - SNK	<2		Sink
310-061	Boy's Restroom 900 (left) - SNK	<2		Sink
310-062	Boy's Restroom 900 (right) - SNK	<2		Sink
310-063	Girl's Restroom 1101 (left) - SNK	<2		Sink
310-064	Girl's Restroom 1101 (right) - SNK	28		Sink
310-065	Room 1101B Custodial - SNK	<2		Slop
310-064.5	Girl's Restroom 1101 (right) - SNK (flush)		<2	Sink
310-066	Men's Restroom 915 Offices - SNK	<2		Sink
310-067	Women's Restroom 914 Offices - SNK	<2		Sink
310-068	Room 1014 Lounge - SNK	9		Sink
310-069	Restroom 1014C (Women's) (left) - SNK	<2		Sink
310-070	Restroom 1014C (Women's) (Right) - SNK	<2		Sink
310-071	Restroom 1014B Men's - SNK	<2		Sink
310-072	1014A Cooridor - WC	<2		Water Cooler
310-073	1106 Cooridor (left) - WC	<2		Water Cooler
310-074	1106 Cooridor (right) - WC	<2		Water Cooler
310-075	Room 1003 Nurse's - SNK	<2		Sink
310-076	Girl's Restroom 913 - SNK	<2		Sink
310-077	Boy's Restroom 912 - SNK	<2		Sink
310-078	Cooridor H100 - WC	30		Water Cooler
310-078.5	Cooridor H100 - WC (flush)		<2	Water Cooler
310-079	Room 1502 Mechanical - SNK	6		Slop
310-080	Room 1406 Mechanical - SNK	<2		Slop
310-081	Outside Restroom 1405 - WC	<2		Water Cooler
310-082	Girl's Restroom 1405 (left) - SNK	<2		Sink
310-083	Girl's Restroom 1405 (right) - SNK	5		Sink
310-084	Outside Restroom 1401 - WC	<2		Water Cooler
310-085	Boy's Restroom 1401 (left) - SNK	<2		Sink
310-086	Boy's Restroom 1401 (right) - SNK	14		Sink
310-087	Room 1208 North Wall - SNK	<2		Sink
310-088	Room 1208 East Wall - SNK	<2		Sink
310-089	Room 1208 South Wall - SNK	<2		Sink
310-090	Room 1207 - SNK	<2		Sink
310-091	Room 1206 North Wall (east) - SNK	3		Sink
310-092	Room 1206 North Wall (middle) - SNK	12		Sink
310-093	Room 1206 North Wall (west) - SNK	6		Sink
310-094	Room 1206 West Wall (north) - SNK	<2		Sink
310-095	Room 1206 West Wall (middle) - SNK	<2		Sink
310-096	Room 1206 West Wall (south) - SNK	<2		Sink
310-097	Room 1206 South Wall (west) - SNK	<2		Sink
310-098	Room 1206 South Wall (middle) - SNK	<2		Sink
310-099	Room 1206 South Wall (east) - SNK	<2		Sink
310-100	Room 1206 East Wall - SNK	<2		Sink
310-101	Room 1306 Boy's Locker - WC	<2		Water Cooler
310-102	Room 1306 Boy's Locker - SNK	<2		Sink
310-103	Room 1311 Girl's Locker - WC	<2		Water Cooler
310-104	Room 1311 Girl's Locker - SNK	<2		Sink
310-105	Gymnasium 1304 (right) - WC	<2		Water Cooler
310-106	Cooridor 109 - WC	<2		Water Cooler
310-107	Gymnasium 1304 (left) - WC	4		Water Cooler
310-108	Gymnasium 2303 - WC	8		Water Cooler
310-109	Kitchen - Bunn	7		Bunn

Building Number: 330

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
330-001	3rd Floor Boy's RR - L to R (1)	2ppb		Hand Sink
330-002	3rd Floor Boy's RR - L to R (2)	<2ppb		Hand Sink
330-003	3rd Floor Boy's RR - L to R (3)	2ppb		Hand Sink
330-004	3rd Floor Boy's RR - L to R (4)	<2ppb		Hand Sink
330-005	3rd Floor Boy's RR - L to R (5)	<2ppb		Hand Sink
330-006	Room 3211 Teacher's Station	<2ppb		Sink
330-007	Hallway Across from Room 3210	<2ppb		Cooler
330-008	Office 3210A	5ppb		Sink
330-009	Storage 3210B	<2ppb		Sink
330-010	Room 3210 Teacher Station	<2ppb		Sink
330-011	Room 3210 Inside Wall	<2ppb		Sink
330-012	Room 3210 Outside Wall	<2ppb		Sink
330-013	Room 3207 Teacher's Station	NS		Sink
330-014	Room 3207A Office	>100ppb	<2ppb	Sink
330-015	Room 3207B Teacher's Station	31ppb	<2ppb	Sink
330-016	Room 3207 Inside Wall	<2ppb		
330-017	Room 3207 Outside Wall	<2ppb		Sink
330-018	Across from Room 3206	<2ppb		Fountain
330-019	Room 3206	<2ppb		Sink
330-020	3206A	<2ppb		Sink
330-021	Room 3205 Teacher Station	NS		Sink
330-022	Room 3205 Inside Wall Left	<2ppb		Sink
330-023	Classroom 3205 Inside Wall - R	<2ppb		Sink
330-024	Prep Room 3205A	2ppb		Sink
330-025	Room 3205C	<2ppb		Sink
330-026	Room 3205D Inside Wall	3ppb		Sink
330-027	Room 3204 - Teachers Station	<2ppb		Sink
330-028	3204 Inside Wall	<2ppb		Sink
330-029	3204A	6ppb		Sink
330-030	Room 3203B Inside Wall	<2ppb		Sink
330-031	Room 3203 Teacher's Station	<2ppb		Sink
330-032	Storage 3203 Inside Wall	<2ppb		Sink
330-033	3203A	<2ppb		Sink
330-034	Room 3202 Inside Wall	<2ppb		Sink
330-035	Room 3202 Teacher's Station	<2ppb		Sink
330-036	3120A	<2ppb		Sink
330-037	3120B	51ppb	<2ppb	Sink
330-038	Room 3210 - Inside Wall	<2ppb		Sink
330-039	Room 3210 Teacher's Station	<2ppb		Sink
330-040	Storage Room 3312B	<2ppb		Sink
330-041	Storage Room 3312 Inside Wall	<2ppb		Sink
330-042	Room 3312 Inside Wall Teacher's Station	5ppb		Sink
330-043	Room 3312A Teacher's Station	<2ppb		Sink
330-044	Hall by 3312	<2ppb		Fountain
330-045	Hallway by Room 3309	<2ppb		Fountain
330-046	Hallway by Room 3308	<2ppb		Fountain
330-047	Room 3306A	<2ppb		Sink
330-048	Room 3307	<2ppb		Sink
330-049	Room 3305	<2ppb		Sink
330-050	Room 3304	<2ppb		Sink
330-051	Room 3303	<2ppb		Sink
330-052	Room 3302A	<2ppb		Sink
330-053	Office/Storage JC 3301A	<2ppb		Sink
330-054	3rd Floor Girl's RR - L to R (1)	<2ppb		Sink
330-055	3rd Floor Girl's RR - L to R (2)	<2ppb		Sink
330-056	3rd Floor Girl's RR - L to R (3)	<2ppb		Sink
330-057	3rd Floor Girl's RR - L to R (4)	<2ppb		Sink
330-058	3rd Floor Girl's RR - L to R (5)	<2ppb		Sink
330-059	2nd Floor Boy's RR - L to R (1)	<2ppb		Sink
330-060	2nd Floor Boy's RR - L to R (2)	<2ppb		Sink
330-061	2nd Floor Boy's RR - L to R (3)	<2ppb		Sink
330-062	2nd Floor Boy's RR - L to R (4)	2ppb		Sink
330-063	2nd Floor Boy's RR - L to R (5)	<2ppb		Sink
330-064	Hallway By Room 2220	3ppb		Cooler
330-065	Faculty Women's RR - Left	<2ppb		Sink
330-066	Faculty Women's RR - Right	<2ppb		Sink
330-067	Faculty Men's RR	<2ppb		Sink
330-068	Hallway By Room 2214	<2ppb		Fountain
330-069	2206	<2ppb		Sink
330-070	Room 219 Left	4ppb		Sink
330-071	Room 219 Left Middle	<2ppb		Sink
330-072	Room 219 Right Middle	8ppb		Sink
330-073	Room 219 Right	<2ppb		Sink
330-074	Hallway by Rm 2313	<2ppb		Fountain
330-075	Hall by Rm 2310	2ppb		Fountain
330-076	Faculty Lounge Rm 2308	<2ppb		Sink
330-077	2nd Floor Girl's RR - L to R (1)	<2ppb		Sink
330-078	2nd Floor Girl's RR - L to R (2)	<2ppb		Sink
330-079	2nd Floor Girl's RR - L to R (3)	3ppb		Sink
330-080	2nd Floor Girl's RR - L to R (4)	<2ppb		Sink
330-081	2nd Floor Girl's RR - L to R (5)	<2ppb		Sink
330-082	1st Floor Boy's RR - L to R (1)	<2ppb		Sink

330-083	1st Floor Boy's RR - L to R (2)	<2ppb		Sink
330-084	1st Floor Boy's RR - L to R (3)	2ppb		Sink
330-085	1st Floor Boy's RR - L to R (4)	3ppb		Sink
330-086	1st Floor Boy's RR - L to R (5)	<2ppb		Sink
330-087	Classroom 1217	<2ppb		Sink
330-088	Hydration Station by Room 1216	<2ppb		Hydra
330-089	Classroom 1215	<2ppb		Sink
330-090	1213 RR	<2ppb		Sink
330-091	Room 1212 - Laundry Tub	<2ppb		Utility Sink
330-092	Home Econ Room 1211 - NW	<2ppb		Sink
330-093	Home Econ Room 1211 North	<2ppb		Sink
330-094	Home Econ Room 1211 NE	NS		Sink
330-095	Home Econ Room 1211 SW	NS		Sink
330-096	Home Econ Room 1211 South	NS		Sink
330-097	Home Econ Room 1211 - SW	<2ppb		Sink
330-098	Hall by Room 1211	<2ppb		Fountain
330-099	Library Work Area 1205	<2ppb		Sink
330-100	Toilet Room 1901 RR	<2ppb		Sink
330-101	Concessions (106A)	<2ppb		Sink
330-102	Custodial Office Break Room 1201	<2ppb		Sink
330-103	Custodial Office Restroom	<2ppb		Sink
330-104	Custodial Office Restroom	<2ppb		Sink
330-105	Girl's Dressing Rm	<2ppb		Sink
330-106	Boy's Dressing Room	<2ppb		Sink
330-107	Hydration Station - Outside Auditorium West	<2ppb		Hydra
330-108	Outside Auditorium East	<2ppb		Fountain
330-109	Men's Restroom (A109) - L	3ppb		Sink
330-110	Men's restroom (A109) - Middle	<2ppb		Sink
330-111	Men's restroom (A109) - Right	5ppb		Sink
330-112	Ladies RR - (A107)	<2ppb		Sink
330-113	Ladies restroom (A107) - Middle	4ppb		Sink
330-114	Ladies restroom (A107) - Right	<2ppb		Sink
330-115	Women's Restroom 177 - L	<2ppb		Sink
330-116	Women's Restroom 177 - R	<2ppb		Sink
330-117	Fieldhouse Hall 173 - L	<2ppb		Cooler
330-118	Fieldhouse Hall 173 - R	<2ppb		Cooler
330-119	Men's Restroom 176 - L	<2ppb		Sink
330-120	Men's Restroom 176 - R	<2ppb		Sink
330-121	Girl's Varsity Locker - Left 1119	<2ppb		Sink
330-122	Girl's Varsity Locker-Right 1119	<2ppb		Sink
330-122.1	Main Office Workroom	<2ppb		
330-122.2	Main Office RR West	<2ppb		
330-122.3	Main Office RR East	<2ppb		
330-123	Hallway by Choir Room 13209	3ppb		Fountain
330-124	Hallway across from Room 1315	3ppb		Fountain
330-125	Nurse's Office Restroom South 1325	2ppb		Sink
330-126	Nurse's Office Main 1324	<2ppb		Sink
330-127	Clinic 1315	<2ppb		Sink
330-128	Nurse's Exam Room D	<2ppb		Sink
330-129	Nurse's Exam Room 1317	<2ppb		Sink
330-130	Nurse's Restroom 101C	<2ppb		Sink
330-131	Nurse's Exam Room A	<2ppb		Sink
330-132	Restroom 126B	NS		Sink
330-133	Restroom by Principal's Office 126C	NS		Sink
330-134	Main Office Workroom 124A	NS		Sink
330-135	Restroom East end of Office area F124	<2ppb		Sink
330-136	1st Floor Girl's RR - L to R (1)	<2ppb		Sink
330-137	1st Floor Girl's RR - L to R (2)	<2ppb		Sink
330-138	1st Floor Girl's RR - L to R (3)	<2ppb		Sink
330-139	1st Floor Girl's RR - L to R (4)	<2ppb		Sink
330-140	1st Floor Girl's RR - L to R (5)	<2ppb		Sink
330-141	Aux Gym Room 122	<2ppb		Fountain
330-142	Pool	<2ppb		Fountain
330-143	Laundry B-44	NS		Utility Sink
330-144	Boy's Locker Room Office 0402	<2ppb		Sink
330-145	Boy's Varsity Locker (B-21)	<2ppb		Cooler
330-146	Boy's Varsity Locker toilet room B-17	4ppb		Sink
330-147	Locker room toilet (B-30) Left	24ppb	NF	Sink
330-148	Locker room toilet (B-30) Right	<2ppb		Sink
330-149	Boy's Locker Room Office (B-24)	<2ppb		Sink
330-150	Coaches Staff Room 0412 Hose	<2ppb		Utility Sink
330-151	Gym East Wall 008	<2ppb		Fountain
330-152	Gym West Wall 008	<2ppb		Fountain
330-153	Girl's Lockers Room (B-34)	<2ppb		Cooler
330-154	Girl's Lockers (B-38) - Left	5ppb		Sink
330-155	Girl's Lockers (B-37) - Right	3ppb		Sink
330-156	Girl's Lockers Coaches Office Restroom (B-37)	<2ppb		Sink
330-157	Women's Restroom 801 - L	<2ppb		Sink
330-158	Women's Restroom 801 - R	<2ppb		Sink
330-159	Hydration Station - Shop Hallway	<2ppb		Hydra
330-160	Men's Restroom 803	<2ppb		Sink
330-161	Drafting Room 0150-Left	<2ppb		Sink
330-162	Drafting Room 0150	<2ppb		Fountain
330-163	Drafting Room 0150-Right	<2ppb		Sink
330-164	Wood Shop Room 0154 - Left	<2ppb		Sink
330-165	Wood Shop 0154 - Mid	<2ppb		Sink
330-165.5	Wood Shop 0154 - Right	<2ppb		Sink

330-166	Restroom 131A	<2ppb		Sink
330-167	Metal Shop Rm 132 - Left	<2ppb		Sink
330-168	Metal Shp Rm 132 - right	<2ppb		Sink
330-169	Senior High Cafeteria - East	<2ppb		Cooler
330-170	Senior High Cafeteria - West	<2ppb		Cooler
330-171	Boy's Room 46 - Left	<2ppb		Sink
330-172	Boy's Room 46 - Right	<2ppb		Sink
330-173	Boy's Locker 46	<2ppb		Fountain
330-174	Boy's Locker Room - Left	<2ppb		Sink
330-175	Boy's Locker Room - Right	<2ppb		Sink
330-176	Boy's Locker Room - Office	<2ppb		Sink
330-177	Lower Gym - 60	<2ppb		Fountain
330-178	Girl's Locker - 66	<2ppb		Fountain
330-179	Girl's Locker Room - Right	<2ppb		Sink
330-180	Girl's Locker Room - Left	<2ppb		Sink
330-181	Girl's Locker Room - Office	<2ppb		Sink
330-182	Girl's Restroom 69 - Left	<2ppb		Sink
330-183	Girl's Restroom 69 - Middle	<2ppb		Sink
330-184	Girl's Restroom 69 - Right	<2ppb		Sink
330-185	Custodial Closet by Girl's Restroom	NS		Utility Sink
330-186	Women's Custodial Restroom 82	<2ppb		Sink
330-187	Men's Custodial Restroom 79	<2ppb		Sink
330-188	Boiler Room	<2ppb		Hose Bib
330-189	Boiler Room Slop Sink	<2ppb		Utility Sink
330-190	Gym 39A - West	<2ppb		Fountain
330-191	Gym 39A - South	NS		Fountain
330-192	Gym 39A - East	NS		Fountain
330-193	Hydration Station - Cafeteria	<2ppb		Hydra
330-193.5	Cooler Left	<2ppb		Cooler
330-194	Kitchen East Entrance	<2ppb		Sink
330-195	Kitchen Dishwash 1108 N	<2ppb		Sink
330-196	Kitchen 1108 S	<2ppb		Large Sink
330-197	Main Kitchen West Wall- Left	4ppb		Large Sink
330-198	Main Kitchen West Wall -Right	2ppb		Sink
330-199	Main Kitchen East Wall	<2ppb		Sink
330-200	Kitchen Bunn Machine	NS		Bunn
330-200.1	Handwash Sink North	<2ppb		Sink
330-201	Outside Auditorium North Wall East - Left	<2ppb		Hydra
330-201.1	Outside Auditorium North Wall East - Right	<2ppb		Hydra
330-201.2	Outside Auditorium North Wall West- Left	<2ppb		Hydra
330-201.3	Outside Auditorium North Wall West - Right	<2ppb		Hyrda
330-202	Music Office Rm 1216	<2ppb		Sink
330-203	Room 104 (Now Staff Lounge)	NS		Sink
330-204	Room 1308	<2ppb		Sink
330-205	Room 1306	NS		Sink
330-206	Room 1325	<2ppb		Sink
330-206.1	Room 1325 RR	<2ppb		Sink
330-207	Hall by Room 1304 - Left	NS		Hydra
330-207.1	Hall by Room 1304 - Right	NS		Hydra
330-208	Art Room 1305 - Left	<2ppb		Sink
330-209	Room 1305 - Right	<2ppb		Sink
330-210	Art Storage 1305A	<2ppb		Sink
330-211	Storage 1316A	<2ppb		Sink
330-212	Room 1316 - Teacher's Station	<2ppb		Sink
330-213	Room 1320 - Teacher's Station	<2ppb		Sink
330-214	RR Between 1316 and 1320	<2ppb		Sink
330-215	ECFE Room 1313 - West	8ppb		Sink
330-216	ECFE Room 1313 - East	<2ppb		Sink
330-217	ECFE Room 1315 - West	<2ppb		Sink
330-218	ECFE Room 1315 - East	<2ppb		Sink
330-219	West Hall 1416	<2ppb		Hydra
330-220	West Hall 1416	<2ppb		Cooler
330-221	West Hall Boy's RR - Left	<2ppb		Sink
330-222	West Hall Boy's RR - Right	<2ppb		Sink
330-223	RR by Room 1413	<2ppb		Sink
330-224	Media Center- 1411	<2ppb		Sink
330-225	RR by Room 1405	<2ppb		Sink
330-226	Women's RR -Right	<2ppb		Sink
330-227	Women's RR - Left	<2ppb		Sink
330-228	Hydration Station - Left	<2ppb		Hydra
330-229	Hydration Station - Right	<2ppb		Hyrda
330-230	Custodial Closet	<2ppb		Utility Sink
330-231	Custodial Closet by Room 120	NS		Sink
330-232	Home Econ Room 1325 - SE	<2ppb		Sink
330-233	Home Econ Rm 1325 SW	<2ppb		Sink
330-234	Home Econ Rm 1325 West Left	<2ppb		Sink
330-235	Home Econ Rm 1325 - West Middle	<2ppb		Sink
330-236	Home Econ Rm 1325 - West Right	<2ppb		Sink
330-237	Home Econ Rm 1325 - East Left	<2ppb		Sink
330-238	Home Econ Rm 1325 - East Middle	<2ppb		Sink
330-239	Home Econ Rm 1325 East Right	<2ppb		Sink
330-240	Nurse 1012	<2ppb		Sink
330-241	Nurse 1013	<2ppb		Sink
330-242	Office RR North	<2ppb		Sink
330-243	Office RR South	<2ppb		Sink
330-244	Room 1015	<2ppb		Sink
330-245	Office Room 153	NS		Sink

330-246	Hydration Station Hallway by Room 2401	<2ppb		Hydra
330-247	Hydration Station Hall by Room 2401	<2ppb		Hydra
330-248	Girl's RR - Left	<2ppb		Sink
330-249	Girls' RR - right	<2ppb		Sink
330-250	Room 2407 Teacher Station	<2ppb		Sink
330-251	Room 2407 Wall	<2ppb		Fountain
330-252	Storage Room 2409	<2ppb		Sink
330-253	Room 2411 Teacher Station	<2ppb		Fountain
330-254	Room 2411 Wall	<2ppb		Sink
330-255	Hydration Station West Hall - Left	<2ppb		Hydra
330-256	Hydration Station West Hall - Right	<2ppb		Hydra
330-257	Boys RR- Left	<2ppb		Sink
330-258	Boy's RR -Right	<2ppb		Sink
330-259	Hydration Station 3rd Flr Hall East - Left	<2ppb		Hydra
330-260	Hydration Station - 3rd Flr Hall East - Right	<2ppb		Hydra
330-261	3rd Flr Girl's RR - Left	<2ppb		Sink
330-262	3rd Flr Girls' RR - Right	<2ppb		Sink
330-263	Room 3407	<2ppb		Sink
330-264	Room 3409	<2ppb		Fountain
330-265	Room 3411 Teacher Station	NS		Sink
330-266	Room 3411 Wall - Left	<2ppb		Sink
330-267	Room 3411 Wall - Middle	<2ppb		Sink
330-268	Room 3411 - Right	<2ppb		Fountain
330-269	Hydration Station - 3rd Flr West - Left	>100ppb	<2ppb	Hydra
330-270	Hydration Station - 3rd Flr West - Right	<2ppb		Hydra
330-271	3rd Flr West Boy's RR - Left	<2ppb		Sink
330-272	3rd Flr West Boy's RR- Right	<2ppb		Sink
330-273	Room 320			Sink
330-274	Room 320			Fountain
330-275	Room 322			Sink
330-276	Room 322			Fountain
330-277	Room 324			Sink
330-278	Room 324			Fountain
330-279	Room 326			Sink
330-280	Room 326			Fountain
330-281	Room 326 Teacher's Station			Sink
330-282	Office Area 326A			Sink
330-283	Science Room 328 Hood			Sink
330-284	Science Room 328 Teacher's Station			Sink
330-285	Science Room 328 - South			Sink
330-286	Science Room 328 - West			Sink
330-287	Science Room 328 - North West			Sink
330-288	Science Room 328 - North East			Sink
330-289	Hallway by Room 336			Fountain
330-290	Custodial Room by 336			Utility Sink
330-291	Lower Gym - 60			Fountain
330-292	Gym South Wall West			Fountain
330-293	Gym West Wall			Fountain
330-294	Run until cold - From Service Connector			Utility Sink

Saint Paul Public Schools
Water Sample Results
Highwood Hills
Building Number: 496

Sample Date: July 10th, 2016
Sampled by: Mary Ferrian, Chad Whyalen, & Jens Erickson

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
496-001	Cafeteria (left) - WC	<2		Water Cooler
496-002	Cafeteria (right) - WC	<2		Water Cooler
496-003	Kitchen Sink - KS	5		Kitchen Sink
496-004	Kitchen Sprayer - SPR	<2		Sprayer
496-005	Kitchen Hand Sink - SNK	<2		Sink
496-006	Dish Room Sprayer - SPR	13		Sprayer
496-007	Room 2407C Custodial - SNK	<2		Slop
496-008	Room 2230 - SNK	9		Sink
496-009	Room 2406 - SNK	<2		Sink
496-010	Hallway Outside 2324 Restrooms (left) - WC	<2		Water Cooler
496-011	Hallway Outside 2324 Restrooms (right) - WC	<2		Water Cooler
496-012	Restroom 2324 (left) - SNK	<2		Sink
496-013	Restroom 2324 (center) - SNK	<2		Sink
496-014	Restroom 2324 (right) - SNK	<2		Sink
496-015	Restroom 2320 (left) - SNK	4		Sink
496-016	Restroom 2320 (center) - SNK	<2		Sink
496-017	Restroom 2320 (right) - SNK	<2		Sink
496-018	Restroom 2322 - SNK	<2		Sink
496-019	Room 2320 Mechanical - SNK	<2		Slop
496-020	Room 2317 - SNK	<2		Sink
496-021	Room 2315 - SNK	<2		Sink
496-022	Room 2313 - SNK	<2		Sink
496-023	Room 2316 - SNK	<2		Sink
496-024	Room 2314 - SNK	<2		Sink
496-025	Room 2312 - SNK	<2		Sink

496-026	Room 2303 - SNK	<2		Sink
496-027	Room 2309 - SNK	24		Sink
496-028	Room 2005 Staff Lounge - SNK	<2		Sink
496-029	Outside Restroom 2413/2415 (left) - SNK	<2		Sink
496-030	Outside Restroom 2413/2415 (right) - SNK	13		Sink
496-031	Restroom 2412 Men's - SNK	4		Sink
496-027.5	Room 2309 - SNK (Flush)		<2	Sink
496-032	Restroom 2414 Women's (left) - SNK	12		Sink
496-033	Restroom 2414 Women's (right) - SNK	<2		Sink
496-034	Room 2424 - SNK	<2		Sink
496-035	Room 2427 - SNK	23		Sink
496-036	Room 2507 - SNK	7		Sink
496-035.5	Room 2427 - SNK		<2	Sink
496-037	Hallway Outside 2506 - SNK	<2		Sink
496-038	Hallway Outside 2506 - DF	33		Fountain
496-039	Room 2506 - SNK	<2		Sink
496-040	Room 2506 - DF	<2		Fountain
496-038.5	Hallway Outside 2506 - DF		<2	Fountain
496-041	Hallway Outside 2503 - SNK	5		Sink
496-042	Hallway Outside 2503 - DF	9		Fountain
496-043	Room 2503 - SNK	<2		Sink
496-044	Room 2502 - SNK	<2		Sink
496-045	2610 Lobby (left) - WC	<2		Water Cooler
496-046	2610 Lobby (right) - WC	7		Water Cooler
496-047	Restroom 2613 (left) - SNK	<2		Sink
496-048	Restroom 2613 (right) - SNK	<2		Sink
496-049	Restroom 2612 (left) - SNK	11		Sink
496-050	Restroom 2612 (right) - SNK	<2		Sink
496-051	Room 2613A Storage - SNK	19		Slop
496-052	Hallway Outside of 2606 - SNK	19		Sink
496-053	Hallway Outside 2603 - SNK	<2		S
496-054	Hallway Outside 2603 - DF	<2		Fountain
496-055	Gym East (left) - DF	21		Fountain
496-056	Gym East (right) - DF	19		Fountain
496-057	Gym West (left) - DF	<2		Fountain
496-055.5	Gym East (left) - DF (flush)		2	Fountain
496-058	Room 2201 - SNK	11		Sink
496-059	Room 2201 Restroom - SNK	14		Sink
496-060	Room 2003 Office - SNK	13		Sink
496-061	Room 2203 - SNK	7		Sink
496-062	Room 2220 Nurse's - SNK	<2		Sink
496-063	Room 2325 Nurse's - SNK	<2		Sink
496-064	Nurse's Restroom - SNK	<2		Sink
496-065	Room 1613A Storage - SNK	>100		Slop
496-066	LL14 Restroom Lobby (left) - SNK	10		Sink
496-067	LL14 Restroom Lobby (right) - SNK	<2		Sink
496-068	Restroom 1613 (left) - SNK	25		Sink
496-069	Restroom 1613 (right) - SNK	<2		Sink
496-070	Restroom 1612 (left) - SNK	21		Sink
496-071	Restroom 1612 (right) - SNK	9		Sink
496-065.5	Room 1613A Storage - SNK (flush)		8	Sink
496-068.5	Restroom 1613 (left) - SNK (flush)		11	Sink
496-070.5	Restroom 1612 (left) - SNK (flush)		10	Sink
496-072	Hallway Outside 1506 - SNK	8		Sink
496-073	Hallway Outside 1506 - DF	8		Fountain
496-074	Hallway Outside 1502 - SNK	19		Sink
496-075	Hallway Outside 1502 - DF	<2		Fountain
496-076	Room 1502 - SNK	15		Sink
496-077	Room 1502 - SNK	9		Slop
496-078	Hallway Outside 1606 - SNK	10		Sink
496-079	Hallway Outside 1606 - DF	18		Fountain
496-080	Hallway Outside 1603 - SNK	<2		Sink
496-081	Hallway Outside 1603 - DF	13		Fountain
496-082	Ktchen 1112 - SNK	<2		Sink
496-083	LL33 - WC	<2		Water Cooler
496-084	1111 Restroom - SNK	<2		Sink
496-085	1109 Restroom - SNK	<2		Sink
496-086	Kitchen - Bunn	<2		Bunn

Saint Paul Public Schools
Water Sample Results
Open World - Humboldt Jr.
Building Number: 335

Sample Date: 7/10/2016
Sampled By: Chandala Nagendrappa, Stephanie Pinkalla
Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
335-001	DF Outside Womens Locker room Left	5		DF
335-002	DF Outside Womens Locker room Right	21		DF
335-003	Womens Bathroom Sink Left	15		Sink
335-004	Mens Bathroom Sink Right	<2		Sink
335-004.1	Womens Bathroom Sink Middle	Above 100		Sink

335-005	Womens Bathroom Sink Right	24		Sink
335-006	Mens Bathroom Sink Left	<2		Sink
335-007	Mens Bathroom Middle Sink	8		Sink
335-008	Mens Staff bathroom Locker room Hand Sink	<2		Sink
335-009	Mens Locker room Entrance DF	<2		DF
335-010	Mens Locker room Sink Left	41		Sink
335-010.1	Mens Locker Room Sink Middle	14		Sink
335-011	Drinking Fountain by Mens Locker room	2		Sink
335-012	Mens Locker room Hand Sink RH	5		Sink
335-013	Womens Locker room Left hand Sink	4		Sink
335-014	DF outside womens locker room 1521	<2		DF
335-015	Womens Locker room Middle Sink	4		Sink
335-016	Drinking Fountain Outside Gym, Womens Locker Room	<2		DF
335-017	Womens Locker Room Right Hand Sink	<2		Sink
335-018	Hydration Ststion by room 1104	<2		HS
335-019	Hydration Ststion By Room 1104	<2		HS
335-020	Cooler By room 1104	<2		Cooler
335-021	1601 RR Sink	<2		Sink
335-022	1601 Sink	<2		Sink
335-023	Art Room 1104 Sink	<2		Sink
335-024	1106 Deep Sink	2		Sink
335-025	1106 LH Sink	<2		Sink
335-026	1106 RH Sink	<2		Sink
335-027	1110 LH Sink	<2		Sink
335-028	1110 RH Sink	4		Sink
335-029	1111B Hand Sink	10		Sink
335-030	1111B Dishwash Hose	<2		Sink
335-031	1111B Deep Sink	<2		Sink
335-032	Room 1221 Staff RR Sink	<2		Sink
335-033	Girls RR 1221 Right	<2		Sink
335-034	Girls RR 1221 Right Middle	<2		Sink
335-035	Girls RR 1221 Middle	<2		Sink
335-036	Girls RR 1221 Left Middle	<2		Sink
335-037	Girls RR 1221 Left	<2		Sink
335-038	DF Outside 1215 Right	<2		DF
335-039	DF outside 1215 Left	<2		DF
335-040	1109 Hand Sink Right	<2		Sink
335-041	1108 Dish Sink	<2		Sink
335-042	1109 Hand Sink Left	<2		Sink
335-043	Unisex RR by Room 1221	<2		Sink
335-044	Unisex RR by Room 1221	<2		Sink
335-045	Boys RR by Elevator LH	<2		Sink
335-046	Boys RR by Elevator 2nd from Left	<2		Sink
335-047	Boys RR by Elevator Middle	<2		Sink
335-048	Boys RR By Elevator 2nd from Right	<2		Sink
335-049	Boys RR By Elevator Right	<2		Sink
335-050	2nd floor RR In front of 2207 HS	<2		Sink
335-051	Staff Lounge 2207	<2		Sink
335-052	Boys RR Left Sink by 2215	<2		Sink
335-053	Boys Restroom Middle Sink By 2215	<2		Sink
335-054	Boys RR Right Sink by room 2215	<2		Sink
335-055	Girls RR Left Sink by room 2215	<2		Sink
335-056	Girls RR Middle Sink by room 2215	<2		Sink
335-057	Girls RR Right Sink by room 2215	<2		Sink
335-058	Girls RR Outside 2215 RH	2		Sink
335-059	Room 2217 Custodial Closet	<2		Sink
335-060	DF by Room 2110	<2		DF
335-061	DF By Room 2604	<2		DF
335-062	2601 WR Hand Sink	<2		Sink
335-063	2601 Mens Bathroom	<2		Sink
335-064	Room 2607 Sink	<2		Sink
335-065	1504 Dish Sink	<2		Sink
335-066	3rd Floor DF left of 3212	<2		DF
335-066.1	1504 Hand Sink	<2		Sink
335-067	3rd floor DF Right of 3212	<2		DF
335-068	3209 Sink	<2		Sink
335-069	3207 Hose Bib	<2		Hose Bib
335-070	Girls RR by 3209 Left	<2		Sink
335-071	Girls RR by 3209 Middle	<2		Sink
335-072	Girls RR by 3209 Right	<2		Sink
335-073	3216 Greenhouse Sink	5		Sink
335-074	Boys RR LH Sink 3rd Floor	<2		Sink
335-075	Boys RR Middle Sink 3rd Floor	<2		Sink
335-076	Boys RR RH Sink 3rd Floor	<2		Sink
335-077	3215 Hand Sink	<2		Sink
335-078	3208 Sink	<2		Sink
335-079	3210 LH Sink	<2		Sink
335-080	3210 Sink 1	<2		Sink
335-081	3210 Sink 2	<2		Sink
335-082	3210 Sink 3	<2		Sink
335-083	3210 Sink 4	<2		Sink
335-084	3210 Sink 5	<2		Sink
335-085	3210 Sink 6	<2		Sink
335-086	3210 Sink 7	<2		Sink
335-087	3210 Sink 8	<2		Sink
335-088	3202 Sink	<2		Sink
335-089	3202 Hand Sink	<2		Sink

Saint Paul Public Schools
 Water Sample Results
 Plato Building (345 Plato)
 Building Number: 012

7/24/2016
 Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
012-001	Main hallway - DF	<2		Drinking Fountain
012-002	Main hallway - WBF	<2		
012-003	Men's RR (left) - SNK	12		Sink
012-004	Men's RR (left-middle) - SNK	20		Sink
012-005	Men's RR (middle) - SNK	28		Sink
012-006	Men's RR (right-middle) - SNK	23		Sink
012-007	Men's RR (right) - SNK	16		Sink
012-008	Between restrooms - DF	7		Drinking Fountain
012-009	Women's RR (left) - SNK	13		Sink
012-010	Women's RR (left-middle) - SNK	18		Sink
012-011	Women's RR (middle) - SNK	7		Sink
012-012	Women's RR (right-middle) - SNK	<2		Sink
012-013	Women's RR (right) - SNK	16		Sink
012-014	Outside café - DF	<2		Drinking Fountain
012-015	Closed bathroom (handwash) - SNK	<2		Sink

Saint Paul Public Schools
 Water Sample Results
 District Service Facility
 Building Number: 003

Sample Date: July 24, 2016
 Sampled by: Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
003-001	Room 1107 (left) - SNK	13		Sink
003-002	Room 1107 (handwash) - SNK	<2		Sink
003-003	1st floor Men's RR (left) - SNK	<2		Sink
003-004	1st floor Men's RR (center) - SNK	<2		Sink
003-005	1st floor Men's RR (right) - SNK	<2		Sink
003-006	1st floor Women's RR (left) - SNK	7		Sink
003-007	1st floor Women's RR (center) - SNK	7		Sink
003-008	1st floor Women's RR (right) - SNK	11		Sink
003-009	Room 1206 Deep - SNK	13		Sink
003-010	Room 1203 (left) - SNK	<2		Sink
003-011	Room 1203 (right) - SNK	<2		Sink
003-012	Room 1201 (left) - SNK	<2		Sink
003-013	Room 1201 (right) - SNK	<2		Sink
003-014	1st floor main hall (left) - DF	<2		Drinking fountain
003-015	1st floor main hall (right) - DF	<2		Drinking fountain
003-016	Room 1101B maintenance closet - SNK	9		Sink
003-017	Room 1106 - SNK	<2		Sink
003-018	Restroom 1106 - SNK	<2		Sink
003-019	2nd floor Men's RR (left) - SNK	<2		Sink
003-020	2nd floor Men's RR (right) - SNK	<2		Sink
003-021	2nd floor (left) - DF	<2		Drinking fountain
003-022	2nd floor (right) - DF	<2		Drinking fountain
003-023	2nd floor - WBF	<2		Water bottle filler
003-024	Room 2204 - SNK	<2		Sink
003-025	Room 2409 - SNK	<2		Sink

Saint Paul Public Schools
 Water Sample Results
 BUS GARAGE
 Building Number: 065

Sample Date: 7/24/2016
 Sampled by: Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
065-001	Left side - DF	<2		
065-002	Right side - DF	<2		
065-003	WBF	<2		
065-004	Kitchen - SNK	<2		
065-005	Men's RR (left) - SNK	<2		
065-006	Men's RR (right) - SNK	<2		
065-007	Custodial slop - SNK	<2		
065-008	Maintenance Shop slop - SNK	<2		
065-009	Office restroom (left) - SNK	<2		
065-010	Office restroom (right) - SNK	<2		
065-011	Women's RR Kitchen (left) - SNK	<2		
065-012	Women's RR Kitchen (right) - SNK	<2		

**Saint Paul Public Schools
Water Sample Results
Central Auto Shop
Building Number: 210-2**

**Sample Date: 7/24/2016
Sampled by: Tod Eckberg**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
210-2-001	Handwashing sink (left) - SNK	2		Sink
210-2-002	Handwashing sink (right) - SNK	<2		Sink
210-2-003	Slop sink - SNK	<2		Sink
210-2-004	Restroom - SNK	3		Sink
210-2-005	DF	<2		Drinking fountain

**Saint Paul Public Schools
Water Sample Results
Dayton Bluff
Building Number: 433**

**Sample Date: July 24, 2016
Sampled by: Mary Ferrian & Jens Erickson**

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
433-001	Room 2204 - SP	<2		Sprayer
433-002	Room 2204 - SNK	2		Sink
433-003	Room 2202 - KS	<2		Kitchen Sink
433-004	Room 2202 - SP	<2		Sprayer
433-005	Hall 2300 - DF	<2		Drinking Fountain
433-006	Room 2202B - SNK	2		Sink
433-007	Restroom 2202A - SNK	8		Sink
433-008	Room 2202C - SNK	10		Sink
433-009	Cafeteria 2201 - DF	<2		Drinking Fountain
433-010	Room 2102 - SNK	<2		Sink
433-011	Hall 2100 - WC	<2		Water Cooler
433-012	Restroom 2104 (Right) - SNK	3		Sink
433-013	Restroom 2104 (Left) - SNK	<2		Sink
433-014	Restroom 2105 (Left) - SNK	<2		Sink
433-015	Restroom 2105 (Right) - SNK	<2		Sink
433-016	Room 2012 - SNK	<2		Sink
433-017	Room 2011 - SNK	<2		Sink
433-018	Restroom 2009 - SNK	2		Sink
433-019	Room 2010 - SNK	7		Sink
433-020	Room 2008 - SNK	9		Sink
433-021	Restroom 2414 (Right) - SNK	<2		Sink
433-022	Restroom 2414 (Left) - SNK	3		Sink
433-023	Hall 2400 - DF	3		Drinking Fountain
433-024	Restroom 2413 (Left) - SNK	<2		Sink
433-025	Restroom 2413 (Center) - SNK	<2		Sink
433-026	Restroom 2413 (Right) - SNK	<2		Sink
433-027	Room 2410 - SNK	2		Sink
433-028	Room 2409 - SNK	<2		Sink
433-029	Room 2406 - SNK	8		Sink
433-030	Room 2408 - SNK	5		Sink
433-031	Room 2407 - SNK	<2		Sink
433-032	Room 2405 - SNK	3		Sink
433-033	Room 2403 - SNK	<2		Sink
433-034	Room 2404 - SNK	4		Sink
433-035	Room 2402 - SNK	<2		Sink
433-036	Room 2401 - SNK	<2		Sink
433-037	Room 2301 - SNK	<2		Sink
433-038	Room 2302 - SNK	2		Sink
433-039	Room 2307 - SNK	13		Sink
433-040	Room 2303 - SNK	<2		Sink
433-041	Room 2304 - SNK	<2		Sink
433-042	Room 2305 - SNK	3		Sink
433-043	Room 2306 - SNK	33		Sink
433-044	Boy's Restroom 2308 - SNK	<2		Sink
433-045	Girl's Restroom 2309 - SNK	<2		Sink
433-043.5	Room 2306 - SNK (flush)		10	Sink
433-046	Restroom 2312 - SNK	7		Sink
433-047	Restroom 2311 - SNK	3		Sink
433-048	Room 1206 - SNK	7		Slop
433-049	Restroom 1205 - SNK	<2		Sink
433-050	Room 1204 (Left) - SNK	<2		Sink
433-051	Room 1204 (Right) - SNK	<2		Sink
433-052	Room 1202 - SNK	<2		Sink
433-053	Room 1103 Media Center - SNK	<2		Sink
433-054	Room 1516 - SNK	<2		Sink
433-055	Room 1516 - DF	11		Drinking Fountain
433-056	Room 1510 - SNK	<2		Sink
433-057	Restroom 1511 - SNK	<2		Sink
433-058	Restroom 1309 - SNK	<2		Sink
433-059	Hall 1300 - DF	3		Drinking Fountain
433-060	Restroom 1308 (Left) - SNK	<2		Sink
433-061	Restroom 1308 (Center) - SNK	<2		Sink

433-062	Restroom (Right) - SNK	<2		Sink
433-063	Room 1301 - SNK	<2		Sink
433-064	Room 1302 - SNK	6		Sink
433-065	Room 1307 - SNK	12		Sink
433-066	Room 1303 - SNK	3		Sink
433-067	Room 1304 - SNK	7		Sink
433-068	Room 1305 - SNK	9		Sink
433-069	Room 1306 - SNK	10		Sink
433-070	Room 1407 - SNK	<2		Sink
433-071	Room 1407B Restroom - SNK	5		Sink
433-072	Room 1401 - SNK	5		Sink
433-073	Room 1402 - SNK	<2		Sink
433-074	Room 1404 - SNK	5		Sink
433-075	Restroom 1418 - SNK	<2		Sink
433-076	Hall 1400 - DF	<2		Drinking Fountain
433-077	Restroom 1417 (Left) - SNK	2		Sink
433-078	Restroom 1417 (Right) - SNK	<2		Sink
433-079	Room 1408 - SNK	<2		Sink
433-080	Restroom 1408B - SNK	3		Sink
433-081	Room 1409 - SNK	4		Sink
433-082	Room 1412 Engineer - SNK	6		Sink
433-083	Kitchen Bunn	<2		Bunn

Saint Paul Public Schools
Water Sample Results
District Service Facility
Building Number: 065

Sample Date: July 24, 2016
Sampled by: Mary Ferrian, Jens Erickson, & Tod Eckberg

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
065-001	Room 1658 - SNK	<2		Sink
065-002	Room 1651 (left) - WC	<2		Water Cooler
065-003	Room 1651 (right) - WC	2		Water Cooler
065-004	Room 1651 - WBF	<2		Water Bottle Filler
065-005	Room 1650 (left) - SNK	<2		Sink
065-006	Room 1650 (right) - SNK	<2		Sink
065-007	Room 1654 (left) - SNK	4		Sink
065-008	Room 1654 (right) - SNK	58		Sink
065-009	Room 1652 - SNK	3		Sink
065-010	Room 1605 - SNK	<2		Sink
065-011	Room 1617 - SNK	<2		Sink
065-012	Rom 1618 - SNK	<2		Sink
065-013	Room 1609 - SNK	38		Sink
065-008.5	Room 1654 (right) - SNK (flush)		14	Sink
065-014	Room 1620 - SNK	5		Sink
065-015	Room 1620A - SNK	27		Sink
065-016	Room 1022 - SNK	28		Sink
065-017	Room 1501 - SNK	<2		Sink
065-013.5	Room 1609 - SNK (flush)		9	Sink
065-018	Restroom 1506 (left) - SNK	<2		Sink
065-015.5	Room 1620A - SNK (flush)		<2	Sink
065-019	Restroom 1506 (right) - SNK	<2		Sink
065-016.5	Room 1022 - SNK (flush)		13	Sink
065-020	Room 1501 - Hose bib	2		Hose Bib
065-021	Room 1503 - SNK	<2		Sink
065-022	Room 1508 - Bunn	<2		Kitchen Bunn
065-023	Room 1508 NE (left) - KS	<2		Kitchen Sink
065-024	Room 1508 NE (center) - KS	<2		Kitchen Sink
065-025	Room 1508 NE - SP	<2		Sprayer
065-026	Room 1508 NE (right) - KS	<2		Kitchen Sink
065-027	Room 1508 NW (left) - KS	2		Kitchen Sink
065-028	Room 1508 NW (center) - KS	<2		Kitchen Sink
065-029	Room 1508 NW (right) - KS	<2		Kitchen Sink
065-030	Room 1508 NW (handwash) - SNK	<2		Sink
065-031	Room 1508 North (left) - KS	<2		Kitchen Sink
065-032	Room 1508 North (right) - KS	<2		Kitchen Sink
065-033	Room 1522 - SNK	<2		Sink
065-034	Room 1078 (left) - SNK	5		Sink
065-035	Room 1078 (right) - SNK	8		Sink
065-036	Room 1508 North - WC	<2		Water Cooler
065-037	Room 1081 (left) - SNK	11		Sink
065-038	Room 1081 (right) - SNK	10		Sink
065-039	Room 1508 SW (handwash) - SNK	9		Sink
065-040	Room 1508 SW (left) - KS	<2		Kitchen Sink
065-041	Room 1508 SW (center) - KS	7		Kitchen Sink
065-042	Room 1508 SW - SP	<2		Sprayer
065-043	Room 1508 SW (right) - KS	9		Kitchen Sink
065-044	Room 1085 - SNK	<2		Sink
065-045	Room 1084 - SP	2		Sprayer
065-046	Room 1084 (left) - KS	4		Kitchen Sink
065-047	Room 1084 (center) - KS	<2		Kitchen Sink
065-048	Room 1084 (right) - KS	<2		Kitchen Sink
065-049	Room 1084 (standalone) - SNK	3		Sink
065-050	Room 1084 (handwash) - SNK	8		Sink

065-051	Room 1508 NW - SP	<2		Sprayer
065-052	Room 1516 - SNK	12		Sink
065-053	Restroom 1107 (left) - SNK	<2		Sink
065-054	Restroom 1107 (right) - SNK	<2		Sink
065-055	Room 1113 - SNK	18		Sink
065-056	Hall 1100A - WC	<2		Water Cooler
065-057	Hall 1100A - WBF	<2		Water Bottle Filler
065-058	Room 1103 - SNK	<2		Sink
065-059	Hall 1100 - DF	<2		Drinking Fountain
065-060	Print Shop north - SNK	<2		Sink
065-061	Print Shop south - SNK	<2		Sink
065-062	Room 1202 (left) - SNK	15		Sink
065-063	Room 1202 (center) - SNK	<2		Sink
065-064	Room 1202 - SP	4		Sprayer
065-065	Room 1202 (handwash) - SNK	4		Sink
065-066	Outside Room 2102 - DF	<2		Drinking Fountain
065-067	Room 2104 - SNK	7		Sink
065-068	Outside Room 2110 - DF	<2		Drinking Fountain
065-069	Upstairs Women's RR (left) - SNK	<2		Sink
065-070	Upstairs Women's RR (right) - SNK	<2		Sink
065-071	Room 2112 - SNK	6		Sink
065-072	Upstairs Men's RR - SNK	11		Sink

Saint Paul Public Schools
Water Sample Results
Admin/Bridgeview/Focus Beyond
Building Number: 010

Sample Date: 7/24/2016
Sampled by: Stephanie Pinkalla, Chandala Nagendrappa,
Parker Prose

Sample #	Location	Sample Results 2016	15 Seconds Flush Sample	Fixture Type
010-001	Custodial Office Hand Sink	<2		Sink
010-002	Custodial Office Hose Bib	<2		Hose Bib
010-003	Boiler Room Utility Sink	2		Utility Sink
010-004	SEM Office Custodial Room	<2		Hose Bib
010-005	1st Floor RR Water Fountain Cooler	<2		Cooler
010-006	1st Floor Womens' RR - L	<2		Sink
010-007	1st Floor Womens' RR - M	<2		Sink
010-008	1st Floor Womens' RR - R	<2		Sink
010-009	1st Floor Mens' RR - L	<2		Sink
010-010	1st Floor Mens' RR - R	<2		Sink
010-011	Vending Hall Hydration Station	<2		Hydration
010-012	Vending Hall Water Fountain Cooler	<2		Cooler
010-013	Office Area near Room 208A	<2		Sink
010-014	Office Area near B201	<2		Cooler
010-015	Office Area near B201	<2		Hydration
010-016	2nd Floor Lobby Cooler	<2		Cooler
010-017	2nd Floor Lobby Womens' RR - L	<2		Sink
010-018	2nd Floor Lobby Womens' RR - R	<2		Sink
010-019	2nd Floor Lobby Mens' RR	<2		Sink
010-020	Hall Near Copy Room 219	<2		Sink
010-021	2nd Floor Mens' RR by Room 224	6		Sink
010-022	2nd Floor Womens' RR by Room 224	3		Sink
010-023	3rd Floor Lobby Cooler	<2		Cooler
010-024	3rd Floor Lobby Hydration Station	4		Hydration
010-025	3rd Floor Lobby Mens' RR	<2		Sink
010-026	3rd Floor Lobby Womens' RR - L	<2		Sink
010-027	3rd Floor Lobby Womens' RR - R	3		Sink
010-028	3rd Floor hall by Room 352	<2		Sink
010-029	3rd Floor Mens' RR by Room 333	<2		Sink
010-030	3rd Floor Womens' RR by Room 333	<2		Sink
010-031	4th Floor Lobby Cooler	<2		Cooler
010-032	4th Floor Lobby Mens' RR	<2		Sink
010-033	4th Floor Lobby Womens' RR - L	<2		Sink
010-034	4th Floor Lobby Womens' RR - R	<2		Sink
010-035	4th Floor Staff Lounge	<2		Sink
010-036	4th Floor Womens' RR by Room 433	<2		Sink
010-037	4th Floor Mens' RR by Room 433	<2		Sink
010-038	5th Floor Lobby Cooler	<2		Cooler
010-039	5th Floor Lobby Hydration Station	<2		Hydration
010-040	5th Floor Lobby Mens' RR	<2		Sink
010-041	5th Floor Lobby Womens' RR - L	<2		Sink
010-042	5th Floor Lobby Womens' RR - R	<2		Sink
010-043	Conference Room 511	<2		Sink
010-044	Superintendent RR	<2		Sink
010-045	5th Floor Cafeteria	5		Sink
010-046	5th Floor Hall by Room 524	<2		Sink
010-047	Unisex RR by Room 524	<2		Sink
010-048	Womens' RR by Room 524	<2		Sink
010-049	Staff Lounge Kitchen Sink	<2		Sink
010-050	Staff Lounge Kitchen Fountain	NS		Fountain
010-051	Main Entrance Womens' RR - L	<2		Sink
010-052	Main Entrance Womens' RR - R	<2		Sink
010-053	Main Entrance Mens' RR	<2		Sink
010-054	Maintenance Room 1103	<2		Hose Bib
010-055	Main Entrance Desk area	3		Cooler

010-056	Room 1007	<2		Sink
010-057	Nurse RR Sink	<2		Sink
010-58	Nurse Medication Room Sink	<2		Sink
010-058.1	Girls' Pool Locker Room - L	<2		Sink
010-059	Girls' Pool Locker Room - R	7		Sink
010-060	Pool Area Drinking Fountain	<2		Fountain
010-061	Room 1112	<2		Sink
010-062	RR Between Room 1112 and 1113	<2		Sink
010-063	Room 1113	NS		Sink
010-064	Boys' Pool Locker Room	<2		Sink
010-065	Gymnasium Drinking Fountain	NS		Fountain
010-066	Elem Room 1401 - L	<2		Sink
010-067	Elem Room 1401 - M	<2		Sink
010-068	Elem Room 1401 - R	<2		Sink
010-069	Elem Room 1401 Unisex RR	<2		Sink
010-070	Elem Room 1408 - L	<2		Sink
010-071	Elem Room 1408 - R	6		Sink
010-072	Elem Room 1408 Unisex RR	<2		Sink
010-073	Elem Room 1407 - L	19		Sink
010-074	Elem Room 1407 - R	<2		Sink
010-075	Elem Room 1402 - L	<2		Sink
010-076	Elem Room 1402 - R	<2		Sink
010-077	Elem Room 1403 - L	<2		Sink
010-078	Elem Room 1403 - R	<2		Sink
010-079	Elem Room 1403 Unisex RR	<2		Sink
010-080	Elem Room 1404 - L	3		Sink
010-081	Elem Room 1404 - R	<2		Sink
010-082	Elem Room 1406 - L	3		Sink
010-083	Elem Room 1406 - R	<2		Sink
010-084	Elem Room 1406 Unisex RR	<2		Sink
010-085	Elem Room 1405 - L	<2		Sink
010-086	Elem Room 1405 - R	15		Sink
010-087	Main Kitchen Hand wash Sink	<2		Hand Sink
010-088	Main Kitchen Large -Left	2		Large Sink
010-089	Main Kitchen Small - Right	<2		Sink
010-090	Kitchen 1502 Hand wash Sink	<2		Hand Sink
010-091	Kitchen 1502 Sprayer Sink	4		Sprayer
010-092	Hall outside Staff Lounge	<2		Cooler
010-093	Classroom 1321	<2		Sink
010-094	Classroom 1320	<2		Sink
010-095	Classroom 1320 Unisex RR	<2		Sink
010-096	Hallway RR between 1320 and 1318	<2		Sink
010-097	Classroom 1318 - L	<2		Sink
010-098	Classroom 1318 - R	<2		Sink
010-099	Room 1303 RR	<2		Sink
010-100	Hallway RR outside 1318	<2		Sink
010-101	Classroom 1317 Sink	<2		Sink
010-102	Classroom 1316 RR	34	<2	Sink
010-103	Classroom 1316	14		Sink
010-104	Classroom 1315 Window	NS		Sink
010-105	Classroom 1315 Wall	11		Sink
010-106	Classroom 1315 RR	7		Sink
010-107	Hallway Unisex RR - Left RR	13		Sink
010-108	Hallway Unisex RR - Right RR	<2		Sink
010-109	Maintenance Room 1308	8		Hose Bib
010-110	Hallway Boys' RR - L	<2		Sink
010-111	Hallway Boys' RR - R	<2		Sink
010-112	Hallway Cooler by Room 1311 - Left	10		Cooler
010-113	Hallway Cooler by Room 1311 - Right	6		Cooler
010-114	Music Room 1311 Sink	8		Sink
010-115	Hallway Girls' RR - L	11		Sink
010-116	Hallway Girls' RR - R	6		Sink
010-117	Laundry Room Utility	11		Utility sink
010-118	Room 1610 - L	5		Sink
010-119	Room 1610 - R	7		Sink
010-120	Room 1610 Unisex RR	2		Sink
010-121	Room 1609 - L	3		Sink
010-122	Room 1609 - R	20		Sink
010-123	Room 1608 - L	7		Sink
010-124	Room 1608 - R	<2		Sink
010-125	Room 1608 Unisex RR	<2		Sink
010-126	Room 1607 - L	8		Sink
010-127	Room 1607 - R	<2		Sink
010-128	Room 1605 - L	13		Sink
010-129	Room 1605 - R	5		Sink
010-130	Room 1604 - L	<2		Sink
010-131	Room 1604 - R	<2		Sink
010-132	Room 1603 - L	NS		Sink
010-133	Room 1603 - R	NS		Sink
010-134	Room 1602 - L	<2		Sink
010-135	Room 1602 - R	3		Sink
010-136	Concessions Room 1601	<2		Sink
010-137	Room 1606	<2		Sink
010-138	Room 1606	<2		Fountain
010-139	Hallway RR Water Fountain Cooler	2		Cooler
010-140	Hallway Girls' RR - L	<2		Sink
010-141	Hallway Girls' RR - R	<2		Sink

010-142	Hallway Boys' RR - L	<2		Sink
010-143	Hallway Boys' RR - R	<2		Sink
010-144	Maintenance Room 1510	<2		Hose Bib
010-145	Room 1512 Front Demo Kitchen	<2		Sink
010-146	Room 1512 by Fridge	6		Sink
010-147	Room 1512 by Stovetop	<2		Sink
010-148	Room 1512 Hand wash Sink	<2		Hand sink
010-149	Room 1513 Hand wash Sink	<2		Hand sink
010-150	Room 1513 Kitchen Sink	<2		Sink
010-151	Nurse RR 161A	2		Sink
010-152	Nurse Room 1003	<2		Sink
010-153	Conference Room 1004	<2		Sink
010-154	Changing Room 1007	<2		Sink
010-155	Handwash Area between Girls' and Boys' RR - L	<2		Sink
010-156	Handwash Area between Girls' and Boys' RR - M	<2		Sink
010-157	Handwash Area between Girls' and Boys' RR - R	<2		Sink
010-158	Changing Room 1102A	6		Sink
010-159	Art Room 1104 - L	<2		Sink
010-160	Art Room 1104 - R	<2		Sink
010-161	Hallway outside Cafeteria Cooler - L	7		Cooler
010-162	Hallway outside Cafeteria Cooler - R	<2		Cooler
010-163	Main Kitchen Sprayer	<2		Sprayer
010-164	Main Kitchen Large Sink - L	<2		Sink
010-165	Main Kitchen Large Sink - R	<2		Sink
010-166	Main Kitchen Small Sink	<2		Sink
010-167	Main Kitchen Hand wash Sink	3		Sink
010-168	Main Kitchen Unisex RR	<2		Sink
010-169	Maintenance Room 1108	<2		Hose bib
010-170	Gathering Area 2000 - L	<2		Sink
010-171	Gathering Area 2000 - R	<2		Sink
010-172	Gathering Area 1300 - R	<2		Sink
010-173	Gathering Area 1300 - L	<2		Sink
010-174	Gathering Area 1400 - L	<2		Sink
010-175	Gathering Area 1400 - R	<2		Sink
010-176	Mechanical Room 1405	<2		Utility sink
010-177	Hallway near Room 1300 Cooler - L	<2		Cooler
010-178	Hallway near Room 1300 Cooler - R	<2		Cooler
010-179	Handwash Areas between Girls' and Boys' RR - L	10		Sink
010-180	Handwash Area between Girls' and Boys' RR - M	<2		Sink
010-181	Handwash Area between Girls' and Boys' RR - R	8		Sink
010-182	Room 1502 Sink	<2		Sink
010-183	Room 1502 Unisex RR	<2		Sink
010-184	Room 1503 Sink	<2		Sink
010-185	Room 1503 Unisex RR	<2		Sink
010-186	Staff RR - L	<2		Sink
010-187	Staff RR - R	<2		Sink