



BID TABULATION

Central High School James Griffin Stadium Electrical Service Replacement Project

SPPS BID NUMBER: A23-3542-JG

SPPS PROJECT NUMBER: 3021-22-01

BID OPENING: June 1, 2023, 2:00 PM



444 Cedar Street, Suite 1500
 Saint Paul, MN 55101
 651.292.4400
 tkda.com

CONTRACTOR	Acknowledged Addenda No.1	Contractor Verification Form	Bid Bond	Attachment A-1	TOTAL BASE BID	ALTERNATES		Comments
						No. 1	No. 2	
						Provide 3 in-grade flagpole light fixtures located at the west end of the field. Lighting shall be fed from the new panel LP-4 located in the NW Concession Building spaced 8'-0" away from pole and 3 fixtures spaced at 120 degrees apart. Provide 3/4" conduit with 2#12 & #12 ground from panel for fixtures. Provide photocontrol device mounted on north side of building for control of flagpole lighting shall be equal to Tork Model 2100.	Provide a 2" PVC conduit from a new handhole located at the north side of the stadium near the light tower NE to a new handhole located near light tower SE for future low voltage cabling. See revised Sheet E050.	
Egan Company	x	x	x	x	\$ 344,645.00	\$ 14,898.00	\$ 6,464.00	
Hunt Electric Corporation	x	x	x	x	\$ 236,380.00	\$ 8,830.00	\$ 6,374.00	

Average Bid: \$290,512.50

TKDA Project No. 12800.165